

COMMONWEALTH OF KENTUCKY  
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

APPLICATION OF GREEN RIVER ELECTRIC )  
CORPORATION FOR A CERTIFICATE OF )  
CONVENIENCE AND NECESSITY PURSUANT )  
K.R.S. 278.020(1) AND 807 K.A.R. ) CASE NO. 91-294  
5:001, SECTION 9 AND RELATED )  
SECTIONS, AUTHORIZING CERTAIN )  
PROPOSED CONSTRUCTION )

O R D E R

IT IS ORDERED that Green River Electric Corporation ("Green River") shall file an original and six copies of the following information with this Commission, with a copy to all parties of record within 15 days from the date of this Order. If the information cannot be provided by this date, you should submit a motion for an extension of time stating the reason a delay is necessary and include a date by which it will be furnished. Such motion will be considered by the Commission.


1. The proposed circuit diagram filed in this case appears to have some error regarding wire size and location of line openings. Also, some voltage regulators or auto boosters were not shown on the circuit diagram. Please review the maps filed and make the necessary changes to the circuit diagram to show accurately Green River's existing and proposed systems. Also provide two copies of the corrected circuit diagrams.

2. Item 15-I on page 12 of the two year work plan states: "this ordinary replacement project will reconductor line

section 512 from single phase #6A copper to three-phase 1/0 ACSR for reliability." The circuit diagram shows line section 512 as a single phase. Please indicate whether line section 512 should be single-phase or three-phase.

Done at Frankfort, Kentucky, this 25th day of November, 1991.

PUBLIC SERVICE COMMISSION

  
Robert M. Davis  
For the Commission

ATTEST:

  
Lee M. Madraschen  
Executive Director