

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF OAK HAVEN WATER AND)
SEWER COMPANY FOR A DEVIATION FROM 807)
KAR 5:066, SECTION 5(4) REGARDING WATER) CASE NO. 92-447
STORAGE)

O R D E R


On October 19, 1992, the Commission received a request from Oak Haven Water and Sewer Company, Inc. ("Oak Haven") for a deviation from Commission Regulation 807 KAR 5:066, Section 5(4), which requires each utility to provide water storage to ensure a minimum of one day's supply of average daily water usage. By Order dated November 11, 1992, the Commission directed Oak Haven to provide a statement from its supplier, the city of Falmouth, that it would allocate the required water storage for a specified time period. The city of Falmouth subsequently submitted to the Commission on February 8, 1993 a letter guaranteeing the availability of water to Oak Haven. However, the city of Falmouth failed to include a time period for the guarantee to remain in effect. After a request from Commission Staff for a specific time period, the city of Falmouth on April 19, 1993 filed a letter with the Commission in which it indicated its decision to not commit to a time period for the guarantee.


Based upon the foregoing, the Commission finds that Oak Haven has failed to show good cause for granting the proposed deviation.


IT IS THEREFORE ORDERED that Oak Haven's request for a deviation from Commission Regulation 807 KAR 5:066, Section 5(4), is dismissed.

Done at Frankfort, Kentucky, this 11th day of May, 1993.


PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:


Executive Director