

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF HICKORY WATER DISTRICT)	CASE NO.
FOR A DEVIATION FROM COMMISSION REGULATIONS)	95-391
REGARDING WATER STORAGE)	

O R D E R

By application received September 6, 1995, Hickory Water District ("Hickory Water") requested a deviation from Commission Regulation 807 KAR 5:066, Section 4(4), which provides that each utility shall provide water storage to ensure a minimum of one day's supply of its average daily water usage. Hickory Water states in its application that its average daily water usage, including unaccounted-for water, is approximately 355,507 gallons, and that its current water storage capacity is 300,000 gallons.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. Hickory Water is not in compliance with Commission Regulation 807 KAR 5:066, Section 4(4).

2. Because of the time needed to plan, finance, and implement a program to construct water storage facilities, Hickory Water should be given until December 31, 2000 to bring it within compliance of Commission Regulation 807 KAR 5:066, Section 4(4).

IT IS THEREFORE ORDERED that:

1. Hickory Water be and it hereby is given until December 31, 2000 to comply with the provisions of 807 KAR 5:066, Section 4(4).

2. Hickory Water shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to December 31, 2000.

Done at Frankfort, Kentucky, this 18th day of September, 1995.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:


Executive Director