

COMMONWEALTH OF KENTUCKY  
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

BRACKEN COUNTY WATER DISTRICT }  
FOR APPROVAL OF A DEVIATION } CASE NO. 95-540  
FROM THE REQUIREMENTS OF 807 }  
KAR 5:066, SECTION 10(2)(A) }

ORDER

IT IS ORDERED that Bracken County Water District ("Bracken Water") shall file an original and 10 copies (2 copies of engineering-related materials) of the following information with the Commission, with a copy to all parties of record within 21 days from the date of this Order. Bracken Water shall furnish with each response the name of the witness who will be available at the public hearing, if one is held, for responding to questions concerning each item of information requested.

1. Provide a profile view drawing for each extension showing the location of pressure recordings, the existing ground elevations, the locations of all customers, and the hydraulic grade lines which demonstrates that pressures along the extensions will comply with 807 KAR 5:066, Section 5(1).

2. Provide a system map showing the location of each extension.

Done at Frankfort, Kentucky, this 28th day of December, 1995.

ATTEST:

  
Executive Director

PUBLIC SERVICE COMMISSION

  
For the Commission