

COMMONWEALTH OF KENTUCKY

BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF CAWOOD WATER DISTRICT )  
FOR A DEVIATION FROM COMMISSION ) CASE NO. 96-083  
REGULATIONS REGARDING MINIMUM PIPE SIZES )

O R D E R

On February 29, 1996, Cawood Water District ("Cawood Water") submitted an application for permission to deviate from 807 KAR 5:066, Section 10(2)(a), in order to install approximately 1,900 feet of 2-inch water line. Pursuant to 807 KAR 5:066, Section 10(2)(a), the maximum length of a non-circulating 2-inch water line is 250 feet, but in the case of rural water lines this length may be extended with Commission approval.

On March 26, 1996, the Commission received a letter from Cawood Water stating that it would install a 3-inch water line rather than the 2-inch water line for which it sought a deviation. As Cawood Water intends to install a 3-inch water line, the Commission's permission to deviate from 807 KAR 5:066, Section 10(2)(a), is unnecessary. The Commission shall therefore treat the letter received from Cawood Water as a motion to dismiss this case. Having considered the motion and being otherwise sufficiently advised, the Commission finds that the motion should be granted.

IT IS THEREFORE ORDERED that:

1. Cawood Water's motion to dismiss is granted.
2. This case is dismissed and shall be removed from the Commission's docket.

Done at Frankfort, Kentucky, this 17th day of April, 1996.

PUBLIC SERVICE COMMISSION

*Syida K Breathitt*  
Chairman

*E. J. [unclear]*  
Vice Chairman

*Robert M. Davis*  
Commissioner

ATTEST:

*Don Mills*  
Executive Director