

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

LOUISVILLE GAS AND ELECTRIC COMPANY)	
<hr style="width:40%; margin-left:0"/>)	
ALLEGED FAILURE TO COMPLY WITH)	CASE NO. 98-184
ADMINISTRATIVE REGULATIONS 807 KAR)	
5:006, SECTION 24, AND 807 KAR 5:041,)	
SECTION 3)	

O R D E R

Louisville Gas and Electric Company ("LG&E"), a Kentucky corporation which engages in the distribution of electricity to the public for compensation for lights, heat, power, and other uses, is a utility subject to Commission jurisdiction. KRS 278.010.

KRS 278.280(2) directs the Commission to prescribe rules and regulations for the performance of services by utilities. Pursuant to this statutory directive, the Commission promulgated Administrative Regulation 807 KAR 5:041, Section 3, which requires electric utilities to maintain their plant and facilities in accordance with the standards of the National Electrical Safety Code (1990 edition) ("NESC"). It further promulgated Administrative Regulation 807 KAR 5:006, Section 24, which requires all utilities to adopt and execute a safety program appropriate to their size and type of operations.

Commission Staff has submitted to the Commission a Utility Accident Investigation Report dated November 20, 1997, appended hereto, in which Commission Staff alleges:

1. On July 7, 1997, Walter Lovelace was injured as he repaired LG&E electric distribution facilities in Louisville, Kentucky.

2. At the time of the incident, LG&E had dispatched Lovelace and two other LG&E line technicians, Don Shipley and Gary Razor, to 3413 Bonaventure Boulevard, Louisville, Kentucky, to repair a pad mounted transformer. It had advised the line technicians that an elbow had blown off the bushing in Transformer No. 18. Upon arriving at the scene, the three line technicians switched the feed to Transformer No. 19 to return that transformer to service. They did not de-energize the 7200 volt primary feed to Transformer No. 18. After switching the feed to Transformer No. 19, Lovelace grabbed the blown elbow on the underground primary feed to Transformer No. 18 and received an electric shock.

3. At the time of the incident, Lovelace was not wearing or using the protective equipment which had been provided to him.

4. At the time of the incident, Lovelace was in charge of the work site and supervising the repair and maintenance activity.

5. As a result of his contact with the 7200 volt energized feed line, Lovelace suffered burns to his hands and forearms and required hospitalization.

6. NESC Rule 420H requires persons to use the personal protective equipment, protective devices, and special tools provided for their work.

7. NESC Rule 421A1 requires the person in charge of a work site to adopt such precautions as are within the individual's authority to prevent accidents.

8. NESC Rule 421A2 requires the person in charge of a work site to see that the safety rules and operating procedures are followed by those under his direction.

9. NESC Rule 441A1 prohibits an employee from approaching within certain distances an exposed line or part which is operating at certain voltages unless the line or part is de-energized, the employee is insulated from the energized line or part, the energized line or part is insulated from the employee, or the employee is insulated from all conducting surfaces other than the one upon which the employee is working.

10. LG&E's internal work rules and procedures require all employees to wear their personal protective equipment and to always assume that electrical equipment and conductors are energized until proven to be de-energized.

11. Lovelace violated NESC Section 420H when he failed to wear his protective rubber gloves when attempting to repair the pad mounted transformer.

12. Lovelace failed to see that all safety and operating procedures were observed at the work site. His failure is a violation of NESC Rule 421A which requires a person in charge to adopt such precautions as are within his authority to prevent accidents and to see that the all safety rules and operating procedures are observed by those under his direction.

13. Lovelace violated NESC Section 441A when he failed to wear his protective rubber gloves when attempting to repair the pad mounted transformer.

14. At the time of the incident, Lovelace was an employee of LG&E and acting in the scope of his employment.

Based on its review of the Utility Accident Investigation Report and being otherwise sufficiently advised, the Commission finds that prima facie evidence exists that

LG&E has failed to comply with Administrative Regulations 807 KAR 5:006, Section 24, and 807 KAR 5:041, Section 3.

The Commission, on its own motion, HEREBY ORDERS that:

1. LG&E shall appear before the Commission on July 29, 1998 at 9:00 a.m., Eastern Daylight Time, in Hearing Room 1 of the Commission's offices at 730 Schenkel Lane, Frankfort, Kentucky, for the purpose of presenting evidence concerning the alleged violations of Administrative Regulations 807 KAR 5:006, Section 24, and 807 KAR 5:041, Section 3, and of showing cause why it should not be subject to the penalties prescribed in KRS 278.990(1) for these alleged violations.


2. LG&E shall submit to the Commission within 20 days of the date of this Order a written response to the allegations contained in the Electrical Utility Accident Investigation Report.

3. The Utility Accident Investigation Report of November 20, 1997, a copy of which is appended hereto, is made part of the record of this proceeding.


4. Any motion requesting an informal conference with Commission Staff to consider any matter which would aid in the handling or disposition of this proceeding shall be filed with the Commission no later than 20 days from the date of this Order.

Done at Frankfort, Kentucky, this 27th day of April, 1998.


ATTEST:


Executive Director

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

APPENDIX A


AN APPENDIX TO AN ORDER OF THE KENTUCKY PUBLIC SERVICE
COMMISSION IN CASE NO. 98-184 DATED APRIL 27, 1998

UTILITY ACCIDENT INVESTIGATION REPORT

Utility:	Louisville Gas and Electric				
Reported By:	Larry Miller				
Dates & Times					
Accident Occurred:	07/20/97 - Approximately 7:04 p.m.				
Utility Notified:	07/20/97 - Approximately 7:15 p.m.				
PSC Notified:	07/20/97 - 8:02 p.m.				
Investigated:	07/21/97				
Written Report Rcvd:	07/25/97				
Location of Accident:	3413 Bonaventure Boulevard, Louisville, Kentucky 40219				
Description of Accident:	Mr. Walter Lovelace was injured while working on the underground primary feed to a pad mounted transformer installation. Mr. Lovelace, Lead Line Technician and two fellow crew members, Don Shipley and Gary Razor, both Line Technicians, were dispatched to 3413 Bonaventure Boulevard to work a reported outage on an underground pad mounted transformer installation. Mr. Lovelace inadvertently made contact with an energized 7200 Volt underground primary feed to Transformer No. 18 during the work process. Mr. Lovelace was the Lead Line Technician at the accident site and was not wearing or using protective equipment at the time of the accident.				
Victims:					
Name:	Walter Lovelace	Fatal:	No	Age:	49
Addr./Empl.:	1502 English Station Road, Louisville/Louisville Gas and Electric				
Injuries:	Burns to both hands and forearms.				
Witnesses:	Name	Address/Employment			
	Don Shipley - Line Technician (A)	Louisville Gas and Electric			
	Gary Razor - Line Technician (A)	Louisville Gas and Electric			
Sources of Information:	Name -	Address/Employment			
	Larry Miller	Louisville Gas and Electric			
	Don Shipley	Louisville Gas and Electric			
	Gary Razor	Louisville Gas and Electric			

November 20, 1997

Page 2

	Dave Ridge	Louisville Gas and Electric			
	Dave Britt	Louisville Gas and Electric			
Probable Violations:	NESC, 1990 Edition, Section 42 & 44, Rules for Supply Employees. Rule 420H. Tools and Protective Equipment; Rule 421.A.1 & 2. General Operating Rules; Rule 441A. Approach to Energized Conductors or Parts.				
Line Clearances At Point of Accident:	Measured	Minimum Allowed by NESC	Applicable NESC Edition¹ 1990	Volt.	Constr. Date
Underground Pad Mounted Transformer Installation:	N/A	N/A	1990	7200	1979
Date of Measurement:	N/A				
Approximate Temp.:	80°F				
Type of Facilities:	7200 Volt underground primary feed to pad mounted transformer. Last inspected on 08/28/95.				
Investigated By:	John W. Land				
Signed:					

Attachments A. Louisville Gas and Electric's Accident Report
B. Photographs of Accident Site

¹ Current edition adopted by the Commission. If clearances are not in compliance with the current edition, then the edition in effect when the facilities were last constructed or modified would apply.

Attachment A

Louisville Gas and Electric's Accident Report



Louisville Gas and Electric Company
220 West Main Street
P.O. Box 32010
Louisville, Kentucky 40232

INVESTIGATION REPORT

ELECTRICAL CONTACT

Type of Report

97-E-021A

Report Number

A L Miller

Investigator

JULY 21, 1997

Date of Incident

Reference: **Electrical Contact**

Location: **3413 Bonaventure Blvd.
Louisville, KY. 40006**

Case Summary:

Addendum:

On Sunday, July 20, 1997, at 19:50 hours, I arrived at the above address to investigate Walter Lovelace's accident, and met with the following Louisville Gas and Electric Company employees.

Fred Krebs	--	Manager ESD Service Center
Tony Highland	--	Sr. Distribution Operations Supervisor
Terry Tones	--	Line Construction and Maintenance Supervisor
Dominic Simms	--	Line Technician - Trouble
Jerry Belcher	--	Line Technician - Trouble
Steve Jones	--	Senior Mechanic - Equipment Shop
Gary Darnall	--	Mechanic Helper - Equipment Shop

Investigation Report

Page 2.

Addendum:

On Monday, July 21, 1997, at 09:00 hours, I met with John Land, (Investigator with Public Service Commission) at the above address to investigate Walter Lovelace's accident.

The following Louisville Gas and Electric Company employees were also met with at the above address.

Mike Engleman	--	Sr. Corporate Attorney
Doug Blakeman	--	Director Electric Service Delivery
Fred Krebs	--	Manager ESD Service Center
Dave Ridge	--	Distribution Operations Supervisor
Steve Tacket	--	Line Construction & Maintenance Supervisor
Chuck Carlton Jr.	--	Health & Safety Specialist III
Tony Bullock	--	Production Support Leader and Union Representative
John Probst	--	Line Technician A and Safety Committee Chairman
Ron Hasch	--	Job Coordinator- Distribution Operations
Gray Razor	--	Line Technician A
Don Shipley	--	Line Technician A

After leaving the above address we went to LG&E's South Service Center on Jennings Lane to view the pad mount transformer that was removed from the above address Sunday, July 20, 1997. Then we went to LG&E's East Service Center on Highway 22.

The followings LG&E employees were met with at South Service Center:

Mike Engleman	--	Sr. Corporate Attorney
Doug Blakeman	--	Director of Electric Service Delivered
Dave Britt	--	Group Leader - Transformer Services Operations
Chuck Carlton	--	Health & Safety Specialist III
Mike Hale	--	Mechanic A - Equipment Shop
Richard Bullock	--	Operator - Plant and Union Stewart
Al Judd	--	Operator - Yard and Union Safety Representative
John Probst	--	Line Technician A

Investigation Report
Page 3.

The following LG&E employees were met with at East Service Center:

Fred Krebs	--	Manager ESD Service Center
Steve Tacket	--	Line Construction and maintenance Supervisor
Chuck Carlton	--	Health and Safety Specialist III
Bob Webb	--	Sr. Technical Training Instructor
Chuck Huber	--	Sr. Technical Training Instructor
Al Judd	--	Operator - Yard and Union Safety Representative

LG&E SM**LOUISVILLE GAS AND ELECTRIC COMPANY**

Post Office Box 32010
Louisville, Kentucky 40232
LG&E Fax: 627-2583
Confirmation: 627-_____

Date

7-25-97

Attention

Martha Morton, Manager
Electric Branch
PSC

Company

City and State

Fax Number

1-502-564-1588

Confirmation Number

From

George Siemens

Number of Pages, INCLUDING Cover Page

4

Subject

Message

CONFIDENTIALITY NOTICE

The information contained in this facsimile message, and in any accompanying documents, constitutes privileged confidential information which belongs to the Louisville Gas and Electric Company. This information is intended only for the use of the individual or entity named above. If you are not the intended recipient of this information, or an employee or agent responsible for delivering this message to the intended recipient, you are hereby notified that any disclosure, copying, distribution, dissemination, or the taking of any action in reliance on this information, is strictly prohibited. If you have received this facsimile message in error, please notify us immediately by telephone at the number listed above in order to arrange for its return to us. Thank you.



George R. Siemens, Jr.
Director
External Affairs
LG&E Building
12th Floor
502-627-2323
502-627-2930 FAX

July 25, 1997

VIA FAX

Ms. Martha Morton, Manager
Electric Branch
Kentucky Public Service Commission
P.O. Box 615
Frankfort, KY 40602

RE: Electrical Shock - 3413 Bonaventure Blvd.
Louisville, KY - July 20, 1997

Dear Ms. Morton:

Attached is an "Investigation Report" on the above incident which was prepared by Larry Miller. This is filed in compliance with the seven-day reporting requirement.

A hard copy of this report, along with photographs taken at the scene, will be forthcoming.

If you need additional information concerning this incident, please feel free to contact me at (502) 627-2323.

Sincerely,

A handwritten signature in black ink, appearing to read "George R. Siemens, Jr.", written over a horizontal line.

Attachment



Louisville Gas and Electric Company
220 West Main Street
P.O. Box 32010
Louisville, Kentucky 40232

INVESTIGATION REPORT

ELECTRICAL SHOCK

Type of Report

97-E-021

Report Number

A. L. Miller

Investigator

July 20, 1997

Date of Incident

Reference: Electrical Shock

Location: 3413 Bonaventure Blvd.
Louisville, KY. 40219

Case Summary:

On Sunday, July 20, 1997, at approximately 19:15 hours, I received a call from Electric Trouble Department about an employee receiving an electrical shock. At 19:50 hours, I arrived at the above address and met with several LG&E employees. I was informed Walter A. Lovelace was working on the underground primary feed to a pad mounted transformer when he received the electrical shock.

Walter Lovelace, Lead Line Technician, was dispatched to 3413 Bonaventure Blvd. and was advised there was an elbow blown off the bushing in transformer no. 18. Walter Lovelace and fellow crew members, Don Shipley and Gary Razor, both Line Technicians, arrived on the site and switched the feed to transformer no. 19 to get it back on the line and failed to de-energize the feed to transformer no. 18. Mr. Lovelace received the 7200 volt shock when he grabbed the blown elbow on the normal underground primary feed to transformer no. 18 that is feed from transformer no. 11. Mr. Lovelace was wearing light weight leather gloves and kneeling on a rubber blanket at the time.

At 19:04 hours, Gary Razor reported the accident to Electric Trouble Department and requested the E.M.S. Mistery Shipley and Razor began CPR on Mr. Lovelace. E.M.S. arrived on the scene and transported Mr. Lovelace to the University Hospital at approximately 19:35 hours.

A SUBSIDIARY OF

LG&E ENERGY.

Investigation Report

Page 2

Mr. Lovelace received burns to both hands. He was released from the hospital Thursday, July 24, 1997.

At 20:02 hours, I notified Mr. John Land's answering machine and then I called Ms. Martha Morton, both with the Public Service Commission. Ms. Morton was informed the transformer and the elbow on the conductor would have to be changed out to get the customers back on line. She said to change the equipment out and John Land would meet with us Monday morning, July 21, 1997.

Photographs were taken Sunday night and Monday morning at the accident site.

On Monday, July 21, 1997, at approximately 09:00 hours, Mr. John Land arrived to investigate the accident.

Photographs and additional materials to follow under separate cover.



Louisville Gas and Electric Company
220 West Main Street
P.O. Box 32010
Louisville, Kentucky 40332

INVESTIGATION REPORT

ELECTRICAL SHOCK

Type of Report

97-E-021

Report Number

A. L. Miller

Investigator

July 20, 1997

Date of Incident

Reference: Electrical Shock

Location: 3413 Bonaventure Blvd.
Louisville, KY. 40219

Case Summary:

On Sunday, July 20, 1997, at approximately 19:15 hours, I received a call from Electric Trouble Department about an employee receiving an electrical shock. At 19:50 hours, I arrived at the above address and met with several LG&E employees. I was informed Walter A. Lovelace was working on the underground primary feed to a pad mounted transformer when he received the electrical shock.

Walter Lovelace, Lead Line Technician, was dispatched to 3413 Bonaventure Blvd. and was advised there was an elbow blown off the bushing in transformer no. 18. Walter Lovelace and fellow crew members, Don Shipley and Gary Razor, both Line Technicians, arrived on the site and switched the feed to transformer no. 19 to get it back on the line and failed to de-energize the feed to transformer no. 18. Mr. Lovelace received the 7200 volt shock when he grabbed the blown elbow on the normal underground primary feed to transformer no. 18 that is feed from transformer no. 11. Mr. Lovelace was wearing light weight leather gloves and kneeling on a rubber blanket at the time.

At 19:04 hours, Gary Razor reported the accident to Electric Trouble Department and requested the E.M.S. Mistern Shipley and Razor began CPR on Mr. Lovelace. E.M.S. arrived on the scene and transported Mr. Lovelace to the University Hospital at approximately 19:35 hours.

A SUBSIDIARY OF

LG&E ENERGY.

Investigation Report

Page 2

Mr. Lovelace received burns to both hands. He was released from the hospital Thursday, July 24, 1997.

At 20:02 hours, I notified Mr. John Land's answering machine and then I called Ms. Martha Morton, both with the Public Service Commission. Ms. Morton was informed the transformer and the elbow on the conductor would have to be changed out to get the customers back on line. She said to change the equipment out and John Land would meet with us Monday morning, July 21, 1997.

Photographs were taken Sunday night and Monday morning at the accident site.

On Monday, July 21, 1997, at approximately 09:00 hours, Mr. John Land arrived to investigate the accident.

Photographs and additional materials to follow under separate cover.

Fax Message From:

Jul 25 '97 14:21

Name: LG&E EXEC OF 12th FL.
Fax Number: 1-502-627-2950

[

]

LG&E SM**LOUISVILLE GAS AND ELECTRIC COMPANY**

Post Office Box 32010
Louisville, Kentucky 40232
LG&E Fax: 627-2583
Confirmation: 627-_____

Date

1-25-97

Attention

Martha Morton, Manager
Electric Branch
PSC

Company

City and State

Fax Number

1-502-564-1583

Confirmation Number

From

George Siemens

Number of Pages, INCLUDING Cover Page

4

Subject

Message

CONFIDENTIALITY NOTICE

The information contained in this facsimile message, and in any accompanying documents, constitutes privileged confidential information which belongs to the Louisville Gas and Electric Company. This information is intended only for the use of the individual or entity named above. If you are not the intended recipient of this information, or an employee or agent responsible for delivering this message to the intended recipient, you are hereby notified that any disclosure, copying, distribution, dissemination, or the taking of any action in reliance on this information, is strictly prohibited. If you have received this facsimile message in error, please notify us immediately by telephone at the number listed above in order to arrange for its return to us. Thank you.

LG&E SM**LOUISVILLE GAS AND ELECTRIC COMPANY**

Post Office Box 32010
Louisville, Kentucky 40232
LG&E Fax: 627-2583
Confirmation: 627-_____

Date

Attention

Company

City and State

Fax Number

Confirmation Number

From

Number of Pages, INCLUDING Cover Page

Subject

Message

CONFIDENTIALITY NOTICE

The information contained in this facsimile message, and in any accompanying documents, constitutes privileged confidential information which belongs to the Louisville Gas and Electric Company. This information is intended only for the use of the individual or entity named above. If you are not the intended recipient of this information, or an employee or agent responsible for delivering this message to the intended recipient, you are hereby notified that any disclosure, copying, distribution, dissemination, or the taking of any action in reliance on this information, is strictly prohibited. If you have received this facsimile message in error, please notify us immediately by telephone at the number listed above in order to arrange for its return to us. Thank you.



George R. Siemens, Jr.

Director

External Affairs

LG&E Building

12th Floor

502-627-2323

502-627-2930 FAX

July 25, 1997

VIA FAX

Ms. Martha Morton, Manager
Electric Branch
Kentucky Public Service Commission
P.O. Box 615
Frankfort, KY 40602

**RE: Electrical Shock - 3413 Bonaventure Blvd.
Louisville, KY - July 20, 1997**


Dear Ms. Morton:

Attached is an "Investigation Report" on the above incident which was prepared by Larry Miller. This is filed in compliance with the seven-day reporting requirement.

A hard copy of this report, along with photographs taken at the scene, will be forthcoming.

If you need additional information concerning this incident, please feel free to contact me at (502) 627-2323.

Sincerely,



Attachment



August 5, 1997

Louisville Gas and Electric Company
220 West Main Street
P.O. Box 32010
Louisville, Kentucky 40232

Ms. Martha Morton, Manager
Electric Branch
Kentucky Public Service Commission
P. O. Box 615
Frankfort, KY 40602

**RE: Electric Shock - 3413 Bonaventure Blvd.
Louisville, KY - July 20, 1997**

Dear Ms. Morton:

Attached is the additional information requested relating to the incident indicated above.

If you need any additional information, please let me know. I can be reached at (502) 627-4883.

Very truly yours,

A handwritten signature in cursive script that reads "Gregory B. Fergason".

Gregory B. Fergason
Regulatory Affairs Coordinator

Attachment

T & D TRAINING
COURSE RECORD SHEET

NAME: W.A. LOUGLACE EMPLOYEE NUMBER: 2497

CLASSIFICATION: SENIOR CABLE SPLICER

[illegible]

T & D TRAINING
COURSE RECORD SHEET

NAME: WALT LOVELACE EMPLOYEE NUMBER: 2497

CLASSIFICATION: PHASE II INSTRUCTOR

TRAINING SESSION	TIME	DATE TAKEN	REMARKS
GETGGØ1PRO	2 Hrs	5-24-73	ABRE11 Use of Propane / Devices
GETGGØ2HRD	4 Hrs	5-24-93	BSHØ73 URD Hardware / Material
GETGGØ3SPL	6 Hrs	5-24-93	ABRC16 Secondary Cable Splicing
GETGGØ4TRM	8 Hrs	5-25-93	ABRBØ7 Inst / Replace of Termin.
GETGGØ5ELD	8 Hrs	5-26-93	ABRBØ2 URD Electrical Diagrams
GETGGØ6SWL	8 Hrs	5-27-93	ABRAØ7 Switch Logic / Emrg. Procedure
GETGGØ7TRP	8 Hrs	5-28-93	ABRB11 Advanced Trans. Principles
GETGGØ8TEM	1 Hrs	5-28-93	Installation of Temp Sen.



CLASSIFICATION: SENIOR CABLE SPLICER

[illegible]

**T&D TRAINING
COURSE RECORD SHEET**

2497

NAME W. A. Havelace

EMPLOYEE NUMBER [REDACTED]

CLASSIFICATION SENIOR Cable Splicer X

TRAINING SESSION	TIME	DATE TAKEN	REMARKS
Mwi - Digger	3 1/2	9-15-87	
head buster	1/2	9-15-87	
5'-0" Pole	1 Hr	5-13-88	REC
Rock-T Truck	12 Hr	1-8-88 1-9-88	
HA - - - - -	1 Hr	1-8-88	
NUS 1.1	4 Hr	11-1-88	
NUS 2.1	4 Hr	11-1-88	
PM-III	8	01-18-90	100%
PM-III	8	01-18-90	Successful
SFA	8 Hr	03-08-89	CPR-84 FA-88
AEOC16	7 Hr	1-16-90	83% Q OK
AEOC17	8 Hr	1-17-90	75% F
AEOC19	5 Hr	1-17-90	86% Q OK
AEOC18	4 Hr	1-18-90	100% Q OK
AEOC20	8 Hr	1-19-90	82% Q OK
GSS020	4 Hr	2-15-90	80%
GSS022	4 Hr	2-15-90	COMPLETE
GSS020	4 Hr	2-7-91	80%
GSS025	4 Hr	2-7-91	COMPLETED
GSG008	24 Hr	6-5-91 THRU 6-7-91	COMPLETED (APB)

EMPRP1

LOUISVILLE GAS & ELECTRIC CO.
EMPLOYEE COURSE LISTING

DATE 07/21/97

TIME 14:50:00

EMP	NAME	COURSE	COURSE TITLE	CLASS DATE	CLASS STATUS	CLASS HOURS
2497	W A LOVELACE SR	GEENG01SFA	STANDARD FIRST AID	95/12/18	C	3.50
2497	W A LOVELACE SR	GEENG00091	BASIC FACILITATION	95/10/14	C	8.00
2497	W A LOVELACE SR	GEENG00091	BASIC FACILITATION	95/09/13	C	8.00
2497	W A LOVELACE SR	GEENGSHORT	TAKING SHORTCUTS	95/08/29	C	1.50
2497	W A LOVELACE SR	GEENGSVISN	SAFETY VISION	95/08/29	C	1.50
2497	W A LOVELACE SR	GEENGSTRES	STRESS AND SAFETY	95/07/31	C	1.00
2497	W A LOVELACE SR	GEENG00090	PROCESS IMPROV. - FACILITATORS	95/06/11	C	20.00
2497	W A LOVELACE SR	GEENG00032	PARKING AND BACKING	95/05/01	C	1.00
2497	W A LOVELACE SR	GEENGSLIPS	SLIPS, TRIPS, AND FALLS	95/03/01	C	1.00
2497	W A LOVELACE SR	AEO001	PROTECTIVE EQUIPMENT	95/12/11	C	4.00
2497	W A LOVELACE SR	AETCGRM	BASIC MATHEMATICS	95/12/11	C	3.50
2497	W A LOVELACE SR	AETCGUTWR	USE OF TWO-WAY RADIOS	95/12/11	C	3.00
2497	W A LOVELACE SR	AETCGUCST	CARE/USE CABLE SPLICER TOOLS	95/12/11	C	4.50
2497	W A LOVELACE SR	AETCGWCTM	WIRE/CABLE-TYPES & MATERIALS	95/12/11	C	4.00
2497	W A LOVELACE SR	AETCGTF	TRANSFORMER FUNDAMENTALS	95/12/11	C	3.50
2497	W A LOVELACE SR	AETCGLTP	LEVELING TRANSFORMER PADS	95/12/11	C	4.00
2497	W A LOVELACE SR	AETCISBMC	INSTALLATION SPLICE BOX/MOLES	95/12/11	C	3.50
2497	W A LOVELACE SR	AETCGLA	LIGHTNING ARRESTERS	95/12/11	C	4.00
2497	W A LOVELACE SR	AETCGI	INSULATORS	95/12/11	C	2.50
2497	W A LOVELACE SR	AETCGFF	FUSES AND FUSING	95/12/11	C	7.00
2497	W A LOVELACE SR	AETCGSRW	BASIC STRINGING / REM'L WIRE	95/12/11	C	3.00
2497	W A LOVELACE SR	AETCGBS	BASIC SERVICES	95/12/11	C	4.00
2497	W A LOVELACE SR	AETCGSTR	SECONDARY TIE BREAKERS	95/12/11	C	5.00
2497	W A LOVELACE SR	AETCGSL	STREET LIGHTING	95/12/11	C	3.00
2497	W A LOVELACE SR	AETCGSCST	SECONDARY CABLE SPLICING	95/12/11	C	6.00
2497	W A LOVELACE SR	AETCGUSLT	C/U OF SIMPLE LINEMAN TOOLS	95/12/11	C	6.00
2497	W A LOVELACE SR	BEENGCLASS	"C" CLASS ASSESSMENT PROGRAM	95/12/11	C	8.00
2497	W A LOVELACE SR	GIINGWIN	INTRODUCTION TO WINDOWS '95	95/12/09	C	8.00
2497	W A LOVELACE SR	EXGNLINVES	ACCIDENT INVESTIGATION	95/11/09	C	4.00
2497	W A LOVELACE SR	GEENTRESCU	BUCKET TRUCK RESCUE	95/11/02	C	2.00
2497	W A LOVELACE SR	GEENTEQUIP	PERSONAL PROTECTIVE EQUIPMENT	95/11/02	C	1.00
2497	W A LOVELACE SR	GEUNTHARAS	SEXUAL HARASSMENT	95/10/23	C	.25
2497	W A LOVELACE SR	GEENGVISIN	SAFETY VISION KICKOFF	95/10/18	C	1.50
2497	W A LOVELACE SR	GEENTRS05	PCB SPILLS	95/10/17	C	.50
2497	W A LOVELACE SR	GETNTTDB	SEC TIED BREAKERS	95/10/04	C	.25
2497	W A LOVELACE SR	GEENG01SFA	STANDARD FIRST AID	95/09/12	C	8.00
2497	W A LOVELACE SR	GEENGBEHAV	BEHAVIOR-BASED SAFETY TRAINING	95/07/12	C	3.00
2497	W A LOVELACE SR	GGENG00009	HAZ COM FLAMMABLE LIQUIDS	95/06/12	C	1.00
2497	W A LOVELACE SR	GXTGLMILLR	NO FALL PROTECTION	95/05/10	C	2.00
2497	W A LOVELACE SR	GEENG00001	CODE OF BUSINESS CONDUCT	95/05/02	C	1.00
2497	W A LOVELACE SR	GXENLGDVHS	GOVERNOR'S SAFETY & HEALTH CNF	95/04/19	C	24.00
2497	W A LOVELACE SR	GGENG00023	HAZ COM LABELING	95/03/29	C	1.00
2497	W A LOVELACE SR	BEENTALCPD	ALCOHOL POLICY TRAINING	95/03/15	C	1.00
2497	W A LOVELACE SR	GETGHTRAIN	TRAIN THE NUS TRAINER	95/03/02	C	8.00
2497	W A LOVELACE SR	GEENTOXYMO	OXYGEN MONITORING	95/02/15	C	.50

EMPRF1

LOUISVILLE GAS & ELECTRIC CO.
EMPLOYEE COURSE LISTINGDATE 07/21/97
TIME 14.50.35

EMP	NAME	COURSE	COURSE TITLE	CLASS DATE	CLASS STATUS	CLASS HOURS
2497	W A LOVELACE SR	BEENG0VERV	1910.269 OVERVIEW	95/02/03	C	2.00
2497	W A LOVELACE SR	GEENG0SHA	OSHA 29CFR. 1910.269 TRAINING	95/01/24	C	16.00
2497	W A LOVELACE SR	GXENLOSHA	TRI-STATE ELEC. SYMPOSIUM	95/01/13	C	8.00
2497	W A LOVELACE SR	GEENG0PGND	EQUIPOTENTIAL GROUNDING METHOD	95/01/11	C	2.00
2497	W A LOVELACE SR	GETGGPHAS3	PHASE 3 TRAINING	94/11/18	C	.01
2497	W A LOVELACE SR	GETGGSPDIC	CONDUCT. SIZES & WIRE SPLIC	94/11/18	C	8.00
2497	W A LOVELACE SR	GETGGSWICH	OPER. & INSTAL. OF VAR. SWITCH	94/11/17	C	4.00
2497	W A LOVELACE SR	GETGGTIEBK	SECONDARY TIE BREAKERS	94/11/17	C	4.00
2497	W A LOVELACE SR	GETGGHRTMN	HURT MAN RESCUE	94/11/16	C	2.00
2497	W A LOVELACE SR	GETGGRIGG	BASIC RIGGING, TRANSF & MOUNT.	94/11/16	C	8.00
2497	W A LOVELACE SR	GETGGGRND	GROUNDING PROCEDURES, COMM. EQ	94/11/15	C	6.00
2497	W A LOVELACE SR	GETGGSTRBOH	TROUBLE-SHOOTING O. HEAD LINES	94/11/14	C	4.00
2497	W A LOVELACE SR	GETGGSTRBTR	TROUBLE-SHOOTING OH TRANSF.	94/11/14	C	4.00
2497	W A LOVELACE SR	GEENG0PDTE	BLOODBORNE PATHOGENS UPDATE	94/10/19	C	1.00
2497	W A LOVELACE SR	GEENG0SOLVE	HAZ-COM HALOGENATED SOLVENTS	94/10/05	C	1.00
2497	W A LOVELACE SR	GDGNG00076	ESD TASK FORCE TEAM TRAINING	94/08/18	C	8.00
2497	W A LOVELACE SR	GETNT00001	SAFETY AWARENESS	94/08/03	C	2.00
2497	W A LOVELACE SR	MEENG0PVIL	S-VIOLENCE IN THE WORKPLACE	94/07/18	C	1.00
2497	W A LOVELACE SR	GEUNT0FAMLA	FAMILY AND MEDICAL LEAVE ACT	94/06/20	C	1.00
2497	W A LOVELACE SR	GEENG0IAHAZ	HAZ-COM, WHAT'S IT ALL ABOUT	94/04/20	C	1.00
2497	W A LOVELACE SR	GEENG0ISFA	STANDARD FIRST AID	94/03/23	C	8.00
2497	W A LOVELACE SR	GOUNT0COMUN	COMMUNITY RELATIONS	94/02/11	C	.75
2497	W A LOVELACE SR	GEENT0JAN1	WINCH LINE SAFETY	94/02/09	C	.50
2497	W A LOVELACE SR	GOGNG0BLK	REGULATORY AFFAIRS INFORMATION	94/02/03	C	1.00
2497	W A LOVELACE SR	GEENT04001	COLD WEATHER SAFETY	94/01/07	C	.50
2497	W A LOVELACE SR	GETNT04002	FAULTED CIRCUIT INDICATORS	94/01/07	C	.50
2497	W A LOVELACE SR	GEGNT0CACCT	ESC CLASS OF ACCOUNTS TRAINING	93/12/17	C	1.00
2497	W A LOVELACE SR	GEENG0BLOD1	BLOODBORNE PATHOGENS UPDATE	93/12/14	C	1.00
2497	W A LOVELACE SR	GOENG0HM181	DOT HM181 SHIPPING PAPERS	93/12/13	C	2.00
2497	W A LOVELACE SR	GEENG0TRS01	TRANSFORMER FIELD TICKETS	93/11/03	C	.50
2497	W A LOVELACE SR	GETNH0GIANT	MINI-GIANT TRAINING	93/10/20	C	2.00
2497	W A LOVELACE SR	GETNH0METER	AUTOMATED METER READING	93/09/22	C	1.00
2497	W A LOVELACE SR	BESNG0CUPKA	FOREMAN LEADER SKILLS	93/07/18	C	40.00
2497	W A LOVELACE SR	GETGG07TRP	ADVANCED TRANS. PRINCIPLES	93/05/28	C	8.00
2497	W A LOVELACE SR	GETGG08TEM	INSTALLATION OF TEMPORARY SERV	93/05/28	C	1.00
2497	W A LOVELACE SR	GETGG06SWL	SWITCH. LOGIC & ENERG/DE-ENERG	93/05/27	C	8.00
2497	W A LOVELACE SR	GETGG05ELD	URD-ELECTRICAL DIAGRAMS	93/05/26	C	4.00
2497	W A LOVELACE SR	GETGG04TRM	INSTALL. & REPLACEMENT OF TERM	93/05/25	C	8.00
2497	W A LOVELACE SR	GETGG01PRD	USE OF PROPANE & PROP DEVICES	93/05/24	C	2.00
2497	W A LOVELACE SR	GEENG02CPR	ADULT CPR RECERTIFICATION	93/03/12	C	4.00
2497	W A LOVELACE SR	GEENG04BIP	BACK INJURY PREVENTION	93/03/12	C	4.00
2497	W A LOVELACE SR	GDGNG0BKHST	BLACK HISTORY PRESENTATION	93/02/26	C	1.00
2497	W A LOVELACE SR	GOING0MMIS2	MMIS - MR ISSUE TRAINING	93/02/16	C	4.00
2497	W A LOVELACE SR	GEGNT0CACCT	ESC CLASS OF ACCOUNTS TRAINING	93/01/04	C	1.50
2497	W A LOVELACE SR	GEENG0BLOOD	BLOODBORNE PATHOGENS PLAN	92/11/17	C	2.00

EMFRP1

LOUISVILLE GAS & ELECTRIC CO.
EMPLOYEE COURSE LISTING

DATE 07/21/97

TIME 14.50.35

EMP	NAME	COURSE	COURSE_TITLE	CLASS DATE	CLASS STATUS	CLASS HOURS
2497	W A LOVELACE SR	GEENHHVOLT	HIGH VOLTAGE TRAINING	92/10/10	C	8.00
2497	W A LOVELACE SR	GDGNGRH001	ROGER HALE EMPLOYEE MEETING	92/07/27	C	2.50
2497	W A LOVELACE SR	GEENGHIVLT	HIGH VOLTAGE DEMONSTRATION	92/07/07	C	1.50
2497	W A LOVELACE SR	GEGND00003	FIELD AMBASSADOR TRAINING	92/05/26	C	8.00
2497	W A LOVELACE SR	GEENG01SFA	STANDARD FIRST AID	92/03/12	C	8.00
2497	W A LOVELACE SR	GDRNG0001	MANAGING CUSTOMER INTERACTION	92/02/19	C	16.00
2497	W A LOVELACE SR	GDUNGCD002	CULTURAL DIVERSITY PHASE I	92/02/06	C	3.00
2497	W A LOVELACE SR	GXGNL00042	CULTURAL DIVERSITY	92/02/06	C	4.00
2497	W A LOVELACE SR	GET002	STANDARDS SEMINAR	91/07/31	C	1.50
2497	W A LOVELACE SR	GET001	HI-POT TEST SEMINAR	91/06/26	C	1.50
2497	W A LOVELACE SR	GSS008	ANALYTICAL PROBLEM SOLVING	91/06/05	C	24.00
2497	W A LOVELACE SR	GOENG40232	DEFENSIVE DRIVING	91/05/21	C	8.00
2497	W A LOVELACE SR	GSS020	ADULT CPR RECERTIFICATION	91/02/07	C	4.00
2497	W A LOVELACE SR	GSS025	BACK INJURY PREVENTION	91/02/07	C	4.00
2497	W A LOVELACE SR	GSS020	ADULT CPR RECERTIFICATION	90/02/15	C	4.00
2497	W A LOVELACE SR	GSS022	HAZARD COMMUNICATION TRAINING	90/02/15	C	4.00
2497	W A LOVELACE SR	AEDC20	STREET LIGHTING	90/01/19	C	8.00
2497	W A LOVELACE SR	AEDC18	BASIC SERVICES	90/01/18	C	4.00
2497	W A LOVELACE SR	AEDC17	BASIC STRINGING/REMOVAL WIRE	90/01/17	F	8.00
2497	W A LOVELACE SR	AEOC19	SECONDARY TIE BREAKERS	90/01/17	C	5.00
2497	W A LOVELACE SR	AEOC16	FUSES & FUSING	90/01/16	C	7.00
2497	W A LOVELACE SR	GSS018	STNDRD FIRST AID/CPR	89/03/08	C	1.00
2497	W A LOVELACE SR	BTP002	ORIENTATION TO FCTP	89/03/01	C	1.00
2497	W A LOVELACE SR	AED521	BASIC METERS	89/01/18	C	8.00
2497	W A LOVELACE SR	AED001	ORIENTATION TO T&D SYSTEMS & EQ	88/11/01	C	4.50
2497	W A LOVELACE SR	BTS001	SAFETY IN T&D MAINTENANCE	88/11/01	C	4.00
2497	W A LOVELACE SR	BTP001	FIVE FOOT RULE	88/05/13	C	1.00

TOTAL EMP 2497

543.76

TOTAL

543.76

ESD TRAINING
COURSE RECORD SHEET

NAME: DON SHIPLEY EMPLOYEE NUMBER: 3216

CLASSIFICATION: LINETECHNICIAN A

TRAINING SESSION	TIME	DATE TAKEN	REMARKS
BASIC ELECTRICITY REVIEW	4 HRS	5/14/97	COMPLETED
HIGH VOLTAGE A.C. POWER	4.5 HRS	5/15/97	COMPLETED
ELECTROMAGNETIC INDUCTION REVIEW	4 HRS	5/14/97	COMPLETED
TRANSFORMERS & TRANSF. BANKS	8 HRS	5/12/97 5/13/97	COMPLETED
URD TRANSFORMER II	8 HRS	5/13/97	COMPLETED
SWITCHING LOGIC ENERGIZATION / DE-EN.	8 HRS	5/13/97	COMPLETED
INSTALLATION & REPLACEMENT OF TERM.	8 HRS	5/16/97	COMPLETED
PRIMARY CABLE SPLICING TECHNIQUES	8 HRS	5/16/97	COMPLETED

T&D TRAINING
COURSE RECORD SHEET

3216

NAME D. L. Shipley

EMPLOYEE NUMBER 25-997

CLASSIFICATION LINEMAN A.

TRAINING SESSION	TIME	DATE TAKEN	REMARKS
GATEKEEPER	1 HR	1-20-87	
5'-0" RULE	1 HR	3-24-88	GOOD TAKING 108 HV PSC
NUS 1.1	4 HR	11-1-88	
NUS 2.1	4 HR	11-1-88	
CPR Course B	8 HR	11-23	71%
CPR	2 hr	12/77	74%
SFA	8 HR	03-07-89	CPR-72 FA-100
BM-TTL W)	4 HR	03-27-89	73%
BM-TTL @	4 HR	03-27-89	Completed
GSS020	4 HR	2-15-90	92%
GSS022	4 HR	2-15-90	COMPLETE
AEBOI	24 HR	5-29/31 90	88%
GSS020	4 HR	2-8-91	80%
GSS025	4 HR	2-8-91	COMPLETED
GET002	1 1/2	7-29-91	C
GET003	1 1/2	8-13-91	COMPLETED
XI0010	1 1/4	8-13-91	C
GSS003	8 hr	3-10-92	COMPLETED
GEGNO00003	8		OK MAY 29 1992

T & D TRAINING
COURSE RECORD SHEET

NAME: Don Shipley

EMPLOYEE NUMBER: 35-3216

CLASSIFICATION: Lineman A.

TRAINING SESSION	TIME	DATE TAKEN	REMARKS
GETGG01PRO	2 Hrs	2/22/93	AERE11 USE OF PROPANE DEVICES
GETGG02HRD	4 Hrs	2/22/93	BSH073 URD Hardware & Materials
GETGG03SPL	6 Hrs	2/22/93	AERC16 Secondary Cable Splicing
GETGG04TRM	8 Hrs	2/23/93	AERB07 Inst & Replace of Termin.
GETGG05ELD	4 Hrs	2/24/93	AERB02 URD Electrical Diagram
GETGG06SWL	8 Hrs	2/26/93	AERA07 Switch Logic Energy Proceed
GETGG07TRP	8 Hrs	2/26/93	AERB11 Advanced Trans. Princip.
GETGG08TEM	1 Hr	2/26/93	Installation of Tem Sec
GEENG02CPR	4	3/17/93	COMPLETED
GEENG04BIP	4	3/17/93	COMPLETED
GEGNGAPS	24	2/19/93	COMPLETED
GEENG01SFA	8	3/22/94	COMPLETED
GESNGCUPKA	40	10/17-21/94	COMPLETED
GETNGEXGND	16	2/21-22/95	COMPLETED
GEENG01SFA	8	10-14-96	PASSED

PHASE II TRAINING

EMPRP1

LOUISVILLE GAS & ELECTRIC CO.
EMPLOYEE COURSE LISTINGDATE 07/22/97
TIME 11:26:54

EMP	NAME	COURSE	COURSE_TITLE	CLASS DATE	CLASS STATUS	CLASS HOURS
3216	D L SHIPLEY	GEENGO1SFA	STANDARD-FIRST-AID	96/10/14	C	8.00
3216	D L SHIPLEY	GETNGNDESC	NESC	96/07/22	C	3.25
3216	D L SHIPLEY	GETNGCAPCN	PROG.CAP.CONT.	96/04/02	C	1.50
3216	D L SHIPLEY	MEDIA	MEDIA-TRAINING	96/03/29	C	2.00
3216	D L SHIPLEY	GEENGSLIPS	SLIPS, TRIPS, AND FALLS	96/03/01	C	1.00
3216	D L SHIPLEY	GEENTRESCU	BUCKET TRUCK RESCUE	95/11/02	C	2.00
3216	D L SHIPLEY	GEENTEQUIP	PERSONAL PROTECTIVE-EQUIPMENT	95/11/02	C	1.00
3216	D L SHIPLEY	GEUNTHARAS	SEXUAL HARASSMENT	95/10/23	C	.25
3216	D L SHIPLEY	GEGNVISIN	SAFETY VISION KICKOFF	95/10/18	C	1.50
3216	D L SHIPLEY	GEENTTRS05	PCB-SPILLS	95/10/17	C	.50
3216	D L SHIPLEY	GETNTTCB	SEC TIED BREAKERS	95/10/04	C	.25
3216	D L SHIPLEY	GEENGO1SFA	STANDARD FIRST AID	95/09/13	C	8.00
3216	D L SHIPLEY	GEENGO0009	HAZ COM-FLAMMABLE LIQUIDS	95/06/12	C	1.00
3216	D L SHIPLEY	GEENGREHAV	BEHAVIOR BASED SAFETY TRAINING	95/05/24	C	3.00
3216	D L SHIPLEY	GOGNLVIDEO	CONTINUOUS IMPROVEMENT VIDEO	95/05/01	C	2.00
3216	D L SHIPLEY	GEUNGO0001	CODE OF BUSINESS CONDUCT	95/04/21	C	1.00
3216	D L SHIPLEY	GEGNPIRTL	SAFETY INCIDENT AT PIRTL	95/04/20	C	1.00
3216	D L SHIPLEY	GEENGO0023	HAZ COM LABELING	95/03/29	C	1.00
3216	D L SHIPLEY	BEENTALCP0	ALCOHOL POLICY TRAINING	95/03/15	C	1.00
3216	D L SHIPLEY	GETNTEXEMF	OCCUPATIONAL EXPOSURE TO EMF	95/03/08	C	.50
3216	D L SHIPLEY	GETNGEXGND	SAFETY EXCEL. TRAINING	95/02/22	C	16.00
3216	D L SHIPLEY	GEENTOXYMO	OXYGEN MONITORING	95/02/15	C	.50
3216	D L SHIPLEY	BEENGCOVER	1910.269 OVERVIEW	95/02/03	C	2.00
3216	D L SHIPLEY	RETNTGLOVE	RUBBER GLOVE TESTING	95/02/01	C	.25
3216	D L SHIPLEY	GEENGEPGND	EQUIPOTENTIAL GROUNDING METHOD	95/01/11	C	2.00
3216	D L SHIPLEY	GEENGUPDTE	BLOODBORNE PATHOGENS UPDATE	94/11/04	C	1.00
3216	D L SHIPLEY	GESNGCUPKA	LEADERSHIP SKILLS	94/10/21	C	40.00
3216	D L SHIPLEY	GEENGSLVLE	HAZ COM-HALOGENATED SOLVENTS	94/10/05	C	1.00
3216	D L SHIPLEY	GETNT00001	SAFETY AWARENESS	94/08/03	C	2.00
3216	D L SHIPLEY	GEUNTFAMLA	FAMILY AND MEDICAL LEAVE ACT	94/06/20	C	1.00
3216	D L SHIPLEY	GEENGFLAME	HAZ COM-FLAMMABLE LIQUIDS	94/06/03	C	1.00
3216	D L SHIPLEY	GEENG02HAZ	HAZ-COM, MSDS SHEETS	94/05/02	C	1.00
3216	D L SHIPLEY	GEENG01HAZ	HAZ-COM, WHAT'S IT ALL ABOUT	94/04/20	C	1.00
3216	D L SHIPLEY	GEENGO1SFA	STANDARD-FIRST-AID	94/03/22	C	8.00
3216	D L SHIPLEY	GOGNGMBLK	REGULATORY AFFAIRS INFORMATION	94/02/03	C	1.00
3216	D L SHIPLEY	GEENT94001	COLD WEATHER SAFETY	94/01/07	C	.50
3216	D L SHIPLEY	GETNT94002	FAULTED CIRCUIT INDICATORS	94/01/07	C	.50
3216	D L SHIPLEY	GEGNTCACCT	ESC CLASS OF ACCOUNTS TRAINING	93/12/16	C	1.00
3216	D L SHIPLEY	GEENGBLOO1	BLOODBORNE PATHOGENS UPDATE	93/12/14	C	1.00
3216	D L SHIPLEY	GEENGHM181	DOT-HM181-SHIPPING PAPERS	93/12/13	C	2.00
3216	D L SHIPLEY	GEGNGTRS01	TRANSFORMER FIELD TICKETS	93/11/03	C	.50
3216	D L SHIPLEY	GETNHGIANT	MINI-GIANT TRAINING	93/10/20	C	2.00
3216	D L SHIPLEY	GETNHMETER	AUTOMATED-METER READING	93/09/22	C	1.00
3216	D L SHIPLEY	GEENG02CPR	ADULT CPR RECERTIFICATION	93/03/17	C	4.00
3216	D L SHIPLEY	GEENG04BIP	BACK INJURY PREVENTION	93/03/17	C	4.00

EMPRP1

LOUISVILLE GAS & ELECTRIC CO.
EMPLOYEE COURSE LISTINGDATE 07/22/97
TIME 11:26:54

EMP	NAME	COURSE	COURSE_TITLE	CLASS DATE	CLASS STATUS	CLASS HOURS
3216	D L SHIPLEY	GDGNGBKHST	BLACK HISTORY PRESENTATION	93/02/26	C	1.00
3216	D L SHIPLEY	GETGGPHAS2	PHASE 2 TRAINING	93/02/26	C	.01
3216	D L SHIPLEY	GETGG06SWL	SWITCH. LOGIC & ENERG/DE-ENERG	93/02/26	C	8.00
3216	D L SHIPLEY	GETGG07TRP	ADVANCED TRANS. PRINCIPLES	93/02/26	C	8.00
3216	D L SHIPLEY	GETGG08TEM	INSTALLATION OF TEMPORARY SERV	93/02/26	C	1.00
3216	D L SHIPLEY	GETGG05ELD	URD ELECTRICAL DIAGRAMS	93/02/24	C	4.00
3216	D L SHIPLEY	GETGG04TRM	INSTALL. & REPLACEMENT OF TERM	93/02/23	C	8.00
3216	D L SHIPLEY	GETGG01PRD	USE OF PROPANE & PROP DEVICES	93/02/22	C	2.00
3216	D L SHIPLEY	GETGG02HRD	URD HARDWARE & MATERIALS	93/02/22	C	4.00
3216	D L SHIPLEY	GETGG03SPL	SECONDARY CABLE SPLICING	93/02/22	C	6.00
3216	D L SHIPLEY	GEGNGAPS	ANALYTICAL PROBLEM SOLVING	93/02/19	C	24.00
3216	D L SHIPLEY	GEGNTCACCT	ESC CLASS OF ACCOUNTS TRAINING	93/01/04	C	1.50
3216	D L SHIPLEY	GEENGBLOOD	BLOODBORNE PATHOGENS PLAN	92/11/17	C	2.00
3216	D L SHIPLEY	GEENHHVOLT	HIGH VOLTAGE TRAINING	92/10/10	C	8.00
3216	D L SHIPLEY	GEENGHIVLT	HIGH VOLTAGE DEMONSTRATION	92/07/07	C	1.50
3216	D L SHIPLEY	GEGND00003	FIELD AMBASSADOR TRAINING	92/05/20	C	8.00
3216	D L SHIPLEY	GEGNTTHEFT	THEFT PREVENTION	92/04/23	C	.50
3216	D L SHIPLEY	GEENG01SFA	STANDARD FIRST AID	92/03/10	C	8.00
3216	D L SHIPLEY	GDGNG00002	STRESS MANAGEMENT	92/02/13	C	8.00
3216	D L SHIPLEY	GDUNGCD002	CULTURAL DIVERSITY PHASE I	92/02/06	C	3.00
3216	D L SHIPLEY	GXGNL00042	CULTURAL DIVERSITY	92/02/06	C	4.00
3216	D L SHIPLEY	GETNS01	FIRE POWER	91/11/05	C	2.00
3216	D L SHIPLEY	GOENG40232	DEFENSIVE DRIVING	91/08/27	C	8.00
3216	D L SHIPLEY	GET003	RAILROAD CROSSING SAFETY	91/08/13	C	1.50
3216	D L SHIPLEY	XI0010	CAREER PLANNING & ADVANCEMENT	91/08/13	C	1.25
3216	D L SHIPLEY	GET002	STANDARDS SEMINAR	91/07/31	C	1.50
3216	D L SHIPLEY	GET002	STANDARDS SEMINAR	91/07/29	C	1.50
3216	D L SHIPLEY	GSS020	ADULT CPR RECERTIFICATION	91/02/08	C	4.00
3216	D L SHIPLEY	GSS025	BACK INJURY PREVENTION	91/02/08	C	4.00
3216	D L SHIPLEY	AEOB01	INTERMEDIATE ELEC PRINCIPLES	90/05/29	C	24.00
3216	D L SHIPLEY	GSS020	ADULT CPR RECERTIFICATION	90/02/15	C	4.00
3216	D L SHIPLEY	GSS022	HAZARD COMMUNICATION TRAINING	90/02/15	C	4.00
3216	D L SHIPLEY	AEOB21	BASIC METERS	89/03/27	C	8.00
3216	D L SHIPLEY	BTP002	ORIENTATION TO FCTP	89/03/27	C	1.00
3216	D L SHIPLEY	GSS018	STNDRD FIRST AID/CPR	89/03/07	C	.00
3216	D L SHIPLEY	GSS002	CPR TRAINING	88/11/23	C	8.00
3216	D L SHIPLEY	AEOE01	ORIENTATION TO T&D SYSTEMS & EQ	88/11/01	C	4.50
3216	D L SHIPLEY	BTS001	SAFETY IN T&D MAINTENANCE	88/11/01	C	4.00
3216	D L SHIPLEY	BTP001	FIVE FOOT RULE	88/03/24	C	1.00
3216	D L SHIPLEY	GGA001	NEW EMPLOYEE ORIENTATION		W	8.00

TOTAL EMP 3216

334.76

TOTAL

334.76

SIGN-IN SHEET
(Please Print)

Date 5/13/97 Instructor's Name Webb/Huber
 Subject Presented Switching - - Logic
 Location ESC Training Hours _____
 Training Meeting _____ Tailgate Meeting _____ Safety Meeting _____
 Supervisor's Name _____

Please check one

Last Name/First Name (please print in ink or type)	Signature	Dept/ Empl. #	BU	IC	MS	NE
Massey M. J.	M. J. Massey	35-3144	✓			
KAUFMAN N. L.	N. L. Kaufman	35-3267	✓			
DEHART H.	H. DeHart	35-2475	✓			
GLEEPER D.	D. Gleeper	35-3214	—			
DEZARN GARY	G. DeZarn	34-2419	✓			
CAMBRON T. A.	T. A. Cambron	35-1845	✓			
CARPENTER CHARLIE	Charlie Carpenter	34-1770	X			
KEETH ART	Art Keeth	35-2423	✓			
LUNNINGHAM DENNIS	D. L. Lunningham	35-2231	—			
HEER DANIEL	D. R. Heer	35-2398	✓			
McMILLIAN D. E.	D. E. McMillian	35-1352	✓			
D. L. SEXTON	Danny L. Sexton	35-2673	✓			
KEMPER S. D.	S. D. Kemper	35-2640	✓			

BU = Bargaining Unit
NE = Non-exempt

MS = Manager/Supervisor
IC = Individual Contributor

#1 / 11497
Cross Training Session

ESD TRAINING
COURSE RECORD SHEET

NAME: G. RAZOR EMPLOYEE NUMBER: 3220

CLASSIFICATION: LINE TECHNICIAN A

TRAINING SESSION	TIME	DATE TAKEN	REMARKS
BASIC ELECTRICITY REVIEW	4 HRS	3-3-97	COMPLETED
HIGH VOLTAGE A.C. POWER	4.5 HRS	3-3-97 3-26-97	COMPLETED
ELECTROMAGNETIC INDUCTION REVIEW	4 HRS	3-26-97	COMPLETED
TRANSFORMERS & TRANSF. BANKS	8 HRS	3-25-97	COMPLETED
URD TRANSFORMER II	8 HRS	3-24-97	COMPLETED
SWITCHING LOGIC ENERGIZATION / DE-EN.	8 HRS	3-24-97	COMPLETED
INSTALLATION & REPLACEMENT OF TERM.	8 HRS	3-27-97	COMPLETED
PRIMARY CABLE SPLICING TECHNIQUES	8 HRS	3-27-97	COMPLETED

T & D TRAINING
COURSE RECORD SHEET

NAME: G. RAZOR EMPLOYEE NUMBER: 35-3210

CLASSIFICATION: LINEMAN A

TRAINING SESSION	TIME	DATE TAKEN	REMARKS
GETGG01PRO	2 Hrs	5-10-93	AERE11 USE OF PROPANE DEVICES
GETGG02HRD	4 Hrs	5-10-93	BSH073 URD Hardware & Materials
GETGG03SPL	6 Hrs	5-10-93	AERC16 SECONDARY Cable Splicing
GETGG04TRM	8 Hrs	5-11-93	AERB07 Inst & Replace of Termin.
GETGG05ELD	4 Hrs	5-12-93	AER302 URD ELECTRICAL Diagram
GETGG06SWL	8 Hrs	5-12-93 5-13-93	AERA07 Switch Logic Energy Proceed
GETGG07TRP	8 Hrs	5-13-93 5-14-93	AERB11 ADVANCED TRANS. Princip.
GETGG08TEM	1 Hr	5-14-93	Installation of Tem Ser
GEENG02CPR	4	4/20/94	COMPLETED
GEUNGFAMB2	4	4/20/94	COMPLETED
GESNGCUPKA	40	12/12-16/94	COMPLETED
Fall Protection	2	6-12-97	Passed
First Aid CPR	8	10-9-96	Passed

PHASE II TRAINING

T&D TRAINING
COURSE RECORD SHEET

3220

NAME G.W. PIAZON

EMPLOYEE NUMBER 35-659

CLASSIFICATION LINEMAN A

TRAINING SESSION	TIME	DATE TAKEN	REMARKS
GATEKEEPER	1 HR	1-20-89	
5'-0" INCH	1 HR	2-25-88	6000 Tons 13750
442 - C. 00000	1 HR	5-77	
FIGHT R2	8 HR	11-32	78%
NUS 1.1	4 HR	12-7-88	
NUS 2.1	4 HR	12-7-88	
BM-III W1	4	3-9-89	87%
BM-III Q	4	3-9-89	Completed
GSS003	8 HR	3-12-90	COMPLETED
GSS020	4 HR	2-25-91	COMPLETED
GSS022	4 HR	2-25-91	COMPLETED
GEENG02CPR	4	3-30-92	COMPLETED
GEENG04BIP	4	3-30-92	COMPLETED
GEGN000003	8	6-3-92	COMPLETED
GEENG01SFA	8	4-6-93	COMPLETED
FALL PROTECTION	8	6-12-91	PASSED

SIGN-IN SHEET

(Please Print)

Date 3-24-97 Instructor's Name Webb

Subject Presented Switching Logic

Location ESC Training Hours _____

Training Meeting _____ Tailgate Meeting _____ Safety Meeting _____

Supervisor's Name _____

Please check one

Last Name/First Name (please print in ink or type)	Signature	Dept/ Empl. #	BU	IC	MS	NE
Haberstein Kenneth	<i>Kenneth Haberstein</i>	3010	✓			
RAZOR GARY	<i>Gary Razor</i>	3320	✓			
RL HILL	<i>RL Hill</i>	2350	✓			
D.T. Vinsan	<i>D.T. Vinsan</i>	2597	✓			
D.L. EVANS	<i>D.L. Evans</i>	35-3175	✓			
R.L. Crawford	<i>Richard Crawford</i>	35-2814	✓			
F.N. ABELL	<i>F.N. Abell</i>	35-1764	✓			
MICKLETHREE MICHAEL	<i>Michael Micklethre</i>	35 3300	✓			
Rhodes Kevin	<i>Kevin Rhodes</i>	34 3485	✓			

BU = Bargaining Unit
NE = Non-exempt

MS = Manager/Supervisor
IC = Individual Contributor

EMPRF1

LOUISVILLE GAS & ELECTRIC CO.

DATE 07/22/97

EMPLOYEE COURSE LISTING

TIME 11:24:43

EMP	NAME	COURSE	COURSE_TITLE	DATE	CLASS STATUS	CLASS HOURS
3220	G W RAZOR	GEENG01SFA	STANDARD FIRST AID	95/10/09	C	2.00
3220	G W RAZOR	GEENGSHORT	TAKING SHORTCUTS	95/08/29	C	.50
3220	G W RAZOR	GEENGSVISN	SAFETY VISION	95/08/29	C	.50
3220	G W RAZOR	GEENGSLIPS	SLIPS, TRIPS, AND FALLS	95/03/01	C	1.00
3220	G W RAZOR	GEENTTRS05	PCB SPILLS	95/23/95	C	.50
3220	G W RAZOR	GEENTRESCU	BUCKET TRUCK RESCUE	95/11/02	C	2.00
3220	G W RAZOR	GEENTEQUIP	PERSONAL PROTECTIVE EQUIPMENT	95/11/02	C	1.00
3220	G W RAZOR	GEUNTHARAS	SEXUAL HARASSMENT	95/10/23	C	.25
3220	G W RAZOR	GEENGVISIN	SAFETY VISION KICKOFF	95/10/18	C	1.50
3220	G W RAZOR	GETNTTCB	SEC-TIED BREAKERS	95/10/04	C	.25
3220	G W RAZOR	GEENG01SFA	STANDARD FIRST AID	95/09/12	C	2.00
3220	G W RAZOR	GEENGBEHAV	BEHAVIOR BASED SAFETY TRAINING	95/07/12	C	3.00
3220	G W RAZOR	GEENG00009	HAZ-COM FLAMMABLE LIQUIDS	95/06/12	C	1.00
3220	G W RAZOR	GEENTTRS05	PCB SPILLS	95/05/23	C	.50
3220	G W RAZOR	GOGNLVIDEO	CONTINUOUS IMPROVEMENT VIDEO	95/05/01	C	2.00
3220	G W RAZOR	GETNSEXGND	SAFETY EXCEL TRAINING	95/04/25	C	15.00
3220	G W RAZOR	GOUNG00001	CODE OF BUSINESS CONDUCT	95/04/21	C	1.00
3220	G W RAZOR	GEENPIRTL	SAFETY INCIDENT AT PIRTL	95/04/20	C	1.00
3220	G W RAZOR	GEENG00023	HAZ-COM LABELING	95/03/29	C	1.00
3220	G W RAZOR	BEENTALCPD	ALCOHOL POLICY TRAINING	95/03/15	C	1.00
3220	G W RAZOR	GETNTEXEMF	OCCUPATIONAL EXPOSURE TO EMF	95/03/08	C	.50
3220	G W RAZOR	BEENGGOVER	1910-269 OVERVIEW	95/02/03	C	2.00
3220	G W RAZOR	SETNTGLOVE	RUBBER GLOVE TESTING	95/02/01	C	.25
3220	G W RAZOR	GEENGEPGND	EQUIPOTENTIAL GROUNDING METHOD	95/01/11	C	2.00
3220	G W RAZOR	GESNGCUPKA	LEADERSHIP SKILLS	94/12/16	C	40.00
3220	G W RAZOR	BXONHCONDR	CONDOR CERTIFICATION	94/11/16	C	9.00
3220	G W RAZOR	GEENGGASES	HAZ - COM GASES	94/11/09	C	1.00
3220	G W RAZOR	GEENGUPDTE	BLOODBORNE PATHOGENS UPDATE	94/11/09	C	1.00
3220	G W RAZOR	GEENG SOLVE	HAZ-COM HALOGENATED SOLVENTS	94/10/05	C	1.00
3220	G W RAZOR	GETNT00001	SAFETY AWARENESS	94/08/03	C	2.00
3220	G W RAZOR	GEUNTFAMLA	FAMILY AND MEDICAL LEAVE ACT	94/06/20	C	1.00
3220	G W RAZOR	GEENG01HAZ	HAZ-COM, WHAT'S IT ALL ABOUT	94/04/20	C	1.00
3220	G W RAZOR	GEENG02CPR	ADULT CPR RECERTIFICATION	94/04/20	C	4.00
3220	G W RAZOR	GEUNGFAMB2	FIELD AMBASSADOR REFRESHER	94/04/20	C	4.00
3220	G W RAZOR	GOENGMBLK	REGULATORY AFFAIRS INFORMATION	94/02/03	C	1.00
3220	G W RAZOR	GEENT94001	COLD WEATHER SAFETY	94/01/07	C	.50
3220	G W RAZOR	GETNT94002	FAULTED CIRCUIT INDICATORS	94/01/07	C	.50
3220	G W RAZOR	GEENTCACCT	ESC CLASS OF ACCOUNTS TRAINING	93/12/17	C	1.00
3220	G W RAZOR	GEENG BLOD1	BLOODBORNE PATHOGENS UPDATE	93/12/14	C	1.00
3220	G W RAZOR	GOENGHM181	DOT-HM181 SHIPPING PAPERS	93/12/13	C	2.00
3220	G W RAZOR	GEENGTRS01	TRANSFORMER FIELD TICKETS	93/11/03	C	.50
3220	G W RAZOR	GETNHGIANT	MINI-GIANT TRAINING	93/10/20	C	2.00
3220	G W RAZOR	GETNHMETER	AUTOMATED-METER READING	93/09/22	C	1.00
3220	G W RAZOR	GETGSPHAS2	PHASE 2 TRAINING	93/05/14	C	.01
3220	G W RAZOR	GETG607TRP	ADVANCED TRANS. PRINCIPLES	93/05/14	C	8.00

PAGE 2

EMPRP1

LOUISVILLE GAS & ELECTRIC CO.

DATE 07/22/97

EMPLOYEE COURSE LISTING

TIME 11.24.43

EMP	NAME	COURSE	COURSE_TITLE	CLASS DATE	CLASS STATUS	CLASS HOURS
3220	G W RAZOR	GETG608TEM	INSTALLATION OF TEMPORARY SERV	93/05/14	C	1.00
3220	G W RAZOR	GETG606SWL	SWITCH. LOGIC & ENERG/DE-ENERG	93/05/13	C	8.00
3220	G W RAZOR	GETG605ELD	URD ELECTRICAL DIAGRAMS	93/05/12	C	4.00
3220	G W RAZOR	GETG604TRM	INSTALL. & REPLACEMENT OF TERM	93/05/11	C	8.00
3220	G W RAZOR	GETG601PRD	USE OF PROPANE & PROP DEVICES	93/05/10	C	2.00
3220	G W RAZOR	GETG602HRD	URD HARDWARE & MATERIALS	93/05/10	C	4.00
3220	G W RAZOR	GETG603SPL	SECONDARY CABLE SPLICING	93/05/10	C	6.00
3220	G W RAZOR	GEENG01SFA	STANDARD FIRST AID	93/04/08	C	8.00
3220	G W RAZOR	GEENGAPS	ANALYTICAL PROBLEM SOLVING	93/02/25	C	24.00
3220	G W RAZOR	GEENTCACCT	ESC CLASS OF ACCOUNTS TRAINING	93/01/04	C	1.50
3220	G W RAZOR	GEENG2LOOD	BLOODBORNE PATHOGENS PLAN	92/11/17	C	2.00
3220	G W RAZOR	GEENHHVOLT	HIGH VOLTAGE TRAINING	92/10/10	C	8.00
3220	G W RAZOR	GEENGHIVLT	HIGH-VOLTAGE DEMONSTRATION	92/07/07	C	1.50
3220	G W RAZOR	GEENG00003	FIELD AMBASSADOR TRAINING	92/06/03	C	8.00
3220	G W RAZOR	GEENG04BIP	BACK INJURY PREVENTION	92/03/30	C	4.00
3220	G W RAZOR	GDUNGCD002	CULTURAL DIVERSITY PHASE I	92/02/06	C	3.00
3220	G W RAZOR	GXGNL00042	CULTURAL DIVERSITY	92/02/06	C	4.00
3220	G W RAZOR	GETNG01	FIRE POWER	91/11/05	C	2.00
3220	G W RAZOR	GET003	RAILROAD CROSSING SAFETY	91/08/15	C	1.50
3220	G W RAZOR	XI0010	CAREER PLANNING & ADVANCEMENT	91/08/15	C	1.25
3220	G W RAZOR	GDENG40232	DEFENSIVE DRIVING	91/03/27	C	8.00
3220	G W RAZOR	GSS020	ADULT CPR RECERTIFICATION	91/02/25	C	4.00
3220	G W RAZOR	GSS022	HAZARD COMMUNICATION TRAINING	91/02/25	C	4.00
3220	G W RAZOR	GSS003	STANDARD FIRST AID	90/03/12	C	8.00
3220	G W RAZOR	AE0821	BASIC METERS	89/03/09	C	8.00
3220	G W RAZOR	AE0E01	ORIENTATION TO T&D SYSTEMS & EQ	88/12/07	C	4.50
3220	G W RAZOR	BT5001	SAFETY IN T&D MAINTENANCE	88/12/07	C	4.00
3220	G W RAZOR	GSS001	FIRST AID/MULTI-MEDIA	88/11/17	C	8.00
3220	G W RAZOR	STP001	FIVE FOOT RULE	88/03/25	C	1.00
TOTAL EMP-3220						287.51
TOTAL						287.51

CRIMPING TOOLS & DIES RECOMMENDED FOR ELASTIMOLD ELBOW COMPRESSION CONNECTORS

CAT. NO. 02500	CRIMP BARREL O.D.	CU OR AL CONDUCTOR SIZE AWG OR KCM		T&B	CSA	HOMAC		ALCOA	BURNDY		KEARNEY		BLACKBURN		ANDERSON
		STR. COMPR.	COMPT. SOLID	HYDR		UT5	HYDR	12A	MD6,MD7	Y35 Y45*	O	H1,H2	OD58	HYDR	VC-6
				DIE NO.	DIE NO.	DIE NO.	DIE NO.	DIE NO.	DIE NO.	DIE NO.	DIE NO.	DIE NO.	DIE NO.	DIE NO.	—
180	.625" (15,9mm)	#6	#5	50	22(2) xx	TU	52	B24EA	W243(3) WBG(3) BG Nose(6)	U243(2) UBG(3) U27RT(3)	5/8 Nose or 620	9/16 or 572	5/8	B24EA	** NO DIE REQ'D.
190		#5	#4												
200		#4	#3												
210		#3	#2												
220		#2	#1												
230		#1	1/0												
240		1/0	2/0												
250		2/0	3/0												
260	.781" (20,0mm)	3/0	4/0	—	—	—	—	—	W247(4)	U29RT(3) U27ART(3)	—	—	—	—	VC-6 NOT RECOMMENDED
270		4/0	250												

* Requires Adapter No. 6515.

** To be used on aluminum conductor ONLY.

() Number of crimps.

Wire brush bared aluminum conductor before inserting into connector.
Rotate each successive crimp 90° or 180°.
xx Overlap crimp.

Investigation Report

Page 2

Mr. Lovelace received burns to both hands. He was released from the hospital Thursday, July 24, 1997.

At 20:02 hours, I notified Mr. John Land's answering machine and then I called Ms. Martha Morton, both with the Public Service Commission. Ms. Morton was informed the transformer and the elbow on the conductor would have to be changed out to get the customers back on line. She said to change the equipment out and John Land would meet with us Monday morning, July 21, 1997.

Photographs were taken Sunday night and Monday morning at the accident site.

On Monday, July 21, 1997, at approximately 09:00 hours, Mr. John Land arrived to investigate the accident.

Photographs and additional materials to follow under separate cover.



Louisville
Gas and Electric
Company

**Electric Transmission
and Distribution Department**

T & D TRAINING



SPECIFIC TEXT

**Switching Logic and Energization/De-energization
Procedures IV**

SLEDP-IV (T&D-R)

SWITCHING LOGIC AND ENERGIZATION/DE-ENERGIZATION PROCEDURES IV

1. Introduction

1.4 Isolation and Energization of a Section of Primary Cable and Transformer

When isolating a section of primary cable and transformer from a URD circuit a schematic diagram must be used and the primary cable and transformer must be totally removed from the circuit.

To isolate a section of primary cable from a URD circuit, both ends of the primary cable to be isolated must be disconnected or removed from the terminals where they are connected. After the primary cable ends have been disconnected and removed from the terminals, the primary cable must be tested for dead and should be grounded before starting work.

To isolate a transformer from a URD circuit, the primary cables at the transformers on either side of the transformer to be isolated must be disconnected or removed from the terminals where they are connected. After the primary cables have been disconnected or removed from the terminals, test the isolated transformer and the primary cables to make sure that they are de-energized. Testing all primary cables and transformers to be worked on to make sure they are de-energized is extremely important in URD systems. Since URD cables run underground, out of sight, it is not possible to be absolutely sure where they feed from. Although diagrams and tags are important aids in identifying cables and transformers, they may contain incorrect information. The only way to make sure that the right cables have been disconnected is to test them to make sure no voltage is present.

When a section of primary cable and/or a transformer needs to be energized, a worker should make sure that the primary cable and transformer have been terminated.

5-FOOT RULE

EMPLOYEES SHALL NOT APPROACH, OR TAKE ANY CONDUCTIVE OBJECT WITHOUT APPROVED INSULATION, CLOSER TO UNGUARDED, EXPOSED ENERGIZED PARTS THAN SHOWN IN THE FOLLOWING TABLE: UNLESS, THE EMPLOYEES ARE INSULATED FROM THE ENERGIZED PARTS, OR THE ENERGIZED PARTS ARE INSULATED FROM THE EMPLOYEES. APPROVED, RUBBER GLOVES AND SLEEVES SHALL BE CONSIDERED ADEQUATE INSULATION OF THE EMPLOYEE FROM THE ENERGIZED PART.

600V THROUGH 13.8 KV

UNDERGROUND CABLE HAS ADEQUATE INSULATION: YOU DO NOT HAVE TO WEAR PROTECTIVE EQUIPMENT, UNTIL YOU GET WITHIN FIVE FEET OF TERMINATION. AT THAT POINT, BEFORE COMING WITHIN FIVE FEET OF TERMINATION, YOU PUT YOUR GLOVES AND SLEEVES ON.

UNDERGROUND TRANSFORMERS

DEAD-FRONT TRANSFORMERS, PADMOUNT.

BEFORE OPENING LID OR DOOR, YOU MUST HAVE YOUR GLOVES AND SLEEVES ON. AFTER INSPECTING, AND EVERYTHING IS OK YOU CAN REMOVE GLOVES AND SLEEVES. USE PROTECTIVE EQUIPMENT NEEDED TO DO YOUR JOB.

LIVE-FRONT TRANSFORMERS

BEFORE OPENING LID OR DOOR, YOU MUST HAVE YOUR GLOVES AND SLEEVES ON. IF VOLTAGE OVER 600V, GLOVES AND SLEEVES ARE REQUIRED. IF YOU ADEQUATELY COVER EQUIPMENT OVER 600V, GLOVES AND SLEEVES CAN BE REMOVED. USE PROTECTIVE EQUIPMENT NEEDED TO DO YOUR JOB.

THE RULE FOR USING GLOVES AND SLEEVES TO OPEN PADMOUNT TRANSFORMERS AND SUB-GRADE TRANSFORMERS IS ABOVE AND BEYOND THE FIVE FOOT RULE.

OVERHEAD LINES AND EQUIPMENT


600V THROUGH 13.8 KV - 5-FOOT RULE.

BEFORE COMING WITHIN FIVE FEET OF PRIMARY, YOU PUT YOUR GLOVES AND SLEEVES ON. IF YOU HAVE EVERYTHING ENERGIZED COVERED, YOU CAN REMOVE GLOVES AND SLEEVES. USE PROTECTIVE EQUIPMENT NEEDED TO DO YOUR JOB. WORK-RULE 11 COVERS THE FIVE-FOOT RULE VIOLATION.

ESD

JOINT TASK

TEAM



"Working together to deliver the goods."

SECTION F



**UNDERGROUND
CABLE
MAINTENANCE
INSTRUCTIONS**

TEMPORARY
PROTECTIVE
GROUNDING
PROCEDURES

LOUISVILLE GAS AND ELECTRIC COMPANY

ELECTRIC SERVICE DELIVERY DEPARTMENT

F. UNDERGROUND TEMPORARY PROTECTIVE GROUNDING PROCEDURES

- 1 *It shall always be assumed that electrical equipment and conductors are energized until proven to be de-energized.* Proper administrative clearance shall be obtained and electrical tests shall be made before any work (including the installation of temporary protective grounds) is started. As an additional safeguard, the isolating switches, or other visible line breaks, shall be locked or blocked open and carded before work is started.
- 2 **Hazards for Underground Workers:**

Underground systems have inherently greater hazards than overhead systems. Due to the limited ability to visually verify circuit routes, there is a greater reliance on circuit maps. In addition, cable sheaths often develop induced potentials due to close capacitive coupling with energized phase conductors. In underground vaults, manholes and in padmounted equipment, a significant flash hazard exists in the event of a fault at the work location. The use of arc suppression blankets shall be used. Also, since the worker is in direct contact with the earth, step and touch potential hazards nearly always exist at the work location under fault conditions.
- 3 **Tailgate: BEFORE** protective grounds are applied or the commencement of any work. The person or persons in charge shall advise ALL employees and the general public of all hazards associated with the job. Information conveyed as part of the job briefing shall include but not limited to the following:
 - a) quantity and location of protective grounds;
 - b) electric clearances provided,
 - c) proximity of energized lines or equipment,
 - d) and special considerations regarding the safe completion of the work,
 - e) hazards associated with the job,
 - f) work procedures involved,
 - g) special precautions,
 - h) energy source controls,
 - i) and personal protective equipment requirements.

Note: The above practice shall apply to those employees working alone.

4 Identification

- a) Identification of all cables is accomplished by checking the cable tag and the duct position as shown on conduit and cable maps.
- b) If the cable tag does not agree with the indicated duct position, trace the cable until identification is positive.
- c) Spiking method is used when working the following: All single phase circuits, loop feed systems, when transformers are added to existing systems, two or more cables are in the same ditch.
- d) Cables operating at 300 volts or less are to be tested with a voltmeter or other approved test device.

Note: When three-phase underground feeders out of substations are required to be worked on due to routine work or cable failure the supervisor in charge shall contact the load dispatcher in order to get clearance and grounds shall be installed on the circuit at the station by the station operators. When notified by the load dispatcher that grounds have been installed the crew shall be notified by the supervisor to proceed with work starting by stripping cable down to conductor and checking with an approved voltage detector. When testring any multi-conductor lead primary cable, always do a test on at least two conductors, eliminating the possibility of testing a neutral on a (4) conductor cable. This process is to be done with the use of proper personal protective equipment including gloves and sleeves.

5 Downtown Network

Before cable is cut there must be a ground put on the closest transformer behind where cable is being worked giving the person working on the cable a ground on both sides of the cable once the cable has been cut.

- 6 When working on a circuit out of Class A or B substation, if work to be done is between switch gear housing and lateral pole, a set of grounds should be installed at the lateral pole. Any three-phase cable taken out of service in order to be worked shall have grounds installed on cable at open locations.
- 7 Any U.R.D. cable taken out of service in order to be worked on will have grounds installed at nearest open location on both sides of area to be worked on.

Isolating Underground Primary Cable


When isolating a section of Underground(URD) primary cable, the following steps should be followed:

1. Get the proper administrative clearances on outages , i.e., Service Center Supervisor, Electric Trouble Department Supervisor, or Service Center Manager.
2. Review an URD circuit schematic diagram and/or job print of the work location. Compare the URD circuit schematic diagram and/or job print with the actual job site. Ask yourself the questions:
 - Do the feeder phase(s) on the URD circuit schematic diagram and/or job print correspond with the actual findings at the job site? *Is what you expected to find actually what you have?*
 - If a transformer is indicated on the URD circuit schematic diagram and/or job print as the open, is it really the open? *Check and see for yourself!*
 - *Look around!* Are there any other subdivisions, houses, or businesses that may have other URD circuits in the same vicinity as the circuit you are preparing to work on? *NEVER ASSUME! Don't be tricked?*
3. Tailgate all of your findings with the crew(s) performing the work. Your tailgate should include but not limited to the following:
 - a) quantity and location of protective grounds
 - b) electric clearances provided
 - c) proximity of energized lines, cables, and equipment.
 - d) any special considerations regarding the safe completion of the work
 - e) hazards associated with the job
 - f) work procedures involved
 - g) any special precautions
 - h) energy source controls
 - i) personal protective equipment requirements
4. Switch a section of cable out of service using the following rules:



- a) *Always wear your Personal Protective Equipment! (i.e., Hard Hat, Safety Glasses, Dielectric Boots, Insulating Rubber Gloves and/or insulating rubber sleeves(if applicable)).*
- b) Always check all testing equipment before each use to be sure they are operating properly.
- c) *Identify the cable.* Check for cable tags(if applicable)on the transformer elbows. They indicate the cable feed direction.
- d) *Identify the cable.* If at all possible test the section of cable, to be de-energized to see if in fact it is energized. That way when you de-energize the cable you can test to see if in fact the condition of the cable did change appropriately. This will give you a good indication that the equipment you are working on is the equipment you want to work on! *Don't be fooled!*
- e) *Always Open Before You Close!* Never close the open transformer before you open at another location. You could buck phases and cause injury to yourself, your co-worker, and equipment.
- f) A cable can be tested for energization or de-energization by testing the transformer being fed before and after the elbows are pulled and stood-off on adjacent transformers.(these elbows should always be mounted on grounded stand-off bushings to be considered dead.)*If It Is Not Grounded It Is Not Dead!* The secondary can be checked with a "voltmeter". The primaries can be checked by standing off the elbows(load break) on stand-off feed through bushings and testing for voltage with an "A. B. Chance Voltage Tester".
- g) A cable can be tested for energization or de-energization by testing the cable before and after de-energization using a "Cable Tester". An example of this is when we splice a cable or terminate a new transformer. The cable may already be exposed by contractors or we may expose it by digging a splice pit. How can we be sure this is the right cable? The best indication is by testing for energization or de-energization before and after de-energization with a "Cable Tester". This way we can monitor the electrical conditions of the cable. If conditions change as we expect them to, we can be better assured the cable is de-energized and we are working on the right cable. *After all testing and conditions have proved out that we very likely have the correct cable,*


there is one more last imperative precautionary step to take. **SPIKE THE CABLE WITH A CABLE SPIKER! DON'T ASSUME!**




- h) The spiking method is used when working on all single phase circuits, loop feed systems, when transformers are added to existing systems, and when two or more cables are in the same ditch.























Attachment B

Photographs of Accident Site

