

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF BULLOCK PEN WATER)	
DISTRICT FOR A DEVIATION FROM THE)	CASE NO.
REQUIREMENTS OF 807 KAR 5:066, SECTION)	2002-00012
4(4), REGARDING WATER STORAGE)	

O R D E R

On January 4, 2002, the Bullock Pen Water District ("Bullock Pen District") applied for permission to deviate from Commission regulation 807 KAR 5:066, Section 4(4), which requires that each utility maintain minimum water storage of one day's supply of its average daily usage. Bullock Pen District states in its application that its average daily water usage, including unaccounted-for water, is approximately 984,000 gallons, and that its current water storage capacity is 925,000 gallons.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. Bullock Pen District is not in compliance with Commission regulation 807 KAR 5:066, Section 4(4).
2. Because of the time needed to plan, finance, and construct water storage facilities, Bullock Pen District should be given until January 1, 2005 to comply with 807 KAR 5:066, Section 4(4).

IT IS THEREFORE ORDERED that:

1. Bullock Pen District is given until January 1, 2005 to comply with the provisions of 807 KAR 5:066, Section 4(4).

2. Bullock Pen District shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to January 1, 2005.

Done at Frankfort, Kentucky, this 6th day of February, 2002.

By the Commission

ATTEST:

A handwritten signature in black ink, appearing to read "Thomas W. O'Dell", written over a horizontal line.

Executive Director