

**PUBLIC SERVICE COMMISSION
METER STANDARDS LABORATORY
METER TEST RESULTS**

Customer: Marilyn L. Chase/Campbellsburg, Ky. Date: July 11, 2003
 Utility: Henry County Water District #2 Tester: George White/Denis Hildenbrand

Complaint Meter

Check Meter

Type: Sensus 5/8 SRII
 Serial #: 47359824

Type: Rockwell 5/8" SRII
 Serial #: 42815091

LOW FLOW RATE

1/4 GPM	End	<u>15183.3</u>	End	<u>9248.5</u>
	Start	<u>15173.8</u>	Start	<u>9238.7</u>
	% Accuracy	<u>95.0</u>	% Accuracy	<u>98.0</u>
1/4 GPM	End	<u>15304.0</u>	End	<u>9733.9</u>
	Start	<u>15294.4</u>	Start	<u>9724.0</u>
	% Accuracy	<u>96.0</u>	% Accuracy	<u>99.0</u>
1/4 GPM	End	<u>15313.6</u>	End	<u>9743.7</u>
	Start	<u>15304.0</u>	Start	<u>9733.9</u>
	% Accuracy	<u>96.0</u>	% Accuracy	<u>98.0</u>
% Average of 3 test runs		<u>95.7</u>	<u>98.3</u>	

MEDIUM FLOW RATE

2 GPM	End	<u>15193.3</u>	End	<u>9258.5</u>
	Start	<u>15183.3</u>	Start	<u>9248.5</u>
	% Accuracy	<u>100.0</u>	% Accuracy	<u>100.0</u>
2 GPM	End	<u>15333.7</u>	End	<u>9763.9</u>
	Start	<u>15323.7</u>	Start	<u>9753.8</u>
	% Accuracy	<u>100.0</u>	% Accuracy	<u>101.0</u>
2 GPM	End	<u>15323.7</u>	End	<u>9753.8</u>
	Start	<u>15313.6</u>	Start	<u>9743.7</u>
	% Accuracy	<u>101.0</u>	% Accuracy	<u>101.0</u>
% Average of 3 test runs		<u>100.3</u>	<u>100.7</u>	

Customer: Marilyn Chase/Campbellsburg, Ky.
Utility: Henry County Water District #2

Date: July 11, 2003
Tester: George White/Denis Hildenbrand

HIGH FLOW RATE

15 GPM	End	<u>15293.3</u>	End	<u>9358.6</u>
	Start	<u>15193.3</u>	Start	<u>9258.5</u>
	% Accuracy	<u>100.0</u>	% Accuracy	<u>100.1</u>
15 GPM	End	<u>15433.8</u>	End	<u>9864.1</u>
	Start	<u>15333.7</u>	Start	<u>9763.9</u>
	% Accuracy	<u>100.1</u>	% Accuracy	<u>100.2</u>
15 GPM	End	<u>15534.0</u>	End	<u>9964.4</u>
	Start	<u>15433.8</u>	Start	<u>9864.1</u>
	% Accuracy	<u>100.2</u>	% Accuracy	<u>100.3</u>
% Average of 3 test runs		<u>100.1</u>		<u>100.2</u>

COMPLAINT METER SUMMARY OF TEST RESULTS

LOW FLOW 1/4 GPM	<u>95.7</u> %	Required	<u>>95%new</u>	<u>>90%used</u>
MED. FLOW 2 GPM	<u>100.3</u> %	Required	<u>>98.5% and <101.5%</u>	
HIGH FLOW 15 GPM	<u>100.1</u> %	Required	<u>>98.5% and <101.5%</u>	

**PUBLIC SERVICE COMMISSION
METER STANDARDS LABORATORY
METER TEST RESULTS**

Customer: Marilyn L. Chase/Campbellsburg, Ky Date: July 11, 2003
 Utility: Henry County Water District #2 Tester: George White/Denis Hildenbrand

Complaint Meter

Check Meter

Type: Badger Recordall/Model 25, 5/8, 3/4" Type: Rockwell 5/8" SRII
 Serial #: 17926843 Serial #: 42815091

LOW FLOW RATE

1/4 GPM	End	<u>3328.8</u>	End	<u>9369.9</u>
	Start	<u>3319.0</u>	Start	<u>9360.1</u>
	% Accuracy	<u>98.0</u>	% Accuracy	<u>98.0</u>
1/4 GPM	End	<u>3450.8</u>	End	<u>9492.7</u>
	Start	<u>3441.0</u>	Start	<u>9482.8</u>
	% Accuracy	<u>98.0</u>	% Accuracy	<u>99.0</u>
1/4 GPM	End	<u>3460.6</u>	End	<u>9502.6</u>
	Start	<u>3450.8</u>	Start	<u>9492.7</u>
	% Accuracy	<u>98.0</u>	% Accuracy	<u>99.0</u>
% Average of 3 test runs		<u>98.0</u>		<u>98.7</u>

MEDIUM FLOW RATE

2 GPM	End	<u>3338.8</u>	End	<u>9380.0</u>
	Start	<u>3328.8</u>	Start	<u>9369.9</u>
	% Accuracy	<u>100.0</u>	% Accuracy	<u>101.0</u>
2 GPM	End	<u>3480.7</u>	End	<u>9522.7</u>
	Start	<u>3470.6</u>	Start	<u>9512.6</u>
	% Accuracy	<u>101.0</u>	% Accuracy	<u>101.0</u>
2 GPM	End	<u>3470.6</u>	End	<u>9512.6</u>
	Start	<u>3460.6</u>	Start	<u>9502.6</u>
	% Accuracy	<u>100.0</u>	% Accuracy	<u>100.0</u>
% Average of 3 test runs		<u>100.3</u>		<u>100.7</u>

Customer: Marilyn Chase/Campbellsburg, Ky. Date: July 11, 2003
 Utility: Henry County Water District #2 Tester: George White/Denis Hildenbrand

HIGH FLOW RATE

15 GPM	End	<u>3438.4</u>	End	<u>9480.0</u>
	Start	<u>3338.8</u>	Start	<u>9380.1</u>
	% Accuracy	<u>99.6</u>	% Accuracy	<u>99.9</u>
15 GPM	End	<u>3580.1</u>	End	<u>9622.8</u>
	Start	<u>3480.7</u>	Start	<u>9522.7</u>
	% Accuracy	<u>99.4</u>	% Accuracy	<u>100.1</u>
15 GPM	End	<u>3679.6</u>	End	<u>9723.0</u>
	Start	<u>3580.1</u>	Start	<u>9622.8</u>
	% Accuracy	<u>99.5</u>	% Accuracy	<u>100.2</u>
% Average of 3 test runs		<u>99.5</u>		<u>100.1</u>

COMPLAINT METER SUMMARY OF TEST RESULTS

LOW FLOW 1/4 GPM	<u>98.0</u> %	Required	<u>>95%new</u>	<u>>90%used</u>
MED. FLOW 2 GPM	<u>100.3</u> %	Required	<u>>98.5% and <101.5%</u>	
HIGH FLOW 15 GPM	<u>99.5</u> %	Required	<u>>98.5% and <101.5%</u>	