

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF MCKINNEY WATER)	
DISTRICT FOR A DEVIATION FROM THE)	CASE NO.
REQUIREMENTS OF 807 KAR 5:066, SECTION)	2003-00129
4(4), REGARDING WATER STORAGE)	

O R D E R

On May 30, 2003, the McKinney Water District ("McKinney District") applied for permission to deviate from Administrative Regulation 807 KAR 5:066, Section 4(4), which requires that each utility maintain minimum water storage of one day's supply of its average daily usage. McKinney District states in its application that its average daily water usage, including unaccounted-for water, is approximately 345,000 gallons, and that its current water storage capacity is 300,000 gallons.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. McKinney District is not in compliance with Administrative Regulation 807 KAR 5:066, Section 4(4).
2. Because of the time needed to plan, finance, and construct water storage facilities, McKinney District should be given until January 1, 2008 to comply with Administrative Regulation 807 KAR 5:066, Section 4(4).

IT IS THEREFORE ORDERED that:

1. McKinney District is given until January 1, 2008 to comply with the provisions of Administrative Regulation 807 KAR 5:066, Section 4(4).

2. McKinney District shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to January 1, 2008.

3. Beginning January 1, 2004 and continuing until January 1, 2008, or until such time as McKinney District comes into compliance, McKinney District shall file, on or before January 1 of each year, a status report of its efforts to comply with Administrative Regulation 807 KAR 5:066, Section 4(4).

Done at Frankfort, Kentucky, this 20th day of August, 2003.

By the Commission

ATTEST:


Executive Director

Case No. 2003-00129