

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF FOUNTAIN RUN WATER)	
DISTRICT FOR A DEVIATION FROM THE)	CASE NO.
REQUIREMENTS OF 807 KAR 5:066, SECTION)	2003-00312
4(4), REGARDING WATER STORAGE)	

O R D E R

On August 7, 2003, the Fountain Run Water District (Fountain District) applied for permission to deviate from Administrative Regulation 807 KAR 5:066, Section 4(4), which requires that each utility maintain minimum water storage of one day's supply of its average daily usage. Fountain District states in its application that its average daily water usage, including unaccounted-for water, is approximately 111,000 gallons, and that its current water storage capacity is 100,000 gallons. Glasgow Water Company, Fountain District s current water supplier, has two connections to the distribution system with a 220,000-gallon water storage tank that supplies potable water to Fountain District s 100,000-gallon tank.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. Fountain District is not in compliance with Administrative Regulation 807 KAR 5:066, Section 4(4), but for good cause shown a deviation should be granted.
2. Because of the time needed to plan, finance, and construct water storage facilities, Fountain District should be given until January 1, 2008 to comply with Administrative Regulation 807 KAR 5:066, Section 4(4).

IT IS THEREFORE ORDERED that:

1. Fountain District's request for deviation is granted until January 1, 2008 to comply with the provisions of Administrative Regulation 807 KAR 5:066, Section 4(4).
2. Fountain District shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to January 1, 2008.

Done at Frankfort, Kentucky, this 10th day of November, 2003.

By the Commission

ATTEST:


Executive Director

Case No. 2003-00312