

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF GREEN-TAYLOR WATER)
DISTRICT FOR A DEVIATION FROM THE) CASE NO.
REQUIREMENTS OF 807 KAR 5:066, SECTION) 2007-00271
4(4), REGARDING WATER STORAGE)

O R D E R

On July 2, 2007, the Green-Taylor Water District ("Green-Taylor") applied for permission to deviate from Administrative Regulation 807 KAR 5:066, Section 4(4), which requires that each utility maintain minimum water storage of one day's supply of its average daily usage. Green-Taylor states in its application that its average daily water usage, including unaccounted-for water, is approximately 975,000 gallons, and that its current water storage capacity is 860,000 gallons.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. Green-Taylor is not in compliance with Administrative Regulation 807 KAR 5:066, Section 4(4).
2. Green-Taylor states in its application that funds are already in place from a state grant to replace its existing 60,000-gallon Black Gnat Water Storage Tank with a 500,000-gallon elevated water storage tank.
3. Because of the time needed to plan, finance, and construct water storage facilities, Green-Taylor should have until January 1, 2009 to comply with Administrative Regulation 807 KAR 5:066, Section 4(4).

IT IS THEREFORE ORDERED that:

1. Green-Taylor shall have until January 1, 2009 to comply with the provisions of Administrative Regulation 807 KAR 5:066, Section 4(4).

2. Green-Taylor shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to January 1, 2009.

Done at Frankfort, Kentucky, this 13th day of August, 2007.

By the Commission

ATTEST:

A handwritten signature in black ink, consisting of several overlapping loops and flourishes, positioned above a horizontal line.

Executive Director