

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF FOUNTAIN RUN WATER)	
DISTRICT NO. 1 FOR A DEVIATION FROM THE)	CASE NO.
REQUIREMENTS OF 807 KAR 5:066, SECTION)	2007-00508
4(4), REGARDING WATER STORAGE)	

O R D E R

On December 10, 2007, Fountain Run Water District No. 1 ("Fountain Run") applied for permission to deviate from Administrative Regulation 807 KAR 5:066, Section 4(4), which requires that each utility maintain minimum water storage of one day's supply of its average daily usage. Fountain Run states in its application that its average daily water usage, including unaccounted-for water, is approximately 150,000 gallons, and that its current water storage capacity is 100,000 gallons.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. Fountain Run is not in compliance with Administrative Regulation 807 KAR 5:066, Section 4(4).
2. Fountain Run states in its application that it has hired HMB Professional Engineers, Inc. of Frankfort, Kentucky to plan and design the project needed to bring them into compliance.
3. Because of the time needed to plan, finance, and construct water storage facilities, Fountain Run should be given until January 1, 2013 to comply with Administrative Regulation 807 KAR 5:066, Section 4(4).

IT IS THEREFORE ORDERED that:

1. Fountain Run is given until January 1, 2013 to comply with the provisions of Administrative Regulation 807 KAR 5:066, Section 4(4).

2. Fountain Run shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to January 1, 2013.

Done at Frankfort, Kentucky, this 25th day of January, 2008.

By the Commission

ATTEST:



Executive Director