

COMMONWEALTH OF KENTUCKY  
BEFORE THE ENERGY REGULATORY COMMISSION

\* \* \* \* \*

In the Matter of

APPLICATION OF MR. IKE SKEEN, )  
PRESTONSBURG, KENTUCKY, TO DEVIATE ) CASE NO. 7882  
FROM COMMISSION REGULATION 807 )  
KAR 50:045 SECTION 6, SUBPART 6 )

O R D E R

On May 15, 1980, Mr. Ike Skeen, Prestonsburg, Kentucky, filed a letter with the Commission requesting authority to use 1-1/4 inch plastic pipe in the construction of a service line from his house to a gas line of Inland Gas Company.

The Commission decided to treat this letter as an Application requesting authority to deviate from the provisions of Commission Regulation 807 KAR 50:045 Section 6, Subpart 6.

A member of the Commission staff inspected the proposed location of the service line and found that it would be possible to bury the line to a sufficient depth to prevent damage to same by various surface plowing and digging activities and recommended the granting of the requested authority.

The Commission, having considered the Application, all evidence of record and being fully advised, is of the opinion and finds:

1. That a hearing to consider the merits of the application will not be necessary.
2. That Mr. Skeen should be granted permission to use 1-1/4 inch plastic pipe in lieu of black steel pipe provided the pipe is of an approved type and is buried a minimum of 36 inches.
3. That the completed service line installation shall be inspected by Commission staff members prior to the filling of the ditch.
4. That Mr. Skeen shall notify the Commission when construction is sufficiently completed to allow for the above inspection.

5. That Mr. Skeen shall meet all other requirements of the Energy Regulatory Commission Regulation 807 KAR 50:045 Section 6 in his installations.


IT IS THEREFORE ORDERED That Mr. Ike Skeen, Prestonsburg, Kentucky, be and he hereby is granted authority to deviate from the Energy Regulatory Commission Regulation 807 KAR 50:045 Section 6, Subpart 6 and install one and one-fourth (1-1/4) inch plastic pipe of an approved type in his service line said pipe to be buried a minimum of 36 inches.

IT IS FURTHER ORDERED That Mr. Skeen notify the Commission when construction is sufficiently completed to allow for the inspection and approval of the line by the Energy Regulatory Commission's Division of Utility Engineering and Services before service is rendered.

Done at Frankfort, Kentucky, this 11th day of July, 1980.

ENERGY REGULATORY COMMISSION

  
Chairman

  
Vice Chairman

  
Commissioner

ATTEST:

\_\_\_\_\_  
Secretary