

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

* * * * *

In the Matter of

THE COMPLAINT OF CHARLES HATTON)
LONDON, KENTUCKY AGAINST THE WOOD)
CREEK WATER DISTRICT) CASE NO. 8303

O R D E R

On May 8, 1981 the Commission received a letter from Mr. Charles Hatton, London, Kentucky, wherein he stated that the Wood Creek Water District ("District") was not providing the water pressure (30 psi) required by 807 KAR 5:066E at the water meter which serves the residence of Mr. Hatton.

By letter received May 23, 1981 the District stated that it owned one booster pump which it has agreed to loan to Mr. Hatton and his neighbors providing they maintain the facility and pay for the electrical service to the pump. This arrangement is not satisfactory to Mr. Hatton and by letter received July 20, 1981 he requests a hearing with respect to the complaint.

The Commission having considered the matter and being advised HEREBY ORDERS That this matter be and it hereby is set for hearing on the 17th day of September, 1981, at 1:30 p.m., Eastern Daylight Time, in the Commission's offices at Frankfort, Kentucky.

IT IS FURTHER ORDERED That Wood Creek Water District shall appear at the hearing and present testimony relative to this matter.

Done at Frankfort, Kentucky, this 4th day of August, 1981.

PUBLIC SERVICE COMMISSION

Marlin M. Voss
For the Commission

ATTEST:

Secretary