

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

* * * * *

In the Matter of:

THE APPLICATION OF RATTLESNAKE)
RIDGE WATER DISTRICT, CARTER,)
ELLIOT, AND LAWRENCE COUNTIES,)
KENTUCKY (1) FOR A CERTIFICATE OF)
PUBLIC CONVENIENCE AND NECESSITY)
AUTHORIZING SAID DISTRICT TO)
CONSTRUCT A WATER DISTRIBUTION)
SYSTEM PURSUANT TO THE PROVISIONS) CASE NO. 9071
OF CHAPTER 74 OF THE KENTUCKY)
REVISED STATUTES; (2) SEEKING AP-)
PROVAL OF A SCHEDULE OF RATES AND)
CHARGES TO BE CHARGED FOR WATER)
SERVICE; AND (3) SEEKING APPROVAL)
OF THE ISSUANCE OF CERTAIN)
SECURITIES)

O R D E R

IT IS ORDERED that Rattlesnake Ridge Water District ("Rattlesnake Ridge") shall file an original and seven copies of the following information with the Commission with a copy to all parties of record by September 28, 1984. If the information requested or a motion for an extension of time is not filed by the stated date, the Commission may dismiss the case without prejudice. Rattlesnake Ridge shall furnish with each response the name of the witness who will be available at the public hearing for responding to questions concerning each item of information requested.

1. PSC Regulation 807 KAR 5:066, Section 11 prohibits 2-inch non-circulating lines in excess of 250 feet in length.

Plan sheets A-35, B-3, B-14, B-16, and B-34 propose 2-inch lines which appear to be in violation of this regulation. It appears that 3-inch or larger lines should be installed. Provide comments concerning this matter.

2. Provide a list of all 2-inch water lines proposed for the project. This list shall include the location, length and possibility for future extension of each line.

3. Provide copy of the pump manufacturer's characteristic (head capacity) curve for each of Rattlesnake Ridge's proposed pumps. Identify each curve as to the particular pump and pump station to which it applies.

Done at Frankfort, Kentucky, this 11th day of September, 1984.

PUBLIC SERVICE COMMISSION

Richard D. Herron
For the Commission

ATTEST:

Secretary