

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF NORTH MARSHALL)
WATER DISTRICT FOR A DEVIATION FROM)
807 KAR 5:066, SECTION 5(4) REGARDING) CASE NO. 10483
WATER STORAGE)

O R D E R

By letter received November 21, 1988, North Marshall Water District ("North Marshall") requested a deviation from 807 KAR 5:066, Section 5(4), which requires a utility to provide water storage to insure a minimum of one day's supply of its average daily water usage.

The Commission, having reviewed the evidence of record and being advised, is of the opinion and finds that:

1. North Marshall's current water storage capacity is 775,600 gallons.
2. North Marshall's average daily water usage including unaccounted-for-water is 886,000 gallons.
3. Because of the time needed to plan, finance and implement a program to increase its water storage facilities, North Marshall should be granted a deviation from 807 KAR 5:066, Section 5(4) until January 1, 1992 to bring it within compliance of the Commission's water storage requirements.

IT IS THEREFORE ORDERED that:

1. North Marshall be and it hereby is granted a deviation from 807 KAR 5:066, Section 5(4) until January 1, 1992.

2. North Marshall shall take all necessary actions to bring its water storage facilities within compliance of the Commission regulations prior to the expiration date of the deviation herein granted.

Done at Frankfort, Kentucky, this 13th day of December, 1988.

PUBLIC SERVICE COMMISSION

Chairman

Robert M. Davis

Vice Chairman

Spencer H. Williams

Commissioner

ATTEST:

Executive Director