

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

APPLICATION OF SAM ENDICOTT, LOUISA,)
KENTUCKY, TO DEVIATE FROM COMMISSION) CASE NO. 10,011
REGULATION 807 KAR 5:026, SECTION 6(7))

O R D E R

On August 17, 1987, Sam Endicott, Louisa, Kentucky, filed a letter with the Commission requesting authority to use one-inch yard line to his property from the gas gathering line of Baiden Gas Company.

Jack Stumbo, a member of the Commission staff, inspected the proposed location and found the line had been removed and replaced with one and one-fourth inch, 400-foot long plastic pipe, which is according to the Commission regulations. The line was successfully tested to 3 psi during Mr. Stumbo's inspection. The inspection report is attached as Appendix A.

BACKGROUND

On August 25, 1987, the Commission ordered Baiden Gas Company¹ to comply with the Commission regulation by September 1, 1987, by determining that all of its customers' hookups comply with the Commission regulations.

The customers of the Baiden Gas Company have been notified of changes required in their systems to comply with the Commission

¹ Case No. 9954, Failure of Baiden Gas Company to Comply with Commission Regulations.

regulations, and their systems have been inspected by members of the Commission staff.

One of the violations of some of the Baiden Gas Company customers was using one-inch yard line instead of one and one-fourth inch line.

The lengths of the lines were measured, and the lines were tested by a member of the Commission staff.

CONCLUSION

The Commission, having considered the application and all evidence of record and being fully advised, is of the opinion and finds that:


1. Sam Endicott is not deviating from the Commission regulations by replacing his gas yard line with one and one-fourth inch approved plastic pipe.

2. Mr. Endicott shall meet all other requirements of Public Service Commission Regulation 807 KAR 5:026.

IT IS THEREFORE ORDERED that Sam Endicott's application is hereby dismissed without prejudice.

Done at Frankfort, Kentucky, this 2nd day of October, 1987.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:

Executive Director

INTRA AGENCY MEMORANDUM
 KENTUCKY PUBLIC SERVICE COMMISSION
 FARM TAP INSPECTION REPORT

DATE 8/7/87NAME OF CUSTOMER: Sam EndicottADDRESS: Rt. 5, Box 247Louisa, Kentucky 41230COMPANY: Baiden Gas Company

TYPE OF INSPECTION: Final

PLASTIC PIPE DEVIATION NA CASE # CONSTRUCTION Self CO. REFERENCE #

REPORT: "THE UNDERSIGNED HAS INSPECTED THE CONSTRUCTION OF SERVICE LINES DESIGNED TO PROVIDE NATURAL GAS SERVICE TO THE CUSTOMER(S) NOTED ABOVE IN ACCORDANCE WITH 807 KAR 5:026, SECTION 3, SUBSECTION 4. THE INSPECTION(S) INDICATED THAT THE CONSTRUCTION HAS BEEN COMPLETED IN ACCORDANCE WITH THE KENTUCKY PUBLIC SERVICE COMMISSION REGULATIONS 807 KAR 5:026, GAS SECTION: SERVICE LINES AND HAS BEEN APPROVED FOR NATURAL GAS SERVICES."

INSPECTOR: *Paul Stucke*

AUG. 13, 87

August 10, 1987

Mr. Claude Rhorer, Jr.
Public Service Commission
P.O. Box 615
Frankfort, Kentucky 40602

C.N. 10, 011

Dear Mr. Rhorer,

On July 20, 1987 at a meeting in Inez, Kentucky you stated that if any customers of Baiden Gas had a one inch house line we needed to write a letter requesting approval to use this line.

I live approximately one-fourth of a mile on Route 292 on the left of the road and my line is approximately 150 feet. I would appreciate it if my line could be inspected to see if it meets the State requirements.

Sincerely,

SAM - Gindrecht
Rt 5 Bx 248
Louisa Ky 41230