STATE OF NORTH CAROLINA)	
)	SS:
COUNTY OF MECKLENBURG)	

The undersigned, Benjamin W. B. Passty, Principal Load Forecasting Analyst, being duly sworn, deposes and says that he has personal knowledge of the matters set forth in the foregoing data requests, and that the answers contained therein are true and correct to the best of his knowledge, information and belief.

Benjamin W. B. Passty, Affiant

Subscribed and sworn to before me by Benjamin W. B. Passty on this $\frac{25}{2}$ day of

March 2022.

JOSEPH CATALO
NOTARY PUBLIC
Mecklenburg County
North Carolina
My Commission Expires 10/21/2026

NOTARY PUBLIC

My Commission Expires: |C/2|/2026

STATE OF NORTH CAROLINA)	
COUNTY OF MECKLENBURG)	SS:

2022.

The undersigned, Scott Park, Manager Director IRP & Analytics being duly sworn, deposes and says that he has personal knowledge of the matters set forth in the foregoing data requests, and that the answers contained therein are true and correct to the best of his knowledge, information and belief.

Scott Park, Affiant

Subscribed and sworn to before me by Scott Park on this 31st day of Maran

NOTAP LINE PUBLIC NOTARY PUBLIC

My Commission Expires: 0010012025

STATE OF NORTH CAROLINA)	
)	SS:
COUNTY OF MECKLENBURG)	

The undersigned, Brad Daniel, Director, Generation Dispatch and Operations, being duly sworn, deposes and says that he has personal knowledge of the matters set forth in the foregoing data requests, and that the answers contained therein are true and correct to the best of his knowledge, information and belief.

Brad Daniel, Affiant

Subscribed and sworn to before me by Brad Daniel on this 22 day of Mrc., 2022.

My Commission Expires:

SHAMALE M WILSON Notary Public, North Carolina Mecklenburg County My Commission Expires July 06, 2026

STATE OF OHIO)	
)	SS:
COUNTY OF HAMILTON)	

The undersigned, Maida Session, Lead Energy Accounting Analyst, being duly sworn, deposes and says that she has personal knowledge of the matters set forth in the foregoing data requests, and that the answers contained therein are true and correct to the best of her knowledge, information and belief.

Maida Session, Affiant

Subscribed and sworn to before me by Maida Session on this 22 day of

NOTARY PUBLIC

My Commission Expires: 3/18/26



COREY SWEARINGEN Notary Public State of Ohio My Comm. Expires March 18, 2026

STATE OF INDIANA)	
)	SS:
COUNTY OF HENDRICKS)	

The undersigned, Timothy J. Hohenstatt, Director Transmission Planning, being duly sworn, deposes and says that he has personal knowledge of the matters set forth in the foregoing data requests, and that the answers contained therein are true and correct to the best of his knowledge, information and belief.

Timothy J. Hohenstatt, Affiant

Subscribed and sworn to before me by Timothy J. Hohenstatt on this 16 day of ARCH 2022.

PAULA MCGOWAN ROSEMAN Seal Notary Public – State of Indiana Hendricks County NOTARY PUBLIC

My Commission Expires: 3-17-25

Administrative Case No. 387 TABLE OF CONTENTS

DATA REQUEST	<u>WITNESS</u>	TAB NO.
STAFF-DR-01-003	Benjamin Passty	3
STAFF-DR-01-004	Benjamin Passty	4
STAFF-DR-01-006	Benjamin Passty	6
STAFF-DR-01-007	Scott Park	7
STAFF-DR-01-008	Scott Park	8
PUBLIC STAFF-DR-01-011	Brad Daniel	11
STAFF-DR-01-012	Scott Park	12
STAFF-DR-01-013	Maida Session Tim Hohenstatt	13
STAFF-DR-01-014	Tim Hohenstatt	14

STAFF-DR-01-003

REQUEST:

Actual and weather-normalized monthly coincident peak demands for the just completed calendar year. Demands should be disaggregated into (a) native load demand (firm and non-firm) and (b) off-system demand (firm and non-firm).

RESPONSE:

Duke Energy Kentucky Electric Energy Demands - MW				
	Native	Internal	Weather Normal	
	Peak	Peak	Internal Peak	Total
Jan-21	631	631	698	698
Feb-21	678	678	654	654
Mar-21	601	601	600	600
Apr-21	553	553	542	542
May-21	734	734	575	575
Jun-21	820	820	730	730
Jul-21	787	787	841	841
Aug-21	838	838	807	807
Sep-21	742	742	701	701
Oct-21	611	611	497	497
Nov-21	585	585	580	580
Dec-21	595	595	673	673


PERSON RESPONSIBLE: Benjamin Passty

STAFF-DR-01-004

REQUEST:

Load shape curves that show actual peak demands and weather-normalized peak demands (native load demand and total demand) on a monthly basis for the just completed calendar year.

RESPONSE:



PERSON RESPONSIBLE: Benjamin Passty

REQUEST:

Based on the most recent demand forecast, the base case demand and energy forecasts and high case demand and energy forecasts and high case demand and energy forecasts for the current year and the following four years. The information should be disaggregated into (a) native load (firm and non-firm demand) and (b) off-system load (both firm and non-firm demand).

RESPONSE:

Duke Energy Kentucky – Native Load Forecast				
	Demand	Demand – MW		GWH
	Base	High	Base	High
2022	825	910	3,993	4,403
2023	838	923	4,068	4,480
2024	845	930	4,101	4,513
2025	854	939	4,150	4,563
2026	855	940	4,150	4,562

Duke Energy Kentucky – Non-Firm Electric Forecast				
	Demand	Demand – MW		- MWH
	Base	High	Base	High
2022	n/a	n/a	n/a	n/a
2023	n/a	n/a	n/a	n/a
2024	n/a	n/a	n/a	n/a
2025	n/a	n/a	n/a	n/a
2026	n/a	n/a	n/a	n/a

PERSON RESPONSIBLE: Benjamin Passty

Duke Energy Kentucky Administrative Case No. 387

March 31, 2022

STAFF-DR-01-007

REQUEST:

The target reserve margin currently used for planning purposes, stated as a percentage of

demand. If changed from what was in use in 2001, include a detailed explanation for the

change.

RESPONSE:

In order to better align our internal planning process with that of PJM, we used

the UCAP methodology for the 2021 Duke Energy Kentucky IRP. This will reflect the

capacity accreditation that PJM uses for different types of resources.

Duke Energy Kentucky recognizes that the PJM Planning Reserve Margin varies

with every capacity action and assumed a 9.0% Planning Reserve Margin for the duration

of the IRP. For reference purposes, the most recent PJM Planning Reserve Margin

requirement for Planning Year 2023/24 is 9.0%.

PERSON RESPONSIBLE:

Scott Park

STAFF-DR-01-008

REQUEST:

Projected reserve margins stated in megawatts and as a percentage of demand for the

current year and the following 4 years. Identify projected deficits and current plans for

addressing these. For each year identify the level of firm capacity purchases projected to

meet native load demand.

RESPONSE:

Projected reserve margins are calculated as follows and assume PJM's UCAP methodology:

Reserve Margin (MW) = Generating Capacity – Peak Demand – Demand Response

Reserve Margin (%) = (Generating Capacity / (Peak Demand – Demand Response)) - 1

Year	Projected Reserves (UCAP MW)	Projected Reserve Margin (%)
2022	188	29%
2023	188	27%
2024	198	28%
2025	199	27%
2026	216	27%

This data reflects the Fall 2021 Load Forecast. The current fleet consists of, based on summer rating, the 600 MW East Bend 2 and 462 MW Woodsdale generating stations plus 7 MW solar.

PERSON RESPONSIBLE:

Scott Park

PUBLIC STAFF-DR-01-011

REQUEST:

A list that identifies scheduled outages or retirements of generating capacity during the current year and the following four years.

RESPONSE:

CONFIDENTIAL PROPRIETARY TRADE SECRET

Unit Name	Year	Duration (Weeks)
Woodsdale CT 4	2022	
Woodsdale CT 1	2022	
Woodsdale CT 2	2022	
Woodsdale CT 3	2022	
Woodsdale CT 5	2022	
Woodsdale CT 6	2022	
East Bend 2	2022	
Woodsdale CT 1	2022	
Woodsdale CT 2	2022	
East Bend 2	2022	
Woodsdale CT 3	2022	
Woodsdale CT 4	2022	
Woodsdale CT 5	2022	
Woodsdale CT 6	2022	
Woodsdale CT 1	2023	
Woodsdale CT 2	2023	
Woodsdale CT 3	2023	
Woodsdale CT 4	2023	
Woodsdale CT 5	2023	
Woodsdale CT 6	2023	
East Bend 2	2023	
East Bend 2	2023	
Woodsdale CT 1	2023	
Woodsdale CT 2	2023	
Woodsdale CT 3	2023	
Woodsdale CT 4	2023	

Woodsdale CT 5	2023	
Woodsdale CT 6	2023	
Woodsdale CT 1	2024	
Woodsdale CT 2	2024	
Woodsdale CT 3	2024	
Woodsdale CT 4	2024	
East Bend 2	2024	
Woodsdale CT 5	2024	
Woodsdale CT 6	2024	
Woodsdale CT 1	2024	
Woodsdale CT 2	2024	
Woodsdale CT 3	2024	
Woodsdale CT 4	2024	
Woodsdale CT 5	2024	
Woodsdale CT 6	2024	
East Bend 2	2024	
Woodsdale CT 1	2025	
Woodsdale CT 2	2025	
Woodsdale CT 3	2025	
Woodsdale CT 4	2025	
Woodsdale CT 5	2025	
Woodsdale CT 6	2025	
East Bend 2	2025	
East Bend 2	2025	
Woodsdale CT 1	2025	
Woodsdale CT 2	2025	
Woodsdale CT 3	2025	
Woodsdale CT 4	2025	
Woodsdale CT 5	2025	
Woodsdale CT 6	2025	
Woodsdale CT 1	2026	
Woodsdale CT 2	2026	
Woodsdale CT 3	2026	
Woodsdale CT 4	2026	
Woodsdale CT 5	2026	
Woodsdale CT 6	2026	
East Bend 2	2026	
Woodsdale CT 1	2026	
Woodsdale CT 2	2026	
Woodsdale CT 3	2026	
Woodsdale CT 4	2026	

East Bend 2	2026	
Woodsdale CT 5	2026	
Woodsdale CT 6	2026	

PERSON RESPONSIBLE: Brad Daniel

Duke Energy Kentucky Administrative Case No. 387

March 31, 2022

STAFF-DR-01-012

REQUEST:

Identify all planned base load or peaking capacity additions to meet native load

requirements over the next 10 years. Show the expected in-service date, size and site for

all planned additions. Include additions planned by the utility, as well as those by

affiliates, if constructed in Kentucky or intended to meet load in Kentucky.

RESPONSE:

There are currently no planned base load capacity additions forecasted for the next 10

years, subject to specific assumptions regarding Federal Carbon Legislation as reflected

in the Company's recently filed IRP in Case No. 2021-00245. Additionally, as reflected

in the aforementioned IRP, the Company forecasts a need, based upon specific

assumptions, for additional renewable generation as possible transitional portfolios.

Duke Energy Kentucky continually evaluates its needs for additional base or peaking

capacity based upon annual load projections. No final decision has been made at this

time.

PERSON RESPONSIBLE:

Scott Park

STAFF-DR-01-013

REQUEST:

The following transmission energy data for the just completed calendar year and the forecast for the current year and the following four years:

- a. Total energy received from all interconnections and generation sources connected to the transmission system.
- b. Total energy delivered to all interconnections on the transmission system.
- c. Peak load capacity of the transmission system.
- d. Peak demand for summer and winter seasons on the transmission system.

RESPONSE:

a.

Year	Month	Total Energy Received
2021	January	373,083
	February	358,261
	March	328,023
	April	295,351
	May	322,457
	June	380,508
	July	412,798
	August	423,203
	September	348,431
	October	313,851
	November	317,933
	December	337,519
2020 Total		4,211,419

- b. There were 239,471 MWh delivered to the transmission system from Duke Energy Kentucky.
- c. Neither Duke Energy Kentucky nor the electric utility industry has defined a term "peak load capacity of the transmission system." There is no single number that defines the capacity of a transmission system due to the interconnected nature of the electric grid. Duke Energy Kentucky does perform assessments of its transmission system to ensure all firm loads can be served in a reliable manner. This ensures that the transmission system has the capacity required to reliably serve the load.

d. **SUMMER PEAK**

Date	Hour	MW's
August 12, 2021	16	838

WINTER PEAK

Date	Hour	MW's
February 17, 2021	8	678

PERSON RESPONSIBLE:

Maida Session -a., b., d. Tim Hohenstatt -c.

Duke Energy Kentucky Administrative Case No. 387

March 31, 2022

STAFF-DR-01-014

REQUEST:

Identify all planned transmission capacity additions for the next 10 years. Include the

expected in-service date, size and site for all planned additions and identify the

transmission need each addition is intended to address.

RESPONSE:

The following transmission capacity additions are planned with planned in-service dates

indicated:

Woodspoint to Aero 138 kV line – erect a single circuit 138 kV line from

Woodspoint Substation to Aero Substation, approximately 1.5 miles in

length. Planned in-service Date: 9/1/2022

Hebron to Oakbrook 69 kV line - erect a single circuit 69 kV line from

Hebron Substation to the vicinity of St. Route 237 and Northside Drive,

approximately 1.1 miles in length. Rebuild/upgrade the capacity of a

section of an existing 69 kV line from Limaburg Substation south to St.

Route 18, approximately 1.4 miles in length. (Both the new line section

and the rebuilt/upgraded line section will be constructed to 138 kV

standards to allow future capacity upgrade if required due to future load

growth.) Planned in-service Date: 12/31/2024.

The purpose of the above planned projects is to provide service to the Duke Energy

Kentucky transmission and distribution systems to serve load growth in Boone County, in

the vicinity of the Cincinnati/Northern Kentucky International Airport.

PERSON RESPONSIBLE:

Tim Hohenstatt