ROBY, GLENDA

From:

HORTON, NAORA (ATTSWBT)

Sent:

Sunday, December 07, 2008 5:33 PM

To:

HORTON, NAORA (ATTSWBT); 'alagar@globalconnectioninc.com';

'bob.buerrosse@xo.com'; 'dhoyle@matrixbt.com'; DIGGS, SONYA M (ATTOPS); 'ebalvin@covad.com'; 'edkilb@dnsys.com'; 'Howard.Siegel@LogixCom.com';

'jbilow@mcleodusa.com'; 'jeff.sonnier@sprint.com'; 'jennifer.obenland@gservicesco.com';

'kdisaacs@eschelon.com'; 'knorwood@gapublicweb.net'; 'kristen.smoot@rcn.net';

'lhenneman@buckeye-telesystem.com'; 'lpeterman@choiceonecom.com'; 'mconquest@nuvox.com'; 'ncarroll@birch.com'; 'pamela.blegen@qwest.com';

'pbewick@newedgenetworks.com'; 'rcurry@ststelecom.com'; 'rhester@sagetelecom.net'; 'rod.cox@tdsmetro.com'; 'shobbs@megapath.net'; 'terri.mcmillon@verizonbusiness.com';

'tjzurfluh@cavtel.com'; 'Jackson, Robin'; 'Sanders, Nancy'

Cc:

'bowens@sagetelecom.net'; 'carol.j.frike@sprint.com'; 'cdelrio@covad.com'; 'chuang@cinergycom.com'; 'dpeele@ststelecom.com'; 'kgray@cavtel.com';

'pamela.trickel@tdsmetro.com'; 'robecca.myers@qwest.com'; 'sgolladay@cimco.net'

Subject:

Courtesy CMPOC Outage Notification

Outage Notification

AT&T's St. Louis data center (801 Chestnut Street) building was flooded when a water main broke. Damage to the switch gear necessitated a shutdown of commercial and generator power to the entire building. A variety of Wholesale applications, affecting both local and access services, are currently impacted in all regions, except the West region. AT&T is working aggressively to restore power and Wholesale applications. Further information detailing specific impacts from the outage and expectations for Wholesale application availability will be provided before end of day Sunday.

This notification is being sent to the Change Management Points of Contact List. The server with the Broadcast Outage Notification distribution list was impacted by this outage and so the normal Broadcast Outage Notification distribution list could not be utilized at this time.