




Commonwealth of Kentucky
 Public Service Commission
 211 Sower Boulevard
 Frankfort, KY 40601



August 23, 2002

**Notice of Intent to File Application
 Kentucky Pioneer Energy, LLC.**

Dear Sir or Madam:

Case No. 2002-00317

In accordance with 801 KAR 5:110E, under the authority of SB 257, Kentucky Pioneer Energy hereby submits a "Notice of Intent to File Application" to the Public Service Commission.

Name and Contact

The application will be prepared and filed by the following:

Kentucky Pioneer Energy, LLC 312 Walnut Street, Suite 2000 Cincinnati, OH 45202	Telephone: 513-621-0077	Contact: Dwight N. Lockwood Vice President – Regulatory Affairs
---	----------------------------	---

Brief Description of the Project

Kentucky Pioneer Energy proposes to construct and operate a based-load 540 MW electric Integrated Gasification Combined Cycle (IGCC) generating station comprised of two GE 7FA gas turbine driven generator sets, each with a heat recovery steam generator (HRSG). Steam from the two HRSG units will operate a steam turbine driven generator. Together the three generators will produce the electricity, and with other equipment, deliver it at 138 kilovolts to the wholesale customer. Fuel for the gas turbines will be synthesis gas (syngas) produced in the gasification process. Natural gas will be used for start-up and as a back-up fuel.

Location of the Construction

The project will be located on a 300-acre parcel of land leased from East Kentucky Power Cooperative (EKPC) at their 3200-acre JK Smith site in Trapp, Clark County, Kentucky.

Address: 12145 Irvine Road Trapp, Kentucky 40391	Latitude: 37 Degrees 53 Minutes 00 Seconds Longitude: 84 Degrees 05 Minutes 30 Seconds
---	---

The proposed site is in rural Clark County and not within the boundaries of a city, community or village.

Planning and Zoning Commission

Clark County Planning and Zoning Commission
P.O. Box 40
Winchester, KY 40392


Setback Requirements

There are no setback requirements that apply to this project at this location.

Stringency of Setback Requirements

The exhaust stack location at the proposed facility conforms to the setback requirements in Section 3 (2) of KRS 278, and a deviation request will not be requested in the application.

Respectfully Submitted,



Dwight N. Lockwood
Vice President Regulatory Affairs

Cc: M. Musulin, President, Kentucky Pioneer Energy, LLC.



GLOBAL ENERGY

Dwight N. Lockwood, P.E., QEP
Vice President
Regulatory Affairs

Global Energy Inc., Suite 2000, 312 Walnut Street
Cincinnati, Ohio 45202 USA

US Tel: (513) 621 9077 US Fax: (513) 621 5947

UK Tel: 44 (0) 1592 860293 UK Fax: 44 (0) 1592 860193

email: dnlockwood@globalenergyinc.com