

Kentucky Resources Council, Inc.
Frankfort, KY
Page 33 of 74

**CURRENT GASIFICATION
POWER PLANT PROJECTS**

There are currently at least 35 GPP projects in operation, commissioning, construction, design or planning. These vary in size from 500MW_e to less than 10MW_e and use a variety of fuels such as coal, heavy oil residues, waste woods, sewage sludge and sugar cane bagasse. A selection of these projects are reviewed below whilst a full list of operational and near-operational plants is given in Table 3.

Coal GPPs

Buggenum (Netherlands)

The Buggenum plant is the world's first commercial-sized (252MW_e) coal-fired IGCC (Figure 11). The IGCC is based around a Shell SCGP gasifier and a CCGT supplied by Siemens. The plant was started up in 1993. As well as being the first of the current generation of IGCC plants, the project is important in that it contains a number of advanced design features. The most significant of these is that the ASU and the gas turbine

are very closely coupled together, with the gas turbine compressor supplying all the air to the ASU. This increases efficiency at the cost of making the plant more complex and less easy to start.




Figure 11 Buggenum IGCC (Courtesy of Demiselec)

Name	Location	Output(MW _e)	Fuel	Gasifier	Power Island	1998 Status	Year
Buggenum	Netherlands	252MW _e	Bituminous coal	Shell	CCGT - V54.2	Operational	1995
Pfion Pine	USA	100MW _e	Bituminous coal	KRW	CCGT - GE 6FA	Commissioning	1998
Polk	USA	250MW _e	Bituminous coal	Texaco	CCGT - GE 7F	Operational	1996
Puertoollano	Spain	250MW _e	Coal and petroleum coke	Pirella®	CCGT - V54.3	Commissioning	1998
Vasovai	Czech Republic	400MW _e	Lignite	Lurgi	CCGT - 2xGE 9E	Operational	1995
Wabash River	USA	262MW _e	Bituminous coal	Destec	CCGT - GE 7FA	Operational	1995
Si Darado	USA	40MW _e (gross)	Petroleum coke	Texaco	GT - GE 6B	Operational	1996
Falconara	Italy	234MW _e	Vobreaker residues	Texaco	CCGT - ABB 13E2	Construction	1999
GSK	Japan	550MW _e	Vacuum residue	Texaco	CCGT - 2xGE 9EC	Construction	2000
Pemis	Netherlands	125MW _e	Refinery residues	Shell SGP	CCGT - 2xGE 6B	Operational	1997
Proko Gargallo	Italy	521MW _e	Refinery asphalt	Texaco	2xCCGT V94.2	Construction	1999
Saras	Italy	550MW _e	Vobreaker residue	Texaco	CCGT - 3xGE 9E	Construction	2000
Star	USA	240MW _e	Petroleum coke	Texaco	2xGE 6FA	Construction	1999
Amercentrale	Netherlands	85MW _e	Wood wastes	Lurgi CFB	Existing boiler	Construction	2000
ABRE	UK	8MW _e	SRC willow	TPS CFB	CCGT - AGT typhoon	Construction	1995
Energy Farm	Italy	12MW _e	Short rotation forestry	Lurgi CFB	CCGT - Nuovo Pignone PGT106/1	Construction	2000
Lahti	Finland	70MW _e	Wood wastes	Foster Wheeler CFB	Existing boiler	Operational	1998
Mchiel	USA	~15MW _e	Wood chips	Battelle CFB	Existing boiler	Operational	1997
Vilnimo	Sweden	6MW _e	Wood wastes	Foster Wheeler CFB	CCGT - AGT Typhoon	Operational	1993
Fondotoce	Italy	1MW _e	MSW	Thermo-select (moving bed)	Gas motor generator	Operational	1994
Grive in Chanti	Italy	6.7MW _e (gross)	Refuse - dried fuel	TPS CFB	Boiler and steam turbine	Operational	1992
New Bern	USA	<50MW _e	Black liquor	Chemtec (entrained flow)	Boiler and steam turbine	Operational	1997
Schwarze Pumpe	Germany	60MW _e	Assorted solid and liquid wastes	Noel, Lurgi BGL	CCGT - GE Frame 6	Operational. BGL to start-up in 1999	1997
Westfield	UK	120MW _e	Sewage sludge plus coal	BGL	CCGT - GE 6B	GT Operational on natural gas	1998
Zelweg	Austria	10MW _e	Biomass/wastes	ABRE CFB	Existing boiler	Operational	1997

Table 3 Operational and near-operational GPPs

Kentucky Resources Council, Inc.
Frankfort, KY
Page 34 of 74

Westfield (UK)

The site of British Gas' Westfield Development Centre in Fife is being developed by the US-based Fife Power. The existing BGL gasifiers on the site are being refurbished to gasify a mixture of coal and sewage sludge. When the plant is fully operational, it will generate ~120MW.

In a second project at the same site, Fife Power plans to build a 400MW unit, also using BGL gasifiers, to gasify coal and household refuse.

FUTURE PROSPECTS

Market Opportunities

Coal

The most important markets for new coal-fired plants over the next 10-15 years will be China and South and East Asia. However, overwhelmingly in these markets, the technology chosen will be conventional oil-fired boilers; as the primary pre-requisites for these markets are low capital cost and high reliability, as well as the need to locally-source equipment wherever possible. The most important markets for IGCC will be North America (8-16GW) and China (6-8GW), the former driven by stringent emissions limits, the latter by the sheer amount of new capacity required. The uptake of IGCC in Europe will be constrained by the widespread availability of cheap natural gas. Overall, coal-fired IGCC will represent no more than 10% of new coal-fired plant worldwide until its costs are significantly lowered and its reliability increased.

Oil and Petroleum Coke

There is considerable scope in the short-to-medium term for oil- and petroleum coke-fired IGCCs plant integrated with refinery processes. The key drivers are the refiners' need to find routes for the disposal of heavy oil residues and petroleum coke and their need for H₂ to upgrade other refinery products. There is scope for up to 14GW_e of oil-fired IGCC in the European Union (EU) by 2010 (based on the amount of heavy residue likely to be available). However, the actual oil-IGCC capacity in the EU will be constrained by the availability of natural gas, which is an alternative source of H₂. Another significant market may be India; there, the deployment of oil-IGCC will depend on being able to get reliable and secure power purchase agreements (PPAs). In the short-to-medium term, oil-IGCC plants may well out-number coal IGCC plants.

Biomass

Biomass is becoming increasingly important as a fuel in both the EU and the USA because of concerns over CO₂ emissions. For biomass GPPs to make headway, they will have to become more cost-competitive relative to biomass combustion plants. Typical projects will be combined heat and power schemes utilising agricultural and forestry residues, eg in remote areas of Scandinavia, China, Canada, India and Brazil.

Waste

Gasification is an excellent, if expensive, way to dispose of wastes such as MSW and sewage sludge, both 'treat' and co-gasified with coal. It has several significant advantages over waste incineration, such as producing only an inert solid residue and eliminating the potential for the production of dioxins. Waste gasification will first 'take off' in those parts of Europe with particularly strong environmental concerns over waste incineration, such as Germany and Switzerland. By 2010, perhaps 15% of new waste disposal plants in Europe will be based on gasification.

A further application of the gasification of biomass and wastes is the production of fuel-gas for the partial repowering of existing oil- and coal-fired boilers. Several schemes are already in operation. Biomass and wastes cannot be used directly in conventional boilers. Their low or negative cost can make them attractive fuels in principle but they cannot be fired, as they cannot be ground finely enough. Air-blown gasification converts them into a fuel-gas that can be fired in the boiler, providing a means of waste disposal.

Research and Development Needed

The current weaknesses of GPP technologies are high capital costs, poor reliability (at least for coal-fired IGCCs) and poor operational flexibility. The current strengths are high efficiency and environmental performance. It is therefore clear that, in the short-to-medium term, R&D effort needs to be focused on reducing costs and increasing reliability and operability. This R&D effort can be broken down into three major areas:

- i. research into the fundamentals of gasification
- ii. R&D to improve individual plant components
- iii. R&D into better overall process layout and design

Research into the fundamentals of gasification is required to establish the fuel flexibility of IGCC technologies. This would be directed at understanding gasification reaction rates and carbon conversion and at predicting the gasifiability of individual coals and other fuels, ash/slag behaviour and the potential for sulphur capture in fluidised bed gasifiers.

R&D is required to improve the following components of IGCC, to make them more reliable and/or cheaper:

- gasifiers/syngas coolers
- pressurised coal feeding systems
- gas clean-up
- gas turbines
- ASUs

The required R&D for gasifiers and syngas coolers is centred on the development of improved alloys and manufacturing processes to improve the corrosion resistance and lower the cost of these components.

Pressurised coal feeding systems (both dry-dry systems and briquetting systems) need to be improved to increase reliability and lower costs.

The development of improved hot gas clean-up systems could lower the cost of IGCC by providing a cheaper alternative to the conventional low-temperature processes currently employed. R&D is required to improve the reliability of both hot gas filters and hot gas desulphurisation systems.

The highest priority gas turbine R&D for IGCC is the development of better combustion systems for low-CV syngas. Also required is the development of more rugged gas turbines, capable of reliably running on uncleaned or partly-cleaned syngas.

Further work is required to allow the successful integration of ASUs into an IGCC. The two areas requiring attention are improved control systems for, and better dynamic simulation of, highly integrated ASUs. There is also the need, in the longer term, for alternatives to conventional cryogenic ASUs in order to lower costs.

A key area of R&D for IGCC is optimisation of the overall plant configuration and layout. Specific issues that require study are:

- dynamic simulation
- start-up and shut-down strategies
- operability
- simplified designs which reduce cost
- optimum integration strategies
- combining operability assessments within existing thermo-economic optimisation techniques

**Kentucky Resources Council, Inc.
Frankfort, KY
Page 35 of 74**

TAB 2

Kentucky Resources Council, Inc.
Frankfort, KY
Page 36 of 74

PSC Request 2

Page 1 of 1

EAST KENTUCKY POWER COOPERATIVE, INC.
PSC CASE NO. 2000-079
INFORMATION REQUEST RESPONSE

PUBLIC SERVICE COMMISSION REQUEST DATED 6/1/00

REQUEST 2

RESPONSIBLE PERSON: Dwight Lockwood
COMPANY: Kentucky Pioneer Energy
(responding for East Kentucky Power Cooperative)

Request 2. Provide a copy of the Tender Specification Documents ("TSD") of the construction contractor. Provide the design and engineering of the process if it is not included in the TSD. Were the characteristics of Kentucky-produced coal considered in the selection of the type of process and equipment?

Response 2. Kentucky Coal has qualities well suited for use by the Kentucky Pioneer Project. Kentucky Coal and other fuel components are included in all design work.

The PSD Permit Application to the Commonwealth of Kentucky, Department of Environmental Protection (DEP), and anticipated permit conditions, contain substantial design information for the project. Department of Air Quality (DAQ) within DEP is preparing a Draft Permit for public comment. Since the air permit is a prerequisite to project financing, there is ample opportunity to effectively reflect environmental requirements in the plant design.

Kentucky Pioneer Energy project design information is subject to international contractual secrecy agreements and is therefore business confidential and not available.

**Kentucky Resources Council, Inc.
Frankfort, KY
Page 37 of 74**

TAB 3

Kentucky Resources Council, Inc.
Frankfort, KY
Page 38 of 74

PSC Request 3

Page 1 of 1

EAST KENTUCKY POWER COOPERATIVE, INC.

PSC CASE NO. 2000-079

INFORMATION REQUEST RESPONSE

PUBLIC SERVICE COMMISSION REQUEST DATED 6/1/00

REQUEST 3

RESPONSIBLE PERSON: Dwight Lockwood

COMPANY: Kentucky Pioneer Energy

(responding for East Kentucky Power Cooperative)

Request 3. Provide the estimated budget for the project.

Response 3. The direct costs associated with engineering, major equipment and construction of the project are estimated at \$470 million.

**Kentucky Resources Council, Inc.
Frankfort, KY
Page 39 of 74**

TAB 4

Kentucky Resources Council, Inc.
Frankfort, KY
Page 40 of 74

PSC Request 4

Page 1 of 1

EAST KENTUCKY POWER COOPERATIVE, INC.

PSC CASE NO. 2000-079

INFORMATION REQUEST RESPONSE

PUBLIC SERVICE COMMISSION REQUEST DATED 6/1/00

REQUEST 4

RESPONSIBLE PERSON: Dwight Lockwood

COMPANY: Kentucky Pioneer Energy

(responding for East Kentucky Power Cooperative)

Request 4. Provide the preliminary schedule for the project and estimated date of construction.

Response 4. Kentucky Pioneer Energy expects commercial operation after a 36-month engineering, procurement and construction period following financial closure in late 2000.

**Kentucky Resources Council, Inc.
Frankfort, KY
Page 41 of 74**

TAB 5

Kentucky Resources Council, Inc.
Frankfort, KY
Page 42 of 74

PSC Request 5

Page 1 of 1

EAST KENTUCKY POWER COOPERATIVE, INC.

PSC CASE NO. 2000-079

INFORMATION REQUEST RESPONSE

PUBLIC SERVICE COMMISSION REQUEST DATED 6/1/00

REQUEST 5

RESPONSIBLE PERSON: Dwight Lockwood

COMPANY: Kentucky Pioneer Energy

(responding for East Kentucky Power Cooperative)

Request 5. Provide the ratio of the coal to solid waste.

Response 5. The AFT briquette Coal to RDF ratio can vary and will depend upon economic considerations, component qualities, and desired performance. Kentucky Pioneer Energy anticipates a ratio ranging from 2:1 to 1:1 RDF to Coal.

**Kentucky Resources Council, Inc.
Frankfort, KY
Page 43 of 74**

TAB 6