

Phase II 210s04

Case Summary

Case210s04

Project Name 2002 SERIES, NERC/MMWG BASE CASE LIBRARY
Title1 2004 Summer - CT4&5 Add KPE
Title2 All Phase II Transmission and Spurlock2/Dale1 On-Lin
Case Date 2/12/2003

Power Flow File M:\PROJ\Kypsc\267003\300_Calculations\301_PFlow_Results\case210s04.cft

Power Flow Controls

<i>Area Control</i>	<input type="checkbox"/>	<i>SmoothStep</i>	<input checked="" type="checkbox"/>
<i>Remote Control</i>	<input checked="" type="checkbox"/>	<i>XfrmVcon</i>	<input type="checkbox"/>
<i>GenVar Control</i>	<input checked="" type="checkbox"/>	<i>XfrmFcon</i>	<input type="checkbox"/>
<i>Solve Method</i>	NSOLVE		

Case Settings

<i>Overload</i>	<input checked="" type="checkbox"/>	<i>VlimMin</i>	0.9	<i>RateFactor</i>	1
<i>VLimit</i>	<input checked="" type="checkbox"/>	<i>VlimMax</i>	1.05	<i>AmpFactor</i>	1
<i>VChange</i>	<input checked="" type="checkbox"/>	<i>VlimChange</i>	0.05	<i>RatingNumber</i>	2
<i>Monitored Set</i>	monitor		309 Buses		

Contingency

<i>Use Existing Contingencies from Tables</i>	203 Buses
230 contingencies	

Area	Area Name	Zone	Zone Name	Contingency Buses	Monitored Buses
147	TVA	167	TVA_EAST	0	1
				0	1
205	AEP	254	AEP-KP	0	1
				0	1
208	CIN	280	CGE	1	0
				1	0
209	DPL	209	DPL	1	0
				1	0
211	LGEE	211	LGEE	109	166
				109	166
220	EKPC	220	EKPC	92	141
				92	141
				203	309

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Add KPE

All Phase II Transmission and Spurlock2/Dale1 On-Line

2/12/2003

<u>Overloaded Facility</u>										<u>Normal System Overloads</u>		
From	Name	To	Name	Circuit	Base kV	Area	Zone	Ratings		MVA	Norm (%)	Emer (%)
								Norm	Emer			
24070	05MOREHE	27348	11RODBRN	1	69	205-211	254-211	33	38	34	102	88
26959	11AOSMTH	27383	11SPENC	1	69	211	211	48	59	49	101	82
27347	11RODBRN	27348	11RODBRN	1	138-69	211	211	33	40	33	101	83

Notes:

1. Overloads are based on 100% of Rating 1
2. Normal System Conditions - No Outages
3. Minimum Reporting Level is 100%

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Add KPE

All Phase II Transmission and Spurlock2/Dale1 On-Line

2/12/2003

Overloaded Facility								Normal System				Overloads	
From	Name	To	Name	Circuit	Base kV	Area	Zone	Ratings		MVA	Norm (%)	Count	Max
								Norm	Emer			A / B	(%)
27347	11RODBRN	27348	11RODBRN	1	138-69	211	211	33	40	33.3	101	3 / 0	147
27117	11FAWKES	27339	11RICH S	1	69	211	211	72	72	44.1	61	3 / 0	140
26986	11BEREA	27221	11LK REB	1	69	211	211	72	72	53.1	74	2 / 0	138
27117	11FAWKES	27272	11N.MADS	1	69	211	211	56	56	29.2	52	1 / 0	129
27037	11CLARK	27397	11SYLVAN	1	69	211	211	73	90	55.6	76	3 / 0	122
27221	11LK REB	27340	11RICHMO	1	69	211	211	56	56	19.3	35	1 / 0	121
27113	11FARMER	27264	11MORH W	1	69	211	211	48	48	35.0	73	1 / 0	120
27115	11FAWK T	27231	11LR TAP	1	138	211	211	163	163	35.3	22	2 / 0	115
27358	11SALT L	27383	11SPENC	1	69	211	211	22	22	12.8	58	3 / 0	114
29230	20BOONST	29282	20DALE	1	138	220	220	252	252	142.8	57	1 / 0	113
26959	11AOSMTH	27383	11SPENC	1	69	211	211	48	59	48.6	101	4 / 0	111
27116	11FAWKES	27117	11FAWKES	1	138-69	211	211	143	171	117.4	82	2 / 0	109
27220	11LK REB	27231	11LR TAP	1	138	211	211	149	171	119.7	80	1 / 0	108
27220	11LK REB	27221	11LK REB	1	138-69	211	211	149	171	119.3	80	1 / 0	107
27229	11LOUDON	27228	11LOUD B	1	138-69	211	211	112	129	90.6	81	1 / 0	105
27112	11FARMER	27113	11FARMER	1	138-69	211	211	40	48	30.8	77	0 / 1	105
27330	11PRKRSE	27452	11WINCHS	1	69	211	211	72	79	28.7	40	0 / 2	104
27345	11ROCKWE	27452	11WINCHS	1	69	211	211	63	63	43.4	69	0 / 1	104
27382	11SPENC	27383	11SPENC	1	138-69	211	211	72	79	46.9	65	0 / 1	103
27194	11KENTON	29575	20SPURLK	2	138	211-220	211-220	227	280	148.8	66	0 / 1	102
29203	20BKR LN	29360	20HOLLWJ	1	69	220	220	57	69	9.6	17	0 / 2	101
												29 / 8	147

Notes:

- Overloads are based on 100% of Rating 2
- NS = Normal System Conditions (No Outages)
- Minimum Reporting Level is 100%
- Statistical Information (A/B Stats and Maximum Overload)
 - A = Serious Overload > 105%
 - B = Overloaded Facility between 100% and 105% of Rated Capability

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Add KPE

All Phase II Transmission and Spurlock2/Dale1 On-Line

2/12/2003

<u>Undervoltage</u>					<u>Normal System</u>	<u>Voltage Violations</u>	
<u>Bus</u>	<u>Name</u>	<u>Base kV</u>	<u>Area</u>	<u>Zone</u>	<u>Voltage (pu)</u>	<u>A / B</u>	<u>Min (pu)</u>
29212	20BTYV D	69	220	220	0.9863	1 / 0	0.8395
27449	11WIL D2	69	211	211	1.0008	1 / 0	0.8431
29478	20OAKD J	69	220	220	0.9785	1 / 0	0.8492
29232	20BOONVJ	69	220	220	0.9756	1 / 0	0.8608
29313	20FAYETT	138	220	220	0.9968	1 / 0	0.8698
27210	11LEBN I	69	211	211	0.9782	1 / 0	0.8708
29468	20NEWBY1	69	220	220	1.0049	1 / 0	0.8772
29537	20S FORK	69	220	220	0.9760	0 / 1	0.8878
29315	20FAYETT	69	220	220	1.0108	0 / 2	0.8921
29406	20LNCSTR	69	220	220	0.9913	0 / 1	0.8931
29327	20GARRCO	69	220	220	0.9887	0 / 1	0.8940
29205	20BALLRD	69	220	220	0.9726	0 / 2	0.8982
29596	20TGOOCH	69	220	220	0.9755	0 / 1	0.8989
29237	20BOURNE	69	220	220	0.9835	0 / 1	0.8991
27067	11DANVIL	138	211	211	0.9940	0 / 1	0.8992
						7 / 10	0.8395
Notes:							
1. Minimum Voltage Limit 0.90 (pu)							
2. NS = Normal System Conditions (No Outages)							
3. Maximum Reporting Level is 90%							
4. Statistical Information (A/B Stats and Minimum Voltage)							
A = Serious Undervoltage < 0.88 (pu)							
B = Low Voltages between 0.88 and 0.90 (pu)							

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Add KPE

All Phase II Transmission and Spurlock2/Dale1 On-Line

2/12/2003

<u>Overvoltage</u>					<u>Normal System</u>	<u>Voltage Violations</u>	
<u>Bus</u>	<u>Name</u>	<u>Base kV</u>	<u>Area</u>	<u>Zone</u>	<u>Voltage (pu)</u>	<u>A / B</u>	<u>Max (pu)</u>
29406	20LNCSTR	69	220	220	0.9913	0 / 1	1.0561
29540	20S OAKH	161	220	220	1.0338	0 / 1	1.0516
						0 / 2	1.0561

Notes:

1. Maximum Voltage Limit is 1.05 (pu)
2. NS = Normal System Conditions (No Outages)
3. Minimum Reporting Level for Over Voltages is 105%
4. Statistical Information (A/B Stats and Maximum Voltage)
 - A = Serious Overvoltage > 1.07 (pu)
 - B = High Voltages between 1.05 and 1.07 (pu)

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Add KPE

All Phase II Transmission and Spurlock2/Dale1 On-Line

2/12/2003

VChange Bus Name	Base kV	Area	Zone	Normal System	Voltage Violations	
				Voltage (pu)	A / B	Max (pu)
27449 11WIL D2	69	211	211	1.0008	1 / 0	-0.1577
29212 20BTYV D	69	220	220	0.9863	1 / 0	-0.1468
29478 20OAKD J	69	220	220	0.9785	1 / 0	-0.1293
29468 20NEWBY1	69	220	220	1.0049	1 / 0	-0.1277
29313 20FAYETT	138	220	220	0.9968	1 / 0	-0.1270
29315 20FAYETT	69	220	220	1.0108	2 / 0	-0.1187
29232 20BOONVJ	69	220	220	0.9756	1 / 0	-0.1148
27016 11BUENA	69	211	211	1.0260	1 / 0	-0.1114
27210 11LEBN I	69	211	211	0.9782	1 / 0	-0.1074
29470 20NEWBY2	69	220	220	1.0082	1 / 0	-0.1069
27076 11DIXDAM	69	211	211	1.0370	1 / 0	-0.1041
29406 20LNCSTR	69	220	220	0.9913	1 / 0	-0.0982
27067 11DANVIL	138	211	211	0.9940	1 / 0	-0.0948
29327 20GARRCO	69	220	220	0.9887	1 / 0	-0.0947
27016 11BUENA	69	211	211	1.0260	1 / 0	-0.0940
29291 20DAVIS	69	220	220	0.9973	2 / 0	-0.0940
27136 11GARRD	69	211	211	1.0076	1 / 0	-0.0907
29537 20S FORK	69	220	220	0.9760	1 / 0	-0.0882
29237 20BOURNE	69	220	220	0.9835	1 / 0	-0.0844
29233 20BOONSB	138	220	220	1.0210	1 / 0	-0.0826
29237 20BOURNE	69	220	220	0.9835	1 / 0	-0.0824
27068 11DANVIL	69	211	211	1.0001	2 / 0	-0.0778
29596 20TGOOCH	69	220	220	0.9755	1 / 0	-0.0766
27136 11GARRD	69	211	211	1.0076	1 / 0	-0.0754
29205 20BALLRD	69	220	220	0.9726	1 / 0	-0.0744
29580 20STANTN	69	220	220	0.9982	1 / 0	-0.0744
26972 11ATOKA	69	211	211	0.9987	2 / 0	-0.0743
29205 20BALLRD	69	220	220	0.9726	1 / 0	-0.0736
26999 11BOONSB	69	211	211	1.0360	2 / 0	-0.0735
27450 11WILMOR	69	211	211	1.0087	1 / 0	-0.0732
27000 11BOYLE	69	211	211	0.9980	2 / 0	-0.0723
29205 20BALLRD	69	220	220	0.9726	1 / 0	-0.0719
29411 20LAURLD	161	220	220	1.0029	0 / 1	-0.0688
29325 20FRNCHB	69	220	220	0.9784	0 / 1	-0.0682
29407 20LAURHY	13.8	220	220	0.9839	0 / 1	-0.0675
27220 11LK REB	138	211	211	1.0023	0 / 1	-0.0672
29436 20MARIBJ	69	220	220	0.9800	0 / 1	-0.0670
27065 11DANV 1	69	211	211	0.9976	0 / 2	-0.0668
27167 11HARR T	69	211	211	1.0081	0 / 1	-0.0664
27168 11HARRDS	69	211	211	1.0081	0 / 1	-0.0664
27450 11WILMOR	69	211	211	1.0087	0 / 1	-0.0653
29623 20WBBEREA	138	220	220	1.0028	0 / 1	-0.0652
29288 20DALE4	13.8	220	220	1.0468	0 / 1	-0.0642
27247 11MERCRCR	138	211	211	1.0071	0 / 1	-0.0639
27055 11CRAB O	69	211	211	0.9872	0 / 1	-0.0631
29260 20CLAYCJ	69	220	220	0.9966	0 / 1	-0.0622
29203 20BKR LN	69	220	220	0.9867	0 / 1	-0.0620
29510 20POWELL	69	220	220	0.9984	0 / 1	-0.0615
29580 20STANTN	69	220	220	0.9982	0 / 1	-0.0614
29327 20GARRCO	69	220	220	0.9887	0 / 1	-0.0611
29625 20WBBEREA	69	220	220	0.9982	0 / 1	-0.0605
29625 20WBBEREA	69	220	220	0.9982	0 / 1	-0.0603
29515 20PULASK	161	220	220	1.0131	0 / 1	-0.0601

VChange		Base kV	Area	Zone	Normal System Voltage (pu)	Voltage Violations	
Bus	Name					A / B	Max (pu)
29368	20HUNTFJ	69	220	220	0.9667	0 / 1	-0.0588
29626	20WBER J	69	220	220	0.9979	0 / 1	-0.0583
29368	20HUNTFJ	69	220	220	0.9667	0 / 1	-0.0581
29626	20WBER J	69	220	220	0.9979	0 / 1	-0.0581
29195	20ALCAN	69	220	220	0.9957	0 / 1	-0.0579
29195	20ALCAN	69	220	220	0.9957	0 / 1	-0.0577
29347	20HARGTJ	69	220	220	0.9988	0 / 1	-0.0574
29510	20POWELL	69	220	220	0.9984	0 / 1	-0.0569
29368	20HUNTFJ	69	220	220	0.9667	0 / 1	-0.0568
29580	20STANTN	69	220	220	0.9982	0 / 1	-0.0568
29360	20HOLLWJ	69	220	220	0.9838	0 / 1	-0.0563
29512	20PPG J	69	220	220	0.9952	0 / 1	-0.0561
27067	11DANVIL	138	211	211	0.9940	0 / 1	-0.0560
29511	20PPG	69	220	220	0.9952	0 / 1	-0.0559
29512	20PPG J	69	220	220	0.9952	0 / 1	-0.0558
29511	20PPG	69	220	220	0.9952	0 / 1	-0.0557
29238	20BOWEN	69	220	220	0.9985	0 / 1	-0.0549
26959	11AOSMTH	69	211	211	1.0209	0 / 1	-0.0548
26986	11BEREA	69	211	211	0.9966	0 / 1	-0.0541
29408	20LAURLC	161	220	220	0.9859	0 / 1	-0.0541
27221	11LK REB	69	211	211	1.0128	0 / 2	-0.0536
29605	20THLNKJ	69	220	220	0.9983	0 / 1	-0.0536
29605	20THLNKJ	69	220	220	0.9983	0 / 1	-0.0534
29238	20BOWEN	69	220	220	0.9985	0 / 1	-0.0532
29260	20CLAYCJ	69	220	220	0.9966	0 / 1	-0.0531
29508	20POWELL	138	220	220	1.0007	0 / 1	-0.0526
27339	11RICH S	69	211	211	1.0018	0 / 1	-0.0524
29408	20LAURLC	161	220	220	0.9859	0 / 1	-0.0521
27368	11SHAKRT	69	211	211	1.0281	0 / 1	-0.0519
29516	20PULASK	69	220	220	1.0046	0 / 1	-0.0516
27055	11CRAB O	69	211	211	0.9872	0 / 1	-0.0514
27272	11N.MADS	69	211	211	1.0073	0 / 1	-0.0505
29260	20CLAYCJ	69	220	220	0.9966	0 / 1	-0.0503
29488	20PARIS	138	220	220	0.9937	0 / 1	-0.0502
29237	20BOURNE	69	220	220	0.9835	0 / 1	0.0543
29406	20LNCSTR	69	220	220	0.9913	0 / 1	0.0648

38 / 59 -0.1577

Notes:

1. Voltage Change Limit is 0.05 (pu)
2. NS = Normal System Conditions (No Outages)
3. Minimum Reporting Level is 5%
4. Statistical Information (A/B Stats and Maximum Voltage Change)
 - A = Serious Voltage Change > 0.07 (pu)
 - B = Excessive Voltage Change between 0.05 and 0.07 (pu)

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Add KPE

All Phase II Transmission and Spurlock2/Dale1 On-Line

2/12/2003

Contingency	Overloaded Facility									Overloads		
	From Name	To Name	Ckt	Base kV	Area	Zone	Ratings		MVA	Norm (%)	Emer (%)	
							Norm	Emer				
95	outage of 27036 11CLARK to 27037 11CLARK		1	138-69	211	211						
	26959 11AOSMTH	27383 11SPENC	1	69	211	211	48	59	65.7	137	111	
110	outage of 27111 11FARM T to 27112 11FARMER		1	138	211	211						
	27347 11RODBRN	27348 11RODBRN	1	138-69	211	211	33	40	48.6	147	122	
	27358 11SALT L	27383 11SPENC	1	69	211	211	22	22	24.4	111	111	
115	outage of 27111 11FARM T to 27382 11SPENC		1	138	211	211						
	27358 11SALT L	27383 11SPENC	1	69	211	211	22	22	25.1	114	114	
117	outage of 27112 11FARMER to 27113 11FARMER		1	138-69	211	211						
	27347 11RODBRN	27348 11RODBRN	1	138-69	211	211	33	40	48.6	147	122	
	27358 11SALT L	27383 11SPENC	1	69	211	211	22	22	24.4	111	111	
125	outage of 27116 11FAWKES to 27117 11FAWKES		1	138-69	211	211						
	27221 11LK REB	27340 11RICHMO	1	69	211	211	56	56	67.6	121	121	
	26986 11BEREA	27221 11LK REB	1	69	211	211	72	72	78.1	108	109	
	27220 11LK REB	27231 11LR TAP	1	138	211	211	149	171	184.1	124	108	
	27220 11LK REB	27221 11LK REB	1	138-69	211	211	149	171	183.1	123	107	
157	outage of 27220 11LK REB to 27221 11LK REB		1	138-69	211	211						
	27116 11FAWKES	27117 11FAWKES	1	138-69	211	211	143	171	185.5	130	109	
	27117 11FAWKES	27339 11RICH S	1	69	211	211	72	72	76.0	106	106	
160	outage of 27220 11LK REB to 27231 11LR TAP		1	138	211	211						
	27116 11FAWKES	27117 11FAWKES	1	138-69	211	211	143	171	185.5	130	109	
	27117 11FAWKES	27339 11RICH S	1	69	211	211	72	72	76.0	106	106	
162	outage of 27229 11LOUDON to 27227 11LOUD A		1	138-69	211	211						
	27229 11LOUDON	27228 11LOUD B	1	138-69	211	211	112	129	135.9	121	105	
172	outage of 27347 11RODBRN to 27348 11RODBRN		1	138-69	211	211						
	27113 11FARMER	27264 11MORH W	1	69	211	211	48	48	57.5	120	120	
	27112 11FARMER	27113 11FARMER	1	138-69	211	211	40	48	50.2	126	105	
180	outage of 27382 11SPENC to 27383 11SPENC		2	138-69	211	211						
	27382 11SPENC	27383 11SPENC	1	138-69	211	211	72	79	81.6	113	103	
200	outage of 26986 11BEREA to 27221 11LK REB		1	69	211	211						
	27117 11FAWKES	27339 11RICH S	1	69	211	211	72	72	100.7	140	140	
205	outage of 26999 11BOONSB to 27451 11WINC S		EQ	69	211	211						
	27037 11CLARK	27397 11SYLVAN	1	69	211	211	73	90	100.2	137	111	
	26959 11AOSMTH	27383 11SPENC	1	69	211	211	48	59	62.0	129	105	
242	outage of 27113 11FARMER to 27264 11MORH W		1	69	211	211						
	27347 11RODBRN	27348 11RODBRN	1	138-69	211	211	33	40	58.9	178	147	
247	outage of 27117 11FAWKES to 27339 11RICH S		1	69	211	211						
	26986 11BEREA	27221 11LK REB	1	69	211	211	72	72	99.7	138	138	
260	outage of 27170 11HIGB A to 27449 11WIL D2		1	69	211	211						
	27117 11FAWKES	27272 11N.MADS	1	69	211	211	56	56	72.0	129	129	
322	outage of 27229 11LOUDON to 29202 20AVON		1	138	211-220	211-220						
	27075 NONAME	27300 11PARIS	1	69	211	211	56	56	68.5	122	122	
	27345 11ROCKWE	27452 11WINCHS	1	69	211	211	63	63	65.4	104	104	
325	outage of 27231 11LR TAP to 29616 20UN CTY		1	138	211-220	211-220						
	27115 11FAWK T	27231 11LR TAP	1	138	211	211	163	163	185.1	114	114	
340	outage of 29201 20AVON to 29202 20AVON		1	345-138	220	220						
	29230 20BOONST	29282 20DALE	1	138	220	220	252	252	284.9	113	113	
417	outage of 29202 20AVON to 29313 20FAYETT		1	138	220	220						
	29203 20BKR LN	29360 20HOLLWJ	1	69	220	220	57	69	69.8	122	101	
422	outage of 29230 20BOONST to 29233 20BOONSB		1	138	220	220						
	27037 11CLARK	27397 11SYLVAN	1	69	211	211	73	90	110.2	151	122	

Contingency	Overloaded Facility									Overloads		
	From Name	To Name	Ckt	Base kV	Area	Zone	Ratings		MVA	Norm (%)	Emer (%)	
							Norm	Emer				
	26959 11AOSMTH	27383 11SPENC	1	69	211	211	48	59	65.1	136	110	
	27330 11PRKRSE	27452 11WINCHS	1	69	211	211	72	79	82.5	115	104	
445	outage of 29313 20FAYETT to 29315 20FAYETT		1	138-69	220	220						
	29203 20BKR LN	29360 20HOLLWJ	1	69	220	220	57	69	69.8	122	101	
465	outage of 29397 20JKSMIT to 29616 20UN CTY		1	138	220	220						
	27115 11FAWK T	27231 11LR TAP	1	138	211	211	163	163	187.3	115	115	
595	outage of 29233 20BOONSB to 26999 11BOONSB		1	138-69	220-211	220-211						
	27037 11CLARK	27397 11SYLVAN	1	69	211	211	73	90	110.2	151	122	
	26959 11AOSMTH	27383 11SPENC	1	69	211	211	48	59	65.1	136	110	
	27330 11PRKRSE	27452 11WINCHS	1	69	211	211	72	79	82.5	115	104	
607	outage of 27197 11KENTON to 29575 20SPURLK		1	138	211-220	211-220						
	27194 11KENTON	29575 20SPURLK	2	138	211-220	211-220	227	280	285.0	126	102	

Notes:

1. Overloads are based on 100% of Rating 2

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Add KPE

All Phase II Transmission and Spurlock2/Dale1 On-Line

2/12/2003

Overloaded Facility	Contingency									Overloads		
	From	Name	To	Name	Circuit	Base kV	Area	Zone	Ratings Norm Emer	Norm MVA	Emer (%)	Emer (%)
27347 11RODBRN	27348	11RODBRN			1	138-69	211	211	33 40	NS	33	101 83
	242	outage of 27113 11FARMER to 27264 11MORH			1	69	211	211			59	178 147
	110	outage of 27111 11FARM T to 27112 11FARMER			1	138	211	211			49	147 122
	117	outage of 27112 11FARMER to 27113 11FARME			1	138-69	211	211			49	147 122
											3 / 0	147
27117 11FAWKES	27339	11RICH S			1	69	211	211	72 72	NS	44	61 61
	200	outage of 26986 11BEREA to 27221 11LK REB			1	69	211	211			101	140 140
	157	outage of 27220 11LK REB to 27221 11LK REB			1	138-69	211	211			76	106 106
	160	outage of 27220 11LK REB to 27231 11LR TAP			1	138	211	211			76	106 106
											3 / 0	140
26986 11BEREA	27221	11LK REB			1	69	211	211	72 72	NS	53	74 74
	247	outage of 27117 11FAWKES to 27339 11RICH S			1	69	211	211			100	138 138
	125	outage of 27116 11FAWKES to 27117 11FAWKE			1	138-69	211	211			78	108 109
											2 / 0	138
27117 11FAWKES	27272	11N.MADS			1	69	211	211	56 56	NS	29	52 52
	260	outage of 27170 11HIGB A to 27449 11WIL D2			1	69	211	211			72	129 129
											1 / 0	129
27037 11CLARK	27397	11SYLVAN			1	69	211	211	73 90	NS	56	76 62
	595	outage of 29233 20BOONSB to 26999 11BOONS			1	138-69	220-211	220-211			110	151 122
	422	outage of 29230 20BOONST to 29233 20BOONS			1	138	220	220			110	151 122
	205	outage of 26999 11BOONSB to 27451 11WINC S EQ				69	211	211			100	137 111
											3 / 0	122
27221 11LK REB	27340	11RICHMO			1	69	211	211	56 56	NS	19	35 35
	125	outage of 27116 11FAWKES to 27117 11FAWKE			1	138-69	211	211			68	121 121
											1 / 0	121
27113 11FARMER	27264	11MORH W			1	69	211	211	48 48	NS	35	73 73
	172	outage of 27347 11RODBRN to 27348 11RODBR			1	138-69	211	211			58	120 120
											1 / 0	120
27115 11FAWK T	27231	11LR TAP			1	138	211	211	163 163	NS	35	22 22
	465	outage of 29397 20JKSMIT to 29616 20UN CTY			1	138	220	220			187	115 115
	325	outage of 27231 11LR TAP to 29616 20UN CTY			1	138	211-220	211-220			185	114 114
											2 / 0	115
27358 11SALT L	27383	11SPENC			1	69	211	211	22 22	NS	13	58 58
	115	outage of 27111 11FARM T to 27382 11SPENC			1	138	211	211			25	114 114
	110	outage of 27111 11FARM T to 27112 11FARMER			1	138	211	211			24	111 111
	117	outage of 27112 11FARMER to 27113 11FARME			1	138-69	211	211			24	111 111
											3 / 0	114
29230 20BOONST	29282	20DALE			1	138	220	220	252 252	NS	143	57 57
	340	outage of 29201 20AVON to 29202 20AVON			1	345-138	220	220			285	113 113
											1 / 0	113

Overloaded Facility		Contingency								Overloads				
From	Name	To	Name	Circuit	Base kV	Area	Zone	Ratings		Norm	Emer			
								Norm	Emer	MVA	(%)	(%)		
26959	11AOSMTH	27383	11SPENC		1	69	211	211	48	59	NS	49	101	82
	95	outage of 27036 11CLARK to 27037 11CLARK		1	138-69	211	211					66	137	111
	422	outage of 29230 20BOONST to 29233 20BOONS		1	138	220	220					65	136	110
	595	outage of 29233 20BOONSB to 26999 11BOONS		1	138-69	220-211	220-211					65	136	110
	205	outage of 26999 11BOONSB to 27451 11WINC S EQ			69	211	211					62	129	105
												4 / 0		111
27116	11FAWKES	27117	11FAWKES		1	138-69	211	211	143	171	NS	117	82	69
	157	outage of 27220 11LK REB to 27221 11LK REB		1	138-69	211	211					185	130	109
	160	outage of 27220 11LK REB to 27231 11LR TAP		1	138	211	211					185	130	109
												2 / 0		109
27220	11LK REB	27231	11LR TAP		1	138	211	211	149	171	NS	120	80	70
	125	outage of 27116 11FAWKES to 27117 11FAWKE		1	138-69	211	211					184	124	108
												1 / 0		108
27220	11LK REB	27221	11LK REB		1	138-69	211	211	149	171	NS	119	80	70
	125	outage of 27116 11FAWKES to 27117 11FAWKE		1	138-69	211	211					183	123	107
												1 / 0		107
27229	11LOUDON	27228	11LOUD B		1	138-69	211	211	112	129	NS	91	81	70
	162	outage of 27229 11LOUDON to 27227 11LOUD A		1	138-69	211	211					136	121	105
												1 / 0		105
27112	11FARMER	27113	11FARMER		1	138-69	211	211	40	48	NS	31	77	64
	172	outage of 27347 11RODBRN to 27348 11RODBR		1	138-69	211	211					50	126	105
												0 / 1		105
27330	11PRKRSE	27452	11WINCHS		1	69	211	211	72	79	NS	29	40	36
	595	outage of 29233 20BOONSB to 26999 11BOONS		1	138-69	220-211	220-211					82	115	104
	422	outage of 29230 20BOONST to 29233 20BOONS		1	138	220	220					82	115	104
												0 / 2		104
27345	11ROCKWE	27452	11WINCHS		1	69	211	211	63	63	NS	43	69	69
	322	outage of 27229 11LOUDON to 29202 20AVON		1	138	211-220	211-220					65	104	104
												0 / 1		104
27382	11SPENC	27383	11SPENC		1	138-69	211	211	72	79	NS	47	65	59
	180	outage of 27382 11SPENC to 27383 11SPENC		2	138-69	211	211					82	113	103
												0 / 1		103
27194	11KENTON	29575	20SPURLK		2	138	211-220	211-220	227	280	NS	149	66	53
	607	outage of 27197 11KENTON to 29575 20SPURLK		1	138	211-220	211-220					285	126	102
												0 / 1		102
29203	20BKR LN	29360	20HOLLWJ		1	69	220	220	57	69	NS	10	17	14
	417	outage of 29202 20AVON to 29313 20FAYETT		1	138	220	220					70	122	101
	445	outage of 29313 20FAYETT to 29315 20FAYETT		1	138-69	220	220					70	122	101
												0 / 2		101

Overloaded Facility		Contingency								Overloads		
From	Name	To	Name	Circuit	Base kV	Area	Zone	Ratings		Norm	Emer	
								Norm	Emer	MVA	(%)	(%)
										29 / 8		147.2

Notes:

1. Overloads are based on 100% of Rating 2
2. NS = Normal System Conditions (No Outages)
3. Minimum Reporting Level is 100%
4. Statistical Information (A/B Stats and Maximum Overload)
 - A = Serious Overload > 105%
 - B = Overloaded Facility between 100% and 105% of Rated Capability

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Add KPE

All Phase II Transmission and Spurlock2/Dale1 On-Line

2/12/2003

Contingency

Description	Ckt	kV	Zone	Area	Voltage Violations				Not Solved
					Over load	UnderV	OverV	Change	
82 outage of 27010 11BRWN P to 27247 11MERCRCR	1	138	211	211	0	0	0	2	
95 outage of 27036 11CLARK to 27037 11CLARK	1	138-69	211	211	1	0	0	0	
105 outage of 27067 11DANVIL to 27068 11DANVIL	1	138-69	211	211	0	0	0	4	
107 outage of 27067 11DANVIL to 27247 11MERCRCR	1	138	211	211	0	1	0	5	
110 outage of 27111 11FARM T to 27112 11FARMER	1	138	211	211	2	0	0	0	
115 outage of 27111 11FARM T to 27382 11SPENC	1	138	211	211	1	0	0	0	
117 outage of 27112 11FARMER to 27113 11FARMER	1	138-69	211	211	2	0	0	0	
125 outage of 27116 11FAWKES to 27117 11FAWKES	1	138-69	211	211	4	0	0	0	
157 outage of 27220 11LK REB to 27221 11LK REB	1	138-69	211	211	2	0	0	1	
160 outage of 27220 11LK REB to 27231 11LR TAP	1	138	211	211	2	0	0	2	
162 outage of 27229 11LOUDON to 27227 11LOUD A	1	138-69	211	211	1	0	0	0	
172 outage of 27347 11RODBRN to 27348 11RODBRN	1	138-69	211	211	2	0	0	0	
180 outage of 27382 11SPENC to 27383 11SPENC	2	138-69	211	211	1	0	0	0	
195 outage of 26959 11AOSMTH to 27383 11SPENC	1	69	211	211	0	0	0	1	
200 outage of 26986 11BEREA to 27221 11LK REB	1	69	211	211	1	0	0	1	
205 outage of 26999 11BOONSB to 27451 11WINC S	EQ	69	211	211	2	0	0	0	
207 outage of 27016 11BUENA to 27076 11DIXDAM	1	69	211	211	0	0	0	3	
232 outage of 27076 11DIXDAM to 27436 11WC-DD	1	69	211	211	0	0	0	5	
235 outage of 27076 11DIXDAM to 27450 11WILMOR	1	69	211	211	0	0	0	1	
242 outage of 27113 11FARMER to 27264 11MORH W	1	69	211	211	1	0	0	0	
247 outage of 27117 11FAWKES to 27339 11RICH S	1	69	211	211	1	0	0	1	
255 outage of 27167 11HARR T to 27420 11W CLIF	1	69	211	211	0	0	0	2	
260 outage of 27170 11HIGB A to 27449 11WIL D2	1	69	211	211	1	1	0	2	
267 outage of 27210 11LEBN I to 27213 11LEBNON	1	69	211	211	0	1	0	1	
297 outage of 27368 11SHAKRT to 27420 11W CLIF	1	69	211	211	0	0	0	1	
312 outage of 26990 11BKR LN to 29203 20BKR LN	1	138-69	211-220	211-220	0	0	0	2	
322 outage of 27229 11LOUDON to 29202 20AVON	1	138	211-220	211-220	2	0	0	0	
325 outage of 27231 11LR TAP to 29616 20UN CTY	1	138	211-220	211-220	1	0	0	0	
340 outage of 29201 20AVON to 29202 20AVON	1	345-138	220	220	1	0	0	0	
372 outage of 29271 20COOPER to 29411 20LAURLD	1	161	220	220	0	0	0	3	
377 outage of 29271 20COOPER to 29540 20S OAKH	1	161	220	220	0	0	3	0	
392 outage of 29408 20LAURLC to 29411 20LAURLD	1	161	220	220	0	0	0	1	
407 outage of 29515 20PULASK to 29517 20PULASJ	1	161	220	220	0	0	0	2	
410 outage of 29528 20RUSSEL to 29540 20S OAKH	1	161	220	220	0	0	2	0	
417 outage of 29202 20AVON to 29313 20FAYETT	1	138	220	220	1	2	0	3	
422 outage of 29230 20BOONST to 29233 20BOONSB	1	138	220	220	3	0	0	2	
425 outage of 29230 20BOONST to 29282 20DALE	1	138	220	220	0	0	0	1	
442 outage of 29312 20FAWKES to 29623 20WBEREA	1	138	220	220	0	0	0	7	

Contingency

Description	Ckt	kV	Zone	Area	Over load	Voltage Violations			Not Solved
						UnderV	OverV	Change	
445 outage of 29313 20FAYETT to 29315 20FAYETT	1	138-69	220	220	1	1	0	2	
462 outage of 29397 20JKSMIT to 29508 20POWELL	1	138	220	220	0	0	0	5	
465 outage of 29397 20JKSMIT to 29616 20UN CTY	1	138	220	220	1	0	0	0	
472 outage of 29488 20PARIS to 29490 20PARISJ	1	138	220	220	0	0	0	1	
475 outage of 29508 20POWELL to 29510 20POWELL	1	138-69	220	220	0	0	0	4	
477 outage of 29623 20WBBERA to 29625 20WBBERE	1	138-69	220	220	0	0	0	6	
487 outage of 29205 20BALLRD to 29237 20BOURNE	1	69	220	220	0	1	0	3	
490 outage of 29212 20BTYV D to 29215 20BEATTY	1	69	220	220	0	4	0	4	
497 outage of 29237 20BOURNE to 29470 20NEWBY2	1	69	220	220	0	2	0	3	
532 outage of 29283 20DALE to 29468 20NEWBY1	1	69	220	220	0	4	0	4	
535 outage of 29283 20DALE to 29470 20NEWBY2	1	69	220	220	0	0	0	4	
537 outage of 29325 20FRNCHB to 29361 20HOPE	1	69	220	220	0	0	0	2	
540 outage of 29327 20GARRCO to 29406 20LNCSTR	1	69	220	220	0	0	1	2	
580 outage of 29510 20POWELL to 29580 20STANTN	1	69	220	220	0	0	0	3	
595 outage of 29233 20BOONSB to 26999 11BOONSB	1	138-69	220-211	220-211	3	0	0	1	
602 outage of 26648 09STUART to 29573 20SPURLK	1	345	209-220	209-220	0	0	0	0	F
605 outage of 26367 08ZIMER to 29573 20SPURLK	1	345	280-220	208-220	0	0	0	0	F
607 outage of 27197 11KENTON to 29575 20SPURLK	1	138	211-220	211-220	1	0	0	0	
Totals:					38	17	6	97	2

Notes:

1. Overloads are based on 100% of Rating 2
2. Undervoltage Limit is 0.90 (pu)
3. Overvoltage Limit is 1.05 (pu)
4. Voltage Change Limit is 0.05 (pu)

Not Solved Codes:

- D - Diverged
- I - Interrupted
- F - Failed, One or More Contingency
Commands Failed in PFlow

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Add KPE

All Phase II Transmission and Spurlock2/Dale1 On-Line

2/12/2003

No.	Contingency	Ckt	Base kV	Area	Zone
10	outage of 26950 11ALCALD to 27008 11BRWN N	1	345	211	211
12	outage of 27008 11BRWN N to 27009 11BRWN N	1	345-138	211	211
15	outage of 27008 11BRWN N to 27162 11HARDN	1	345	211	211
17	outage of 27008 11BRWN N to 27427 11W LEXN	1	345	211	211
20	outage of 26951 11ALCALD to 27095 11ELIHU	1	161	211	211
22	outage of 26962 11ARNOLD to 27074 11DELVIN	1	161	211	211
25	outage of 27074 11DELVIN to 27444 11WI TAP	1	161	211	211
27	outage of 27095 11ELIHU to 27096 11ELIHU	1	161-69	211	211
30	outage of 27095 11ELIHU to 27096 11ELIHU	2	161-69	211	211
32	outage of 27230 11LR TAP to 27231 11LR TAP	1	161-138	211	211
35	outage of 27230 11LR TAP to 27444 11WI TAP	1	161	211	211
37	outage of 27425 11W IRVI to 27444 11WI TAP	1	161	211	211
40	outage of 26947 11ADAMS to 27412 11TYRONE	1	138	211	211
42	outage of 26977 11BARDST to 26978 11BARDST	1	138-69	211	211
45	outage of 26977 11BARDST to 27011 11BRWNCT	1	138	211	211
47	outage of 26977 11BARDST to 27276 11NELSON	1	138	211	211
50	outage of 26990 11BKR LN to 27009 11BRWN N	1	138	211	211
52	outage of 26990 11BKR LN to 27172 11HIGBY	1	138	211	211
55	outage of 26998 11BONNIE to 27211 11LEBN W	1	138	211	211
57	outage of 27009 11BRWN N to 27011 11BRWNCT	1	138	211	211
60	outage of 27009 11BRWN N to 27012 11BRWNT1	1	138	211	211
62	outage of 27009 11BRWN N to 27013 11BRWNT2	1	138	211	211
65	outage of 27009 11BRWN N to 27040 11CLAYSM	1	138	211	211
67	outage of 27009 11BRWN N to 27172 11HIGBY	1	138	211	211
70	outage of 27009 11BRWN N to 27312 11PISGAH	1	138	211	211
72	outage of 27009 11BRWN N to 27412 11TYRONE	1	138	211	211
75	outage of 27010 11BRWN P to 27012 11BRWNT1	1	138	211	211
77	outage of 27010 11BRWN P to 27013 11BRWNT2	1	138	211	211
80	outage of 27010 11BRWN P to 27116 11FAWKES	1	138	211	211
82	outage of 27010 11BRWN P to 27247 11MERCRCR	1	138	211	211
85	outage of 27010 11BRWN P to 27419 11W CLIF	1	138	211	211
87	outage of 27010 11BRWN P to 27419 11W CLIF	2	138	211	211
90	outage of 27011 11BRWNCT to 27012 11BRWNT1	1	138	211	211
92	outage of 27011 11BRWNCT to 27013 11BRWNT2	1	138	211	211
95	outage of 27036 11CLARK to 27037 11CLARK	1	138-69	211	211
97	outage of 27036 11CLARK to 27116 11FAWKES	1	138	211	211
100	outage of 27036 11CLARK to 27382 11SPENC	1	138	211	211
102	outage of 27040 11CLAYSM to 27172 11HIGBY	1	138	211	211
105	outage of 27067 11DANVIL to 27068 11DANVIL	1	138-69	211	211
107	outage of 27067 11DANVIL to 27247 11MERCRCR	1	138	211	211
110	outage of 27111 11FARM T to 27112 11FARMER	1	138	211	211

No.	Contingency	Ckt	Base kV	Area	Zone
112	outage of 27111 11FARM T to 27369 11SHARKE	1	138	211	211
115	outage of 27111 11FARM T to 27382 11SPENC	1	138	211	211
117	outage of 27112 11FARMER to 27113 11FARMER	1	138-69	211	211
120	outage of 27115 11FAWK T to 27116 11FAWKES	1	138	211	211
122	outage of 27115 11FAWK T to 27231 11LR TAP	1	138	211	211
125	outage of 27116 11FAWKES to 27117 11FAWKES	1	138-69	211	211
127	outage of 27122 11FFRT E to 27412 11TYRONE	1	138	211	211
130	outage of 27141 11GODDRD to 27347 11RODBRN	1	138	211	211
132	outage of 27172 11HIGBY to 27170 11HIGB A	1	138-69	211	211
135	outage of 27172 11HIGBY to 27171 11HIGB B	1	138-69	211	211
137	outage of 27172 11HIGBY to 27207 11LANSDW	1	138	211	211
140	outage of 27172 11HIGBY to 27337 11REYNOL	1	138	211	211
142	outage of 27186 11IBM N to 27229 11LOUDON	1	138	211	211
145	outage of 27211 11LEBN W to 27212 11LEBNON	1	138	211	211
147	outage of 27212 11LEBNON to 27213 11LEBNON	1	138-69	211	211
150	outage of 27212 11LEBNON to 27213 11LEBNON	2	138-69	211	211
152	outage of 27212 11LEBNON to 27243 11MARION	1	138	211	211
155	outage of 27212 11LEBNON to 27247 11MERCRCR	1	138	211	211
157	outage of 27220 11LK REB to 27221 11LK REB	1	138-69	211	211
160	outage of 27220 11LK REB to 27231 11LR TAP	1	138	211	211
162	outage of 27229 11LOUDON to 27227 11LOUD A	1	138-69	211	211
165	outage of 27229 11LOUDON to 27228 11LOUD B	1	138-69	211	211
167	outage of 27312 11PISGAH to 27313 11PISGAH	1	138-69	211	211
170	outage of 27312 11PISGAH to 27428 11W LEXN	1	138	211	211
172	outage of 27347 11RODBRN to 27348 11RODBRN	1	138-69	211	211
175	outage of 27347 11RODBRN to 27369 11SHARKE	1	138	211	211
177	outage of 27382 11SPENC to 27383 11SPENC	1	138-69	211	211
180	outage of 27382 11SPENC to 27383 11SPENC	2	138-69	211	211
182	outage of 27412 11TYRONE to 27413 11TYRONE	1	138-69	211	211
185	outage of 27419 11W CLIF to 27420 11W CLIF	1	138-69	211	211
187	outage of 27419 11W CLIF to 27420 11W CLIF	2	138-69	211	211
190	outage of 27419 11W CLIF to 27436 11WC-DD	1	138-69	211	211
192	outage of 26959 11AOSMTH to 27129 11FOGG P	EQ	69	211	211
195	outage of 26959 11AOSMTH to 27383 11SPENC	1	69	211	211
197	outage of 26972 11ATOKA to 27068 11DANVIL	1	69	211	211
200	outage of 26986 11BEREA to 27221 11LK REB	1	69	211	211
202	outage of 26986 11BEREA to 27339 11RICH S	EQ	69	211	211
205	outage of 26999 11BOONSB to 27451 11WINC S	EQ	69	211	211
207	outage of 27016 11BUENA to 27076 11DIXDAM	1	69	211	211
210	outage of 27026 11CARON to 27225 11LONDON	1	69	211	211
212	outage of 27030 11CAVE R to 27113 11FARMER	1	69	211	211
215	outage of 27030 11CAVE R to 27358 11SALT L	1	69	211	211
217	outage of 27037 11CLARK to 27129 11FOGG P	1	69	211	211
220	outage of 27037 11CLARK to 27397 11SYLVAN	1	69	211	211
222	outage of 27046 11CMPGEK to 27225 11LONDON	1	69	211	211

No.	Contingency	Ckt	Base kV	Area	Zone
225	outage of 27050 11CORBIN to 27396 11SWEETH	1	69	211	211
227	outage of 27065 11DANV 1 to 27203 11KYSTHO	EQ	69	211	211
230	outage of 27068 11DANVIL to 27168 11HARRDS	1	69	211	211
232	outage of 27076 11DIXDAM to 27436 11WC-DD	1	69	211	211
235	outage of 27076 11DIXDAM to 27450 11WILMOR	1	69	211	211
237	outage of 27082 11E BERN to 27306 11PINEHL	1	69	211	211
240	outage of 27082 11E BERN to 27314 11PITTSB	1	69	211	211
242	outage of 27113 11FARMER to 27264 11MORH W	1	69	211	211
245	outage of 27117 11FAWKES to 27272 11N.MADS	1	69	211	211
247	outage of 27117 11FAWKES to 27339 11RICH S	1	69	211	211
250	outage of 27117 11FAWKES to 27340 11RICHMO	1	69	211	211
252	outage of 27167 11HARR T to 27168 11HARRDS	1	69	211	211
255	outage of 27167 11HARR T to 27420 11W CLIF	1	69	211	211
257	outage of 27170 11HIGB A to 27391 11STONWL	1	69	211	211
260	outage of 27170 11HIGB A to 27449 11WIL D2	1	69	211	211
262	outage of 27178 11HOPEWL to 27396 11SWEETH	1	69	211	211
265	outage of 27203 11KYSTHO to 27420 11W CLIF	1	69	211	211
267	outage of 27210 11LEBN I to 27213 11LEBNON	1	69	211	211
270	outage of 27213 11LEBNON to 27385 11SPRNGF	1	69	211	211
272	outage of 27221 11LK REB to 27340 11RICHMO	1	69	211	211
275	outage of 27221 11LK REB to 27429 11WACO	1	69	211	211
277	outage of 27225 11LONDON to 27314 11PITTSB	1	69	211	211
280	outage of 27271 11N.CORB to 27396 11SWEETH	1	69	211	211
282	outage of 27272 11N.MADS to 27449 11WIL D2	EQ	69	211	211
285	outage of 27330 11PRKRSE to 27397 11SYLVAN	1	69	211	211
287	outage of 27330 11PRKRSE to 27452 11WINCHS	1	69	211	211
290	outage of 27338 11RICE T to 27429 11WACO	1	69	211	211
292	outage of 27358 11SALT L to 27383 11SPENC	1	69	211	211
295	outage of 27359 11SALVIS to 27368 11SHAKRT	1	69	211	211
297	outage of 27368 11SHAKRT to 27420 11W CLIF	1	69	211	211
300	outage of 27420 11W CLIF to 27436 11WC-DD	1	69	211	211
302	outage of 27074 11DELVIN to 29213 20BTYVL	1	161	211-220	211-220
305	outage of 27074 11DELVIN to 29346 20GRNHLJ	1	161	211-220	211-220
307	outage of 27095 11ELIHU to 29271 20COOPER	1	161	211-220	211-220
310	outage of 27243 11MARION to 29437 20MARION	1	138-161	211-220	211-220
312	outage of 26990 11BKR LN to 29203 20BKR LN	1	138-69	211-220	211-220
315	outage of 27115 11FAWK T to 29312 20FAWKES	1	138	211-220	211-220
317	outage of 27116 11FAWKES to 29312 20FAWKES	1	138	211-220	211-220
320	outage of 27116 11FAWKES to 29312 20FAWKES	2	138	211-220	211-220
322	outage of 27229 11LOUDON to 29202 20AVON	1	138	211-220	211-220
325	outage of 27231 11LR TAP to 29616 20UN CTY	1	138	211-220	211-220
327	outage of 26982 11BEATTY to 29215 20BEATTY	1	69	211-220	211-220
330	outage of 27082 11E BERN to 29300 20EBRNST	1	69	211-220	211-220
332	outage of 27110 11FARLEY to 29536 20SCORBN	1	69	211-220	211-220
335	outage of 27117 11FAWKES to 29280 20CROOKJ	1	69	211-220	211-220

No.	Contingency	Ckt	Base kV	Area	Zone
337	outage of 27178 11HOPEWL to 29410 20LAURLC	1	69	211-220	211-220
340	outage of 29201 20AVON to 29202 20AVON	1	345-138	220	220
342	outage of 29201 20AVON to 29573 20SPURLK	1	345	220	220
345	outage of 29201 20AVON to 29651 20KPE345	1	345	220	220
350	outage of 29573 20SPURLK to 29575 20SPURLK	2	345-138	220	220
352	outage of 29575 20SPURLK to 29573 20SPURLK	1	138-345	220	220
355	outage of 29651 20KPE345 to 29652 20KPE138	1	345-138	220	220
357	outage of 29213 20BTYVL to 29215 20BEATTY	1	161-69	220	220
360	outage of 29213 20BTYVL to 29507 20POWELL	1	161	220	220
362	outage of 29271 20COOPER to 29272 20COOPER	1	161-69	220	220
370	outage of 29271 20COOPER to 29292 20DENNY	1	161	220	220
372	outage of 29271 20COOPER to 29411 20LAURLD	1	161	220	220
375	outage of 29271 20COOPER to 29517 20PULASJ	1	161	220	220
377	outage of 29271 20COOPER to 29540 20S OAKH	1	161	220	220
380	outage of 29292 20DENNY to 29293 20DENNY	1	161-69	220	220
382	outage of 29308 20FALLRK to 29310 20FALLRK	1	161-69	220	220
385	outage of 29308 20FALLRK to 29613 20TYNER	1	161	220	220
387	outage of 29346 20GRNHLJ to 29613 20TYNER	1	161	220	220
390	outage of 29408 20LAURLC to 29410 20LAURLC	1	161-69	220	220
392	outage of 29408 20LAURLC to 29411 20LAURLD	1	161	220	220
395	outage of 29408 20LAURLC to 29503 20PITTSB	1	161	220	220
400	outage of 29418 20LIBERT to 29517 20PULASJ	1	161	220	220
402	outage of 29503 20PITTSB to 29613 20TYNER	1	161	220	220
405	outage of 29507 20POWELL to 29508 20POWELL	1	161-138	220	220
407	outage of 29515 20PULASK to 29517 20PULASJ	1	161	220	220
410	outage of 29528 20RUSSEL to 29540 20S OAKH	1	161	220	220
412	outage of 29613 20TYNER to 29615 20TYNER	1	161-69	220	220
415	outage of 29202 20AVON to 29230 20BOONST	1	138	220	220
417	outage of 29202 20AVON to 29313 20FAYETT	1	138	220	220
420	outage of 29202 20AVON to 29490 20PARISJ	1	138	220	220
422	outage of 29230 20BOONST to 29233 20BOONSB	1	138	220	220
425	outage of 29230 20BOONST to 29282 20DALE	1	138	220	220
430	outage of 29282 20DALE to 29397 20JKSMIT	1	138	220	220
432	outage of 29282 20DALE to 29603 20TFJ	1	138	220	220
435	outage of 29283 20DALE to 29282 20DALE	1	69-138	220	220
437	outage of 29312 20FAWKES to 29397 20JKSMIT	1	138	220	220
440	outage of 29312 20FAWKES to 29603 20TFJ	1	138	220	220
442	outage of 29312 20FAWKES to 29623 20WBBEREA	1	138	220	220
445	outage of 29313 20FAYETT to 29315 20FAYETT	1	138-69	220	220
447	outage of 29375 20JACKVJ to 29490 20PARISJ	1	138	220	220
462	outage of 29397 20JKSMIT to 29508 20POWELL	1	138	220	220
465	outage of 29397 20JKSMIT to 29616 20UN CTY	1	138	220	220
467	outage of 29397 20JKSMIT to 29652 20KPE138	1	138	220	220
470	outage of 29397 20JKSMIT to 29652 20KPE138	2	138	220	220
472	outage of 29488 20PARIS to 29490 20PARISJ	1	138	220	220

No.	Contingency	Ckt	Base kV	Area	Zone
475	outage of 29508 20POWELL to 29510 20POWELL	1	138-69	220	220
477	outage of 29623 20WBBEREA to 29625 20WBBEREA	1	138-69	220	220
480	outage of 29195 20ALCAN to 29512 20PPG J	1	69	220	220
482	outage of 29195 20ALCAN to 29625 20WBBEREA	1	69	220	220
485	outage of 29196 20ANNVLJ to 29615 20TYNER	1	69	220	220
487	outage of 29205 20BALLRD to 29237 20BOURNE	1	69	220	220
490	outage of 29212 20BTYV D to 29215 20BEATTY	1	69	220	220
492	outage of 29215 20BEATTY to 29648 20ZACHAR	1	69	220	220
495	outage of 29222 20BLEV T to 29361 20HOPE	1	69	220	220
497	outage of 29237 20BOURNE to 29470 20NEWBY2	1	69	220	220
500	outage of 29238 20BOWEN to 29355 20HIGHHRK	1	69	220	220
502	outage of 29238 20BOWEN to 29510 20POWELL	1	69	220	220
505	outage of 29243 20BRONSJ to 29272 20COOPER	1	69	220	220
507	outage of 29260 20CLAYCJ to 29347 20HARGTJ	1	69	220	220
510	outage of 29260 20CLAYCJ to 29580 20STANTN	1	69	220	220
512	outage of 29272 20COOPER to 29566 20SOMERS	1	69	220	220
515	outage of 29272 20COOPER to 29566 20SOMERS	2	69	220	220
517	outage of 29280 20CROOKJ to 29352 20HICK P	1	69	220	220
527	outage of 29283 20DALE to 29366 20HUNT1	1	69	220	220
530	outage of 29283 20DALE to 29367 20HUNT2	1	69	220	220
532	outage of 29283 20DALE to 29468 20NEWBY1	1	69	220	220
535	outage of 29283 20DALE to 29470 20NEWBY2	1	69	220	220
537	outage of 29325 20FRNCHB to 29361 20HOPE	1	69	220	220
540	outage of 29327 20GARRCO to 29406 20LNCSTR	1	69	220	220
542	outage of 29352 20HICK P to 29511 20PPG	1	69	220	220
545	outage of 29355 20HIGHHRK to 29547 20SANDLK	1	69	220	220
547	outage of 29361 20HOPE to 29377 20JEFFVL	1	69	220	220
550	outage of 29366 20HUNT1 to 29556 20SIDEV	1	69	220	220
552	outage of 29367 20HUNT2 to 29398 20JKSMIT	1	69	220	220
555	outage of 29377 20JEFFVL to 29510 20POWELL	1	69	220	220
557	outage of 29398 20JKSMIT to 29607 20TRAPP	1	69	220	220
560	outage of 29401 20KEAVY to 29403 20KEAVJ2	1	69	220	220
562	outage of 29402 20KEAVJ1 to 29410 20LAURLC	1	69	220	220
565	outage of 29402 20KEAVJ1 to 29501 20PINEGJ	1	69	220	220
567	outage of 29403 20KEAVJ2 to 29410 20LAURLC	1	69	220	220
570	outage of 29403 20KEAVJ2 to 29536 20SCORBN	1	69	220	220
572	outage of 29406 20LNCSTR to 29468 20NEWBY1	1	69	220	220
575	outage of 29446 20MCKEE to 29615 20TYNER	1	69	220	220
577	outage of 29501 20PINEGJ to 29631 20W LOND	1	69	220	220
580	outage of 29510 20POWELL to 29580 20STANTN	1	69	220	220
582	outage of 29511 20PPG to 29512 20PPG J	1	69	220	220
585	outage of 29537 20S FORK to 29615 20TYNER	1	69	220	220
587	outage of 29605 20THLNKJ to 29626 20WBBER J	1	69	220	220
590	outage of 29625 20WBBEREA to 29626 20WBBER J	1	69	220	220
592	outage of 29503 20PITTSB to 27314 11PITTSB	1	161-69	220-211	220-211

No.	Contingency	Ckt	Base kV	Area	Zone
595	outage of 29233 20BOONSB to 26999 11BOONSB	1	138-69	220-211	220-211
597	outage of 29397 20JKSMIT to 27382 11SPENC	1	138	220-211	220-211
602	outage of 26648 09STUART to 29573 20SPURLK	1	345	209-220	209-220
605	outage of 26367 08ZIMER to 29573 20SPURLK	1	345	208-220	280-220
607	outage of 27197 11KENTON to 29575 20SPURLK	1	138	211-220	211-220
610	outage of 29372 20INLAND to 29575 20SPURLK	1	138	220	220
612	outage of 29440 20MAYSJV to 29575 20SPURLK	1	138	220	220
615	outage of 29521 20RENAKR to 29575 20SPURLK	1	138	220	220
617	outage of 29575 20SPURLK to 29585 20S PARK	1	138	220	220

Case 300s04

Case Summary

Case300s04

Project Name 2002 SERIES, NERC/MMWG BASE CASE LIBRARY
Title1 2004 Summer - CT4&5 & Gilbert
Title2 New Transmission and Cooper2/Love Off-Line
Case Date 2/12/2003

Power Flow File M:\PROJ\Kypsc\267003\300_Calculations\301_PFlow_Results\Case300s04.cft

Power Flow Controls

<i>Area Control</i>	<input type="checkbox"/>	<i>SmoothStep</i>	<input checked="" type="checkbox"/>
<i>Remote Control</i>	<input checked="" type="checkbox"/>	<i>XfrmVcon</i>	<input type="checkbox"/>
<i>GenVar Control</i>	<input checked="" type="checkbox"/>	<i>XfrmFcon</i>	<input type="checkbox"/>
<i>Solve Method</i>	NSOLVE		

Case Settings

<i>Overload</i>	<input checked="" type="checkbox"/>	<i>VlimMin</i>	0.9	<i>RateFactor</i>	1
<i>VLimit</i>	<input checked="" type="checkbox"/>	<i>VlimMax</i>	1.05	<i>AmpFactor</i>	1
<i>VChange</i>	<input checked="" type="checkbox"/>	<i>VlimChange</i>	0.05	<i>RatingNumber</i>	2
<i>Monitored Set</i>	monitor		321 Buses		

Contingency

<i>Contingencies loaded from file M:\PROJ\Kypsc\267003\300_Calculations\301_PFlow_Results\Case300s</i>	
230 contingencies	

Area	Area Name	Zone	Zone Name	Contingency Buses	Monitored Buses
147	TVA	167	TVA_EAST	0	1
				0	1
205	AEP	254	AEP-KP	0	1
				0	1
208	CIN	280	CGE	1	4
		286	CGE GENS	0	2
				1	6
209	DPL	209	DPL	1	5
				1	5
211	LGEE	211	LGEE	109	166
				109	166
220	EKPC	220	EKPC	92	142
				92	142
				203	321

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Gilbert

New Transmission and Cooper2/Love Off-Line

2/12/2003

<u>Overloaded Facility</u>										<u>Normal System Overloads</u>		
From	Name	To	Name	Circuit	Base kV	Area	Zone	Ratings		MVA	Norm (%)	Emer (%)
								Norm	Emer			
27347	11RODBRN	27348	11RODBRN	1	138-69	211	211	33	40	34	104	86

Notes:

1. Overloads are based on 100% of Rating 1
2. Normal System Conditions - No Outages
3. Minimum Reporting Level is 100%

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Gilbert

New Transmission and Cooper2/Love Off-Line

2/12/2003

Overloaded Facility								Normal System				Overloads	
From	Name	To	Name	Circuit	Base kV	Area	Zone	Ratings Norm	Emer	MVA	Norm (%)	Count A / B	Max (%)
27117	11FAWKES	27339	11RICH S	1	69	211	211	72	72	45.9	64	3 / 0	140
27347	11RODBRN	27348	11RODBRN	1	138-69	211	211	33	40	34.5	104	3 / 0	140
26986	11BEREA	27221	11LK REB	1	69	211	211	72	72	51.2	71	1 / 1	139
27117	11FAWKES	27272	11N.MADS	1	69	211	211	56	56	18.8	33	1 / 0	129
27194	11KENTON	29575	20SPURLK	2	138	211-220	211-220	227	280	167.9	74	1 / 0	113
27037	11CLARK	27397	11SYLVAN	1	69	211	211	73	90	47.0	64	2 / 1	112
27221	11LK REB	27340	11RICHMO	1	69	211	211	56	56	15.2	27	1 / 0	110
27113	11FARMER	27264	11MORH W	1	69	211	211	48	48	28.8	60	1 / 0	110
27115	11FAWK T	27231	11LR TAP	1	138	211	211	163	163	54.0	33	2 / 0	108
26959	11AOSMTH	27383	11SPENC	1	69	211	211	48	59	46.8	98	2 / 2	107
27112	11FARMER	27113	11FARMER	1	138-69	211	211	40	48	30.2	76	0 / 1	105
27116	11FAWKES	27117	11FAWKES	1	138-69	211	211	143	171	112.6	79	0 / 2	103
27229	11LOUDON	27228	11LOUD B	1	138-69	211	211	112	129	88.5	79	0 / 1	103
27220	11LK REB	27231	11LR TAP	1	138	211	211	149	171	111.7	75	0 / 1	102
29203	20BKR LN	29360	20HOLLWJ	1	69	220	220	57	69	11.3	20	0 / 2	101
27220	11LK REB	27221	11LK REB	1	138-69	211	211	149	171	111.3	75	0 / 1	101
												17 / 12	140

Notes:

- Overloads are based on 100% of Rating 2
- NS = Normal System Conditions (No Outages)
- Minimum Reporting Level is 100%
- Statistical Information (A/B Stats and Maximum Overload)
 - A = Serious Overload > 105%
 - B = Overloaded Facility between 100% and 105% of Rated Capability

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Gilbert

New Transmission and Cooper2/Love Off-Line

2/12/2003

Undervoltage		Base kV	Area	Zone	Normal System Voltage (pu)	Voltage Violations	
Bus	Name					A / B	Min (pu)
29212	20BTYV D	69	220	220	0.9806	1 / 0	0.8254
29478	20OAKD J	69	220	220	0.9723	1 / 0	0.8353
27449	11WIL D2	69	211	211	0.9996	1 / 0	0.8377
29468	20NEWBY1	69	220	220	0.9957	1 / 0	0.8379
29232	20BOONVJ	69	220	220	0.9689	1 / 0	0.8471
27210	11LEBN I	69	211	211	0.9666	1 / 0	0.8532
29406	20LNCSTR	69	220	220	0.9782	1 / 0	0.8546
29327	20GARRCO	69	220	220	0.9753	1 / 0	0.8558
29596	20TGOOCH	69	220	220	0.9600	1 / 1	0.8622
29313	20FAYETT	138	220	220	0.9944	1 / 0	0.8687
29537	20S FORK	69	220	220	0.9685	1 / 0	0.8745
29205	20BALLRD	69	220	220	0.9681	0 / 3	0.8885
29237	20BOURNE	69	220	220	0.9791	0 / 2	0.8894
29315	20FAYETT	69	220	220	1.0082	0 / 2	0.8910
29470	20NEWBY2	69	220	220	1.0032	0 / 1	0.8916
27067	11DANVIL	138	211	211	0.9911	0 / 1	0.8974
29368	20HUNTFJ	69	220	220	0.9617	0 / 2	0.8984
						11 / 12	0.8254
Notes:							
1. Minimum Voltage Limit 0.90 (pu)							
2. NS = Normal System Conditions (No Outages)							
3. Maximum Reporting Level is 90%							
4. Statistical Information (A/B Stats and Minimum Voltage)							
A = Serious Undervoltage < 0.88 (pu)							
B = Low Voltages between 0.88 and 0.90 (pu)							

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Gilbert

New Transmission and Cooper2/Love Off-Line

2/12/2003

Overvoltage					Normal System	Voltage Violations		
Bus Name	Base kV	Area	Zone		Voltage (pu)	A / B	Max (pu)	
29406 20LNCSTR	69	220	220		0.9782	0 / 1	1.0508	
Notes:							0 / 1	1.0508
<ol style="list-style-type: none"> 1. Maximum Voltage Limit is 1.05 (pu) 2. NS = Normal System Conditions (No Outages) 3. Minimum Reporting Level for Over Voltages is 105% 4. Statistical Information (A/B Stats and Maximum Voltage) <ul style="list-style-type: none"> A = Serious Overvoltage > 1.07 (pu) B = High Voltages between 1.05 and 1.07 (pu) 								

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Gilbert

New Transmission and Cooper2/Love Off-Line

2/12/2003

VChange Bus Name	Base kV	Area	Zone	Normal System Voltage (pu)	Voltage Violations	
					A / B	Max (pu)
27449 11WIL D2	69	211	211	0.9996	1 / 0	-0.1618
29468 20NEWBY1	69	220	220	0.9957	1 / 0	-0.1578
29212 20BTYV D	69	220	220	0.9806	1 / 0	-0.1552
29478 20OAKD J	69	220	220	0.9723	1 / 0	-0.1369
29313 20FAYETT	138	220	220	0.9944	1 / 0	-0.1257
29406 20LNCSTR	69	220	220	0.9782	1 / 0	-0.1236
29232 20BOONVJ	69	220	220	0.9689	1 / 0	-0.1217
29327 20GARRCO	69	220	220	0.9753	1 / 0	-0.1195
27016 11BUENA	69	211	211	1.0241	1 / 0	-0.1193
29315 20FAYETT	69	220	220	1.0082	2 / 0	-0.1172
27210 11LEBN I	69	211	211	0.9666	1 / 0	-0.1134
29470 20NEWBY2	69	220	220	1.0032	1 / 0	-0.1116
27076 11DIXDAM	69	211	211	1.0359	1 / 0	-0.1078
29596 20TGOOCH	69	220	220	0.9600	1 / 0	-0.0978
27016 11BUENA	69	211	211	1.0241	1 / 0	-0.0974
27136 11GARRD	69	211	211	1.0040	1 / 0	-0.0969
29537 20S FORK	69	220	220	0.9685	1 / 0	-0.0939
27067 11DANVIL	138	211	211	0.9911	1 / 0	-0.0937
29291 20DAVIS	69	220	220	0.9955	2 / 0	-0.0934
29237 20BOURNE	69	220	220	0.9791	1 / 0	-0.0897
29237 20BOURNE	69	220	220	0.9791	1 / 0	-0.0877
29233 20BOONSB	138	220	220	1.0164	1 / 0	-0.0830
29205 20BALLRD	69	220	220	0.9681	1 / 0	-0.0796
29205 20BALLRD	69	220	220	0.9681	1 / 0	-0.0788
27136 11GARRD	69	211	211	1.0040	1 / 0	-0.0778
27068 11DANVIL	69	211	211	0.9976	2 / 0	-0.0771
29205 20BALLRD	69	220	220	0.9681	1 / 0	-0.0770
29580 20STANTN	69	220	220	0.9921	1 / 0	-0.0762
27450 11WILMOR	69	211	211	1.0074	1 / 0	-0.0759
29327 20GARRCO	69	220	220	0.9753	1 / 0	-0.0753
26999 11BOONSB	69	211	211	1.0310	2 / 0	-0.0737
26972 11ATOKA	69	211	211	0.9962	2 / 0	-0.0736
27247 11MERCRCR	138	211	211	1.0040	1 / 0	-0.0726
29623 20WBEREA	138	220	220	0.9971	1 / 0	-0.0721
27000 11BOYLE	69	211	211	0.9955	2 / 0	-0.0716
27220 11LK REB	138	211	211	0.9978	0 / 1	-0.0682
27167 11HARR T	69	211	211	1.0063	0 / 1	-0.0678
27168 11HARRDS	69	211	211	1.0063	0 / 1	-0.0678
27055 11CRAB O	69	211	211	0.9802	0 / 1	-0.0669
27065 11DANV 1	69	211	211	0.9952	0 / 2	-0.0661
27450 11WILMOR	69	211	211	1.0074	0 / 1	-0.0658
29325 20FRNCHB	69	220	220	0.9745	0 / 1	-0.0658
29625 20WBEREA	69	220	220	0.9901	0 / 1	-0.0651
29625 20WBEREA	69	220	220	0.9901	0 / 1	-0.0649
29203 20BKR LN	69	220	220	0.9862	0 / 1	-0.0645
29436 20MARIBJ	69	220	220	0.9760	0 / 1	-0.0643
29626 20WBER J	69	220	220	0.9890	0 / 1	-0.0640
27067 11DANVIL	138	211	211	0.9911	0 / 1	-0.0636
29260 20CLAYCJ	69	220	220	0.9903	0 / 1	-0.0636
29368 20HUNTFJ	69	220	220	0.9617	0 / 1	-0.0633
29626 20WBER J	69	220	220	0.9890	0 / 1	-0.0628
29368 20HUNTFJ	69	220	220	0.9617	0 / 1	-0.0627
29605 20THLNKJ	69	220	220	0.9870	0 / 1	-0.0626

VChange		Base kV	Area	Zone	Normal System Voltage (pu)	Voltage Violations	
Bus	Name					A / B	Max (pu)
29626	20WBER J	69	220	220	0.9890	0 / 1	-0.0626
29195	20ALCAN	69	220	220	0.9879	0 / 1	-0.0621
29605	20THLNKJ	69	220	220	0.9870	0 / 1	-0.0621
29195	20ALCAN	69	220	220	0.9879	0 / 1	-0.0618
29368	20HUNTFJ	69	220	220	0.9617	0 / 1	-0.0613
29515	20PULASK	161	220	220	0.9878	0 / 1	-0.0609
29512	20PPG J	69	220	220	0.9874	0 / 1	-0.0602
29511	20PPG	69	220	220	0.9874	0 / 1	-0.0601
29596	20TGOOCH	69	220	220	0.9600	0 / 1	-0.0601
29512	20PPG J	69	220	220	0.9874	0 / 1	-0.0599
29511	20PPG	69	220	220	0.9874	0 / 1	-0.0598
29347	20HARGTJ	69	220	220	0.9924	0 / 1	-0.0588
29360	20HOLLWJ	69	220	220	0.9830	0 / 1	-0.0584
29605	20THLNKJ	69	220	220	0.9870	0 / 1	-0.0577
29605	20THLNKJ	69	220	220	0.9870	0 / 1	-0.0575
29510	20POWELL	69	220	220	0.9923	0 / 1	-0.0569
29580	20STANTN	69	220	220	0.9921	0 / 1	-0.0566
27068	11DANVIL	69	211	211	0.9976	0 / 1	-0.0553
29406	20LNCSTR	69	220	220	0.9782	0 / 1	-0.0551
26959	11AOSMTH	69	211	211	1.0153	0 / 1	-0.0550
29510	20POWELL	69	220	220	0.9923	0 / 1	-0.0548
29580	20STANTN	69	220	220	0.9921	0 / 1	-0.0546
26986	11BEREA	69	211	211	0.9908	0 / 1	-0.0542
27221	11LK REB	69	211	211	1.0070	0 / 2	-0.0536
29508	20POWELL	138	220	220	0.9972	0 / 1	-0.0535
27339	11RICH S	69	211	211	0.9962	0 / 1	-0.0532
29327	20GARRCO	69	220	220	0.9753	0 / 1	-0.0531
26972	11ATOKA	69	211	211	0.9962	0 / 1	-0.0529
27055	11CRAB O	69	211	211	0.9802	0 / 1	-0.0527
29338	20GRNBRJ	69	220	220	0.9788	0 / 1	-0.0526
29338	20GRNBRJ	69	220	220	0.9788	0 / 1	-0.0524
29516	20PULASK	69	220	220	0.9793	0 / 1	-0.0524
29346	20GRNHLJ	161	220	220	0.9701	0 / 1	-0.0523
27368	11SHAKRT	69	211	211	1.0273	0 / 1	-0.0521
27000	11BOYLE	69	211	211	0.9955	0 / 1	-0.0516
29440	20MAYSVJ	138	220	220	1.0240	0 / 1	-0.0516
29615	20TYNER	69	220	220	0.9743	0 / 1	-0.0512
29238	20BOWEN	69	220	220	0.9930	0 / 1	-0.0511
29310	20FALLRK	69	220	220	0.9877	0 / 1	-0.0508
29310	20FALLRK	69	220	220	0.9877	0 / 1	-0.0507
27203	11KYSTHO	69	211	211	1.0111	0 / 1	-0.0505
27272	11N.MADS	69	211	211	1.0028	0 / 1	-0.0505
29615	20TYNER	69	220	220	0.9743	0 / 1	-0.0505
29488	20PARIS	138	220	220	0.9915	0 / 1	-0.0504
29238	20BOWEN	69	220	220	0.9930	0 / 1	-0.0502
29237	20BOURNE	69	220	220	0.9791	0 / 1	0.0529
29406	20LNCSTR	69	220	220	0.9782	1 / 0	0.0726

42 / 66 -0.1618

Notes:

1. Voltage Change Limit is 0.05 (pu)
2. NS = Normal System Conditions (No Outages)
3. Minimum Reporting Level is 5%
4. Statistical Information (A/B Stats and Maximum Voltage Change)
 - A = Serious Voltage Change > 0.07 (pu)
 - B = Excessive Voltage Change between 0.05 and 0.07 (pu)

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Gilbert

New Transmission and Cooper2/Love Off-Line

2/12/2003

Contingency	Overloaded Facility									Overloads		
	From Name	To Name	Ckt	Base kV	Area	Zone	Ratings		MVA	Norm (%)	Emer (%)	
							Norm	Emer				
95	outage of 27036 11CLARK to 27037 11CLARK		1	138-69	211	211						
	26959 11AOSMTH	27383 11SPENC	1	69	211	211	48	59	61.6	128	105	
110	outage of 27111 11FARM T to 27112 11FARMER		1	138	211	211						
	27347 11RODBRN	27348 11RODBRN	1	138-69	211	211	33	40	49.4	150	124	
117	outage of 27112 11FARMER to 27113 11FARMER		1	138-69	211	211						
	27347 11RODBRN	27348 11RODBRN	1	138-69	211	211	33	40	49.4	150	124	
125	outage of 27116 11FAWKES to 27117 11FAWKES		1	138-69	211	211						
	27221 11LK REB	27340 11RICHMO	1	69	211	211	56	56	61.7	110	110	
	26986 11BEREA	27221 11LK REB	1	69	211	211	72	72	75.2	104	105	
	27220 11LR REB	27231 11LR TAP	1	138	211	211	149	171	173.7	117	102	
	27220 11LK REB	27221 11LK REB	1	138-69	211	211	149	171	172.8	116	101	
132	outage of 27172 11HIGBY to 27170 11HIGB A		1	138-69	211	211						
	26956 NONAME	27304 11PICADO	1	69	211	211	95	95	97.7	103	103	
157	outage of 27220 11LK REB to 27221 11LK REB		1	138-69	211	211						
	27117 11FAWKES	27339 11RICH S	1	69	211	211	72	72	75.9	105	105	
	27116 11FAWKES	27117 11FAWKES	1	138-69	211	211	143	171	176.4	123	103	
160	outage of 27220 11LK REB to 27231 11LR TAP		1	138	211	211						
	27117 11FAWKES	27339 11RICH S	1	69	211	211	72	72	75.9	105	105	
	27116 11FAWKES	27117 11FAWKES	1	138-69	211	211	143	171	176.4	123	103	
162	outage of 27229 11LOUDON to 27227 11LOUD A		1	138-69	211	211						
	27229 11LOUDON	27228 11LOUD B	1	138-69	211	211	112	129	132.6	118	103	
172	outage of 27347 11RODBRN to 27348 11RODBRN		1	138-69	211	211						
	27113 11FARMER	27264 11MORH W	1	69	211	211	48	48	52.7	110	110	
	27112 11FARMER	27113 11FARMER	1	138-69	211	211	40	48	50.2	125	105	
200	outage of 26986 11BEREA to 27221 11LK REB		1	69	211	211						
	27117 11FAWKES	27339 11RICH S	1	69	211	211	72	72	100.7	140	140	
205	outage of 26999 11BOONSB to 27451 11WINC S		EQ	69	211	211						
	26959 11AOSMTH	27383 11SPENC	1	69	211	211	48	59	59.7	124	101	
	27037 11CLARK	27397 11SYLVAN	1	69	211	211	73	90	90.3	124	100	
242	outage of 27113 11FARMER to 27264 11MORH W		1	69	211	211						
	27347 11RODBRN	27348 11RODBRN	1	138-69	211	211	33	40	55.9	169	140	
247	outage of 27117 11FAWKES to 27339 11RICH S		1	69	211	211						
	26986 11BEREA	27221 11LK REB	1	69	211	211	72	72	99.7	139	139	
260	outage of 27170 11HIGB A to 27449 11WIL D2		1	69	211	211						
	27117 11FAWKES	27272 11N.MADS	1	69	211	211	56	56	72.1	129	129	
322	outage of 27229 11LOUDON to 29202 20AVON		1	138	211-220	211-220						
	27075 NONAME	27300 11PARIS	1	69	211	211	56	56	65.0	116	116	
325	outage of 27231 11LR TAP to 29616 20UN CTY		1	138	211-220	211-220						
	27115 11FAWK T	27231 11LR TAP	1	138	211	211	163	163	174.0	107	107	
417	outage of 29202 20AVON to 29313 20FAYETT		1	138	220	220						
	29203 20BKR LN	29360 20HOLLWJ	1	69	220	220	57	69	69.8	122	101	
422	outage of 29230 20BOONST to 29233 20BOONSB		1	138	220	220						
	27037 11CLARK	27397 11SYLVAN	1	69	211	211	73	90	100.5	138	112	
	26959 11AOSMTH	27383 11SPENC	1	69	211	211	48	59	62.9	131	107	
445	outage of 29313 20FAYETT to 29315 20FAYETT		1	138-69	220	220						
	29203 20BKR LN	29360 20HOLLWJ	1	69	220	220	57	69	69.8	122	101	
465	outage of 29397 20JKSMIT to 29616 20UN CTY		1	138	220	220						
	27115 11FAWK T	27231 11LR TAP	1	138	211	211	163	163	176.2	108	108	
595	outage of 29233 20BOONSB to 26999 11BOONSB		1	138-69	220-211	220-211						
	27037 11CLARK	27397 11SYLVAN	1	69	211	211	73	90	100.5	138	112	

Contingency	Overloaded Facility										Overloads		
	From Name		To Name		Ckt	Base kV	Area	Zone	Ratings		MVA	Norm (%)	Emer (%)
									Norm	Emer			
	26959	11AOSMTH	27383	11SPENC	1	69	211	211	48	59	62.9	131	107
607	outage of 27197 11KENTON to 29575 20SPURLK				1	138	211-220	211-220					
	27194	11KENTON	29575	20SPURLK	2	138	211-220	211-220	227	280	316.8	140	113

Notes:

1. Overloads are based on 100% of Rating 2

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Gilbert

New Transmission and Cooper2/Love Off-Line

2/12/2003

Overloaded Facility	Contingency									Overloads			
	From	Name	To	Name	Circuit	Base kV	Area	Zone	Ratings Norm Emer	NS	Norm MVA	Emer (%)	Emer (%)
27117 11FAWKES	27339	11RICH S			1	69	211	211	72 72	NS	46	64	64
	200 outage of 26986 11BEREA to 27221 11LK REB										101	140	140
	157 outage of 27220 11LK REB to 27221 11LK REB										76	105	105
	160 outage of 27220 11LK REB to 27231 11LR TAP										76	105	105
											3 / 0		140
27347 11RODBRN	27348	11RODBRN			1	138-69	211	211	33 40	NS	34	104	86
	242 outage of 27113 11FARMER to 27264 11MORH										56	169	140
	110 outage of 27111 11FARM T to 27112 11FARMER										49	150	124
	117 outage of 27112 11FARMER to 27113 11FARME										49	150	124
											3 / 0		140
26986 11BEREA	27221	11LK REB			1	69	211	211	72 72	NS	51	71	71
	247 outage of 27117 11FAWKES to 27339 11RICH S										100	139	139
	125 outage of 27116 11FAWKES to 27117 11FAWKE										75	104	105
											1 / 1		139
27117 11FAWKES	27272	11N.MADS			1	69	211	211	56 56	NS	19	33	33
	260 outage of 27170 11HIGB A to 27449 11WIL D2										72	129	129
											1 / 0		129
27194 11KENTON	29575	20SPURLK			2	138	211-220	211-220	227 280	NS	168	74	60
	607 outage of 27197 11KENTON to 29575 20SPURLK										317	140	113
											1 / 0		113
27037 11CLARK	27397	11SYLVAN			1	69	211	211	73 90	NS	47	64	52
	595 outage of 29233 20BOONSB to 26999 11BOONS										101	138	112
	422 outage of 29230 20BOONST to 29233 20BOONS										101	138	112
	205 outage of 26999 11BOONSB to 27451 11WINC S EQ										90	124	100
											2 / 1		112
27221 11LK REB	27340	11RICHMO			1	69	211	211	56 56	NS	15	27	27
	125 outage of 27116 11FAWKES to 27117 11FAWKE										62	110	110
											1 / 0		110
27113 11FARMER	27264	11MORH W			1	69	211	211	48 48	NS	29	60	60
	172 outage of 27347 11RODBRN to 27348 11RODBR										53	110	110
											1 / 0		110
27115 11FAWK T	27231	11LR TAP			1	138	211	211	163 163	NS	54	33	33
	465 outage of 29397 20JKSMIT to 29616 20UN CTY										176	108	108
	325 outage of 27231 11LR TAP to 29616 20UN CTY										174	107	107
											2 / 0		108

Overloaded Facility		Contingency								Overloads			
From	Name	To	Name	Circuit	Base kV	Area	Zone	Ratings		NS	Norm	Emer	
								Norm	Emer		MVA	(%)	(%)
26959	11AOSMTH	27383	11SPENC	1	69	211	211	48	59	NS	47	98	79
	595 outage of 29233 20BOONSB to 26999 11BOONS			1	138-69	220-211	220-211				63	131	107
	422 outage of 29230 20BOONST to 29233 20BOONS			1	138	220	220				63	131	107
	95 outage of 27036 11CLARK to 27037 11CLARK			1	138-69	211	211				62	128	105
	205 outage of 26999 11BOONSB to 27451 11WINC S EQ				69	211	211				60	124	101
											2 / 2		107
27112	11FARMER	27113	11FARMER	1	138-69	211	211	40	48	NS	30	76	63
	172 outage of 27347 11RODBRN to 27348 11RODBR			1	138-69	211	211				50	125	105
											0 / 1		105
27116	11FAWKES	27117	11FAWKES	1	138-69	211	211	143	171	NS	113	79	66
	160 outage of 27220 11LK REB to 27231 11LR TAP			1	138	211	211				176	123	103
	157 outage of 27220 11LK REB to 27221 11LK REB			1	138-69	211	211				176	123	103
											0 / 2		103
27229	11LOUDON	27228	11LOUD B	1	138-69	211	211	112	129	NS	89	79	69
	162 outage of 27229 11LOUDON to 27227 11LOUD A			1	138-69	211	211				133	118	103
											0 / 1		103
27220	11LK REB	27231	11LR TAP	1	138	211	211	149	171	NS	112	75	65
	125 outage of 27116 11FAWKES to 27117 11FAWKE			1	138-69	211	211				174	117	102
											0 / 1		102
29203	20BKR LN	29360	20HOLLWJ	1	69	220	220	57	69	NS	11	20	16
	417 outage of 29202 20AVON to 29313 20FAYETT			1	138	220	220				70	122	101
	445 outage of 29313 20FAYETT to 29315 20FAYETT			1	138-69	220	220				70	122	101
											0 / 2		101
27220	11LK REB	27221	11LK REB	1	138-69	211	211	149	171	NS	111	75	65
	125 outage of 27116 11FAWKES to 27117 11FAWKE			1	138-69	211	211				173	116	101
											0 / 1		101
											17 / 12		139.9

Notes:

- Overloads are based on 100% of Rating 2
- NS = Normal System Conditions (No Outages)
- Minimum Reporting Level is 100%
- Statistical Information (A/B Stats and Maximum Overload)
 - A = Serious Overload > 105%
 - B = Overloaded Facility between 100% and 105% of Rated Capability

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Gilbert

New Transmission and Cooper2/Love Off-Line

2/12/2003

Contingency

Description	Ckt	kV	Zone	Area	Voltage Violations				Not Solved
					Over load	UnderV	OverV	Change	
82 outage of 27010 11BRWN P to 27247 11MERC R	1	138	211	211	0	0	0	5	
95 outage of 27036 11CLARK to 27037 11CLARK	1	138-69	211	211	1	0	0	0	
105 outage of 27067 11DANVIL to 27068 11DANVIL	1	138-69	211	211	0	0	0	4	
107 outage of 27067 11DANVIL to 27247 11MERC R	1	138	211	211	0	1	0	5	
110 outage of 27111 11FARM T to 27112 11FARMER	1	138	211	211	1	0	0	0	
117 outage of 27112 11FARMER to 27113 11FARMER	1	138-69	211	211	1	0	0	0	
125 outage of 27116 11FAWKES to 27117 11FAWKES	1	138-69	211	211	4	0	0	0	
132 outage of 27172 11HIGBY to 27170 11HIGB A	1	138-69	211	211	1	0	0	0	
157 outage of 27220 11LK REB to 27221 11LK REB	1	138-69	211	211	2	0	0	1	
160 outage of 27220 11LK REB to 27231 11LR TAP	1	138	211	211	2	0	0	2	
162 outage of 27229 11LOUDON to 27227 11LOUD A	1	138-69	211	211	1	0	0	0	
172 outage of 27347 11RODBRN to 27348 11RODBRN	1	138-69	211	211	2	0	0	0	
195 outage of 26959 11AOSMTH to 27383 11SPENC	1	69	211	211	0	0	0	1	
200 outage of 26986 11BEREA to 27221 11LK REB	1	69	211	211	1	0	0	1	
205 outage of 26999 11BOONSB to 27451 11WINC S	EQ	69	211	211	2	0	0	0	
207 outage of 27016 11BUENA to 27076 11DIXDAM	1	69	211	211	0	0	0	3	
232 outage of 27076 11DIXDAM to 27436 11WC-DD	1	69	211	211	0	0	0	5	
235 outage of 27076 11DIXDAM to 27450 11WILMOR	1	69	211	211	0	0	0	1	
242 outage of 27113 11FARMER to 27264 11MORH W	1	69	211	211	1	0	0	0	
247 outage of 27117 11FAWKES to 27339 11RICH S	1	69	211	211	1	0	0	1	
255 outage of 27167 11HARR T to 27420 11W CLIF	1	69	211	211	0	0	0	2	
260 outage of 27170 11HIGB A to 27449 11WIL D2	1	69	211	211	1	1	0	2	
265 outage of 27203 11KYSTHO to 27420 11W CLIF	1	69	211	211	0	0	0	1	
267 outage of 27210 11LEBN I to 27213 11LEBNON	1	69	211	211	0	1	0	1	
297 outage of 27368 11SHAKRT to 27420 11W CLIF	1	69	211	211	0	0	0	1	
305 outage of 27074 11DELVIN to 29346 20GRNHLJ	1	161	211-220	211-220	0	0	0	4	
312 outage of 26990 11BKR LN to 29203 20BKR LN	1	138-69	211-220	211-220	0	0	0	2	
322 outage of 27229 11LOUDON to 29202 20AVON	1	138	211-220	211-220	1	0	0	0	
325 outage of 27231 11LR TAP to 29616 20UN CTY	1	138	211-220	211-220	1	0	0	0	
387 outage of 29346 20GRNHLJ to 29613 20TYNER	1	161	220	220	0	0	0	3	
407 outage of 29515 20PULASK to 29517 20PULASJ	1	161	220	220	0	0	0	2	
417 outage of 29202 20AVON to 29313 20FAYETT	1	138	220	220	1	2	0	3	
422 outage of 29230 20BOONST to 29233 20BOONSB	1	138	220	220	2	0	0	2	
442 outage of 29312 20FAWKES to 29623 20WBBEREA	1	138	220	220	0	0	0	7	
445 outage of 29313 20FAYETT to 29315 20FAYETT	1	138-69	220	220	1	1	0	2	
462 outage of 29397 20JKSMIT to 29508 20POWELL	1	138	220	220	0	0	0	4	
465 outage of 29397 20JKSMIT to 29616 20UN CTY	1	138	220	220	1	0	0	0	
472 outage of 29488 20PARIS to 29490 20PARISJ	1	138	220	220	0	0	0	1	

Contingency

Description	Ckt	kV	Zone	Area	Voltage Violations				Not Solved
					Over load	UnderV	OverV	Change	
475 outage of 29508 20POWELL to 29510 20POWELL	1	138-69	220	220	0	0	0	3	
477 outage of 29623 20WBBEREA to 29625 20WBBERE	1	138-69	220	220	0	0	0	6	
487 outage of 29205 20BALLRD to 29237 20BOURNE	1	69	220	220	0	2	0	3	
490 outage of 29212 20BTYV D to 29215 20BEATTY	1	69	220	220	0	4	0	4	
497 outage of 29237 20BOURNE to 29470 20NEWBY2	1	69	220	220	0	3	0	3	
532 outage of 29283 20DALE to 29468 20NEWBY1	1	69	220	220	0	4	0	4	
535 outage of 29283 20DALE to 29470 20NEWBY2	1	69	220	220	0	3	0	4	
537 outage of 29325 20FRNCHB to 29361 20HOPE	1	69	220	220	0	0	0	2	
540 outage of 29327 20GARRCO to 29406 20LNCSTR	1	69	220	220	0	1	1	3	
572 outage of 29406 20LNCSTR to 29468 20NEWBY1	1	69	220	220	0	0	0	2	
580 outage of 29510 20POWELL to 29580 20STANTN	1	69	220	220	0	0	0	3	
587 outage of 29605 20THLNKJ to 29626 20WBBER J	1	69	220	220	0	0	0	1	
590 outage of 29625 20WBBEREA to 29626 20WBBER J	1	69	220	220	0	0	0	2	
595 outage of 29233 20BOONSB to 26999 11BOONSB	1	138-69	220-211	220-211	2	0	0	1	
607 outage of 27197 11KENTON to 29575 20SPURLK	1	138	211-220	211-220	1	0	0	0	
612 outage of 29440 20MAYSJV to 29575 20SPURLK	1	138	220	220	0	0	0	1	
Totals:					31	23	1	108	0

Notes:

1. Overloads are based on 100% of Rating 2
2. Undervoltage Limit is 0.90 (pu)
3. Overvoltage Limit is 1.05 (pu)
4. Voltage Change Limit is 0.05 (pu)

Not Solved Codes:

- D - Diverged
I - Interrupted
F - Failed, One or More Contingency Commands Failed in PFlow

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Gilbert

New Transmission and Cooper2/Love Off-Line

2/12/2003

No.	Contingency	Ckt	Base kV	Area	Zone
10	outage of 26950 11ALCALD to 27008 11BRWN N	1	345	211	211
12	outage of 27008 11BRWN N to 27009 11BRWN N	1	345-138	211	211
15	outage of 27008 11BRWN N to 27162 11HARDN	1	345	211	211
17	outage of 27008 11BRWN N to 27427 11W LEXN	1	345	211	211
20	outage of 26951 11ALCALD to 27095 11ELIHU	1	161	211	211
22	outage of 26962 11ARNOLD to 27074 11DELVIN	1	161	211	211
25	outage of 27074 11DELVIN to 27444 11WI TAP	1	161	211	211
27	outage of 27095 11ELIHU to 27096 11ELIHU	1	161-69	211	211
30	outage of 27095 11ELIHU to 27096 11ELIHU	2	161-69	211	211
32	outage of 27230 11LR TAP to 27231 11LR TAP	1	161-138	211	211
35	outage of 27230 11LR TAP to 27444 11WI TAP	1	161	211	211
37	outage of 27425 11W IRVI to 27444 11WI TAP	1	161	211	211
40	outage of 26947 11ADAMS to 27412 11TYRONE	1	138	211	211
42	outage of 26977 11BARDST to 26978 11BARDST	1	138-69	211	211
45	outage of 26977 11BARDST to 27011 11BRWNCT	1	138	211	211
47	outage of 26977 11BARDST to 27276 11NELSON	1	138	211	211
50	outage of 26990 11BKR LN to 27009 11BRWN N	1	138	211	211
52	outage of 26990 11BKR LN to 27172 11HIGBY	1	138	211	211
55	outage of 26998 11BONNIE to 27211 11LEBN W	1	138	211	211
57	outage of 27009 11BRWN N to 27011 11BRWNCT	1	138	211	211
60	outage of 27009 11BRWN N to 27012 11BRWNT1	1	138	211	211
62	outage of 27009 11BRWN N to 27013 11BRWNT2	1	138	211	211
65	outage of 27009 11BRWN N to 27040 11CLAYSM	1	138	211	211
67	outage of 27009 11BRWN N to 27172 11HIGBY	1	138	211	211
70	outage of 27009 11BRWN N to 27312 11PISGAH	1	138	211	211
72	outage of 27009 11BRWN N to 27412 11TYRONE	1	138	211	211
75	outage of 27010 11BRWN P to 27012 11BRWNT1	1	138	211	211
77	outage of 27010 11BRWN P to 27013 11BRWNT2	1	138	211	211
80	outage of 27010 11BRWN P to 27116 11FAWKES	1	138	211	211
82	outage of 27010 11BRWN P to 27247 11MERCRCR	1	138	211	211
85	outage of 27010 11BRWN P to 27419 11W CLIF	1	138	211	211
87	outage of 27010 11BRWN P to 27419 11W CLIF	2	138	211	211
90	outage of 27011 11BRWNCT to 27012 11BRWNT1	1	138	211	211
92	outage of 27011 11BRWNCT to 27013 11BRWNT2	1	138	211	211
95	outage of 27036 11CLARK to 27037 11CLARK	1	138-69	211	211
97	outage of 27036 11CLARK to 27116 11FAWKES	1	138	211	211
100	outage of 27036 11CLARK to 27382 11SPENC	1	138	211	211
102	outage of 27040 11CLAYSM to 27172 11HIGBY	1	138	211	211
105	outage of 27067 11DANVIL to 27068 11DANVIL	1	138-69	211	211
107	outage of 27067 11DANVIL to 27247 11MERCRCR	1	138	211	211
110	outage of 27111 11FARM T to 27112 11FARMER	1	138	211	211

No.	Contingency	Ckt	Base kV	Area	Zone
112	outage of 27111 11FARM T to 27369 11SHARKE	1	138	211	211
115	outage of 27111 11FARM T to 27382 11SPENC	1	138	211	211
117	outage of 27112 11FARMER to 27113 11FARMER	1	138-69	211	211
120	outage of 27115 11FAWK T to 27116 11FAWKES	1	138	211	211
122	outage of 27115 11FAWK T to 27231 11LR TAP	1	138	211	211
125	outage of 27116 11FAWKES to 27117 11FAWKES	1	138-69	211	211
127	outage of 27122 11FFRT E to 27412 11TYRONE	1	138	211	211
130	outage of 27141 11GODDRD to 27347 11RODBRN	1	138	211	211
132	outage of 27172 11HIGBY to 27170 11HIGB A	1	138-69	211	211
135	outage of 27172 11HIGBY to 27171 11HIGB B	1	138-69	211	211
137	outage of 27172 11HIGBY to 27207 11LANSDW	1	138	211	211
140	outage of 27172 11HIGBY to 27337 11REYNOL	1	138	211	211
142	outage of 27186 11IBM N to 27229 11LOUDON	1	138	211	211
145	outage of 27211 11LEBN W to 27212 11LEBNON	1	138	211	211
147	outage of 27212 11LEBNON to 27213 11LEBNON	1	138-69	211	211
150	outage of 27212 11LEBNON to 27213 11LEBNON	2	138-69	211	211
152	outage of 27212 11LEBNON to 27243 11MARION	1	138	211	211
155	outage of 27212 11LEBNON to 27247 11MERCRCR	1	138	211	211
157	outage of 27220 11LK REB to 27221 11LK REB	1	138-69	211	211
160	outage of 27220 11LK REB to 27231 11LR TAP	1	138	211	211
162	outage of 27229 11LOUDON to 27227 11LOUD A	1	138-69	211	211
165	outage of 27229 11LOUDON to 27228 11LOUD B	1	138-69	211	211
167	outage of 27312 11PISGAH to 27313 11PISGAH	1	138-69	211	211
170	outage of 27312 11PISGAH to 27428 11W LEXN	1	138	211	211
172	outage of 27347 11RODBRN to 27348 11RODBRN	1	138-69	211	211
175	outage of 27347 11RODBRN to 27369 11SHARKE	1	138	211	211
177	outage of 27382 11SPENC to 27383 11SPENC	1	138-69	211	211
180	outage of 27382 11SPENC to 27383 11SPENC	2	138-69	211	211
182	outage of 27412 11TYRONE to 27413 11TYRONE	1	138-69	211	211
185	outage of 27419 11W CLIF to 27420 11W CLIF	1	138-69	211	211
187	outage of 27419 11W CLIF to 27420 11W CLIF	2	138-69	211	211
190	outage of 27419 11W CLIF to 27436 11WC-DD	1	138-69	211	211
192	outage of 26959 11AOSMTH to 27129 11FOGG P	EQ	69	211	211
195	outage of 26959 11AOSMTH to 27383 11SPENC	1	69	211	211
197	outage of 26972 11ATOKA to 27068 11DANVIL	1	69	211	211
200	outage of 26986 11BEREA to 27221 11LK REB	1	69	211	211
202	outage of 26986 11BEREA to 27339 11RICH S	EQ	69	211	211
205	outage of 26999 11BOONSB to 27451 11WINC S	EQ	69	211	211
207	outage of 27016 11BUENA to 27076 11DIXDAM	1	69	211	211
210	outage of 27026 11CARON to 27225 11LONDON	1	69	211	211
212	outage of 27030 11CAVE R to 27113 11FARMER	1	69	211	211
215	outage of 27030 11CAVE R to 27358 11SALT L	1	69	211	211
217	outage of 27037 11CLARK to 27129 11FOGG P	1	69	211	211
220	outage of 27037 11CLARK to 27397 11SYLVAN	1	69	211	211
222	outage of 27046 11CMPGEK to 27225 11LONDON	1	69	211	211

No.	Contingency	Ckt	Base kV	Area	Zone
225	outage of 27050 11CORBIN to 27396 11SWEETH	1	69	211	211
227	outage of 27065 11DANV 1 to 27203 11KYSTHO	EQ	69	211	211
230	outage of 27068 11DANVIL to 27168 11HARRDS	1	69	211	211
232	outage of 27076 11DIXDAM to 27436 11WC-DD	1	69	211	211
235	outage of 27076 11DIXDAM to 27450 11WILMOR	1	69	211	211
237	outage of 27082 11E BERN to 27306 11PINEHL	1	69	211	211
240	outage of 27082 11E BERN to 27314 11PITTSB	1	69	211	211
242	outage of 27113 11FARMER to 27264 11MORH W	1	69	211	211
245	outage of 27117 11FAWKES to 27272 11N.MADS	1	69	211	211
247	outage of 27117 11FAWKES to 27339 11RICH S	1	69	211	211
250	outage of 27117 11FAWKES to 27340 11RICHMO	1	69	211	211
252	outage of 27167 11HARR T to 27168 11HARRDS	1	69	211	211
255	outage of 27167 11HARR T to 27420 11W CLIF	1	69	211	211
257	outage of 27170 11HIGB A to 27391 11STONWL	1	69	211	211
260	outage of 27170 11HIGB A to 27449 11WIL D2	1	69	211	211
262	outage of 27178 11HOPEWL to 27396 11SWEETH	1	69	211	211
265	outage of 27203 11KYSTHO to 27420 11W CLIF	1	69	211	211
267	outage of 27210 11LEBN I to 27213 11LEBNON	1	69	211	211
270	outage of 27213 11LEBNON to 27385 11SPRNGF	1	69	211	211
272	outage of 27221 11LK REB to 27340 11RICHMO	1	69	211	211
275	outage of 27221 11LK REB to 27429 11WACO	1	69	211	211
277	outage of 27225 11LONDON to 27314 11PITTSB	1	69	211	211
280	outage of 27271 11N.CORB to 27396 11SWEETH	1	69	211	211
282	outage of 27272 11N.MADS to 27449 11WIL D2	EQ	69	211	211
285	outage of 27330 11PRKRSE to 27397 11SYLVAN	1	69	211	211
287	outage of 27330 11PRKRSE to 27452 11WINCHS	1	69	211	211
290	outage of 27338 11RICE T to 27429 11WACO	1	69	211	211
292	outage of 27358 11SALT L to 27383 11SPENC	1	69	211	211
295	outage of 27359 11SALVIS to 27368 11SHAKRT	1	69	211	211
297	outage of 27368 11SHAKRT to 27420 11W CLIF	1	69	211	211
300	outage of 27420 11W CLIF to 27436 11WC-DD	1	69	211	211
302	outage of 27074 11DELVIN to 29213 20BTYVL	1	161	211-220	211-220
305	outage of 27074 11DELVIN to 29346 20GRNHLJ	1	161	211-220	211-220
307	outage of 27095 11ELIHU to 29271 20COOPER	1	161	211-220	211-220
310	outage of 27243 11MARION to 29437 20MARION	1	138-161	211-220	211-220
312	outage of 26990 11BKR LN to 29203 20BKR LN	1	138-69	211-220	211-220
315	outage of 27115 11FAWK T to 29312 20FAWKES	1	138	211-220	211-220
317	outage of 27116 11FAWKES to 29312 20FAWKES	1	138	211-220	211-220
320	outage of 27116 11FAWKES to 29312 20FAWKES	2	138	211-220	211-220
322	outage of 27229 11LOUDON to 29202 20AVON	1	138	211-220	211-220
325	outage of 27231 11LR TAP to 29616 20UN CTY	1	138	211-220	211-220
327	outage of 26982 11BEATTY to 29215 20BEATTY	1	69	211-220	211-220
330	outage of 27082 11E BERN to 29300 20EBRNST	1	69	211-220	211-220
332	outage of 27110 11FARLEY to 29536 20SCORBN	1	69	211-220	211-220
335	outage of 27117 11FAWKES to 29280 20CROOKJ	1	69	211-220	211-220

No.	Contingency	Ckt	Base kV	Area	Zone
337	outage of 27178 11HOPEWL to 29410 20LAURLC	1	69	211-220	211-220
340	outage of 29201 20AVON to 29202 20AVON	1	345-138	220	220
342	outage of 29201 20AVON to 29573 20SPURLK	1	345	220	220
345	outage of 29201 20AVON to 29651 20KPE345	1	345	220	220
350	outage of 29573 20SPURLK to 29575 20SPURLK	2	345-138	220	220
352	outage of 29575 20SPURLK to 29573 20SPURLK	1	138-345	220	220
355	outage of 29651 20KPE345 to 29652 20KPE138	1	345-138	220	220
357	outage of 29213 20BTYVL to 29215 20BEATTY	1	161-69	220	220
360	outage of 29213 20BTYVL to 29507 20POWELL	1	161	220	220
362	outage of 29271 20COOPER to 29272 20COOPER	1	161-69	220	220
370	outage of 29271 20COOPER to 29292 20DENNY	1	161	220	220
372	outage of 29271 20COOPER to 29411 20LAURLD	1	161	220	220
375	outage of 29271 20COOPER to 29517 20PULASJ	1	161	220	220
377	outage of 29271 20COOPER to 29540 20S OAKH	1	161	220	220
380	outage of 29292 20DENNY to 29293 20DENNY	1	161-69	220	220
382	outage of 29308 20FALLRK to 29310 20FALLRK	1	161-69	220	220
385	outage of 29308 20FALLRK to 29613 20TYNER	1	161	220	220
387	outage of 29346 20GRNHLJ to 29613 20TYNER	1	161	220	220
390	outage of 29408 20LAURLC to 29410 20LAURLC	1	161-69	220	220
392	outage of 29408 20LAURLC to 29411 20LAURLD	1	161	220	220
395	outage of 29408 20LAURLC to 29503 20PITTSB	1	161	220	220
400	outage of 29418 20LIBERT to 29517 20PULASJ	1	161	220	220
402	outage of 29503 20PITTSB to 29613 20TYNER	1	161	220	220
405	outage of 29507 20POWELL to 29508 20POWELL	1	161-138	220	220
407	outage of 29515 20PULASK to 29517 20PULASJ	1	161	220	220
410	outage of 29528 20RUSSEL to 29540 20S OAKH	1	161	220	220
412	outage of 29613 20TYNER to 29615 20TYNER	1	161-69	220	220
415	outage of 29202 20AVON to 29230 20BOONST	1	138	220	220
417	outage of 29202 20AVON to 29313 20FAYETT	1	138	220	220
420	outage of 29202 20AVON to 29490 20PARISJ	1	138	220	220
422	outage of 29230 20BOONST to 29233 20BOONSB	1	138	220	220
425	outage of 29230 20BOONST to 29282 20DALE	1	138	220	220
430	outage of 29282 20DALE to 29397 20JKSMIT	1	138	220	220
432	outage of 29282 20DALE to 29603 20TFJ	1	138	220	220
435	outage of 29283 20DALE to 29282 20DALE	1	69-138	220	220
437	outage of 29312 20FAWKES to 29397 20JKSMIT	1	138	220	220
440	outage of 29312 20FAWKES to 29603 20TFJ	1	138	220	220
442	outage of 29312 20FAWKES to 29623 20WBBEREA	1	138	220	220
445	outage of 29313 20FAYETT to 29315 20FAYETT	1	138-69	220	220
447	outage of 29375 20JACKVJ to 29490 20PARISJ	1	138	220	220
462	outage of 29397 20JKSMIT to 29508 20POWELL	1	138	220	220
465	outage of 29397 20JKSMIT to 29616 20UN CTY	1	138	220	220
467	outage of 29397 20JKSMIT to 29652 20KPE138	1	138	220	220
470	outage of 29397 20JKSMIT to 29652 20KPE138	2	138	220	220
472	outage of 29488 20PARIS to 29490 20PARISJ	1	138	220	220

No.	Contingency	Ckt	Base kV	Area	Zone
475	outage of 29508 20POWELL to 29510 20POWELL	1	138-69	220	220
477	outage of 29623 20WBBEREA to 29625 20WBBEREA	1	138-69	220	220
480	outage of 29195 20ALCAN to 29512 20PPG J	1	69	220	220
482	outage of 29195 20ALCAN to 29625 20WBBEREA	1	69	220	220
485	outage of 29196 20ANNVLJ to 29615 20TYNER	1	69	220	220
487	outage of 29205 20BALLRD to 29237 20BOURNE	1	69	220	220
490	outage of 29212 20BTYV D to 29215 20BEATTY	1	69	220	220
492	outage of 29215 20BEATTY to 29648 20ZACHAR	1	69	220	220
495	outage of 29222 20BLEV T to 29361 20HOPE	1	69	220	220
497	outage of 29237 20BOURNE to 29470 20NEWBY2	1	69	220	220
500	outage of 29238 20BOWEN to 29355 20HIGHHRK	1	69	220	220
502	outage of 29238 20BOWEN to 29510 20POWELL	1	69	220	220
505	outage of 29243 20BRONSJ to 29272 20COOPER	1	69	220	220
507	outage of 29260 20CLAYCJ to 29347 20HARGTJ	1	69	220	220
510	outage of 29260 20CLAYCJ to 29580 20STANTN	1	69	220	220
512	outage of 29272 20COOPER to 29566 20SOMERS	1	69	220	220
515	outage of 29272 20COOPER to 29566 20SOMERS	2	69	220	220
517	outage of 29280 20CROOKJ to 29352 20HICK P	1	69	220	220
527	outage of 29283 20DALE to 29366 20HUNT1	1	69	220	220
530	outage of 29283 20DALE to 29367 20HUNT2	1	69	220	220
532	outage of 29283 20DALE to 29468 20NEWBY1	1	69	220	220
535	outage of 29283 20DALE to 29470 20NEWBY2	1	69	220	220
537	outage of 29325 20FRNCHB to 29361 20HOPE	1	69	220	220
540	outage of 29327 20GARRCO to 29406 20LNCSTR	1	69	220	220
542	outage of 29352 20HICK P to 29511 20PPG	1	69	220	220
545	outage of 29355 20HIGHHRK to 29547 20SANDLK	1	69	220	220
547	outage of 29361 20HOPE to 29377 20JEFFVL	1	69	220	220
550	outage of 29366 20HUNT1 to 29556 20SIDEV	1	69	220	220
552	outage of 29367 20HUNT2 to 29398 20JKSMIT	1	69	220	220
555	outage of 29377 20JEFFVL to 29510 20POWELL	1	69	220	220
557	outage of 29398 20JKSMIT to 29607 20TRAPP	1	69	220	220
560	outage of 29401 20KEAVY to 29403 20KEAVJ2	1	69	220	220
562	outage of 29402 20KEAVJ1 to 29410 20LAURLC	1	69	220	220
565	outage of 29402 20KEAVJ1 to 29501 20PINEGJ	1	69	220	220
567	outage of 29403 20KEAVJ2 to 29410 20LAURLC	1	69	220	220
570	outage of 29403 20KEAVJ2 to 29536 20SCORBN	1	69	220	220
572	outage of 29406 20LNCSTR to 29468 20NEWBY1	1	69	220	220
575	outage of 29446 20MCKEE to 29615 20TYNER	1	69	220	220
577	outage of 29501 20PINEGJ to 29631 20W LOND	1	69	220	220
580	outage of 29510 20POWELL to 29580 20STANTN	1	69	220	220
582	outage of 29511 20PPG to 29512 20PPG J	1	69	220	220
585	outage of 29537 20S FORK to 29615 20TYNER	1	69	220	220
587	outage of 29605 20THLNKJ to 29626 20WBER J	1	69	220	220
590	outage of 29625 20WBBEREA to 29626 20WBER J	1	69	220	220
592	outage of 29503 20PITTSB to 27314 11PITTSB	1	161-69	220-211	220-211

No.	Contingency	Ckt	Base kV	Area	Zone
595	outage of 29233 20BOONSB to 26999 11BOONSB	1	138-69	220-211	220-211
597	outage of 29397 20JKSMIT to 27382 11SPENC	1	138	220-211	220-211
602	outage of 26648 09STUART to 29573 20SPURLK	1	345	209-220	209-220
605	outage of 26367 08ZIMER to 29573 20SPURLK	1	345	208-220	280-220
607	outage of 27197 11KENTON to 29575 20SPURLK	1	138	211-220	211-220
610	outage of 29372 20INLAND to 29575 20SPURLK	1	138	220	220
612	outage of 29440 20MAYSJV to 29575 20SPURLK	1	138	220	220
615	outage of 29521 20RENAKR to 29575 20SPURLK	1	138	220	220
617	outage of 29575 20SPURLK to 29585 20S PARK	1	138	220	220

Case 310s04

Case Summary

case310s04

Project Name 2002 SERIES, NERC/MMWG BASE CASE LIBRARY
Title1 2004 Summer - CT4&5 & Gilbert
Title2 External Dispatch and Gilbert/268MW
Case Date 2/12/2003

Power Flow File M:\PROJKypsc\267003\300_Calculations\301_PFlow_Results\case310s04.cft

Power Flow Controls

<i>Area Control</i>	<input type="checkbox"/>	<i>SmoothStep</i>	<input checked="" type="checkbox"/>
<i>Remote Control</i>	<input checked="" type="checkbox"/>	<i>XfrmVcon</i>	<input type="checkbox"/>
<i>GenVar Control</i>	<input checked="" type="checkbox"/>	<i>XfrmFcon</i>	<input type="checkbox"/>
<i>Solve Method</i>	NSOLVE		

Case Settings

<i>Overload</i>	<input checked="" type="checkbox"/>	<i>VlimMin</i>	0.9	<i>RateFactor</i>	1
<i>VLimit</i>	<input checked="" type="checkbox"/>	<i>VlimMax</i>	1.05	<i>AmpFactor</i>	1
<i>VChange</i>	<input checked="" type="checkbox"/>	<i>VlimChange</i>	0.05	<i>RatingNumber</i>	2
<i>Monitored Set</i>	monitor		321 Buses		

Contingency

<i>Contingencies loaded from file M:\PROJKypsc\267003\300_Calculations\301_PFlow_Results\Case300s</i>	
230 contingencies	

Area	Area Name	Zone	Zone Name	Contingency Buses	Monitored Buses
147	TVA	167	TVA_EAST	0	1
				0	1
205	AEP	254	AEP-KP	0	1
				0	1
208	CIN	280	CGE	1	4
		286	CGE GENS	0	2
				1	6
209	DPL	209	DPL	1	5
				1	5
211	LGEE	211	LGEE	109	166
				109	166
220	EKPC	220	EKPC	92	142
				92	142
				203	321

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Gilbert

External Dispatch and Gilbert/268MW

2/12/2003

Area	Name		Scheduled		Load MW	Loss MW	Shunt MW	Generation MW	Slack Bus Generator		
			Export MW	Mis- Match					Bus	Name	Slack MW
142	DUK	Ref.	-282	0	20140	462.8	14	20335	11096	COWANS	53
		New	-326	0	20140	461.1	14	20289			51
		Chg.	-44	0	0	-1.7	0	-46			-2
146	SOCO	Ref.	1302	0	46262	901.9	38	48503	15100	1GASTON	861
		New	1257	0	46262	904.9	38	48461			863
		Chg.	-45	0	0	3.0	0	-42			2
205	AEP	Ref.	-854	0	23573	666.5	0	23386	22987	05SPORN	500
		New	-899	0	23573	669.8	0	23344			502
		Chg.	-45	0	0	3.3	0	-42			2
208	CIN	Ref.	283	0	11900	380.6	0	12564	25895	08BCKJD	187
		New	239	0	11900	380.0	0	12519			186
		Chg.	-44	0	0	-0.6	0	-45			-1
220	EKPC	Ref.	-112	-268	1948	74.9	0	2179	29569	20SPLK2	527
		New	156	0	1948	78.7	0	2183			531
		Chg.	268	268	0	3.8	0	4			4
356	AMRN	Ref.	-911	0	11769	217.5	15	11091	31400	OSAGE	166
		New	-956	0	11769	216.4	15	11045			164
		Chg.	-45	0	0	-1.1	0	-46			-2
401	FPL	Ref.	-4613	0	20770	514.6	0	16672	40363	CAPECA	401
		New	-4658	0	20770	517.3	0	16630			402
		Chg.	-45	0	0	2.7	0	-42			2

Reference Case : M:\PROJ\Kypsc\267003\300_Calculations\301_PFlow_Results\case3

Transfer Case (New): M:\PROJ\Kypsc\267003\300_Calculations\301_PFlow_Results\Cas

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Gilbert

External Dispatch and Gilbert/268MW

2/12/2003

<u>Overloaded Facility</u>										<u>Normal System Overloads</u>		
From	Name	To	Name	Circuit	Base kV	Area	Zone	Ratings		MVA	Norm (%)	Emer (%)
								Norm	Emer			
27347	11RODBRN	27348	11RODBRN	1	138-69	211	211	33	40	34	103	85

Notes:

1. Overloads are based on 100% of Rating 1
2. Normal System Conditions - No Outages
3. Minimum Reporting Level is 100%

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Gilbert

External Dispatch and Gilbert/268MW

2/12/2003

Overloaded Facility								Normal System				Overloads	
From	Name	To	Name	Circuit	Base kV	Area	Zone	Ratings		MVA	Norm (%)	Count	Max (%)
								Norm	Emer			A / B	
27117	11FAWKES	27339	11RICH S	1	69	211	211	72	72	45.8	64	1 / 2	140
27347	11RODBRN	27348	11RODBRN	1	138-69	211	211	33	40	34.0	103	3 / 0	139
26986	11BEREA	27221	11LK REB	1	69	211	211	72	72	51.3	71	1 / 1	139
27117	11FAWKES	27272	11N.MADS	1	69	211	211	56	56	19.5	35	1 / 0	129
27037	11CLARK	27397	11SYLVAN	1	69	211	211	73	90	47.1	65	2 / 1	112
27194	11KENTON	29575	20SPURLK	2	138	211-220	211-220	227	280	165.5	73	1 / 0	112
27221	11LK REB	27340	11RICHMO	1	69	211	211	56	56	15.5	28	1 / 0	109
27113	11FARMER	27264	11MORH W	1	69	211	211	48	48	28.9	60	1 / 0	109
26959	11AOSMTH	27383	11SPENC	1	69	211	211	48	59	46.6	97	2 / 2	106
27115	11FAWK T	27231	11LR TAP	1	138	211	211	163	163	50.9	31	0 / 2	104
27112	11FARMER	27113	11FARMER	1	138-69	211	211	40	48	30.0	75	0 / 1	104
27229	11LOUDON	27228	11LOUD B	1	138-69	211	211	112	129	88.0	79	0 / 1	102
27116	11FAWKES	27117	11FAWKES	1	138-69	211	211	143	171	111.0	78	0 / 2	102
29203	20BKR LN	29360	20HOLLWJ	1	69	220	220	57	69	11.5	20	0 / 2	101
27220	11LK REB	27231	11LR TAP	1	138	211	211	149	171	110.4	74	0 / 1	100
												13 / 15	140

Notes:

- Overloads are based on 100% of Rating 2
- NS = Normal System Conditions (No Outages)
- Minimum Reporting Level is 100%
- Statistical Information (A/B Stats and Maximum Overload)
 - A = Serious Overload > 105%
 - B = Overloaded Facility between 100% and 105% of Rated Capability

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Gilbert

External Dispatch and Gilbert/268MW

2/12/2003

Undervoltage		Base kV	Area	Zone	Normal System Voltage (pu)	Voltage Violations	
Bus	Name					A / B	Min (pu)
27449	11WIL D2	69	211	211	1.0009	1 / 0	0.8413
29212	20BTYV D	69	220	220	0.9892	1 / 0	0.8438
29478	20OAKD J	69	220	220	0.9818	1 / 0	0.8535
29232	20BOONVJ	69	220	220	0.9791	1 / 0	0.8650
29313	20FAYETT	138	220	220	0.9956	1 / 0	0.8694
27210	11LEBN I	69	211	211	0.9786	1 / 0	0.8703
29468	20NEWBY1	69	220	220	1.0050	1 / 0	0.8770
29315	20FAYETT	69	220	220	1.0093	0 / 2	0.8917
29537	20S FORK	69	220	220	0.9798	0 / 1	0.8918
29406	20LNCSTR	69	220	220	0.9932	0 / 1	0.8930
29327	20GARRCO	69	220	220	0.9908	0 / 1	0.8938
29205	20BALLRD	69	220	220	0.9740	0 / 2	0.8978
29237	20BOURNE	69	220	220	0.9846	0 / 1	0.8987
29596	20TGOOCH	69	220	220	0.9779	0 / 1	0.8988
27067	11DANVIL	138	211	211	0.9942	0 / 1	0.8992
						7 / 10	0.8413

Notes:

1. Minimum Voltage Limit 0.90 (pu)
2. NS = Normal System Conditions (No Outages)
3. Maximum Reporting Level is 90%
4. Statistical Information (A/B Stats and Minimum Voltage)
 - A = Serious Undervoltage < 0.88 (pu)
 - B = Low Voltages between 0.88 and 0.90 (pu)

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Gilbert

External Dispatch and Gilbert/268MW

2/12/2003

Overvoltage					Normal System	Voltage Violations	
Bus Name	Base kV	Area	Zone	Voltage (pu)	A / B Max (pu)		
29406 20LNCSTR	69	220	220	0.9932	0 / 1	1.0531	
29540 20S OAKH	161	220	220	1.0341	0 / 1	1.0512	
Notes:					0 / 2	1.0531	
1. Maximum Voltage Limit is 1.05 (pu)							
2. NS = Normal System Conditions (No Outages)							
3. Minimum Reporting Level for Over Voltages is 105%							
4. Statistical Information (A/B Stats and Maximum Voltage)							
A = Serious Overvoltage > 1.07 (pu)							
B = High Voltages between 1.05 and 1.07 (pu)							

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Gilbert

External Dispatch and Gilbert/268MW

2/12/2003

VChange Bus Name	Base kV	Area	Zone	Normal System Voltage (pu)	Voltage Violations	
					A / B	Max (pu)
27449 11WIL D2	69	211	211	1.0009	1 / 0	-0.1596
29212 20BTYV D	69	220	220	0.9892	1 / 0	-0.1454
29478 20OAKD J	69	220	220	0.9818	1 / 0	-0.1283
29468 20NEWBY1	69	220	220	1.0050	1 / 0	-0.1280
29313 20FAYETT	138	220	220	0.9956	1 / 0	-0.1262
29315 20FAYETT	69	220	220	1.0093	2 / 0	-0.1176
29232 20BOONVJ	69	220	220	0.9791	1 / 0	-0.1141
27016 11BUENA	69	211	211	1.0261	1 / 0	-0.1107
27210 11LEBN I	69	211	211	0.9786	1 / 0	-0.1083
29470 20NEWBY2	69	220	220	1.0077	1 / 0	-0.1068
27076 11DIXDAM	69	211	211	1.0369	1 / 0	-0.1040
29406 20LNCSTR	69	220	220	0.9932	1 / 0	-0.1002
29327 20GARRCO	69	220	220	0.9908	1 / 0	-0.0970
27067 11DANVIL	138	211	211	0.9942	1 / 0	-0.0950
27016 11BUENA	69	211	211	1.0261	1 / 0	-0.0941
29291 20DAVIS	69	220	220	0.9966	1 / 0	-0.0938
29291 20DAVIS	69	220	220	0.9966	1 / 0	-0.0937
27136 11GARRD	69	211	211	1.0078	1 / 0	-0.0902
29537 20S FORK	69	220	220	0.9798	1 / 0	-0.0880
29237 20BOURNE	69	220	220	0.9846	1 / 0	-0.0859
29237 20BOURNE	69	220	220	0.9846	1 / 0	-0.0840
29233 20BOONSB	138	220	220	1.0181	1 / 0	-0.0830
29596 20GOOCH	69	220	220	0.9779	1 / 0	-0.0791
27068 11DANVIL	69	211	211	1.0004	2 / 0	-0.0781
29580 20STANTN	69	220	220	0.9961	1 / 0	-0.0763
29205 20BALLRD	69	220	220	0.9740	1 / 0	-0.0762
27136 11GARRD	69	211	211	1.0078	1 / 0	-0.0755
29205 20BALLRD	69	220	220	0.9740	1 / 0	-0.0754
26972 11ATOKA	69	211	211	0.9990	2 / 0	-0.0745
29205 20BALLRD	69	220	220	0.9740	1 / 0	-0.0737
26999 11BOONSB	69	211	211	1.0327	2 / 0	-0.0736
27450 11WILMOR	69	211	211	1.0084	1 / 0	-0.0731
27000 11BOYLE	69	211	211	0.9983	2 / 0	-0.0725
27220 11LK REB	138	211	211	1.0005	0 / 1	-0.0671
27065 11DANV 1	69	211	211	0.9978	0 / 2	-0.0669
29325 20FRNCHB	69	220	220	0.9777	0 / 1	-0.0664
29411 20LAURLD	161	220	220	1.0038	0 / 1	-0.0663
27167 11HARR T	69	211	211	1.0082	0 / 1	-0.0662
27168 11HARRDS	69	211	211	1.0082	0 / 1	-0.0662
27450 11WILMOR	69	211	211	1.0084	0 / 1	-0.0656
29407 20LAURHY	13.8	220	220	0.9848	0 / 1	-0.0650
29436 20MARIBJ	69	220	220	0.9792	0 / 1	-0.0650
29203 20BKR LN	69	220	220	0.9873	0 / 1	-0.0640
29260 20CLAYCJ	69	220	220	0.9942	0 / 1	-0.0639
27247 11MERCRCR	138	211	211	1.0073	0 / 1	-0.0637
29623 20WBBEREA	138	220	220	1.0009	0 / 1	-0.0637
29327 20GARRCO	69	220	220	0.9908	0 / 1	-0.0630
27055 11CRAB O	69	211	211	0.9880	0 / 1	-0.0626
29368 20HUNTFJ	69	220	220	0.9681	0 / 1	-0.0606
29368 20HUNTFJ	69	220	220	0.9681	0 / 1	-0.0599
29347 20HARGTJ	69	220	220	0.9964	0 / 1	-0.0589
29515 20PULASK	161	220	220	1.0138	0 / 1	-0.0589
29368 20HUNTFJ	69	220	220	0.9681	0 / 1	-0.0586

VChange Bus Name	Base kV	Area	Zone	Normal System Voltage (pu)	Voltage Violations	
					A / B	Max (pu)
29625 20WBEREA	69	220	220	0.9955	0 / 1	-0.0583
29625 20WBEREA	69	220	220	0.9955	0 / 1	-0.0581
29360 20HOLLWJ	69	220	220	0.9840	0 / 1	-0.0579
29510 20POWELL	69	220	220	0.9964	0 / 1	-0.0567
29580 20STANTN	69	220	220	0.9961	0 / 1	-0.0565
29626 20WBER J	69	220	220	0.9953	0 / 1	-0.0564
29626 20WBER J	69	220	220	0.9953	0 / 1	-0.0562
27067 11DANVIL	138	211	211	0.9942	0 / 1	-0.0557
29195 20ALCAN	69	220	220	0.9931	0 / 1	-0.0555
29195 20ALCAN	69	220	220	0.9931	0 / 1	-0.0553
26959 11AOSMTH	69	211	211	1.0167	0 / 1	-0.0546
26986 11BEREA	69	211	211	0.9939	0 / 1	-0.0543
29512 20PPG J	69	220	220	0.9925	0 / 1	-0.0538
29511 20PPG	69	220	220	0.9925	0 / 1	-0.0536
29512 20PPG J	69	220	220	0.9925	0 / 1	-0.0536
29511 20PPG	69	220	220	0.9925	0 / 1	-0.0534
27221 11LK REB	69	211	211	1.0102	0 / 2	-0.0527
27339 11RICH S	69	211	211	0.9992	0 / 1	-0.0527
29408 20LAURLC	161	220	220	0.9875	0 / 1	-0.0522
27368 11SHAKRT	69	211	211	1.0282	0 / 1	-0.0521
29605 20THLNKJ	69	220	220	0.9954	0 / 1	-0.0520
29605 20THLNKJ	69	220	220	0.9954	0 / 1	-0.0519
29288 20DALE4	13.8	220	220	1.0442	0 / 1	-0.0517
27055 11CRAB O	69	211	211	0.9880	0 / 1	-0.0514
29516 20PULASK	69	220	220	1.0058	0 / 1	-0.0509
29440 20MAYSVJ	138	220	220	1.0240	0 / 1	-0.0505
29408 20LAURLC	161	220	220	0.9875	0 / 1	-0.0503
29488 20PARIS	138	220	220	0.9927	0 / 1	-0.0503
29238 20BOWEN	69	220	220	0.9974	0 / 1	-0.0502
29596 20TGOOCH	69	220	220	0.9779	0 / 1	-0.0502
27272 11N.MADS	69	211	211	1.0054	0 / 1	-0.0501
29237 20BOURNE	69	220	220	0.9846	0 / 1	0.0507
29406 20LNCSTR	69	220	220	0.9932	0 / 1	0.0599

38 / 55 -0.1596

Notes:

1. Voltage Change Limit is 0.05 (pu)
2. NS = Normal System Conditions (No Outages)
3. Minimum Reporting Level is 5%
4. Statistical Information (A/B Stats and Maximum Voltage Change)
 - A = Serious Voltage Change > 0.07 (pu)
 - B = Excessive Voltage Change between 0.05 and 0.07 (pu)

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Gilbert

External Dispatch and Gilbert/268MW

2/12/2003

Contingency	Overloaded Facility								Overloads		
	From Name	To Name	Ckt	Base kV	Area	Zone	Norm	Emer	MVA	Norm (%)	Emer (%)
95	outage of 27036 11CLARK to 27037 11CLARK		1	138-69	211	211					
	26959 11AOSMTH	27383 11SPENC	1	69	211	211	48	59	61.5	128	104
110	outage of 27111 11FARM T to 27112 11FARMER		1	138	211	211					
	27347 11RODBRN	27348 11RODBRN	1	138-69	211	211	33	40	48.8	148	122
117	outage of 27112 11FARMER to 27113 11FARMER		1	138-69	211	211					
	27347 11RODBRN	27348 11RODBRN	1	138-69	211	211	33	40	48.8	148	122
125	outage of 27116 11FAWKES to 27117 11FAWKES		1	138-69	211	211					
	27221 11LK REB	27340 11RICHMO	1	69	211	211	56	56	61.2	109	109
	26986 11BEREA	27221 11LK REB	1	69	211	211	72	72	75.0	104	104
	27220 11LK REB	27231 11LR TAP	1	138	211	211	149	171	171.4	115	100
132	outage of 27172 11HIGBY to 27170 11HIGB A		1	138-69	211	211					
	26956 NONAME	27304 11PICADO	1	69	211	211	95	95	97.1	102	102
157	outage of 27220 11LK REB to 27221 11LK REB		1	138-69	211	211					
	27117 11FAWKES	27339 11RICH S	1	69	211	211	72	72	75.4	105	105
	27116 11FAWKES	27117 11FAWKES	1	138-69	211	211	143	171	173.7	121	102
160	outage of 27220 11LK REB to 27231 11LR TAP		1	138	211	211					
	27117 11FAWKES	27339 11RICH S	1	69	211	211	72	72	75.4	105	105
	27116 11FAWKES	27117 11FAWKES	1	138-69	211	211	143	171	173.7	121	102
162	outage of 27229 11LOUDON to 27227 11LOUD A		1	138-69	211	211					
	27229 11LOUDON	27228 11LOUD B	1	138-69	211	211	112	129	131.9	118	102
172	outage of 27347 11RODBRN to 27348 11RODBRN		1	138-69	211	211					
	27113 11FARMER	27264 11MORH W	1	69	211	211	48	48	52.4	109	109
	27112 11FARMER	27113 11FARMER	1	138-69	211	211	40	48	49.7	124	104
200	outage of 26986 11BEREA to 27221 11LK REB		1	69	211	211					
	27117 11FAWKES	27339 11RICH S	1	69	211	211	72	72	100.7	140	140
205	outage of 26999 11BOONSB to 27451 11WINC S		EQ	69	211	211					
	26959 11AOSMTH	27383 11SPENC	1	69	211	211	48	59	59.5	124	101
	27037 11CLARK	27397 11SYLVAN	1	69	211	211	73	90	90.5	124	101
242	outage of 27113 11FARMER to 27264 11MORH W		1	69	211	211					
	27347 11RODBRN	27348 11RODBRN	1	138-69	211	211	33	40	55.5	168	139
247	outage of 27117 11FAWKES to 27339 11RICH S		1	69	211	211					
	26986 11BEREA	27221 11LK REB	1	69	211	211	72	72	99.7	138	139
260	outage of 27170 11HIGB A to 27449 11WIL D2		1	69	211	211					
	27117 11FAWKES	27272 11N.MADS	1	69	211	211	56	56	72.0	129	129
322	outage of 27229 11LOUDON to 29202 20AVON		1	138	211-220	211-220					
	27075 NONAME	27300 11PARIS	1	69	211	211	56	56	63.7	114	114
325	outage of 27231 11LR TAP to 29616 20UN CTY		1	138	211-220	211-220					
	27115 11FAWK T	27231 11LR TAP	1	138	211	211	163	163	166.9	102	102
417	outage of 29202 20AVON to 29313 20FAYETT		1	138	220	220					
	29203 20BKR LN	29360 20HOLLWJ	1	69	220	220	57	69	69.8	122	101
422	outage of 29230 20BOONST to 29233 20BOONSB		1	138	220	220					
	27037 11CLARK	27397 11SYLVAN	1	69	211	211	73	90	100.7	138	112
	26959 11AOSMTH	27383 11SPENC	1	69	211	211	48	59	62.6	130	106
445	outage of 29313 20FAYETT to 29315 20FAYETT		1	138-69	220	220					
	29203 20BKR LN	29360 20HOLLWJ	1	69	220	220	57	69	69.8	122	101
465	outage of 29397 20JKSMIT to 29616 20UN CTY		1	138	220	220					
	27115 11FAWK T	27231 11LR TAP	1	138	211	211	163	163	169.1	104	104
595	outage of 29233 20BOONSB to 26999 11BOONSB		1	138-69	220-211	220-211					
	27037 11CLARK	27397 11SYLVAN	1	69	211	211	73	90	100.7	138	112
	26959 11AOSMTH	27383 11SPENC	1	69	211	211	48	59	62.6	130	106

Contingency	Overloaded Facility									Overloads		
	From Name	To Name	Ckt	Base kV	Area	Zone	Ratings		MVA	Norm (%)	Emer (%)	
							Norm	Emer				
607 outage of 27197 11KENTON to 29575 20SPURLK			1	138	211-220	211-220						
	27194 11KENTON	29575 20SPURLK	2	138	211-220	211-220	227	280	312.3	138	112	

Notes:

1. Overloads are based on 100% of Rating 2

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Gilbert

External Dispatch and Gilbert/268MW

2/12/2003

Overloaded Facility		Contingency								Overloads			
From	Name	To	Name	Circuit	Base kV	Area	Zone	Ratings		NS	MVA	Norm (%)	Emer (%)
								Norm	Emer				
27117	11FAWKES	27339	11RICH S	1	69	211	211	72	72	NS	46	64	64
	200 outage of 26986 11BEREA to 27221 11LK REB			1	69	211	211				101	140	140
	157 outage of 27220 11LK REB to 27221 11LK REB			1	138-69	211	211				75	105	105
	160 outage of 27220 11LK REB to 27231 11LR TAP			1	138	211	211				75	105	105
											1 / 2		140
27347	11RODBRN	27348	11RODBRN	1	138-69	211	211	33	40	NS	34	103	85
	242 outage of 27113 11FARMER to 27264 11MORH			1	69	211	211				55	168	139
	110 outage of 27111 11FARM T to 27112 11FARMER			1	138	211	211				49	148	122
	117 outage of 27112 11FARMER to 27113 11FARME			1	138-69	211	211				49	148	122
											3 / 0		139
26986	11BEREA	27221	11LK REB	1	69	211	211	72	72	NS	51	71	71
	247 outage of 27117 11FAWKES to 27339 11RICH S			1	69	211	211				100	138	139
	125 outage of 27116 11FAWKES to 27117 11FAWKE			1	138-69	211	211				75	104	104
											1 / 1		139
27117	11FAWKES	27272	11N.MADS	1	69	211	211	56	56	NS	19	35	35
	260 outage of 27170 11HIGB A to 27449 11WIL D2			1	69	211	211				72	129	129
											1 / 0		129
27037	11CLARK	27397	11SYLVAN	1	69	211	211	73	90	NS	47	65	52
	595 outage of 29233 20BOONSB to 26999 11BOONS			1	138-69	220-211	220-211				101	138	112
	422 outage of 29230 20BOONST to 29233 20BOONS			1	138	220	220				101	138	112
	205 outage of 26999 11BOONSB to 27451 11WINC S EQ				69	211	211				90	124	101
											2 / 1		112
27194	11KENTON	29575	20SPURLK	2	138	211-220	211-220	227	280	NS	165	73	59
	607 outage of 27197 11KENTON to 29575 20SPURLK			1	138	211-220	211-220				312	138	112
											1 / 0		112
27221	11LK REB	27340	11RICHMO	1	69	211	211	56	56	NS	15	28	28
	125 outage of 27116 11FAWKES to 27117 11FAWKE			1	138-69	211	211				61	109	109
											1 / 0		109
27113	11FARMER	27264	11MORH W	1	69	211	211	48	48	NS	29	60	60
	172 outage of 27347 11RODBRN to 27348 11RODBR			1	138-69	211	211				52	109	109
											1 / 0		109
26959	11AOSMTH	27383	11SPENC	1	69	211	211	48	59	NS	47	97	79
	422 outage of 29230 20BOONST to 29233 20BOONS			1	138	220	220				63	130	106
	595 outage of 29233 20BOONSB to 26999 11BOONS			1	138-69	220-211	220-211				63	130	106
	95 outage of 27036 11CLARK to 27037 11CLARK			1	138-69	211	211				61	128	104
	205 outage of 26999 11BOONSB to 27451 11WINC S EQ				69	211	211				59	124	101
											2 / 2		106

Overloaded Facility		Contingency								Overloads			
From	Name	To	Name	Circuit	Base kV	Area	Zone	Ratings		Norm	Emer	Emer	
								Norm	Emer				MVA
27115	11FAWK T	27231	11LR TAP	1	138	211	211	163	163	NS	51	31	31
	465	outage of 29397 20JKSMIT to 29616 20UN CTY		1	138	220	220				169	104	104
	325	outage of 27231 11LR TAP to 29616 20UN CTY		1	138	211-220	211-220				167	102	102
											0 / 2		104
27112	11FARMER	27113	11FARMER	1	138-69	211	211	40	48	NS	30	75	63
	172	outage of 27347 11RODBRN to 27348 11RODBR		1	138-69	211	211				50	124	104
											0 / 1		104
27229	11LOUDON	27228	11LOUD B	1	138-69	211	211	112	129	NS	88	79	68
	162	outage of 27229 11LOUDON to 27227 11LOUD A		1	138-69	211	211				132	118	102
											0 / 1		102
27116	11FAWKES	27117	11FAWKES	1	138-69	211	211	143	171	NS	111	78	65
	160	outage of 27220 11LK REB to 27231 11LR TAP		1	138	211	211				174	121	102
	157	outage of 27220 11LK REB to 27221 11LK REB		1	138-69	211	211				174	121	102
											0 / 2		102
29203	20BKR LN	29360	20HOLLWJ	1	69	220	220	57	69	NS	12	20	17
	445	outage of 29313 20FAYETT to 29315 20FAYETT		1	138-69	220	220				70	122	101
	417	outage of 29202 20AVON to 29313 20FAYETT		1	138	220	220				70	122	101
											0 / 2		101
27220	11LK REB	27231	11LR TAP	1	138	211	211	149	171	NS	110	74	65
	125	outage of 27116 11FAWKES to 27117 11FAWKE		1	138-69	211	211				171	115	100
											0 / 1		100
											13 / 15		139.8

Notes:

1. Overloads are based on 100% of Rating 2
2. NS = Normal System Conditions (No Outages)
3. Minimum Reporting Level is 100%
4. Statistical Information (A/B Stats and Maximum Overload)
 - A = Serious Overload > 105%
 - B = Overloaded Facility between 100% and 105% of Rated Capability

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Gilbert

External Dispatch and Gilbert/268MW

2/12/2003

Contingency

Description	Ckt	kV	Zone	Area	Over load	Voltage Violations			Not Solved
						UnderV	OverV	Change	
82 outage of 27010 11BRWN P to 27247 11MERCRCR	1	138	211	211	0	0	0	2	
95 outage of 27036 11CLARK to 27037 11CLARK	1	138-69	211	211	1	0	0	0	
105 outage of 27067 11DANVIL to 27068 11DANVIL	1	138-69	211	211	0	0	0	4	
107 outage of 27067 11DANVIL to 27247 11MERCRCR	1	138	211	211	0	1	0	5	
110 outage of 27111 11FARM T to 27112 11FARMER	1	138	211	211	1	0	0	0	
117 outage of 27112 11FARMER to 27113 11FARMER	1	138-69	211	211	1	0	0	0	
125 outage of 27116 11FAWKES to 27117 11FAWKES	1	138-69	211	211	3	0	0	0	
132 outage of 27172 11HIGBY to 27170 11HIGB A	1	138-69	211	211	1	0	0	0	
157 outage of 27220 11LK REB to 27221 11LK REB	1	138-69	211	211	2	0	0	1	
160 outage of 27220 11LK REB to 27231 11LR TAP	1	138	211	211	2	0	0	2	
162 outage of 27229 11LOUDON to 27227 11LOUD A	1	138-69	211	211	1	0	0	0	
172 outage of 27347 11RODBRN to 27348 11RODBRN	1	138-69	211	211	2	0	0	0	
195 outage of 26959 11AOSMTH to 27383 11SPENC	1	69	211	211	0	0	0	1	
200 outage of 26986 11BEREA to 27221 11LK REB	1	69	211	211	1	0	0	1	
205 outage of 26999 11BOONSB to 27451 11WINC S	EQ	69	211	211	2	0	0	0	
207 outage of 27016 11BUENA to 27076 11DIXDAM	1	69	211	211	0	0	0	3	
232 outage of 27076 11DIXDAM to 27436 11WC-DD	1	69	211	211	0	0	0	5	
235 outage of 27076 11DIXDAM to 27450 11WILMOR	1	69	211	211	0	0	0	1	
242 outage of 27113 11FARMER to 27264 11MORH W	1	69	211	211	1	0	0	0	
247 outage of 27117 11FAWKES to 27339 11RICH S	1	69	211	211	1	0	0	1	
255 outage of 27167 11HARR T to 27420 11W CLIF	1	69	211	211	0	0	0	2	
260 outage of 27170 11HIGB A to 27449 11WIL D2	1	69	211	211	1	1	0	2	
267 outage of 27210 11LEBN I to 27213 11LEBNON	1	69	211	211	0	1	0	1	
297 outage of 27368 11SHAKRT to 27420 11W CLIF	1	69	211	211	0	0	0	1	
312 outage of 26990 11BKR LN to 29203 20BKR LN	1	138-69	211-220	211-220	0	0	0	2	
322 outage of 27229 11LOUDON to 29202 20AVON	1	138	211-220	211-220	1	0	0	0	
325 outage of 27231 11LR TAP to 29616 20UN CTY	1	138	211-220	211-220	1	0	0	0	
372 outage of 29271 20COOPER to 29411 20LAURLD	1	161	220	220	0	0	0	3	
377 outage of 29271 20COOPER to 29540 20S OAKH	1	161	220	220	0	0	3	0	
392 outage of 29408 20LAURLC to 29411 20LAURLD	1	161	220	220	0	0	0	1	
407 outage of 29515 20PULASK to 29517 20PULASJ	1	161	220	220	0	0	0	2	
410 outage of 29528 20RUSSEL to 29540 20S OAKH	1	161	220	220	0	0	2	0	
417 outage of 29202 20AVON to 29313 20FAYETT	1	138	220	220	1	2	0	3	
422 outage of 29230 20BOONST to 29233 20BOONSB	1	138	220	220	2	0	0	2	
425 outage of 29230 20BOONST to 29282 20DALE	1	138	220	220	0	0	0	1	
442 outage of 29312 20FAWKES to 29623 20WBBEREA	1	138	220	220	0	0	0	7	
445 outage of 29313 20FAYETT to 29315 20FAYETT	1	138-69	220	220	1	1	0	2	
465 outage of 29397 20JKSMIT to 29616 20UN CTY	1	138	220	220	1	0	0	0	

Contingency

Description	Ckt	kV	Zone	Area	Over load	Voltage Violations			Not Solved
						UnderV	OverV	Change	
472 outage of 29488 20PARIS to 29490 20PARISJ	1	138	220	220	0	0	0	1	
475 outage of 29508 20POWELL to 29510 20POWELL	1	138-69	220	220	0	0	0	3	
477 outage of 29623 20WBBEREA to 29625 20WBBERE	1	138-69	220	220	0	0	0	6	
487 outage of 29205 20BALLRD to 29237 20BOURNE	1	69	220	220	0	1	0	3	
490 outage of 29212 20BTYV D to 29215 20BEATTY	1	69	220	220	0	4	0	4	
497 outage of 29237 20BOURNE to 29470 20NEWBY2	1	69	220	220	0	2	0	3	
532 outage of 29283 20DALE to 29468 20NEWBY1	1	69	220	220	0	4	0	4	
535 outage of 29283 20DALE to 29470 20NEWBY2	1	69	220	220	0	0	0	4	
537 outage of 29325 20FRNCHB to 29361 20HOPE	1	69	220	220	0	0	0	2	
540 outage of 29327 20GARRCO to 29406 20LNCSTR	1	69	220	220	0	0	1	3	
580 outage of 29510 20POWELL to 29580 20STANTN	1	69	220	220	0	0	0	3	
595 outage of 29233 20BOONSB to 26999 11BOONSB	1	138-69	220-211	220-211	2	0	0	1	
607 outage of 27197 11KENTON to 29575 20SPURLK	1	138	211-220	211-220	1	0	0	0	
612 outage of 29440 20MAYSJV to 29575 20SPURLK	1	138	220	220	0	0	0	1	
Totals:					30	17	6	93	0

Notes:

1. Overloads are based on 100% of Rating 2
2. Undervoltage Limit is 0.90 (pu)
3. Overvoltage Limit is 1.05 (pu)
4. Voltage Change Limit is 0.05 (pu)

Not Solved Codes:

- D - Diverged
- I - Interrupted
- F - Failed, One or More Contingency
Commands Failed in PFlow

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Gilbert

External Dispatch and Gilbert/268MW

2/12/2003

No.	Contingency	Ckt	Base kV	Area	Zone
10	outage of 26950 11ALCALD to 27008 11BRWN N	1	345	211	211
12	outage of 27008 11BRWN N to 27009 11BRWN N	1	345-138	211	211
15	outage of 27008 11BRWN N to 27162 11HARDN	1	345	211	211
17	outage of 27008 11BRWN N to 27427 11W LEXN	1	345	211	211
20	outage of 26951 11ALCALD to 27095 11ELIHU	1	161	211	211
22	outage of 26962 11ARNOLD to 27074 11DELVIN	1	161	211	211
25	outage of 27074 11DELVIN to 27444 11WI TAP	1	161	211	211
27	outage of 27095 11ELIHU to 27096 11ELIHU	1	161-69	211	211
30	outage of 27095 11ELIHU to 27096 11ELIHU	2	161-69	211	211
32	outage of 27230 11LR TAP to 27231 11LR TAP	1	161-138	211	211
35	outage of 27230 11LR TAP to 27444 11WI TAP	1	161	211	211
37	outage of 27425 11W IRVI to 27444 11WI TAP	1	161	211	211
40	outage of 26947 11ADAMS to 27412 11TYRONE	1	138	211	211
42	outage of 26977 11BARDST to 26978 11BARDST	1	138-69	211	211
45	outage of 26977 11BARDST to 27011 11BRWNCT	1	138	211	211
47	outage of 26977 11BARDST to 27276 11NELSON	1	138	211	211
50	outage of 26990 11BKR LN to 27009 11BRWN N	1	138	211	211
52	outage of 26990 11BKR LN to 27172 11HIGBY	1	138	211	211
55	outage of 26998 11BONNIE to 27211 11LEBN W	1	138	211	211
57	outage of 27009 11BRWN N to 27011 11BRWNCT	1	138	211	211
60	outage of 27009 11BRWN N to 27012 11BRWNT1	1	138	211	211
62	outage of 27009 11BRWN N to 27013 11BRWNT2	1	138	211	211
65	outage of 27009 11BRWN N to 27040 11CLAYSM	1	138	211	211
67	outage of 27009 11BRWN N to 27172 11HIGBY	1	138	211	211
70	outage of 27009 11BRWN N to 27312 11PISGAH	1	138	211	211
72	outage of 27009 11BRWN N to 27412 11TYRONE	1	138	211	211
75	outage of 27010 11BRWN P to 27012 11BRWNT1	1	138	211	211
77	outage of 27010 11BRWN P to 27013 11BRWNT2	1	138	211	211
80	outage of 27010 11BRWN P to 27116 11FAWKES	1	138	211	211
82	outage of 27010 11BRWN P to 27247 11MERCRCR	1	138	211	211
85	outage of 27010 11BRWN P to 27419 11W CLIF	1	138	211	211
87	outage of 27010 11BRWN P to 27419 11W CLIF	2	138	211	211
90	outage of 27011 11BRWNCT to 27012 11BRWNT1	1	138	211	211
92	outage of 27011 11BRWNCT to 27013 11BRWNT2	1	138	211	211
95	outage of 27036 11CLARK to 27037 11CLARK	1	138-69	211	211
97	outage of 27036 11CLARK to 27116 11FAWKES	1	138	211	211
100	outage of 27036 11CLARK to 27382 11SPENC	1	138	211	211
102	outage of 27040 11CLAYSM to 27172 11HIGBY	1	138	211	211
105	outage of 27067 11DANVIL to 27068 11DANVIL	1	138-69	211	211
107	outage of 27067 11DANVIL to 27247 11MERCRCR	1	138	211	211
110	outage of 27111 11FARM T to 27112 11FARMER	1	138	211	211

No.	Contingency	Ckt	Base kV	Area	Zone
112	outage of 27111 11FARM T to 27369 11SHARKE	1	138	211	211
115	outage of 27111 11FARM T to 27382 11SPENC	1	138	211	211
117	outage of 27112 11FARMER to 27113 11FARMER	1	138-69	211	211
120	outage of 27115 11FAWK T to 27116 11FAWKES	1	138	211	211
122	outage of 27115 11FAWK T to 27231 11LR TAP	1	138	211	211
125	outage of 27116 11FAWKES to 27117 11FAWKES	1	138-69	211	211
127	outage of 27122 11FFRT E to 27412 11TYRONE	1	138	211	211
130	outage of 27141 11GODDRD to 27347 11RODBRN	1	138	211	211
132	outage of 27172 11HIGBY to 27170 11HIGB A	1	138-69	211	211
135	outage of 27172 11HIGBY to 27171 11HIGB B	1	138-69	211	211
137	outage of 27172 11HIGBY to 27207 11LANSDW	1	138	211	211
140	outage of 27172 11HIGBY to 27337 11REYNOL	1	138	211	211
142	outage of 27186 11IBM N to 27229 11LOUDON	1	138	211	211
145	outage of 27211 11LEBN W to 27212 11LEBNON	1	138	211	211
147	outage of 27212 11LEBNON to 27213 11LEBNON	1	138-69	211	211
150	outage of 27212 11LEBNON to 27213 11LEBNON	2	138-69	211	211
152	outage of 27212 11LEBNON to 27243 11MARION	1	138	211	211
155	outage of 27212 11LEBNON to 27247 11MERCRCR	1	138	211	211
157	outage of 27220 11LK REB to 27221 11LK REB	1	138-69	211	211
160	outage of 27220 11LK REB to 27231 11LR TAP	1	138	211	211
162	outage of 27229 11LOUDON to 27227 11LOUD A	1	138-69	211	211
165	outage of 27229 11LOUDON to 27228 11LOUD B	1	138-69	211	211
167	outage of 27312 11PISGAH to 27313 11PISGAH	1	138-69	211	211
170	outage of 27312 11PISGAH to 27428 11W LEXN	1	138	211	211
172	outage of 27347 11RODBRN to 27348 11RODBRN	1	138-69	211	211
175	outage of 27347 11RODBRN to 27369 11SHARKE	1	138	211	211
177	outage of 27382 11SPENC to 27383 11SPENC	1	138-69	211	211
180	outage of 27382 11SPENC to 27383 11SPENC	2	138-69	211	211
182	outage of 27412 11TYRONE to 27413 11TYRONE	1	138-69	211	211
185	outage of 27419 11W CLIF to 27420 11W CLIF	1	138-69	211	211
187	outage of 27419 11W CLIF to 27420 11W CLIF	2	138-69	211	211
190	outage of 27419 11W CLIF to 27436 11WC-DD	1	138-69	211	211
192	outage of 26959 11AOSMTH to 27129 11FOGG P	EQ	69	211	211
195	outage of 26959 11AOSMTH to 27383 11SPENC	1	69	211	211
197	outage of 26972 11ATOKA to 27068 11DANVIL	1	69	211	211
200	outage of 26986 11BEREA to 27221 11LK REB	1	69	211	211
202	outage of 26986 11BEREA to 27339 11RICH S	EQ	69	211	211
205	outage of 26999 11BOONSB to 27451 11WINC S	EQ	69	211	211
207	outage of 27016 11BUENA to 27076 11DIXDAM	1	69	211	211
210	outage of 27026 11CARON to 27225 11LONDON	1	69	211	211
212	outage of 27030 11CAVE R to 27113 11FARMER	1	69	211	211
215	outage of 27030 11CAVE R to 27358 11SALT L	1	69	211	211
217	outage of 27037 11CLARK to 27129 11FOGG P	1	69	211	211
220	outage of 27037 11CLARK to 27397 11SYLVAN	1	69	211	211
222	outage of 27046 11CMPGEK to 27225 11LONDON	1	69	211	211

No.	Contingency	Ckt	Base kV	Area	Zone
225	outage of 27050 11CORBIN to 27396 11SWEETH	1	69	211	211
227	outage of 27065 11DANV 1 to 27203 11KYSTHO	EQ	69	211	211
230	outage of 27068 11DANVIL to 27168 11HARRDS	1	69	211	211
232	outage of 27076 11DIXDAM to 27436 11WC-DD	1	69	211	211
235	outage of 27076 11DIXDAM to 27450 11WILMOR	1	69	211	211
237	outage of 27082 11E BERN to 27306 11PINEHL	1	69	211	211
240	outage of 27082 11E BERN to 27314 11PITTSB	1	69	211	211
242	outage of 27113 11FARMER to 27264 11MORH W	1	69	211	211
245	outage of 27117 11FAWKES to 27272 11N.MADS	1	69	211	211
247	outage of 27117 11FAWKES to 27339 11RICH S	1	69	211	211
250	outage of 27117 11FAWKES to 27340 11RICHMO	1	69	211	211
252	outage of 27167 11HARR T to 27168 11HARRDS	1	69	211	211
255	outage of 27167 11HARR T to 27420 11W CLIF	1	69	211	211
257	outage of 27170 11HIGB A to 27391 11STONWL	1	69	211	211
260	outage of 27170 11HIGB A to 27449 11WIL D2	1	69	211	211
262	outage of 27178 11HOPEWL to 27396 11SWEETH	1	69	211	211
265	outage of 27203 11KYSTHO to 27420 11W CLIF	1	69	211	211
267	outage of 27210 11LEBN I to 27213 11LEBNON	1	69	211	211
270	outage of 27213 11LEBNON to 27385 11SPRNGF	1	69	211	211
272	outage of 27221 11LK REB to 27340 11RICHMO	1	69	211	211
275	outage of 27221 11LK REB to 27429 11WACO	1	69	211	211
277	outage of 27225 11LONDON to 27314 11PITTSB	1	69	211	211
280	outage of 27271 11N.CORB to 27396 11SWEETH	1	69	211	211
282	outage of 27272 11N.MADS to 27449 11WIL D2	EQ	69	211	211
285	outage of 27330 11PRKRSE to 27397 11SYLVAN	1	69	211	211
287	outage of 27330 11PRKRSE to 27452 11WINCHS	1	69	211	211
290	outage of 27338 11RICE T to 27429 11WACO	1	69	211	211
292	outage of 27358 11SALT L to 27383 11SPENC	1	69	211	211
295	outage of 27359 11SALVIS to 27368 11SHAKRT	1	69	211	211
297	outage of 27368 11SHAKRT to 27420 11W CLIF	1	69	211	211
300	outage of 27420 11W CLIF to 27436 11WC-DD	1	69	211	211
302	outage of 27074 11DELVIN to 29213 20BTYVL	1	161	211-220	211-220
305	outage of 27074 11DELVIN to 29346 20GRNHLJ	1	161	211-220	211-220
307	outage of 27095 11ELIHU to 29271 20COOPER	1	161	211-220	211-220
310	outage of 27243 11MARION to 29437 20MARION	1	138-161	211-220	211-220
312	outage of 26990 11BKR LN to 29203 20BKR LN	1	138-69	211-220	211-220
315	outage of 27115 11FAWK T to 29312 20FAWKES	1	138	211-220	211-220
317	outage of 27116 11FAWKES to 29312 20FAWKES	1	138	211-220	211-220
320	outage of 27116 11FAWKES to 29312 20FAWKES	2	138	211-220	211-220
322	outage of 27229 11LOUDON to 29202 20AVON	1	138	211-220	211-220
325	outage of 27231 11LR TAP to 29616 20UN CTY	1	138	211-220	211-220
327	outage of 26982 11BEATTY to 29215 20BEATTY	1	69	211-220	211-220
330	outage of 27082 11E BERN to 29300 20EBRNST	1	69	211-220	211-220
332	outage of 27110 11FARLEY to 29536 20SCORBN	1	69	211-220	211-220
335	outage of 27117 11FAWKES to 29280 20CROOKJ	1	69	211-220	211-220

No.	Contingency	Ckt	Base kV	Area	Zone
337	outage of 27178 11HOPEWL to 29410 20LAURLC	1	69	211-220	211-220
340	outage of 29201 20AVON to 29202 20AVON	1	345-138	220	220
342	outage of 29201 20AVON to 29573 20SPURLK	1	345	220	220
345	outage of 29201 20AVON to 29651 20KPE345	1	345	220	220
350	outage of 29573 20SPURLK to 29575 20SPURLK	2	345-138	220	220
352	outage of 29575 20SPURLK to 29573 20SPURLK	1	138-345	220	220
355	outage of 29651 20KPE345 to 29652 20KPE138	1	345-138	220	220
357	outage of 29213 20BTYVL to 29215 20BEATTY	1	161-69	220	220
360	outage of 29213 20BTYVL to 29507 20POWELL	1	161	220	220
362	outage of 29271 20COOPER to 29272 20COOPER	1	161-69	220	220
370	outage of 29271 20COOPER to 29292 20DENNY	1	161	220	220
372	outage of 29271 20COOPER to 29411 20LAURLD	1	161	220	220
375	outage of 29271 20COOPER to 29517 20PULASJ	1	161	220	220
377	outage of 29271 20COOPER to 29540 20S OAKH	1	161	220	220
380	outage of 29292 20DENNY to 29293 20DENNY	1	161-69	220	220
382	outage of 29308 20FALLRK to 29310 20FALLRK	1	161-69	220	220
385	outage of 29308 20FALLRK to 29613 20TYNER	1	161	220	220
387	outage of 29346 20GRNHLJ to 29613 20TYNER	1	161	220	220
390	outage of 29408 20LAURLC to 29410 20LAURLC	1	161-69	220	220
392	outage of 29408 20LAURLC to 29411 20LAURLD	1	161	220	220
395	outage of 29408 20LAURLC to 29503 20PITTSB	1	161	220	220
400	outage of 29418 20LIBERT to 29517 20PULASJ	1	161	220	220
402	outage of 29503 20PITTSB to 29613 20TYNER	1	161	220	220
405	outage of 29507 20POWELL to 29508 20POWELL	1	161-138	220	220
407	outage of 29515 20PULASK to 29517 20PULASJ	1	161	220	220
410	outage of 29528 20RUSSEL to 29540 20S OAKH	1	161	220	220
412	outage of 29613 20TYNER to 29615 20TYNER	1	161-69	220	220
415	outage of 29202 20AVON to 29230 20BOONST	1	138	220	220
417	outage of 29202 20AVON to 29313 20FAYETT	1	138	220	220
420	outage of 29202 20AVON to 29490 20PARISJ	1	138	220	220
422	outage of 29230 20BOONST to 29233 20BOONSB	1	138	220	220
425	outage of 29230 20BOONST to 29282 20DALE	1	138	220	220
430	outage of 29282 20DALE to 29397 20JKSMIT	1	138	220	220
432	outage of 29282 20DALE to 29603 20TFJ	1	138	220	220
435	outage of 29283 20DALE to 29282 20DALE	1	69-138	220	220
437	outage of 29312 20FAWKES to 29397 20JKSMIT	1	138	220	220
440	outage of 29312 20FAWKES to 29603 20TFJ	1	138	220	220
442	outage of 29312 20FAWKES to 29623 20WBBEREA	1	138	220	220
445	outage of 29313 20FAYETT to 29315 20FAYETT	1	138-69	220	220
447	outage of 29375 20JACKVJ to 29490 20PARISJ	1	138	220	220
462	outage of 29397 20JKSMIT to 29508 20POWELL	1	138	220	220
465	outage of 29397 20JKSMIT to 29616 20UN CTY	1	138	220	220
467	outage of 29397 20JKSMIT to 29652 20KPE138	1	138	220	220
470	outage of 29397 20JKSMIT to 29652 20KPE138	2	138	220	220
472	outage of 29488 20PARIS to 29490 20PARISJ	1	138	220	220

No.	Contingency	Ckt	Base kV	Area	Zone
475	outage of 29508 20POWELL to 29510 20POWELL	1	138-69	220	220
477	outage of 29623 20WBBEREA to 29625 20WBBEREA	1	138-69	220	220
480	outage of 29195 20ALCAN to 29512 20PPG J	1	69	220	220
482	outage of 29195 20ALCAN to 29625 20WBBEREA	1	69	220	220
485	outage of 29196 20ANNVLJ to 29615 20TYNER	1	69	220	220
487	outage of 29205 20BALLRD to 29237 20BOURNE	1	69	220	220
490	outage of 29212 20BTYV D to 29215 20BEATTY	1	69	220	220
492	outage of 29215 20BEATTY to 29648 20ZACHAR	1	69	220	220
495	outage of 29222 20BLEV T to 29361 20HOPE	1	69	220	220
497	outage of 29237 20BOURNE to 29470 20NEWBY2	1	69	220	220
500	outage of 29238 20BOWEN to 29355 20HIGHHRK	1	69	220	220
502	outage of 29238 20BOWEN to 29510 20POWELL	1	69	220	220
505	outage of 29243 20BRONSJ to 29272 20COOPER	1	69	220	220
507	outage of 29260 20CLAYCJ to 29347 20HARGTJ	1	69	220	220
510	outage of 29260 20CLAYCJ to 29580 20STANTN	1	69	220	220
512	outage of 29272 20COOPER to 29566 20SOMERS	1	69	220	220
515	outage of 29272 20COOPER to 29566 20SOMERS	2	69	220	220
517	outage of 29280 20CROOKJ to 29352 20HICK P	1	69	220	220
527	outage of 29283 20DALE to 29366 20HUNT1	1	69	220	220
530	outage of 29283 20DALE to 29367 20HUNT2	1	69	220	220
532	outage of 29283 20DALE to 29468 20NEWBY1	1	69	220	220
535	outage of 29283 20DALE to 29470 20NEWBY2	1	69	220	220
537	outage of 29325 20FRNCHB to 29361 20HOPE	1	69	220	220
540	outage of 29327 20GARRCO to 29406 20LNCSTR	1	69	220	220
542	outage of 29352 20HICK P to 29511 20PPG	1	69	220	220
545	outage of 29355 20HIGHHRK to 29547 20SANDLK	1	69	220	220
547	outage of 29361 20HOPE to 29377 20JEFFVL	1	69	220	220
550	outage of 29366 20HUNT1 to 29556 20SIDEV	1	69	220	220
552	outage of 29367 20HUNT2 to 29398 20JKSMIT	1	69	220	220
555	outage of 29377 20JEFFVL to 29510 20POWELL	1	69	220	220
557	outage of 29398 20JKSMIT to 29607 20TRAPP	1	69	220	220
560	outage of 29401 20KEAVY to 29403 20KEAVJ2	1	69	220	220
562	outage of 29402 20KEAVJ1 to 29410 20LAURLC	1	69	220	220
565	outage of 29402 20KEAVJ1 to 29501 20PINEGJ	1	69	220	220
567	outage of 29403 20KEAVJ2 to 29410 20LAURLC	1	69	220	220
570	outage of 29403 20KEAVJ2 to 29536 20SCORBN	1	69	220	220
572	outage of 29406 20LNCSTR to 29468 20NEWBY1	1	69	220	220
575	outage of 29446 20MCKEE to 29615 20TYNER	1	69	220	220
577	outage of 29501 20PINEGJ to 29631 20W LOND	1	69	220	220
580	outage of 29510 20POWELL to 29580 20STANTN	1	69	220	220
582	outage of 29511 20PPG to 29512 20PPG J	1	69	220	220
585	outage of 29537 20S FORK to 29615 20TYNER	1	69	220	220
587	outage of 29605 20THLNKJ to 29626 20WBER J	1	69	220	220
590	outage of 29625 20WBBEREA to 29626 20WBER J	1	69	220	220
592	outage of 29503 20PITTSB to 27314 11PITTSB	1	161-69	220-211	220-211

No.	Contingency	Ckt	Base kV	Area	Zone
595	outage of 29233 20BOONSB to 26999 11BOONSB	1	138-69	220-211	220-211
597	outage of 29397 20JKSMIT to 27382 11SPENC	1	138	220-211	220-211
602	outage of 26648 09STUART to 29573 20SPURLK	1	345	209-220	209-220
605	outage of 26367 08ZIMER to 29573 20SPURLK	1	345	208-220	280-220
607	outage of 27197 11KENTON to 29575 20SPURLK	1	138	211-220	211-220
610	outage of 29372 20INLAND to 29575 20SPURLK	1	138	220	220
612	outage of 29440 20MAYSJV to 29575 20SPURLK	1	138	220	220
615	outage of 29521 20RENAKR to 29575 20SPURLK	1	138	220	220
617	outage of 29575 20SPURLK to 29585 20S PARK	1	138	220	220

Case Summary

Case410s04

Project Name 2002 SERIES, NERC/MMWG BASE CASE LIBRARY
Title1 2004 Summer - CT4&5 & Gilbert
Title2 New Transmission-Gilbert/268 MW, KPE/540 MW
Case Date 2/13/2003

Power Flow File M:\PROJKypsc\267003\300_Calculations\301_PFlow_Results\Case410s04.cft

Power Flow Controls

<i>Area Control</i>	<input type="checkbox"/>	<i>SmoothStep</i>	<input checked="" type="checkbox"/>
<i>Remote Control</i>	<input checked="" type="checkbox"/>	<i>XfrmVcon</i>	<input type="checkbox"/>
<i>GenVar Control</i>	<input checked="" type="checkbox"/>	<i>XfrmFcon</i>	<input type="checkbox"/>
<i>Solve Method</i>	NSOLVE		

Case Settings

<i>Overload</i>	<input checked="" type="checkbox"/>	<i>VlimMin</i>	0.9	<i>RateFactor</i>	1
<i>VLimit</i>	<input checked="" type="checkbox"/>	<i>VlimMax</i>	1.05	<i>AmpFactor</i>	1
<i>VChange</i>	<input checked="" type="checkbox"/>	<i>VlimChange</i>	0.05	<i>RatingNumber</i>	2
<i>Monitored Set</i>	monitor		321 Buses		

Contingency

Contingencies loaded from file M:\PROJKypsc\267003\300_Calculations\301_PFlow_Results\Case300s
230 contingencies

Area	Area Name	Zone	Zone Name	Contingency Buses	Monitored Buses		
147	TVA	167	TVA_EAST	0	1		
				0	1		
205	AEP	254	AEP-KP	0	1		
				0	1		
208	CIN	280	CGE	1	4		
				286	CGE GENS	0	2
						1	6
209	DPL	209	DPL	1	5		
				1	5		
211	LGEE	211	LGEE	109	166		
				109	166		
220	EKPC	220	EKPC	92	142		
				92	142		
				203	321		

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Gilbert

New Transmission-Gilbert/268 MW, KPE/540 MW

2/13/2003

Area	Name		Scheduled		Load MW	Loss MW	Shunt MW	Generation MW	Slack Bus Generator		
			Export MW	Mis- Match					Bus	Name	Slack MW
142	DUK	Ref.	-282	0	20140	462.8	14	20335	11096	COWANS	53
		New	-416	0	20140	458.3	14	20197			48
		Chg.	-134	0	0	-4.4	0	-138			-5
146	SOCO	Ref.	1302	0	46262	901.9	38	48503	15100	1GASTON	861
		New	1167	0	46262	911.4	38	48378			868
		Chg.	-135	0	0	9.5	0	-126			7
205	AEP	Ref.	-854	0	23573	666.5	0	23386	22987	05SPORN	500
		New	-989	0	23573	675.2	0	23259			505
		Chg.	-135	0	0	8.7	0	-126			6
208	CIN	Ref.	283	0	11900	380.6	0	12564	25895	08BCKJD	187
		New	149	0	11900	379.8	0	12429			184
		Chg.	-134	0	0	-0.8	0	-135			-3
220	EKPC	Ref.	-112	-808	1948	74.9	0	2719	29569	20SPLK2	527
		New	696	0	1948	87.7	0	2732			540
		Chg.	808	808	0	12.8	0	13			13
356	AMRN	Ref.	-911	0	11769	217.5	15	11091	31400	OSAGE	166
		New	-1046	0	11769	214.8	15	10953			161
		Chg.	-135	0	0	-2.7	0	-138			-5
401	FPL	Ref.	-4613	0	20770	514.6	0	16672	40363	CAPECA	401
		New	-4748	0	20770	522.9	0	16545			406
		Chg.	-135	0	0	8.2	0	-127			5

Reference Case : M:\PROJ\Kypsc\267003\300_Calculations\301_PFlow_Results\case3

Transfer Case (New):

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Gilbert

New Transmission-Gilbert/268 MW, KPE/540 MW

2/13/2003

<u>Overloaded Facility</u>										<u>Normal System Overloads</u>		
From	Name	To	Name	Circuit	Base kV	Area	Zone	Ratings		MVA	Norm (%)	Emer (%)
								Norm	Emer			
24070	05MOREHE	27348	11RODBRN	1	69	205-211	254-211	33	38	36	109	95
27347	11RODBRN	27348	11RODBRN	1	138-69	211	211	33	40	35	106	87
26959	11AOSMTH	27383	11SPENC	1	69	211	211	48	59	49	102	83

Notes:

1. Overloads are based on 100% of Rating 1
2. Normal System Conditions - No Outages
3. Minimum Reporting Level is 100%

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Gilbert

New Transmission-Gilbert/268 MW, KPE/540 MW

2/13/2003

Overloaded Facility								Normal System				Overloads	
From	Name	To	Name	Circuit	Base kV	Area	Zone	Ratings		MVA	Norm (%)	Count	Max
								Norm	Emer			A / B	(%)
27347	11RODBRN	27348	11RODBRN	1	138-69	211	211	33	40	34.8	106	3 / 0	152
27117	11FAWKES	27339	11RICH S	1	69	211	211	72	72	44.1	61	3 / 0	140
26986	11BEREA	27221	11LK REB	1	69	211	211	72	72	53.1	74	2 / 0	138
27117	11FAWKES	27272	11N.MADS	1	69	211	211	56	56	30.3	54	1 / 0	129
27037	11CLARK	27397	11SYLVAN	1	69	211	211	73	90	56.4	77	3 / 0	124
27113	11FARMER	27264	11MORH W	1	69	211	211	48	48	35.9	75	1 / 0	124
27221	11LK REB	27340	11RICHMO	1	69	211	211	56	56	19.5	35	1 / 0	122
27115	11FAWK T	27231	11LR TAP	1	138	211	211	163	163	35.8	22	2 / 0	118
29230	20BOONST	29282	20DALE	1	138	220	220	252	252	138.5	55	1 / 0	113
26959	11AOSMTH	27383	11SPENC	1	69	211	211	48	59	49.2	102	4 / 0	112
27358	11SALT L	27383	11SPENC	1	69	211	211	22	22	12.7	58	3 / 0	112
27116	11FAWKES	27117	11FAWKES	1	138-69	211	211	143	171	118.8	83	2 / 0	110
27194	11KENTON	29575	20SPURLK	2	138	211-220	211-220	227	280	162.1	71	1 / 0	109
27220	11LK REB	27231	11LR TAP	1	138	211	211	149	171	120.9	81	1 / 0	109
27220	11LK REB	27221	11LK REB	1	138-69	211	211	149	171	120.5	81	1 / 0	108
27112	11FARMER	27113	11FARMER	1	138-69	211	211	40	48	31.8	79	1 / 0	108
27229	11LOUDON	27228	11LOUD B	1	138-69	211	211	112	129	92.7	83	1 / 0	108
27330	11PRKRSE	27452	11WINCHS	1	69	211	211	72	79	29.5	41	2 / 0	106
27345	11ROCKWE	27452	11WINCHS	1	69	211	211	63	63	45.0	71	1 / 0	105
27382	11SPENC	27383	11SPENC	1	138-69	211	211	72	79	47.1	65	0 / 1	104
27229	11LOUDON	29202	20AVON	1	138	211-220	211-220	287	302	276.2	96	0 / 4	103
29203	20BKR LN	29360	20HOLLWJ	1	69	220	220	57	69	9.3	16	0 / 2	101
27271	11N.CORB	27396	11SWEETH	1	69	211	211	72	72	27.4	38	0 / 1	101
27338	11RICE T	27429	11WACO	1	69	211	211	47	47	18.2	39	0 / 2	101
												34 / 10	152

Notes:

- Overloads are based on 100% of Rating 2
- NS = Normal System Conditions (No Outages)
- Minimum Reporting Level is 100%
- Statistical Information (A/B Stats and Maximum Overload)
 - A = Serious Overload > 105%
 - B = Overloaded Facility between 100% and 105% of Rated Capability

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Gilbert

New Transmission-Gilbert/268 MW, KPE/540 MW

2/13/2003

<u>Undervoltage</u>					<u>Normal System</u>	<u>Voltage Violations</u>	
<u>Bus</u>	<u>Name</u>	<u>Base kV</u>	<u>Area</u>	<u>Zone</u>	<u>Voltage (pu)</u>	<u>A / B</u>	<u>Min (pu)</u>
29212	20BTYV D	69	220	220	0.9851	1 / 0	0.8380
27449	11WIL D2	69	211	211	1.0010	1 / 0	0.8440
29478	20OAKD J	69	220	220	0.9772	1 / 0	0.8478
29232	20BOONVJ	69	220	220	0.9743	1 / 0	0.8594
29313	20FAYETT	138	220	220	0.9984	1 / 0	0.8700
27210	11LEBN I	69	211	211	0.9778	1 / 0	0.8708
29468	20NEWBY1	69	220	220	1.0048	1 / 0	0.8773
29537	20S FORK	69	220	220	0.9747	0 / 1	0.8864
29315	20FAYETT	69	220	220	1.0125	0 / 2	0.8923
29406	20LNCSTR	69	220	220	0.9906	0 / 1	0.8932
29327	20GARRCO	69	220	220	0.9880	0 / 1	0.8941
29205	20BALLRD	69	220	220	0.9722	0 / 2	0.8981
29237	20BOURNE	69	220	220	0.9832	0 / 1	0.8990
29596	20TGOOCH	69	220	220	0.9748	0 / 1	0.8990
27067	11DANVIL	138	211	211	0.9939	0 / 1	0.8991
						7 / 10	0.8380
Notes:							
1. Minimum Voltage Limit 0.90 (pu)							
2. NS = Normal System Conditions (No Outages)							
3. Maximum Reporting Level is 90%							
4. Statistical Information (A/B Stats and Minimum Voltage)							
A = Serious Undervoltage < 0.88 (pu)							
B = Low Voltages between 0.88 and 0.90 (pu)							

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Gilbert

New Transmission-Gilbert/268 MW, KPE/540 MW

2/13/2003

Overvoltage					Normal System	Voltage Violations	
Bus	Name	Base kV	Area	Zone	Voltage (pu)	A / B	Max (pu)
29406	20LNCSTR	69	220	220	0.9906	0 / 1	1.0560
29540	20S OAKH	161	220	220	1.0338	0 / 1	1.0516
						0 / 2	1.0560
Notes:							
1. Maximum Voltage Limit is 1.05 (pu)							
2. NS = Normal System Conditions (No Outages)							
3. Minimum Reporting Level for Over Voltages is 105%							
4. Statistical Information (A/B Stats and Maximum Voltage)							
A = Serious Overvoltage > 1.07 (pu)							
B = High Voltages between 1.05 and 1.07 (pu)							

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Gilbert

New Transmission-Gilbert/268 MW, KPE/540 MW

2/13/2003

VChange Bus Name	Base kV	Area	Zone	Normal System Voltage (pu)	Voltage Violations	
					A / B	Max (pu)
27449 11WIL D2	69	211	211	1.0010	1 / 0	-0.1570
29212 20BTYV D	69	220	220	0.9851	1 / 0	-0.1471
29478 20OAKD J	69	220	220	0.9772	1 / 0	-0.1294
29313 20FAYETT	138	220	220	0.9984	1 / 0	-0.1284
29468 20NEWBY1	69	220	220	1.0048	1 / 0	-0.1275
29315 20FAYETT	69	220	220	1.0125	2 / 0	-0.1202
29232 20BOONVJ	69	220	220	0.9743	1 / 0	-0.1149
27016 11BUENA	69	211	211	1.0259	1 / 0	-0.1119
29470 20NEWBY2	69	220	220	1.0083	1 / 0	-0.1071
27210 11LEBN I	69	211	211	0.9778	1 / 0	-0.1070
27076 11DIXDAM	69	211	211	1.0369	1 / 0	-0.1040
29406 20LNCSTR	69	220	220	0.9906	1 / 0	-0.0974
29291 20DAVIS	69	220	220	0.9984	2 / 0	-0.0949
27067 11DANVIL	138	211	211	0.9939	1 / 0	-0.0948
27016 11BUENA	69	211	211	1.0259	1 / 0	-0.0940
29327 20GARRCO	69	220	220	0.9880	1 / 0	-0.0939
27136 11GARRD	69	211	211	1.0074	1 / 0	-0.0912
29537 20S FORK	69	220	220	0.9747	1 / 0	-0.0883
29237 20BOURNE	69	220	220	0.9832	1 / 0	-0.0842
29233 20BOONSB	138	220	220	1.0222	1 / 0	-0.0834
29237 20BOURNE	69	220	220	0.9832	1 / 0	-0.0822
27068 11DANVIL	69	211	211	1.0000	2 / 0	-0.0778
29596 20TGOOCH	69	220	220	0.9748	1 / 0	-0.0758
27136 11GARRD	69	211	211	1.0074	1 / 0	-0.0753
26972 11ATOKA	69	211	211	0.9985	1 / 0	-0.0742
26999 11BOONSB	69	211	211	1.0371	2 / 0	-0.0742
26972 11ATOKA	69	211	211	0.9985	1 / 0	-0.0741
29205 20BALLRD	69	220	220	0.9722	1 / 0	-0.0741
27450 11WILMOR	69	211	211	1.0088	1 / 0	-0.0733
29205 20BALLRD	69	220	220	0.9722	1 / 0	-0.0733
29580 20STANTN	69	220	220	0.9980	1 / 0	-0.0730
27000 11BOYLE	69	211	211	0.9978	2 / 0	-0.0722
29205 20BALLRD	69	220	220	0.9722	1 / 0	-0.0716
29411 20LAURLD	161	220	220	1.0026	1 / 0	-0.0704
29407 20LAURHY	13.8	220	220	0.9836	0 / 1	-0.0691
29325 20FRNCHB	69	220	220	0.9782	0 / 1	-0.0683
29436 20MARIBJ	69	220	220	0.9799	0 / 1	-0.0671
27220 11LK REB	138	211	211	1.0027	0 / 1	-0.0670
27065 11DANV 1	69	211	211	0.9974	0 / 2	-0.0666
27167 11HARR T	69	211	211	1.0080	0 / 1	-0.0665
27168 11HARRDS	69	211	211	1.0080	0 / 1	-0.0665
29623 20WBAREA	138	220	220	1.0033	0 / 1	-0.0655
27450 11WILMOR	69	211	211	1.0088	0 / 1	-0.0651
29288 20DALE4	13.8	220	220	1.0478	0 / 1	-0.0648
27247 11MERCRCR	138	211	211	1.0069	0 / 1	-0.0641
27055 11CRAB O	69	211	211	0.9868	0 / 1	-0.0634
29510 20POWELL	69	220	220	0.9983	0 / 1	-0.0617
29580 20STANTN	69	220	220	0.9980	0 / 1	-0.0615
29260 20CLAYCJ	69	220	220	0.9966	0 / 1	-0.0610
29625 20WBAREA	69	220	220	0.9987	0 / 1	-0.0609
29625 20WBAREA	69	220	220	0.9987	0 / 1	-0.0607
29327 20GARRCO	69	220	220	0.9880	0 / 1	-0.0605
29515 20PULASK	161	220	220	1.0130	0 / 1	-0.0605

VChange		Base kV	Area	Zone	Normal System Voltage (pu)	Voltage Violations	
Bus	Name					A / B	Max (pu)
29203	20BKR LN	69	220	220	0.9867	0 / 1	-0.0595
29626	20WBER J	69	220	220	0.9984	0 / 1	-0.0587
29626	20WBER J	69	220	220	0.9984	0 / 1	-0.0585
29195	20ALCAN	69	220	220	0.9963	0 / 1	-0.0584
29368	20HUNTFJ	69	220	220	0.9662	0 / 1	-0.0584
29510	20POWELL	69	220	220	0.9983	0 / 1	-0.0584
29580	20STANTN	69	220	220	0.9980	0 / 1	-0.0582
29195	20ALCAN	69	220	220	0.9963	0 / 1	-0.0581
29368	20HUNTFJ	69	220	220	0.9662	0 / 1	-0.0577
29512	20PPG J	69	220	220	0.9958	0 / 1	-0.0566
29368	20HUNTFJ	69	220	220	0.9662	0 / 1	-0.0564
29511	20PPG	69	220	220	0.9957	0 / 1	-0.0564
29512	20PPG J	69	220	220	0.9958	0 / 1	-0.0564
27067	11DANVIL	138	211	211	0.9939	0 / 1	-0.0563
29347	20HARGTJ	69	220	220	0.9989	0 / 1	-0.0563
29511	20PPG	69	220	220	0.9957	0 / 1	-0.0561
29408	20LAURLC	161	220	220	0.9852	0 / 1	-0.0553
29238	20BOWEN	69	220	220	0.9982	0 / 1	-0.0549
26959	11AOSMTH	69	211	211	1.0219	0 / 1	-0.0546
29238	20BOWEN	69	220	220	0.9982	0 / 1	-0.0543
29360	20HOLLWJ	69	220	220	0.9840	0 / 1	-0.0540
26986	11BEREA	69	211	211	0.9971	0 / 1	-0.0539
29508	20POWELL	138	220	220	1.0005	0 / 1	-0.0538
29605	20THLNKJ	69	220	220	0.9988	0 / 1	-0.0538
29605	20THLNKJ	69	220	220	0.9988	0 / 1	-0.0537
27221	11LK REB	69	211	211	1.0133	0 / 1	-0.0536
27221	11LK REB	69	211	211	1.0133	0 / 1	-0.0535
29408	20LAURLC	161	220	220	0.9852	0 / 1	-0.0534
29260	20CLAYCJ	69	220	220	0.9966	0 / 1	-0.0532
27339	11RICH S	69	211	211	1.0023	0 / 1	-0.0524
27368	11SHAKRT	69	211	211	1.0281	0 / 1	-0.0519
29516	20PULASK	69	220	220	1.0044	0 / 1	-0.0519
29260	20CLAYCJ	69	220	220	0.9966	0 / 1	-0.0515
27055	11CRAB O	69	211	211	0.9868	0 / 1	-0.0513
29605	20THLNKJ	69	220	220	0.9988	0 / 1	-0.0511
29488	20PARIS	138	220	220	0.9949	0 / 1	-0.0508
29605	20THLNKJ	69	220	220	0.9988	0 / 1	-0.0506
27068	11DANVIL	69	211	211	1.0000	0 / 1	-0.0504
27272	11N.MADS	69	211	211	1.0078	0 / 1	-0.0502
27300	11PARIS	69	211	211	1.0185	0 / 1	-0.0502
29626	20WBER J	69	220	220	0.9984	0 / 1	-0.0502
29237	20BOURNE	69	220	220	0.9832	0 / 1	0.0553
29406	20LNCSTR	69	220	220	0.9906	0 / 1	0.0654

39 / 63 -0.1570

Notes:

1. Voltage Change Limit is 0.05 (pu)
2. NS = Normal System Conditions (No Outages)
3. Minimum Reporting Level is 5%
4. Statistical Information (A/B Stats and Maximum Voltage Change)
 - A = Serious Voltage Change > 0.07 (pu)
 - B = Excessive Voltage Change between 0.05 and 0.07 (pu)

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Gilbert

New Transmission-Gilbert/268 MW, KPE/540 MW

2/13/2003

Contingency	Overloaded Facility										Overloads		
	From Name	To Name	Ckt	Base kV	Area	Zone	Ratings		MVA	Norm (%)	Emer (%)		
							Norm	Emer					
32	outage of 27230 11LR TAP to 27231 11LR TAP		1	161-138	211	211							
	27338 11RICE T	27429 11WACO	1	69	211	211	47	47	47.2	100	101		
35	outage of 27230 11LR TAP to 27444 11WI TAP		1	161	211	211							
	27338 11RICE T	27429 11WACO	1	69	211	211	47	47	47.2	100	100		
95	outage of 27036 11CLARK to 27037 11CLARK		1	138-69	211	211							
	26959 11AOSMTH	27383 11SPENC	1	69	211	211	48	59	66.3	138	112		
110	outage of 27111 11FARM T to 27112 11FARMER		1	138	211	211							
	27347 11RODBRN	27348 11RODBRN	1	138-69	211	211	33	40	50.6	153	126		
	27358 11SALT L	27383 11SPENC	1	69	211	211	22	22	24.7	112	112		
115	outage of 27111 11FARM T to 27382 11SPENC		1	138	211	211							
	27358 11SALT L	27383 11SPENC	1	69	211	211	22	22	24.6	112	112		
117	outage of 27112 11FARMER to 27113 11FARMER		1	138-69	211	211							
	27347 11RODBRN	27348 11RODBRN	1	138-69	211	211	33	40	50.6	153	126		
	27358 11SALT L	27383 11SPENC	1	69	211	211	22	22	24.7	112	112		
125	outage of 27116 11FAWKES to 27117 11FAWKES		1	138-69	211	211							
	27221 11LK REB	27340 11RICHMO	1	69	211	211	56	56	68.3	122	122		
	26986 11BEREA	27221 11LK REB	1	69	211	211	72	72	78.4	109	109		
	27220 11LK REB	27231 11LR TAP	1	138	211	211	149	171	186.1	125	109		
	27220 11LK REB	27221 11LK REB	1	138-69	211	211	149	171	185.1	124	108		
157	outage of 27220 11LK REB to 27221 11LK REB		1	138-69	211	211							
	27116 11FAWKES	27117 11FAWKES	1	138-69	211	211	143	171	187.5	131	110		
	27117 11FAWKES	27339 11RICH S	1	69	211	211	72	72	76.2	106	106		
160	outage of 27220 11LK REB to 27231 11LR TAP		1	138	211	211							
	27116 11FAWKES	27117 11FAWKES	1	138-69	211	211	143	171	187.5	131	110		
	27117 11FAWKES	27339 11RICH S	1	69	211	211	72	72	76.2	106	106		
162	outage of 27229 11LOUDON to 27227 11LOUD A		1	138-69	211	211							
	27229 11LOUDON	27228 11LOUD B	1	138-69	211	211	112	129	138.9	124	108		
172	outage of 27347 11RODBRN to 27348 11RODBRN		1	138-69	211	211							
	27113 11FARMER	27264 11MORH W	1	69	211	211	48	48	59.4	124	124		
	27112 11FARMER	27113 11FARMER	1	138-69	211	211	40	48	51.9	130	108		
180	outage of 27382 11SPENC to 27383 11SPENC		2	138-69	211	211							
	27382 11SPENC	27383 11SPENC	1	138-69	211	211	72	79	82.0	114	104		
200	outage of 26986 11BEREA to 27221 11LK REB		1	69	211	211							
	27117 11FAWKES	27339 11RICH S	1	69	211	211	72	72	100.6	140	140		
205	outage of 26999 11BOONSB to 27451 11WINC S		EQ	69	211	211							
	27037 11CLARK	27397 11SYLVAN	1	69	211	211	73	90	101.4	139	113		
	26959 11AOSMTH	27383 11SPENC	1	69	211	211	48	59	62.7	131	106		
242	outage of 27113 11FARMER to 27264 11MORH W		1	69	211	211							
	27347 11RODBRN	27348 11RODBRN	1	138-69	211	211	33	40	61.0	185	152		
247	outage of 27117 11FAWKES to 27339 11RICH S		1	69	211	211							
	26986 11BEREA	27221 11LK REB	1	69	211	211	72	72	99.7	138	138		
260	outage of 27170 11HIGB A to 27449 11WIL D2		1	69	211	211							
	27117 11FAWKES	27272 11N.MADS	1	69	211	211	56	56	72.0	128	129		
277	outage of 27225 11LONDON to 27314 11PITTSB		1	69	211	211							
	27271 11N.CORB	27396 11SWEETH	1	69	211	211	72	72	72.4	101	101		
322	outage of 27229 11LOUDON to 29202 20AVON		1	138	211-220	211-220							
	27075 NONAME	27300 11PARIS	1	69	211	211	56	56	70.1	125	125		
	27345 11ROCKWE	27452 11WINCHS	1	69	211	211	63	63	66.4	105	105		
325	outage of 27231 11LR TAP to 29616 20UN CTY		1	138	211-220	211-220							
	27115 11FAWK T	27231 11LR TAP	1	138	211	211	163	163	189.3	116	116		

Contingency	Overloaded Facility									Overloads		
	From Name	To Name	Ckt	Base kV	Area	Zone	Ratings		MVA	Norm (%)	Emer (%)	
							Norm	Emer				
340	outage of 29201 20AVON to 29202 20AVON		1	345-138	220	220						
	29230 20BOONST	29282 20DALE	1	138	220	220	252	252	283.4	112	113	
417	outage of 29202 20AVON to 29313 20FAYETT		1	138	220	220						
	29203 20BKR LN	29360 20HOLLWJ	1	69	220	220	57	69	69.8	122	101	
	27229 11LOUDON	29202 20AVON	1	138	211-220	211-220	287	302	303.7	106	101	
420	outage of 29202 20AVON to 29490 20PARISJ		1	138	220	220						
	27229 11LOUDON	29202 20AVON	1	138	211-220	211-220	287	302	304.5	106	101	
422	outage of 29230 20BOONST to 29233 20BOONSB		1	138	220	220						
	27037 11CLARK	27397 11SYLVAN	1	69	211	211	73	90	111.3	152	124	
	26959 11AOSMTH	27383 11SPENC	1	69	211	211	48	59	65.8	137	112	
	27330 11PRKRSE	27452 11WINCHS	1	69	211	211	72	79	83.6	116	106	
445	outage of 29313 20FAYETT to 29315 20FAYETT		1	138-69	220	220						
	29203 20BKR LN	29360 20HOLLWJ	1	69	220	220	57	69	69.8	122	101	
	27229 11LOUDON	29202 20AVON	1	138	211-220	211-220	287	302	303.8	106	101	
465	outage of 29397 20JKSMIT to 29616 20UN CTY		1	138	220	220						
	27115 11FAWK T	27231 11LR TAP	1	138	211	211	163	163	191.5	117	118	
472	outage of 29488 20PARIS to 29490 20PARISJ		1	138	220	220						
	27229 11LOUDON	29202 20AVON	1	138	211-220	211-220	287	302	310.9	108	103	
595	outage of 29233 20BOONSB to 26999 11BOONSB		1	138-69	220-211	220-211						
	27037 11CLARK	27397 11SYLVAN	1	69	211	211	73	90	111.3	152	124	
	26959 11AOSMTH	27383 11SPENC	1	69	211	211	48	59	65.8	137	112	
	27330 11PRKRSE	27452 11WINCHS	1	69	211	211	72	79	83.6	116	106	
607	outage of 27197 11KENTON to 29575 20SPURLK		1	138	211-220	211-220						
	27194 11KENTON	29575 20SPURLK	2	138	211-220	211-220	227	280	306.0	135	109	

Notes:

1. Overloads are based on 100% of Rating 2

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Gilbert

New Transmission-Gilbert/268 MW, KPE/540 MW

2/13/2003

Contingency

Description	Ckt	kV	Zone	Area	Over load	Voltage Violations			Not Solved
						UnderV	OverV	Change	
32 outage of 27230 11LR TAP to 27231 11LR TAP	1	161-138	211	211	1	0	0	0	
35 outage of 27230 11LR TAP to 27444 11WI TAP	1	161	211	211	1	0	0	0	
82 outage of 27010 11BRWN P to 27247 11MERCRCR	1	138	211	211	0	0	0	3	
95 outage of 27036 11CLARK to 27037 11CLARK	1	138-69	211	211	1	0	0	0	
105 outage of 27067 11DANVIL to 27068 11DANVIL	1	138-69	211	211	0	0	0	4	
107 outage of 27067 11DANVIL to 27247 11MERCRCR	1	138	211	211	0	1	0	5	
110 outage of 27111 11FARM T to 27112 11FARMER	1	138	211	211	2	0	0	0	
115 outage of 27111 11FARM T to 27382 11SPENC	1	138	211	211	1	0	0	0	
117 outage of 27112 11FARMER to 27113 11FARMER	1	138-69	211	211	2	0	0	0	
125 outage of 27116 11FAWKES to 27117 11FAWKES	1	138-69	211	211	4	0	0	0	
157 outage of 27220 11LK REB to 27221 11LK REB	1	138-69	211	211	2	0	0	1	
160 outage of 27220 11LK REB to 27231 11LR TAP	1	138	211	211	2	0	0	2	
162 outage of 27229 11LOUDON to 27227 11LOUD A	1	138-69	211	211	1	0	0	0	
172 outage of 27347 11RODBRN to 27348 11RODBRN	1	138-69	211	211	2	0	0	0	
180 outage of 27382 11SPENC to 27383 11SPENC	2	138-69	211	211	1	0	0	0	
195 outage of 26959 11AOSMTH to 27383 11SPENC	1	69	211	211	0	0	0	1	
200 outage of 26986 11BEREA to 27221 11LK REB	1	69	211	211	1	0	0	1	
205 outage of 26999 11BOONSB to 27451 11WINC S	EQ	69	211	211	2	0	0	0	
207 outage of 27016 11BUENA to 27076 11DIXDAM	1	69	211	211	0	0	0	3	
232 outage of 27076 11DIXDAM to 27436 11WC-DD	1	69	211	211	0	0	0	5	
235 outage of 27076 11DIXDAM to 27450 11WILMOR	1	69	211	211	0	0	0	1	
242 outage of 27113 11FARMER to 27264 11MORH W	1	69	211	211	1	0	0	0	
247 outage of 27117 11FAWKES to 27339 11RICH S	1	69	211	211	1	0	0	1	
255 outage of 27167 11HARR T to 27420 11W CLIF	1	69	211	211	0	0	0	2	
260 outage of 27170 11HIGB A to 27449 11WIL D2	1	69	211	211	1	1	0	2	
267 outage of 27210 11LEBN I to 27213 11LEBNON	1	69	211	211	0	1	0	1	
277 outage of 27225 11LONDON to 27314 11PITTSB	1	69	211	211	1	0	0	0	
297 outage of 27368 11SHAKRT to 27420 11W CLIF	1	69	211	211	0	0	0	1	
312 outage of 26990 11BKR LN to 29203 20BKR LN	1	138-69	211-220	211-220	0	0	0	2	
322 outage of 27229 11LOUDON to 29202 20AVON	1	138	211-220	211-220	2	0	0	0	
325 outage of 27231 11LR TAP to 29616 20UN CTY	1	138	211-220	211-220	1	0	0	0	
340 outage of 29201 20AVON to 29202 20AVON	1	345-138	220	220	1	0	0	0	
372 outage of 29271 20COOPER to 29411 20LAURLD	1	161	220	220	0	0	0	3	
377 outage of 29271 20COOPER to 29540 20S OAKH	1	161	220	220	0	0	3	0	
392 outage of 29408 20LAURLC to 29411 20LAURLD	1	161	220	220	0	0	0	1	
407 outage of 29515 20PULASK to 29517 20PULASJ	1	161	220	220	0	0	0	2	
410 outage of 29528 20RUSSEL to 29540 20S OAKH	1	161	220	220	0	0	2	0	
417 outage of 29202 20AVON to 29313 20FAYETT	1	138	220	220	2	2	0	3	

Contingency

Description	Ckt	kV	Zone	Area	Over load	Voltage Violations			Not Solved
						UnderV	OverV	Change	
420 outage of 29202 20AVON to 29490 20PARISJ	1	138	220	220	1	0	0	0	
422 outage of 29230 20BOONST to 29233 20BOONSB	1	138	220	220	3	0	0	2	
425 outage of 29230 20BOONST to 29282 20DALE	1	138	220	220	0	0	0	1	
442 outage of 29312 20FAWKES to 29623 20WBEREA	1	138	220	220	0	0	0	7	
445 outage of 29313 20FAYETT to 29315 20FAYETT	1	138-69	220	220	2	1	0	2	
462 outage of 29397 20JKSMIT to 29508 20POWELL	1	138	220	220	0	0	0	5	
465 outage of 29397 20JKSMIT to 29616 20UN CTY	1	138	220	220	1	0	0	0	
472 outage of 29488 20PARIS to 29490 20PARISJ	1	138	220	220	1	0	0	2	
475 outage of 29508 20POWELL to 29510 20POWELL	1	138-69	220	220	0	0	0	4	
477 outage of 29623 20WBEREA to 29625 20WBERE	1	138-69	220	220	0	0	0	6	
487 outage of 29205 20BALLRD to 29237 20BOURNE	1	69	220	220	0	1	0	3	
490 outage of 29212 20BTYV D to 29215 20BEATTY	1	69	220	220	0	4	0	4	
497 outage of 29237 20BOURNE to 29470 20NEWBY2	1	69	220	220	0	2	0	3	
532 outage of 29283 20DALE to 29468 20NEWBY1	1	69	220	220	0	4	0	4	
535 outage of 29283 20DALE to 29470 20NEWBY2	1	69	220	220	0	0	0	4	
537 outage of 29325 20FRNCHB to 29361 20HOPE	1	69	220	220	0	0	0	2	
540 outage of 29327 20GARRCO to 29406 20LNCSTR	1	69	220	220	0	0	1	2	
580 outage of 29510 20POWELL to 29580 20STANTN	1	69	220	220	0	0	0	3	
587 outage of 29605 20THLNKJ to 29626 20WBER J	1	69	220	220	0	0	0	1	
590 outage of 29625 20WBEREA to 29626 20WBER J	1	69	220	220	0	0	0	2	
595 outage of 29233 20BOONSB to 26999 11BOONSB	1	138-69	220-211	220-211	3	0	0	1	
607 outage of 27197 11KENTON to 29575 20SPURLK	1	138	211-220	211-220	1	0	0	0	
Totals:					45	17	6	102	0

Notes:

1. Overloads are based on 100% of Rating 2
2. Undervoltage Limit is 0.90 (pu)
3. Overvoltage Limit is 1.05 (pu)
4. Voltage Change Limit is 0.05 (pu)

Not Solved Codes:

D - Diverged
I - Interrupted
F - Failed, One or More Contingency
Commands Failed in PFlow

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Gilbert

New Transmission-Gilbert/268 MW, KPE/540 MW

2/13/2003

Overloaded Facility	Contingency									Overloads			
	From	Name	To	Name	Circuit	Base kV	Area	Zone	Ratings Norm Emer	NS	Norm MVA	Emer (%)	Emer (%)
27347 11RODBRN	27348	11RODBRN			1	138-69	211	211	33 40	NS	35	106	87
	242	outage of 27113 11FARMER to 27264 11MORH			1	69	211	211			61	185	152
	110	outage of 27111 11FARM T to 27112 11FARMER			1	138	211	211			51	153	126
	117	outage of 27112 11FARMER to 27113 11FARME			1	138-69	211	211			51	153	126
											3 / 0		152
27117 11FAWKES	27339	11RICH S			1	69	211	211	72 72	NS	44	61	61
	200	outage of 26986 11BEREA to 27221 11LK REB			1	69	211	211			101	140	140
	157	outage of 27220 11LK REB to 27221 11LK REB			1	138-69	211	211			76	106	106
	160	outage of 27220 11LK REB to 27231 11LR TAP			1	138	211	211			76	106	106
											3 / 0		140
26986 11BEREA	27221	11LK REB			1	69	211	211	72 72	NS	53	74	74
	247	outage of 27117 11FAWKES to 27339 11RICH S			1	69	211	211			100	138	138
	125	outage of 27116 11FAWKES to 27117 11FAWKE			1	138-69	211	211			78	109	109
											2 / 0		138
27117 11FAWKES	27272	11N.MADS			1	69	211	211	56 56	NS	30	54	54
	260	outage of 27170 11HIGB A to 27449 11WIL D2			1	69	211	211			72	128	129
											1 / 0		129
27037 11CLARK	27397	11SYLVAN			1	69	211	211	73 90	NS	56	77	63
	595	outage of 29233 20BOONSB to 26999 11BOONS			1	138-69	220-211	220-211			111	152	124
	422	outage of 29230 20BOONST to 29233 20BOONS			1	138	220	220			111	152	124
	205	outage of 26999 11BOONSB to 27451 11WINC S EQ				69	211	211			101	139	113
											3 / 0		124
27113 11FARMER	27264	11MORH W			1	69	211	211	48 48	NS	36	75	75
	172	outage of 27347 11RODBRN to 27348 11RODBR			1	138-69	211	211			59	124	124
											1 / 0		124
27221 11LK REB	27340	11RICHMO			1	69	211	211	56 56	NS	20	35	35
	125	outage of 27116 11FAWKES to 27117 11FAWKE			1	138-69	211	211			68	122	122
											1 / 0		122
27115 11FAWK T	27231	11LR TAP			1	138	211	211	163 163	NS	36	22	22
	465	outage of 29397 20JKSMIT to 29616 20UN CTY			1	138	220	220			192	117	118
	325	outage of 27231 11LR TAP to 29616 20UN CTY			1	138	211-220	211-220			189	116	116
											2 / 0		118
29230 20BOONST	29282	20DALE			1	138	220	220	252 252	NS	139	55	55
	340	outage of 29201 20AVON to 29202 20AVON			1	345-138	220	220			283	112	113
											1 / 0		113

Overloaded Facility	Contingency									Overloads				
	From	Name	To	Name	Circuit	Base kV	Area	Zone	Ratings	Norm	Emer	MVA	Norm (%)	Emer (%)
									Norm Emer					
26959	11AOSMTH		27383	11SPENC	1	69	211	211	48	59	NS	49	102	83
		95 outage of 27036 11CLARK to 27037 11CLARK			1	138-69	211	211				66	138	112
		422 outage of 29230 20BOONST to 29233 20BOONS			1	138	220	220				66	137	112
		595 outage of 29233 20BOONSB to 26999 11BOONS			1	138-69	220-211	220-211				66	137	112
		205 outage of 26999 11BOONSB to 27451 11WINC S EQ				69	211	211				63	131	106
												4 / 0		112
27358	11SALT L		27383	11SPENC	1	69	211	211	22	22	NS	13	58	58
		110 outage of 27111 11FARM T to 27112 11FARMER			1	138	211	211				25	112	112
		117 outage of 27112 11FARMER to 27113 11FARME			1	138-69	211	211				25	112	112
		115 outage of 27111 11FARM T to 27382 11SPENC			1	138	211	211				25	112	112
												3 / 0		112
27116	11FAWKES		27117	11FAWKES	1	138-69	211	211	143	171	NS	119	83	69
		160 outage of 27220 11LK REB to 27231 11LR TAP			1	138	211	211				188	131	110
		157 outage of 27220 11LK REB to 27221 11LK REB			1	138-69	211	211				188	131	110
												2 / 0		110
27194	11KENTON		29575	20SPURLK	2	138	211-220	211-220	227	280	NS	162	71	58
		607 outage of 27197 11KENTON to 29575 20SPURLK			1	138	211-220	211-220				306	135	109
												1 / 0		109
27220	11LK REB		27231	11LR TAP	1	138	211	211	149	171	NS	121	81	71
		125 outage of 27116 11FAWKES to 27117 11FAWKE			1	138-69	211	211				186	125	109
												1 / 0		109
27220	11LK REB		27221	11LK REB	1	138-69	211	211	149	171	NS	121	81	70
		125 outage of 27116 11FAWKES to 27117 11FAWKE			1	138-69	211	211				185	124	108
												1 / 0		108
27112	11FARMER		27113	11FARMER	1	138-69	211	211	40	48	NS	32	79	66
		172 outage of 27347 11RODBRN to 27348 11RODBR			1	138-69	211	211				52	130	108
												1 / 0		108
27229	11LOUDON		27228	11LOUD B	1	138-69	211	211	112	129	NS	93	83	72
		162 outage of 27229 11LOUDON to 27227 11LOUD A			1	138-69	211	211				139	124	108
												1 / 0		108
27330	11PRKRSE		27452	11WINCHS	1	69	211	211	72	79	NS	30	41	37
		422 outage of 29230 20BOONST to 29233 20BOONS			1	138	220	220				84	116	106
		595 outage of 29233 20BOONSB to 26999 11BOONS			1	138-69	220-211	220-211				84	116	106
												2 / 0		106
27345	11ROCKWE		27452	11WINCHS	1	69	211	211	63	63	NS	45	71	71
		322 outage of 27229 11LOUDON to 29202 20AVON			1	138	211-220	211-220				66	105	105
												1 / 0		105
27382	11SPENC		27383	11SPENC	1	138-69	211	211	72	79	NS	47	65	60
		180 outage of 27382 11SPENC to 27383 11SPENC			2	138-69	211	211				82	114	104
												0 / 1		104

Overloaded Facility	Contingency									Overloads				
	From	Name	To	Name	Circuit	Base kV	Area	Zone	Ratings		NS	MVA	Norm (%)	Emer (%)
									Norm	Emer				
27229	11LOUDON	29202	20AVON		1	138	211-220	211-220	287	302	NS	276	96	91
	472	outage of 29488 20PARIS to 29490 20PARISJ		1	138	220	220					311	108	103
	420	outage of 29202 20AVON to 29490 20PARISJ		1	138	220	220					304	106	101
	445	outage of 29313 20FAYETT to 29315 20FAYETT		1	138-69	220	220					304	106	101
	417	outage of 29202 20AVON to 29313 20FAYETT		1	138	220	220					304	106	101
											0 / 4		103	
29203	20BKR LN	29360	20HOLLWJ		1	69	220	220	57	69	NS	9	16	13
	417	outage of 29202 20AVON to 29313 20FAYETT		1	138	220	220					70	122	101
	445	outage of 29313 20FAYETT to 29315 20FAYETT		1	138-69	220	220					70	122	101
											0 / 2		101	
27271	11N.CORB	27396	11SWEETH		1	69	211	211	72	72	NS	27	38	38
	277	outage of 27225 11LONDON to 27314 11PITTSB		1	69	211	211					72	101	101
											0 / 1		101	
27338	11RICE T	27429	11WACO		1	69	211	211	47	47	NS	18	39	39
	32	outage of 27230 11LR TAP to 27231 11LR TAP		1	161-138	211	211					47	100	101
	35	outage of 27230 11LR TAP to 27444 11WI TAP		1	161	211	211					47	100	100
											0 / 2		101	
											34 / 10		152.4	

Notes:

1. Overloads are based on 100% of Rating 2
2. NS = Normal System Conditions (No Outages)
3. Minimum Reporting Level is 100%
4. Statistical Information (A/B Stats and Maximum Overload)
 - A = Serious Overload > 105%
 - B = Overloaded Facility between 100% and 105% of Rated Capability

2002 SERIES, NERC/MMWG BASE CASE LIBRARY

2004 Summer - CT45 Gilbert

New Transmission-Gilbert/268 MW, KPE/540 MW

2/13/2003

No.	Contingency	Ckt	Base kV	Area	Zone
10	outage of 26950 11ALCALD to 27008 11BRWN N	1	345	211	211
12	outage of 27008 11BRWN N to 27009 11BRWN N	1	345-138	211	211
15	outage of 27008 11BRWN N to 27162 11HARDN	1	345	211	211
17	outage of 27008 11BRWN N to 27427 11W LEXN	1	345	211	211
20	outage of 26951 11ALCALD to 27095 11ELIHU	1	161	211	211
22	outage of 26962 11ARNOLD to 27074 11DELVIN	1	161	211	211
25	outage of 27074 11DELVIN to 27444 11WI TAP	1	161	211	211
27	outage of 27095 11ELIHU to 27096 11ELIHU	1	161-69	211	211
30	outage of 27095 11ELIHU to 27096 11ELIHU	2	161-69	211	211
32	outage of 27230 11LR TAP to 27231 11LR TAP	1	161-138	211	211
35	outage of 27230 11LR TAP to 27444 11WI TAP	1	161	211	211
37	outage of 27425 11W IRVI to 27444 11WI TAP	1	161	211	211
40	outage of 26947 11ADAMS to 27412 11TYRONE	1	138	211	211
42	outage of 26977 11BARDST to 26978 11BARDST	1	138-69	211	211
45	outage of 26977 11BARDST to 27011 11BRWNCT	1	138	211	211
47	outage of 26977 11BARDST to 27276 11NELSON	1	138	211	211
50	outage of 26990 11BKR LN to 27009 11BRWN N	1	138	211	211
52	outage of 26990 11BKR LN to 27172 11HIGBY	1	138	211	211
55	outage of 26998 11BONNIE to 27211 11LEBN W	1	138	211	211
57	outage of 27009 11BRWN N to 27011 11BRWNCT	1	138	211	211
60	outage of 27009 11BRWN N to 27012 11BRWNT1	1	138	211	211
62	outage of 27009 11BRWN N to 27013 11BRWNT2	1	138	211	211
65	outage of 27009 11BRWN N to 27040 11CLAYSM	1	138	211	211
67	outage of 27009 11BRWN N to 27172 11HIGBY	1	138	211	211
70	outage of 27009 11BRWN N to 27312 11PISGAH	1	138	211	211
72	outage of 27009 11BRWN N to 27412 11TYRONE	1	138	211	211
75	outage of 27010 11BRWN P to 27012 11BRWNT1	1	138	211	211
77	outage of 27010 11BRWN P to 27013 11BRWNT2	1	138	211	211
80	outage of 27010 11BRWN P to 27116 11FAWKES	1	138	211	211
82	outage of 27010 11BRWN P to 27247 11MERCRCR	1	138	211	211
85	outage of 27010 11BRWN P to 27419 11W CLIF	1	138	211	211
87	outage of 27010 11BRWN P to 27419 11W CLIF	2	138	211	211
90	outage of 27011 11BRWNCT to 27012 11BRWNT1	1	138	211	211
92	outage of 27011 11BRWNCT to 27013 11BRWNT2	1	138	211	211
95	outage of 27036 11CLARK to 27037 11CLARK	1	138-69	211	211
97	outage of 27036 11CLARK to 27116 11FAWKES	1	138	211	211
100	outage of 27036 11CLARK to 27382 11SPENC	1	138	211	211
102	outage of 27040 11CLAYSM to 27172 11HIGBY	1	138	211	211
105	outage of 27067 11DANVIL to 27068 11DANVIL	1	138-69	211	211
107	outage of 27067 11DANVIL to 27247 11MERCRCR	1	138	211	211
110	outage of 27111 11FARM T to 27112 11FARMER	1	138	211	211

No.	Contingency	Ckt	Base kV	Area	Zone
112	outage of 27111 11FARM T to 27369 11SHARKE	1	138	211	211
115	outage of 27111 11FARM T to 27382 11SPENC	1	138	211	211
117	outage of 27112 11FARMER to 27113 11FARMER	1	138-69	211	211
120	outage of 27115 11FAWK T to 27116 11FAWKES	1	138	211	211
122	outage of 27115 11FAWK T to 27231 11LR TAP	1	138	211	211
125	outage of 27116 11FAWKES to 27117 11FAWKES	1	138-69	211	211
127	outage of 27122 11FFRT E to 27412 11TYRONE	1	138	211	211
130	outage of 27141 11GODDRD to 27347 11RODBRN	1	138	211	211
132	outage of 27172 11HIGBY to 27170 11HIGB A	1	138-69	211	211
135	outage of 27172 11HIGBY to 27171 11HIGB B	1	138-69	211	211
137	outage of 27172 11HIGBY to 27207 11LANSDW	1	138	211	211
140	outage of 27172 11HIGBY to 27337 11REYNOL	1	138	211	211
142	outage of 27186 11IBM N to 27229 11LOUDON	1	138	211	211
145	outage of 27211 11LEBN W to 27212 11LEBNON	1	138	211	211
147	outage of 27212 11LEBNON to 27213 11LEBNON	1	138-69	211	211
150	outage of 27212 11LEBNON to 27213 11LEBNON	2	138-69	211	211
152	outage of 27212 11LEBNON to 27243 11MARION	1	138	211	211
155	outage of 27212 11LEBNON to 27247 11MERC R	1	138	211	211
157	outage of 27220 11LK REB to 27221 11LK REB	1	138-69	211	211
160	outage of 27220 11LK REB to 27231 11LR TAP	1	138	211	211
162	outage of 27229 11LOUDON to 27227 11LOUD A	1	138-69	211	211
165	outage of 27229 11LOUDON to 27228 11LOUD B	1	138-69	211	211
167	outage of 27312 11PISGAH to 27313 11PISGAH	1	138-69	211	211
170	outage of 27312 11PISGAH to 27428 11W LEXN	1	138	211	211
172	outage of 27347 11RODBRN to 27348 11RODBRN	1	138-69	211	211
175	outage of 27347 11RODBRN to 27369 11SHARKE	1	138	211	211
177	outage of 27382 11SPENC to 27383 11SPENC	1	138-69	211	211
180	outage of 27382 11SPENC to 27383 11SPENC	2	138-69	211	211
182	outage of 27412 11TYRONE to 27413 11TYRONE	1	138-69	211	211
185	outage of 27419 11W CLIF to 27420 11W CLIF	1	138-69	211	211
187	outage of 27419 11W CLIF to 27420 11W CLIF	2	138-69	211	211
190	outage of 27419 11W CLIF to 27436 11WC-DD	1	138-69	211	211
192	outage of 26959 11AOSMTH to 27129 11FOGG P	EQ	69	211	211
195	outage of 26959 11AOSMTH to 27383 11SPENC	1	69	211	211
197	outage of 26972 11ATOKA to 27068 11DANVIL	1	69	211	211
200	outage of 26986 11BEREA to 27221 11LK REB	1	69	211	211
202	outage of 26986 11BEREA to 27339 11RICH S	EQ	69	211	211
205	outage of 26999 11BOONSB to 27451 11WINC S	EQ	69	211	211
207	outage of 27016 11BUENA to 27076 11DIXDAM	1	69	211	211
210	outage of 27026 11CARON to 27225 11LONDON	1	69	211	211
212	outage of 27030 11CAVE R to 27113 11FARMER	1	69	211	211
215	outage of 27030 11CAVE R to 27358 11SALT L	1	69	211	211
217	outage of 27037 11CLARK to 27129 11FOGG P	1	69	211	211
220	outage of 27037 11CLARK to 27397 11SYLVAN	1	69	211	211
222	outage of 27046 11CMPGEK to 27225 11LONDON	1	69	211	211

No.	Contingency	Ckt	Base kV	Area	Zone
225	outage of 27050 11CORBIN to 27396 11SWEETH	1	69	211	211
227	outage of 27065 11DANV 1 to 27203 11KYSTHO	EQ	69	211	211
230	outage of 27068 11DANVIL to 27168 11HARRDS	1	69	211	211
232	outage of 27076 11DIXDAM to 27436 11WC-DD	1	69	211	211
235	outage of 27076 11DIXDAM to 27450 11WILMOR	1	69	211	211
237	outage of 27082 11E BERN to 27306 11PINEHL	1	69	211	211
240	outage of 27082 11E BERN to 27314 11PITTSB	1	69	211	211
242	outage of 27113 11FARMER to 27264 11MORH W	1	69	211	211
245	outage of 27117 11FAWKES to 27272 11N.MADS	1	69	211	211
247	outage of 27117 11FAWKES to 27339 11RICH S	1	69	211	211
250	outage of 27117 11FAWKES to 27340 11RICHMO	1	69	211	211
252	outage of 27167 11HARR T to 27168 11HARRDS	1	69	211	211
255	outage of 27167 11HARR T to 27420 11W CLIF	1	69	211	211
257	outage of 27170 11HIGB A to 27391 11STONWL	1	69	211	211
260	outage of 27170 11HIGB A to 27449 11WIL D2	1	69	211	211
262	outage of 27178 11HOPEWL to 27396 11SWEETH	1	69	211	211
265	outage of 27203 11KYSTHO to 27420 11W CLIF	1	69	211	211
267	outage of 27210 11LEBN I to 27213 11LEBNON	1	69	211	211
270	outage of 27213 11LEBNON to 27385 11SPRNGF	1	69	211	211
272	outage of 27221 11LK REB to 27340 11RICHMO	1	69	211	211
275	outage of 27221 11LK REB to 27429 11WACO	1	69	211	211
277	outage of 27225 11LONDON to 27314 11PITTSB	1	69	211	211
280	outage of 27271 11N.CORB to 27396 11SWEETH	1	69	211	211
282	outage of 27272 11N.MADS to 27449 11WIL D2	EQ	69	211	211
285	outage of 27330 11PRKRSE to 27397 11SYLVAN	1	69	211	211
287	outage of 27330 11PRKRSE to 27452 11WINCHS	1	69	211	211
290	outage of 27338 11RICE T to 27429 11WACO	1	69	211	211
292	outage of 27358 11SALT L to 27383 11SPENC	1	69	211	211
295	outage of 27359 11SALVIS to 27368 11SHAKRT	1	69	211	211
297	outage of 27368 11SHAKRT to 27420 11W CLIF	1	69	211	211
300	outage of 27420 11W CLIF to 27436 11WC-DD	1	69	211	211
302	outage of 27074 11DELVIN to 29213 20BTYVL	1	161	211-220	211-220
305	outage of 27074 11DELVIN to 29346 20GRNHLJ	1	161	211-220	211-220
307	outage of 27095 11ELIHU to 29271 20COOPER	1	161	211-220	211-220
310	outage of 27243 11MARION to 29437 20MARION	1	138-161	211-220	211-220
312	outage of 26990 11BKR LN to 29203 20BKR LN	1	138-69	211-220	211-220
315	outage of 27115 11FAWK T to 29312 20FAWKES	1	138	211-220	211-220
317	outage of 27116 11FAWKES to 29312 20FAWKES	1	138	211-220	211-220
320	outage of 27116 11FAWKES to 29312 20FAWKES	2	138	211-220	211-220
322	outage of 27229 11LOUDON to 29202 20AVON	1	138	211-220	211-220
325	outage of 27231 11LR TAP to 29616 20UN CTY	1	138	211-220	211-220
327	outage of 26982 11BEATTY to 29215 20BEATTY	1	69	211-220	211-220
330	outage of 27082 11E BERN to 29300 20EBRNST	1	69	211-220	211-220
332	outage of 27110 11FARLEY to 29536 20SCORBN	1	69	211-220	211-220
335	outage of 27117 11FAWKES to 29280 20CROOKJ	1	69	211-220	211-220

No.	Contingency	Ckt	Base kV	Area	Zone
337	outage of 27178 11HOPEWL to 29410 20LAURLC	1	69	211-220	211-220
340	outage of 29201 20AVON to 29202 20AVON	1	345-138	220	220
342	outage of 29201 20AVON to 29573 20SPURLK	1	345	220	220
345	outage of 29201 20AVON to 29651 20KPE345	1	345	220	220
350	outage of 29573 20SPURLK to 29575 20SPURLK	2	345-138	220	220
352	outage of 29575 20SPURLK to 29573 20SPURLK	1	138-345	220	220
355	outage of 29651 20KPE345 to 29652 20KPE138	1	345-138	220	220
357	outage of 29213 20BTYVL to 29215 20BEATTY	1	161-69	220	220
360	outage of 29213 20BTYVL to 29507 20POWELL	1	161	220	220
362	outage of 29271 20COOPER to 29272 20COOPER	1	161-69	220	220
370	outage of 29271 20COOPER to 29292 20DENNY	1	161	220	220
372	outage of 29271 20COOPER to 29411 20LAURLD	1	161	220	220
375	outage of 29271 20COOPER to 29517 20PULASJ	1	161	220	220
377	outage of 29271 20COOPER to 29540 20S OAKH	1	161	220	220
380	outage of 29292 20DENNY to 29293 20DENNY	1	161-69	220	220
382	outage of 29308 20FALLRK to 29310 20FALLRK	1	161-69	220	220
385	outage of 29308 20FALLRK to 29613 20TYNER	1	161	220	220
387	outage of 29346 20GRNHLJ to 29613 20TYNER	1	161	220	220
390	outage of 29408 20LAURLC to 29410 20LAURLC	1	161-69	220	220
392	outage of 29408 20LAURLC to 29411 20LAURLD	1	161	220	220
395	outage of 29408 20LAURLC to 29503 20PITTSB	1	161	220	220
400	outage of 29418 20LIBERT to 29517 20PULASJ	1	161	220	220
402	outage of 29503 20PITTSB to 29613 20TYNER	1	161	220	220
405	outage of 29507 20POWELL to 29508 20POWELL	1	161-138	220	220
407	outage of 29515 20PULASK to 29517 20PULASJ	1	161	220	220
410	outage of 29528 20RUSSEL to 29540 20S OAKH	1	161	220	220
412	outage of 29613 20TYNER to 29615 20TYNER	1	161-69	220	220
415	outage of 29202 20AVON to 29230 20BOONST	1	138	220	220
417	outage of 29202 20AVON to 29313 20FAYETT	1	138	220	220
420	outage of 29202 20AVON to 29490 20PARISJ	1	138	220	220
422	outage of 29230 20BOONST to 29233 20BOONSB	1	138	220	220
425	outage of 29230 20BOONST to 29282 20DALE	1	138	220	220
430	outage of 29282 20DALE to 29397 20JKSMIT	1	138	220	220
432	outage of 29282 20DALE to 29603 20TFJ	1	138	220	220
435	outage of 29283 20DALE to 29282 20DALE	1	69-138	220	220
437	outage of 29312 20FAWKES to 29397 20JKSMIT	1	138	220	220
440	outage of 29312 20FAWKES to 29603 20TFJ	1	138	220	220
* 442	outage of 29312 20FAWKES to 29623 20WBEREA	1	138	220	220
445	outage of 29313 20FAYETT to 29315 20FAYETT	1	138-69	220	220
447	outage of 29375 20JACKVJ to 29490 20PARISJ	1	138	220	220
462	outage of 29397 20JKSMIT to 29508 20POWELL	1	138	220	220
465	outage of 29397 20JKSMIT to 29616 20UN CTY	1	138	220	220
467	outage of 29397 20JKSMIT to 29652 20KPE138	1	138	220	220
470	outage of 29397 20JKSMIT to 29652 20KPE138	2	138	220	220
472	outage of 29488 20PARIS to 29490 20PARISJ	1	138	220	220

No.	Contingency	Ckt	Base kV	Area	Zone
475	outage of 29508 20POWELL to 29510 20POWELL	1	138-69	220	220
477	outage of 29623 20WBBEREA to 29625 20WBBEREA	1	138-69	220	220
480	outage of 29195 20ALCAN to 29512 20PPG J	1	69	220	220
482	outage of 29195 20ALCAN to 29625 20WBBEREA	1	69	220	220
485	outage of 29196 20ANNVLJ to 29615 20TYNER	1	69	220	220
487	outage of 29205 20BALLRD to 29237 20BOURNE	1	69	220	220
490	outage of 29212 20BTYV D to 29215 20BEATTY	1	69	220	220
492	outage of 29215 20BEATTY to 29648 20ZACHAR	1	69	220	220
495	outage of 29222 20BLEV T to 29361 20HOPE	1	69	220	220
497	outage of 29237 20BOURNE to 29470 20NEWBY2	1	69	220	220
500	outage of 29238 20BOWEN to 29355 20HIGHHRK	1	69	220	220
502	outage of 29238 20BOWEN to 29510 20POWELL	1	69	220	220
505	outage of 29243 20BRONSJ to 29272 20COOPER	1	69	220	220
507	outage of 29260 20CLAYCJ to 29347 20HARGTJ	1	69	220	220
510	outage of 29260 20CLAYCJ to 29580 20STANTN	1	69	220	220
512	outage of 29272 20COOPER to 29566 20SOMERS	1	69	220	220
515	outage of 29272 20COOPER to 29566 20SOMERS	2	69	220	220
517	outage of 29280 20CROOKJ to 29352 20HICK P	1	69	220	220
527	outage of 29283 20DALE to 29366 20HUNT1	1	69	220	220
530	outage of 29283 20DALE to 29367 20HUNT2	1	69	220	220
532	outage of 29283 20DALE to 29468 20NEWBY1	1	69	220	220
535	outage of 29283 20DALE to 29470 20NEWBY2	1	69	220	220
537	outage of 29325 20FRNCHB to 29361 20HOPE	1	69	220	220
540	outage of 29327 20GARRCO to 29406 20LNCSTR	1	69	220	220
542	outage of 29352 20HICK P to 29511 20PPG	1	69	220	220
545	outage of 29355 20HIGHHRK to 29547 20SANDLK	1	69	220	220
547	outage of 29361 20HOPE to 29377 20JEFFVL	1	69	220	220
550	outage of 29366 20HUNT1 to 29556 20SIDEV	1	69	220	220
552	outage of 29367 20HUNT2 to 29398 20JKSMIT	1	69	220	220
555	outage of 29377 20JEFFVL to 29510 20POWELL	1	69	220	220
557	outage of 29398 20JKSMIT to 29607 20TRAPP	1	69	220	220
560	outage of 29401 20KEAVY to 29403 20KEAVJ2	1	69	220	220
562	outage of 29402 20KEAVJ1 to 29410 20LAURLC	1	69	220	220
565	outage of 29402 20KEAVJ1 to 29501 20PINEGJ	1	69	220	220
567	outage of 29403 20KEAVJ2 to 29410 20LAURLC	1	69	220	220
570	outage of 29403 20KEAVJ2 to 29536 20SCORBN	1	69	220	220
572	outage of 29406 20LNCSTR to 29468 20NEWBY1	1	69	220	220
575	outage of 29446 20MCKEE to 29615 20TYNER	1	69	220	220
577	outage of 29501 20PINEGJ to 29631 20W LOND	1	69	220	220
580	outage of 29510 20POWELL to 29580 20STANTN	1	69	220	220
582	outage of 29511 20PPG to 29512 20PPG J	1	69	220	220
585	outage of 29537 20S FORK to 29615 20TYNER	1	69	220	220
587	outage of 29605 20THLNKJ to 29626 20WBER J	1	69	220	220
590	outage of 29625 20WBBEREA to 29626 20WBER J	1	69	220	220
592	outage of 29503 20PITTSB to 27314 11PITTSB	1	161-69	220-211	220-211

No.	Contingency	Ckt	Base kV	Area	Zone
595	outage of 29233 20BOONSB to 26999 11BOONSB	1	138-69	220-211	220-211
597	outage of 29397 20JKSMIT to 27382 11SPENC	1	138	220-211	220-211
602	outage of 26648 09STUART to 29573 20SPURLK	1	345	209-220	209-220
605	outage of 26367 08ZIMER to 29573 20SPURLK	1	345	208-220	280-220
607	outage of 27197 11KENTON to 29575 20SPURLK	1	138	211-220	211-220
610	outage of 29372 20INLAND to 29575 20SPURLK	1	138	220	220
612	outage of 29440 20MAYSJV to 29575 20SPURLK	1	138	220	220
615	outage of 29521 20RENAKR to 29575 20SPURLK	1	138	220	220
617	outage of 29575 20SPURLK to 29585 20S PARK	1	138	220	220