

McBRAYER, McGINNIS, LESLIE & KIRKLAND, ^{PLLC}
ATTORNEYS-AT-LAW

Jason R. Bentley
jbentley@mmlk.com

305 Ann Street, Suite 308
Frankfort, KY 40601
(502) 875-1176
FAX (502) 226-6234

VIA HAND DELIVERY

February 15, 2013

Mr. Jeff Derouen
Executive Director
Kentucky Public Service Commission
KY State Board on Electric Generation & Transmission Siting
211 Sower Boulevard
P.O.Box 615
Frankfort, KY 40601

RE: Corrected Final Location of the Electric Transmission Line Structures by Southern Indiana Gas & Electric Co. d/b/a Vectren Energy Delivery of Indiana, Inc. Pursuant to Order of the Kentucky State Board on Electric Generation and Transmission Siting, Case No. 2010-00223

Dear Mr. Derouen:

On February 8, Vectren Energy Delivery of Indiana, Inc. (hereafter, Vectren), filed with the Siting Board an original paper copy and electronic CD copy of the "as-built" drawings/maps of the final location of the line and structures in the above referenced matter. Upon further review by Vectren, the construction engineers and the design group, we discovered three discrepancies between the as-built structures and the previously filed drawings/maps, which we are hereby correcting with this filing. Vectren respectfully requests to withdraw the maps previously filed and replace them with the enclosed, corrected paper and electronic maps.

Specifically, the three discrepancies corrected herein are as follows: Sheet 2 as previously filed incorrectly labeled Structure #67 as two poles, whereas the diagrams correctly indicate three poles as-built; Sheet 4 incorrectly listed the height of Structure #85 as 145 feet when it is actually 165 feet; and Sheet 15 incorrectly listed the height of Structure #157 as 150 feet when it is actually 145 feet. This attached maps and diagrams include these corrections. Please do not hesitate to contact me if you have any questions or concerns.

Sincerely,


Jason R. Bentley
Attorney for Vectren Energy Delivery of Indiana