

RECEIVED

JUL 23 2010

PUBLIC SERVICE  
COMMISSION

# Shelby Energy Cooperative, Inc.


## 2010-2014 Construction Work Plan

November 2009

Kentucky 30 Shelby


Shelbyville, Kentucky

I hereby certify that this 2010-2014 CWP Report was prepared by me or under my direct supervision and that I am a duly registered professional engineer under the laws of the State of Kentucky. Registration No. 16457



Dec 8, 2009  
Date

By: James D. Bridges, P.E.  
James D. Bridges, P.E.



COMMONWEALTH OF KENTUCKY  
BEFORE THE PUBLIC SERVICE COMMISSION

RECEIVED

JUL 23 2010

PUBLIC SERVICE  
COMMISSION

In the Matter of:

APPLICATION OF SHELBY ENERGY )  
COOPERATIVE, INC. FOR A CERTIFICATE )  
OF PUBLIC CONVENIENCE AND NECESSITY ) CASE NO. 2010-00244  
FOR ITS 2010 – 2014 CONSTRUCTION WORK )  
PLAN )  
)

APPLICATION

Shelby Energy Cooperative hereinafter called the "Applicant", respectfully advises the Commission that:

1. The applicant is a nonprofit membership cooperative corporation without capital stock, duly organized and existing under K.R.S. Chapter 279, engaged in the sale of electric energy at retail rates to its member-consumers in the Kentucky counties of Anderson, Carroll, Franklin, Henry, Jefferson, Oldham, Owen, Shelby, Spencer, and Trimble.

2. The name of the Applicant is "Shelby Energy Cooperative, Inc.", and its business address is 620 Old Finchville Road, Shelbyville, Kentucky 40065-1714. {807 KAR 5:001, Section 8(1)}

3. The Articles of Incorporation and all amendments thereto for the Applicant were filed in Case No. 97-231 of the Kentucky Public Service Commission and incorporated by reference herein. {807 KAR 5:001, Section 8(3)}

4. This application is for a Certificate of Public Convenience and Necessity ("CPCN") to construct electric distribution facilities as set out in the attached 2010 ~ 2014 Construction Work Plan, hereinafter referred to as the CWP.

5. The CPCN for the CWP will permit the Applicant to construct certain improvements and additions to existing distribution plant necessary to provide adequate and dependable electric service to existing and anticipated new members. System improvements recommended within the CWP will not duplicate existing facilities and are needed to correct voltage problems, improve phase balance, reduce system energy losses and provide for improved service reliability.

6. The CWP covers the period of four (4) years between 2010 and 2014, and was prepared by Shelby Energy Cooperative Inc. Engineering Department and James Bridges, PE., Distribution System Solutions. A copy of the CWP is filed herein and made a part hereof as Exhibit 1 (Shelby Energy 2010-2014 CWP Report.pdf). The CWP was submitted to the Rural Utility Service ("RUS"), for approval, which was granted December 2009; said approval is filed herein and made a part hereof within Exhibit 2 (RUS Approval.pdf).

7. The CWP was approved by the Applicant's Board of Directors on December 17, 2009. Said approval is filed herein and made a part hereof within Exhibit 3 (Board Resolution.pdf).

8. No CWP construction or extensions will require franchises or permits to be filed with the Commission.

9. The CWP and maps filed with this Application provide a description and location of new construction and extensions. All construction and extensions will

provide service to retail consuming facilities located in the territory certified to the Applicant for retail electric service under K.R.S. 278.016 ~.018.

10. Total projected expenditures for the four-year (4) CWP are estimated to be \$16,685,739 and summarized as follows:

- a) \$2,864,079 ~ Line Construction for New Services totaling 34 miles
- b) \$6,244,027 ~ Line Conversions and Line Changes totaling 63 miles
- c) \$1,431,517 ~ Transformers and Meters
- d) \$547,454 ~ Increased Service Capacity
- e) \$400,000 ~ Sectionalizing Equipment
- f) \$276,000 ~ Line Voltage Regulators
- g) \$8,000 ~ Line Capacitors
- h) \$1,085,587 ~ Poles
- i) \$316,480 ~ Security Lights

11. The anticipated annual cost of operations, excluding the cost of power, of the proposed facilities is \$1,440,000. Said anticipated cost of operation is filed herein and made a part hereof as Exhibit 4 (SEC\_costofoperation\_05312010.pdf).

12. The Applicant is filing an application with RUS to arrange 100% financing of CWP projects with the RUS treasury rate loan program. Contract and force accounts financed with internally generated funds and a short-term line of credit will be used until all loan approvals are granted. Said RUS financing will reimburse the general funds expended for the initial portion of the CWP and finance the balance of the CWP

13. The current and projected revenues are sufficient to cover any additional operating expenses that may be incurred in relation to the CWP. The addition of new

consumers-members should assist in offsetting any additional expenses. The upgraded lines will also reduce system energy losses and assist in offsetting additional expenses.

WHEREFORE, the Applicant now moves the Public Service Commission of the Commonwealth of Kentucky to grant the said Certificate of Public Convenience and Necessity for Applicant's CWP which the Applicant has herein requested and which the Commission has discretion to grant pursuant to KRS 278.020 (1).

WITNESS the hand of the Applicant on this the 15<sup>th</sup> day of July, 2010; by its authorized representative.

**SHELBY ENERGY COOPERATIVE, INC.**

BY: Gary Grubbs  
Gary Grubbs, P.E.  
Interim Engineer

BY: Don Prather  
Don Prather  
Mathis, Riggs & Prather  
Attorneys for Applicant  
500 Main Street  
Shelbyville, Ky. 40065

STATE OF KENTUCKY

COUNTY OF SHELBY

Subscribed, sworn to and acknowledged before me by Gary Grubbs, P.E., as Interim Engineer of SHELBY ENERGY COOPERATIVE, INC. this 15<sup>th</sup> day of July, 2010.

*Candice H. Waford*

NOTARY PUBLIC, STATE AT LARGE, KY

MY COMMISSION EXPIRES: 01/13/14

STATE OF KENTUCKY

COUNTY OF SHELBY

Subscribed, sworn to and acknowledged before me by Don Prather, as Attorney for SHELBY ENERGY COOPERATIVE, INC. this 15<sup>th</sup> day of July, 2010.

*Mary Ellen White*


NOTARY PUBLIC, STATE AT LARGE, KY


MY COMMISSION EXPIRES: 7/5/12

Case No. 2010-00244







Your Touchstone Energy® Partner 

## KY 30 2010-2014 CONSTRUCTION WORK PLAN

December 2009

### **BER – Borrower's Environmental Report**

1. Construction techniques
  - a. Overhead construction
  - b. No new right-of-way normally required – the code 300 projects have not been staked
  - c. Pole replacements will be necessary but not in the same holes
  - d. Re-alignment of lines will not be necessary
2. Best Management Practices
  - a. Truck ruts are filled in and soil re-seeded
  - b. Old pole holes are re-filled and soil re-seeded
  - c. Old poles are disposed properly



RECEIVED  
FEB 18 2010

**United States Department of Agriculture  
Rural Development**

*David G*

Ms. Debbie Martin, Jr.  
President and CEO  
Shelby Energy Cooperative, Inc.  
620 Old Finchville Road  
Shelbyville, Kentucky 40065-1714


Dear Ms. Martin:

We have reviewed the Environmental Report (ER) covering the facilities recommended in Shelby Electric Cooperative, Inc.'s (Shelby Energy) 2010-2014 Construction Work Plan (CWP). In accordance with 7 CFR Part 1794, Environmental Policies and Procedures, as amended, all projects proposed in the CWP are Categorical Exclusions. No additional environmental information needs to be submitted for review, provided the projects do not change from what has been described in the ER.

Your CWP was approved by Mike Norman on December 17, 2009, contingent on approval of the ER. Shelby Energy now has environmental clearance for all projects in the CWP and is responsible for acquiring the necessary permits for construction and operation of the proposed projects.

Thank you for your assistance and cooperation in helping us fulfill our environmental review requirements. If you have any questions, please contact me at (202) 720-1994 or Ms. Lauren McGee, Environmental Scientist, at (202) 720-1482 or [lauren.mcgee@wdc.usda.gov](mailto:lauren.mcgee@wdc.usda.gov).

Sincerely,




CHARLES M. PHILPOTT  
Chief, Engineering Branch  
Northern Regional Division  
USDA Rural Utilities Service

1400 Independence Ave, S.W. - Washington DC 20250-0700  
Web: <http://www.rurdev.usda.gov>

Committed to the future of rural communities.

"USDA is an equal opportunity provider, employer and lender."  
To file a complaint of discrimination, write USDA, Director, Office of Civil Rights,  
1400 Independence Avenue, S.W., Washington, DC 20250-9410 or call (800) 795-3272 (Voice) or (202) 720-6382 (TDD).




Your Touchstone Energy® Partner 

## RESOLUTION

WHEREAS, a four-year construction work plan dated 2010 - 2014, in the amount of \$16,685,739.00 has been prepared by Shelby Energy Cooperative Inc. Engineering Department and James Bridges, P.E., Distribution System Solutions.

NOW, THEREFORE BE IT RESOLVED, that the Board of Directors of Shelby Energy Cooperative Inc. hereby approves the 2010 - 2014 work plan as a course of action to be followed, or until amended with approval of RUS.

I, Roger Taylor, Secretary - Treasurer of Shelby Energy Cooperative Inc., do hereby certify that the above is true and correct excerpt from the minutes of a regular meeting of the Board of Directors of Shelby Energy Cooperative Inc. held on the 17th day of December, 2009, at which meeting a quorum was present.

  
\_\_\_\_\_  
ROGER TAYLOR, Secretary - Treasurer

December 17, 2009

**2010-2014 Construction Workplan (CWP)**

Debbie Martin, President & CEO  
Shelby Energy Cooperative

I have completed my review of the cooperative's 2010-2014 CWP, which was prepared by Jim Bridges, and find it to be generally satisfactory for loan contract purposes. Approval to proceed with the proposed distribution system construction is contingent upon RUS's review and approval of an Environmental Report (reference 7 CFR 1794).

Headquarters, SCADA, and load management projects will be reviewed/approved by the Northern Regional Division office, as necessary. This action will be taken after their receipt of the CWP and other supporting documents (i.e., appropriate feasibility and engineering studies).

You should make a special effort to inform all of the cooperative's employees and contractors, involved in the construction of utility plant of any commitments made in the Environmental Report covering the construction of the facilities recommended in the CWP.

Changes (line improvements, tie lines, extensions, substations, etc.) in the CWP will require RUS approval. The environmental acceptability of any such changes shall also be established in accordance with 7 CFR 1794. The procedure for satisfying these environmental requirements shall be the same as that used in connection with this CWP approval.

It is your responsibility to determine whether or not loan funds and/or general funds are available for the proposed construction. If general funds are used, the requirements as outlined in 7 CFR 1717 need to be followed.

The construction shall be accomplished in accordance with RUS requirements. Specific reference should be made to 7 CFR 1726, Electric System Construction Policies and Procedures.

*Mike Norman*

Mike Norman  
RUS Field Representative

**Anticipated Annual Additional Cost of Operation After Completion of all CWP Projects:**

**Estimated Depreciation:**

<i>Account No.</i>	<i>Balance 5/31/2010</i>	<i>Monthly Rate X 12</i>	<i>Depreciation</i>	<i>per cent of total</i>	<i>Estimated Capitalization</i>	<i>Estimated Depreciation</i>
36400	\$19,110,120.00	3.00%	\$573,303.60	30.94%	\$4,950,982	\$148,529
36500	\$17,390,384.16	3.00%	\$521,711.52	28.16%	\$4,505,439	\$135,163
36600	\$307,518.52	3.00%	\$9,225.56	0.50%	\$79,671	\$2,390
36700	\$3,482,458.58	3.00%	\$104,473.76	5.64%	\$902,223	\$27,067
36800	\$8,739,110.38	3.00%	\$262,173.31	14.15%	\$2,264,098	\$67,923
36900	\$9,514,028.23	3.00%	\$285,420.85	15.41%	\$2,464,861	\$73,946
37000	\$1,430,258.83	3.00%	\$42,907.76	2.32%	\$370,546	\$11,116
37100	\$1,725,032.00	3.00%	\$51,750.96	2.79%	\$446,915	\$13,407
37300	\$58,916.23	3.00%	\$1,767.49	0.10%	\$15,264	\$458
	\$61,757,826.93		\$1,852,734.81	100.00%	\$16,000,000	<b>\$480,000</b>

**Estimated Property Taxes:**

<i>2009 Taxes</i>	<i>Property @ 12/31/09</i>	<i>Average Rate</i>	<i>Work Plan Amount</i>	<i>Estimated Taxes</i>
\$579,301	\$53,483,849	1.08%	\$16,000,000	<b>\$173,301</b>

**Estimated Interest Expense:**

<i>Plant</i>	<i>Estimated Interest Rate</i>	<i>Estimated Interest Expense</i>
\$16,000,000	5.00%	<b>\$800,000</b>

**Estimated Operation and Maintenance Expense:**

<i>Plant</i>	<i>Estimated O&amp;M %</i>	<i>Estimated O&amp;M Expense</i>
\$16,000,000	2.00%	<b>\$320,000</b>

**Estimated cost of operation after the proposed facilities are completed:**

**\$1,773,301**

TABLE OF CONTENTS

**SHELBY ENERGY COOPERATIVE, INC.  
2010 – 2014 CONSTRUCTION WORK PLAN REPORT**

**Kentucky 30 Shelby**

**TABLE OF CONTENTS**

<b>SECTION NUMBER</b>	<b>TITLE</b>
<b>I.</b>	<b>EXECUTIVE SUMMARY</b>
	A. Purpose, Results and General Basis of Study
	B. Service Area and Power Supply
	C. Summary of Construction Program and Costs
<b>II.</b>	<b>STUDY GUIDELINES AND ANALYSIS OF SYSTEM</b>
	A. Distribution System Design Criteria
	B. Distribution and Line Equipment Costs
	C. Status of Previous CWP Items
	D. Analysis of System Studies
	E. Analysis of Substation Loading and Reliability
<b>III.</b>	<b>DATA RESOURCES</b>
	A. Data Resources
	B. Basic Data and Assumptions, Historical Data/Cost Summary
<b>IV.</b>	<b>PROPOSED CONSTRUCTION ITEMS</b>
	A. Service to New Customers
	B. System Improvements
	C. Miscellaneous Distribution Equipment
	D. Security Lights
	<b>APPENDICES</b>
	A. Economic Conductor Analysis
	B. EKPC LRP Review

EXECUTIVE SUMMARY



**PURPOSE OF REPORT**

This report documents the engineering analysis of, and summarizes the proposed construction for Shelby Energy Cooperative, Inc.'s (SEC) electric distribution system for the four-year planning period of 2010-2014.

The report also provides engineering support in the form of descriptions, costs and justifications of the required new facilities for a loan application to RUS in order to finance the proposed construction program.

**GENERAL BASIS OF STUDY**

The winter 2014 projected total peak system load was taken from the 2008 Load Forecast (LF) as approved by RUS. Residential and small commercial loads were grown at rates consistent with the LF.

System analysis models are based on non-coincidental (NC) system peaks that are outlined in the LF. The projected winter 2014 NC peak (based on LF and GFR meeting) is 125,000 kW. The system annual load factor is projected to average 53.8% over the next four years.

The existing winter and summer growth models were examined for what is a winter-peaking system. The existing summer model was reviewed to ensure that any system deficiencies for the cooling load closely tracked the winter model. This was determined to be the case.

The SEC 1999-2018 Long Range Plan (LRP) load projections and improvement recommendations were reviewed and they generally agree with scope of the 2010-2014 CWP recommendations. A review of the LRP is included in this report.

A RUS Operations and Maintenance Survey (FORM 300) has been completed with the RUS GFR. This survey is used to determine portions of the construction required to replace physically deteriorated equipment and material, upgrade areas of the system to conform to code or safety requirements, and improve the reliability and quality of service.

**GENERAL BASIS OF STUDY (cont.)**

A system analysis using RUS guidelines and the SEC Design Criteria was performed on all of the substations and distribution lines of the system. Milsoft Integrated Solutions' PC-Based Distribution Analysis Program – "Windmil" was used to analyze the existing system configuration that was modeled with the projected load growth.

**SUMMARY - RESULTS OF PROPOSED CONSTRUCTION**

Upon completion of the proposed construction, the system will provide adequate and dependable service to 16,200 residential customers as well as 9 large power loads and 580 small commercial loads. Average monthly residential usage is projected to be 1,370 kWh. It is estimated that there will be 1,800 idle services.

A majority of this plan deals with the replacement of single-phase conductor. There are several three-phase conductor replacements. 143 circuit miles of conductor replacement and conversion will take place in the four-year plan period. Conductor replacement line sections were selected based on conductor condition, operational experience and the number of customers served.

A new double circuit feeder out of the New Castle Substation will relieve end-of-line loading on two Clay Village feeders and will defer a new distribution substation in the Defoe area. This new feed will also eliminate the need for a distribution feeder from Bluegrass Energy in southeast Henry County.

**SERVICE AREA**



Shelby Energy Cooperative, Inc. is a RUS-funded electric distribution cooperative. SEC is located in north central Kentucky between Louisville and Lexington. SEC serves portions of Carroll, Henry, Shelby and Trimble Counties with a few members in six other surrounding counties. The headquarters are located in Shelbyville, Kentucky (Shelby County) with a branch office in Bedford (Trimble County). *See Map on following page.*

The principal counties served by SEC are mostly rural with a high percentage of people relying on agricultural enterprises, manufacturing and government services for income. A number of commercial and industrial areas are in the service territory. Steady growth is projected for new commercial, small manufacturing and residential customers in selected areas of the system. The Shelby Industrial Park remains the focal point of SEC's present and future industrial and large commercial growth.

**The following data is from SEC's 12/08 RUS Form 7:**

<i>Total Services in Place</i>	<i>17,288</i>
<i>MWH Purchases</i>	<i>473,891</i>
<i>MWH Sold</i>	<i>453,798</i>
<i>Maximum kW Demand</i>	<i>113,000</i>
<i>Total Utility Plant</i>	<i>\$62,537,689</i>
<i>Plant Dollars Per Member</i>	<i>\$3,617</i>
<i>Consumers/Mile</i>	<i>8.3</i>

SEC has 38 distribution circuits with 11 of the circuits operating at 14,400/24,900 kV. The remaining circuits operate at 7,200/12.47 kV.



# SHELBY ENERGY COOPERATIVE SERVICE AREA

**GENERATION and TRANSMISSION POWER SUPPLIER**

East Kentucky Power Cooperative (EKPC) provides all power and energy needs to SEC and fifteen other distribution cooperatives. EKPC is located in Winchester, Kentucky.

The Load Forecast (LF) is a joint effort between SEC and EKPC. SEC provides loading data and system growth predictions to EKPC for use in the LF growth models.

All new distribution, transmission, and substation construction requirements are considered simultaneously as a "one system" concept - between SEC & EKPC - for the orderly and economical development of the total system. All of the recommendations relative to power supply and delivery are discussed with EKPC.

**SUMMARY OF CONSTRUCTION PROGRAM AND COSTS**

Shelby Energy Cooperative's distribution system was analyzed in order to identify the construction requirements needed to adequately serve the projected CWP load of 125 MW. Improvements were identified based on voltage drop, conductor loading, system reliability improvement, economic conductor analysis and operational experience. A narrative list of system improvements is located in Section IV.

A breakdown of proposed construction projects by RUS 740C codes is listed below in Table I-C-1.

**Table I-C-1  
System Additions and Improvements Summary**

<b>RUS Form 740C Category</b>	<b>Category Name</b>	<b>Estimated Cost</b>
<b>100</b>	<b>New Distribution Line</b>	<b>\$2,864,078</b>
<b>300</b>	<b>Line Conversion &amp; Improvements</b>	<b>\$6,244,027</b>
<b>600</b>	<b>Misc. Equip &amp; Poles</b>	<b>\$7,261,154</b>
<b>700</b>	<b>Security Lights</b>	<b>\$316,480</b>
	<b>2010-2014 CWP TOTAL</b>	<b>\$16,685,739</b>

100 – New Construction planned to serve 1,258 new services.

300 – 63 miles of conductor upgrading, replacement and feeder rehabilitation.

600 – Miscellaneous distribution equipment and pole changes. This includes 80 miles of aged conductor replacement, voltage regulators, sectionalizing, meters, transformers, pole changes and increased service capacity upgrades.

700 – Other Distribution Items - Security Lights 701.

SHELBY ENERGY COOPERATIVE, INC 2010-2014 CWP  
COST SUMMARY SPREADSHEET

NEW CONSTRUCTION -- RUS CODE 100

ITEM	RUS CODE	AVE. \$/CONSUMER	# CONS.	2010/2011	2011/2012	2012/2013	2013/2014	TOTAL
New Services	100	\$2,223	1250	\$627,300	\$652,392	\$735,028	\$764,429	\$2,779,150
New Large Poppers	102	\$10,616	8	\$20,000	\$20,800	\$21,632	\$22,497	\$84,929
Total Mileage				8.5	8.5	8.5	8.5	34.0
		TOTAL CODE 100:		\$647,300	\$673,192	\$756,660	\$786,926	\$2,864,079

LINE CONVERSION - RUS CODE 300

SUB-SECTION	RUS CODE	CONDUCTOR	\$/MILE	MILES	2010/2011	2011/2012	2012/2013	2013/2014	TOTAL
Logan II 450	301	#2 ACSR-1φ to #2 ACSR-Vφ	\$55,820	0.5	\$27,910				\$27,910
Jericho 319 & 952	302	#4 ACSR-1φ to 1/0 ACSR-3φ	\$78,510	1.9	\$149,169				\$149,169
Jericho 317	303	#4 ACSR-1φ to #2 ACSR-Vφ	\$62,790	1.7			\$106,743		\$106,743
Jericho 788	304	#4 ACSR-3φ to 336.4 ACSR-3φ	\$131,650	0.3			\$39,489		\$39,489
Clayville 443	305	#4 ACSR-1φ to #2 ACSR-Vφ	\$55,820	0.9	\$50,238				\$50,238
Clayville 384	306	#4 ACSR-1φ to #2 ACSR-Vφ	\$55,820	1.5	\$83,730				\$83,730
Clayville 391	307	#4 ACSR-1φ to #2 ACSR-Vφ	\$55,820	0.8	\$44,656				\$44,656
Clayville 417 "Bardstown Trail"	308	#2 ACSR-1φ to #2 ACSR-Vφ	\$58,050	2.5		\$145,125			\$145,125
New Castle 257	309	#2 CU-3φ to 336.4 ACSR-3φ	\$121,700	1.9		\$231,230			\$231,230
New Castle 325	310	#4 ACSR-3φ to #2 ACSR-3φ	\$76,180	1.8		\$137,124			\$137,124
New Castle 331	311	#4 ACSR-1φ to #2 ACSR-Vφ	\$58,050	0.1	\$5,805				\$5,805
New Castle 300 & 302	312	#2 ACSR-1φ to #2 ACSR-Vφ	\$58,050	1.3		\$75,465			\$75,465
New Castle 299 & 726	313	#2 ACSR-1φ to #2 ACSR-3φ	\$79,230	3.1		\$245,613			\$245,613
New Castle 297	314	#4 ACSR-1φ to #2 ACSR-Vφ	\$60,375	0.4		\$24,150			\$24,150
New Castle 306, 308, 929 & 830*	324	#4 ACSR-1φ to 1/0 ACSR-3φ	\$82,400	3.9		\$321,360			\$321,360
New Castle 305, 294 & 293	315	1/0 ACSR-3φ to 336.4 ACSR-3φ	\$126,570	3.7		\$468,309			\$468,309
New Castle 284LD, 312, 315 & 316	316	4ACWC-3φ to 336.4 ACSR-3φ	\$117,020	3.4	\$397,868				\$397,868
Campbellsburg 237 & 197	317	1/0CU-3φ to DCT336.4 ACSR-3φ	\$218,000	1.2		\$261,600			\$261,600
Campbellsburg 236	318	1/0CU-3φ to 336.4 ACSR-3φ	\$131,650	0.9			\$118,467		\$118,467
Campbellsburg 232 & 235	319	#2 CU-3φ to 336.4 ACSR-3φ	\$131,650	3.5			\$460,705		\$460,705
Campbellsburg 134 & 158	320	#2 CU-3φ to 336.4 ACSR-3φ	\$117,020	2.5	\$292,550				\$292,550
Campbellsburg 150 & 155	321	#2 CU-3φ to 336.4 ACSR-3φ	\$121,700	1.7		\$206,890			\$206,890
Campbellsburg 766	322	#2 ACSR-1φ to #2 ACSR-3φ	\$76,180	1.4		\$106,652			\$106,652
Campbellsburg 765 & 144	323	#2 ACSR-Vφ to #2 ACSR-3φ	\$79,230	1.5		\$118,845			\$118,845
Campbellsburg 196	325	#2 CU-3φ to 336.4 ACSR-3φ	\$121,700	2.7		\$328,590			\$328,590
Campbellsburg 188 & 185	326	#4 ACSR-3φ to 336.4 ACSR-3φ	\$126,570	5.1		\$645,507			\$645,507
Bedford 65	327	#2 ACSR-1φ to #2 ACSR-Vφ	\$55,820	2.5	\$139,550				\$139,550
Bedford 74, 73, 71 & 764	328	#2 CU-3φ to 336.4 ACSR-3φ	\$117,020	2.9	\$339,358				\$339,358
Bedford 230 & 724	329	#2 CU-3φ to 336.4 ACSR-3φ	\$131,650	3.5			\$460,705		\$460,705
Southville 301	330	#2 ACSR-1φ to #2 ACSR-Vφ	\$55,820	1.3	\$72,566				\$72,566
Southville 864	331	#2 ACSR-Vφ to #2 ACSR-3φ	\$73,250	0.1	\$7,325				\$7,325
Milton 11	332	#2 ACSR-1φ to #2 ACSR-Vφ	\$58,050	0.9		\$52,245			\$52,245
Milton 23	333	#2 ACSR-1φ to #2 ACSR-Vφ	\$60,375	1.3		\$78,488			\$78,488
		TOTAL CODE 300:		62.7	\$1,604,920	\$1,550,726	\$1,580,912	\$1,507,469	\$6,244,027

\* Carryover Item

MISCELLANEOUS DISTRIBUTION EQUIPMENT - RUS CODE 600'S

ITEM	RUS CODE	4 YR. AVE. COST	# ITEMS	2010/2011	2011/2012	2012/2013	2013/2014	TOTAL
New Transformers	601	\$1,231	1036	\$279,750	\$290,940	\$345,371	\$339,394	\$1,275,655
New Meters	601	\$120	1298	\$35,340	\$36,754	\$41,063	\$42,705	\$155,862
Service Upgrades	602	\$3,111	176	\$128,920	\$134,077	\$139,440	\$145,017	\$547,454
Sectionalizing	603			\$100,000	\$100,000	\$100,000	\$100,000	\$400,000
Voltage Regulators	604			\$74,000	\$91,400	\$60,600	\$50,000	\$276,000
Capacitors	605			\$8,000	\$0	\$0	\$0	\$8,000
Pole Changes -Including Clearance	606	\$2,320	468	\$255,645	\$265,871	\$276,506	\$287,566	\$1,085,587
Miscellaneous Replacement	607			\$100,000	\$100,000	\$100,000	\$100,000	\$400,000
Conductor Replacement	608		80 miles	\$733,000	\$762,300	\$792,792	\$824,504	\$3,112,596
		TOTAL						
		MISC. CODE 600'S:		\$1,714,655	\$1,781,342	\$1,855,972	\$1,909,186	\$7,261,154

OTHER DIST. ITEMS - RUS CODE 700

ITEM	RUS CODE	4 YR. AVE. COST	# ITEMS	2010/2011	2011/2012	2012/2013	2013/2014	TOTAL
Security Lights	701	\$578	548	\$74,528	\$77,509	\$80,609	\$83,834	\$316,480
		TOTAL						
		CODE 700:		\$74,528	\$77,509	\$80,609	\$83,834	\$316,480


CONSTRUCTION WORK PLAN TOTAL:

\$16,685,739

2010-2014 Kentucky 30 - Shelby



STUDY GUIDELINES



**DISTRIBUTION SYSTEM DESIGN CRITERIA**

- 1) The minimum voltage on primary distribution lines is 118 volts (120 volt base, 126 volts at source) after re-regulation.
- 2) Primary conductors will be evaluated at 75% of their thermal rating.
- 3) The following equipment will be evaluated at the percentage shown:
  - a) Distribution Transformers 130% winter; 100% summer
  - b) Voltage Regulators 130% winter; 100% summer
  - c) Step Voltage Transformers 130% winter; 100% summer
  - d) Reclosers and Fuses 80% winter; 80% summer
- 4) Conversions to multiphase are to correct voltage drop and phase balance. Line sections operating at 12.5/7.2 kV with load currents exceeding 45 amps will be considered for multiphasing. 24.9/14.4 kV lines with load currents exceeding 40 amps will be considered for multiphasing. Line sections with greater than 60 customers will be considered for multiphasing. Operation and engineering practices used to develop the loading criteria are based on a single phase line interruption that may cause an operation of the ground trip relay on three phase oil circuit reclosers.
- 5) Three phase tie points between substations should be equipped with air break switches.
- 6) Conductors and structures will be considered for replacement as needed.

**DISTRIBUTION LINE AND EQUIPMENT COSTS**

Construction cost estimates for the four year planning period are shown in Table II-B-1. Cost summaries for distribution equipment are shown in Table II-B-2.

**Table II-B-1  
Line Construction Cost Estimates  
Annual Projected Dollars/Mile**

SIZE	TYPE	10/11	11/12	12/13	13/14
#2 ACSR	CONV 3-PH	\$73,250	\$76,180	\$79,230	\$82,400
1/0 ACSR	CONV 3-PH	\$78,510	\$81,650	\$84,915	\$88,315
336.4 ACSR	CONV 3-PH	\$117,020	\$121,700	\$126,570	\$131,630
#2 ACSR	CONV V-PH	\$55,820	\$58,050	\$60,375	\$62,790
336.4 ACSR	CON DC 3-PH	\$209,615	\$218,000	\$226,720	\$235,790
#2 ACSR	CONV 1-PH	\$36,650	\$38,115	\$39,640	\$41,225
1/0 ACSR	CONV 1-PH	\$45,360	\$47,175	\$49,060	\$51,025
1/0 ALUG	REPL 1-PH	\$66,600	\$69,300	\$72,000	\$74,900
1/0 ALUG	REPL 3-PH	\$183,600	\$191,000	\$198,500	\$206,500

**Table II-B-2  
Distribution Equipment Cost Estimates  
Annual Projected Unit Costs**

DEVICE	TYPE	10/11	11/12	12/13	13/14
V.Regulators (3)	100 amp	\$36,000	\$37,400	\$39,000	\$40,500
V.Regulators (3)	150 amp	\$44,000	\$45,700	\$47,600	\$49,500
V.Regulators (3)	219 amp	\$50,000	\$52,000	\$54,100	\$56,250
V.Regulators (1)	100 amp	\$12,000	\$12,500	\$13,000	\$13,500
300 kVAR Capacitors	3-ph w/ cont.	\$4,000	\$4,160	\$4,325	\$4,500
600 kVAR Capacitors	3-ph w/ cont.	\$5,000	\$5,200	\$5,400	\$5,625
Reclosers	3-ph Elect.	\$38,000	\$39,500	\$41,100	\$42,750
Reclosers	1-ph OCR	\$3,500	\$3,640	\$3,800	\$3,940

**STATUS OF PREVIOUS CWP ITEMS**

All projects from the 2005-2009 CWP have been completed except the following items.

<b>740 C #</b>	<b>Project Description</b>	<b>Status</b>
310	Clayvillage 422	DEFERRED
322	New Castle 303, 291, 293, 294	DEFERRED
324	New Castle 306,308,929, & 830	CARRYOVER
326	Campbellsburg 232 & 235	REVISED/UPGRADED (319)
327	Campbellsburg 150,153,154&158	REVISED/UPGRADED (320,321)
328	Campbellsburg 234	DEFERRED
332	Southville 506	DEFERRED
338	Jericho 931	REVISED (302)

**ANALYSIS OF 1999-2018 LONG RANGE PLAN**

The current Long Range Plan (LRP) projects a peak of 124 MW for the winter of 2008/2009. The loading level of 125 MW for the 2014 construction work plan peak is in basic agreement with the LRP. With the recent economic slowdown, the work plan projections are in line with the most recent EKPC load forecast.

The LRP preferred plan projects the *Todd's Point Substation*. The *Long Run Substation*, was energized in the summer of 2000 and will defer the construction of a substation at Todd's Point for a number of years past the CWP planning period.

There are no new substations required in the 2010-2014 CWP period. A new substation at Defoe has been deferred by double circuiting a feeder line heading southeast from the New Castle Substation.

Continued conductor replacement is scheduled in the LRP. This CWP report recommends and outlines an ongoing conductor replacement program.

In *summary*, the 2010-2014 Construction Work Plan is in basic agreement with the current LRP.

**OPERATIONS & MAINTENANCE SURVEY**

The current O&M Survey ("Review Rating Summary") was completed in June 2008.

The following items were noted:

- A program is underway to remove telephone poles left next to electric poles.
- There were some shade tree problems noted in the right-of-way.
- The report of idle services is being reconciled with billing records.

### SECTIONALIZING STUDIES

A sectionalizing study analyzes the existing overcurrent protection scheme and proposes changes to improve the overall effectiveness of the scheme.

Sectionalizing studies take place on a substation-by-substation basis.

The four main goals of a sectionalizing study are Safety, Reliability, Coordination, and Protection.

1. Safety – Sectionalizing devices should be able to detect and interrupt the full range of fault currents available in their zone of protection coverage. Calculated minimum fault current values (Using RUS Bulletin 61-2) should be detected and cleared by the protective device.
2. Reliability – Limit the outage hours per consumer by isolating or “sectionalizing” faulted portions of the circuit so that the minimum number of customers are interrupted. Additional devices – where needed – will further limit the overall outage hours.
3. Coordination – Good protective device coordination will ensure that the closest device to the fault opens. Fault locating is also enhanced. Miscoordination of protective devices can cause confusion and ultimately add to outage times.
4. Protection – A well designed protection scheme will minimize damage to the distribution system by limiting the time that damaging overcurrent is present on the faulted portion of the system.

Changes that can affect the coordination scheme include: load growth; substation transformer capacity increases; reconductoring distribution lines; single-phase to three-phase conversions; changes in the system’s circuit configuration; and the addition of loads in specific locations.

The ongoing, substation-by-substation sectionalizing study will coincide with the construction projects in the CWP report. General sectionalizing device cost projections will be listed in the “603” category in this report.

Substation Loading

TABLE II-E-1 HISTORY & FORECAST

SUBSTATION/BASE KVA	KVA CAPACITY	Jan-09	Aug-07	%LOAD 2009	Jan-14	%LOAD 1/14
Bedford/11200	18144	11005	8061	60.65	10980	60.52
Bekaert #1/14000	13620	10633	13565	99.60	4347	23.96
Bekaert #2/11200	13620	7369	8620	63.29	10752	59.26
Bekaert #3/15000	14900				8539	56.93
Blue Grass Tie*	--	148	201	---	148	---
Budd/11200	13620	5722	9052	66.46	6582	36.28
Campbellsburg/11200	18144	10617	7841	58.52	13500	74.40
Clay Village/11200	18144	14201	9858	78.27	16492	90.90
Jericho/11200	15720	11429	8216	72.70	13078	83.19
Logan #1/14000	18144	7374	6109	40.64	10588	58.36
Logan #2/14000	18144	7648	5445	42.15	9375	51.68
Long Run/5600	5540	4436	4547	82.08	4984	63.41
Milton/11200	15720	8053	4824	51.23	8609	54.76
New Castle/11200	15720	8953	6278	56.95	10079	64.12
Southville/11200	15720	8418	7363	53.55	9264	58.93

SUMMER RATINGS IN GREEN  
Bekaert #1 relieved  
by Bekaert #3 - Energized in 2009

**SERVICE RELIABILITY**

The record of SEC's service interruptions for the past five years is shown in Table II-E-2. The five-year average outage hours per consumer were **5.95**. An average of five hours per consumer per year is generally considered to be an indication of good reliability by RUS. Major storms in 2006 and Hurricane Ike in 2008 were major factors that have skewed this indicator.

**TABLE II-E-2**

	<u>Power Supplier</u>	<u>Extreme Storm</u>	<u>Prearranged</u>	<u>All Other</u>	<u>Total</u>
<i>2004</i>					
<i>OUTAGE HR/CONS</i>	<i>0.02</i>	<i>2.89</i>	<i>0.04</i>	<i>1.04</i>	<i>3.99</i>
<i>2005</i>					
<i>OUTAGE HR/CONS</i>	<i>0.05</i>	<i>0.00</i>	<i>0.01</i>	<i>1.08</i>	<i>1.14</i>
<i>2006</i>					
<i>OUTAGE HR/CONS</i>	<i>0.15</i>	<i>7.23*</i>	<i>0.02</i>	<i>1.58</i>	<i>8.98</i>
<i>2007</i>					
<i>OUTAGE HR/CONS</i>	<i>1.36</i>	<i>0.00</i>	<i>0.00</i>	<i>1.50</i>	<i>2.86</i>
<i>2008</i>					
<i>OUTAGE HR/CONS</i>	<i>0.31</i>	<i>11.40*</i>	<i>0.04</i>	<i>1.04</i>	<i>12.79</i>
<i>FIVE YEAR AVE.</i>					
<i>OUTAGE HR/CONS</i>	<i>0.38</i>	<i>4.30</i>	<i>0.02</i>	<i>1.25</i>	<i>5.95</i>



DATA RESOURCES

**DATA RESOURCES**

The following is a list of the basic data used for this analysis and report.

1. Updated primary map indicating the following items:
  - a) Substations with present feeder configurations.
  - b) All open points.
2. Monthly substation non-coincident peak(NCP) demands for the past year and annual system peaks as listed in the Load Forecast.
3. Billing system kW and kWh sales for last winter and summer peaks.
4. 2008 East Kentucky Power Cooperative/SEC *Load Forecast*.
5. Five Year Outage Summary.
6. RUS Form 7 data.
7. Substation transformer ratings.
8. Load projections for each existing and proposed substation covering the summer and winter peak demands.
9. Substation Data Sheets.
10. Windmil circuit model databases with voltage drop calculations for each line section.

## **BASIC DATA AND ASSUMPTIONS**

**Design Load** – The construction program in the CWP covers a four year period to serve the 125 MW, January 2014 winter peak. The design load was derived after reviewing the 2008 Load Forecast with the GFR.

**Load Allocation** – Individual substations were grown at similar rates. The total system design load was attained by allocating each substation's load to its individual line sections proportional to the number of consumers and the kWh consumption on each of the line sections. Peak summer and peak winter loading were modeled and analyzed. The system is generally winter peaking with the exception of the industrial load in the Shelbyville Industrial Park area and the Long Run residential area.

**Voltage Drop** – For the design load, an eight volt drop with one set of downline voltage regulators was assumed to be the maximum allowable drop from the substation to the end of the distribution feeder.

**Substation Voltage Regulation** – Voltage regulation was assumed for each substation such that a 10% voltage drop could be experienced on the transmission system at peak load and 126 volts could still be supplied to the substation bus.

**System Power Factor** – System power factor values were reviewed from the East Kentucky Power Substation Reports. Power factor values for each substation were within acceptable levels.

**Single-Phase Loading** – On taps where more than (*a 7.2 kV load of 325 kW or a 14.4 kV load of 575 kW*) is served from a single-phase line, conversion to 2 or 3 phase was considered in order to provide greater system reliability. Two-phase conversions were generally chosen where a single-phase line split into two taps – with a large amount of load being present on only one of the taps. Three-phase conversions were chosen for the more heavily loaded taps and when the single- phase tap split into more than two directions.

**Inflation** – An annual inflation rate of 4.0% was used in this CWP.

**Construction Cost Estimates** – Cost estimates for the various distribution equipment and conductor sizes are presented in Tables II-B-1 and II-B-2.

**Computer Model of Distribution System** – The system is modeled on Milsoft Utility Solution's Windmil analysis software. Downloading monthly billing computer data into the Windmil billing file directory was the framework for building the winter and summer models. Projected models were analyzed for Design Criteria violations.

**Economic Conductor Analysis** – Economic Conductor analysis includes the consideration of initial construction costs and the associated losses of the selected conductors. For two alternative conductors compared, there is generally a kW load level at which the fixed costs associated with construction plus the variable costs related to line losses are equal for both alternatives.

The following general recommendations were generated from the analysis:

1. New single phase line extensions should be constructed of #2 ACSR.
2. Conversions that are to remain single-phase should generally be constructed of #2 ACSR.
3. Converted 25 kv three-phase construction should be 1/0 ACSR for initial loads of up to 3,700 kW; 336.4 ACSR for initial loads of greater than 3,700 kW and also near substations.
4. Converted 12.5 kv three-phase construction should be 1/0 ACSR for initial loads of 2,200 kW and 336.4 ACSR for initial loads greater than 2,200 kW and also near substations.

The data tables preceding each analysis graph lists the assumptions that were made in each scenario of the conductor analysis. This analysis appears in the Appendices of this report.

#### **FINANCIAL DATA**

- *Cost of Capital = 5.0%*
- *Inflation = 4.0%*
- *Increase in Cost of Power = 2.0%*
- *Present Worth Discount Factor = 5.0%*
- *Depreciation = 2.88%*
- *O & M = 4.44%*
- *Tax & Insurance = 0.1%*

SHELBY CWP: III-B

SHELBY ENERGY

TABLE III-B-1

Inflation = 4%

COST SUMMARY DATA

DESCRIPTION	Jan07-Dec-08	2010/2011	2011/2012	2012/2013	2013/2014	CWP TOTAL
<b>New Construction (100)</b>						
1. New services constructed	612	300	300	325	325	1250
2. Cost per Customer	\$1,934	\$2,091	\$2,175	\$2,262	\$2,352	
3. Cost of New Customers	\$1,183,809	\$627,300	\$652,392	\$735,028	\$764,429	\$2,779,150
4. Total Footage	88,227	44,000	44,000	44,000	44,000	176,000
5. Total Mileage	16.7	8.3	8.3	8.3	8.3	33.3
<b>New LP Construction (102)</b>						
1. New services constructed	4	2	2	2	2	8
2. Cost per Customer	\$9,237	\$10,000	\$10,400	\$10,816	\$11,249	
3. Cost of New Customers	\$36,947	\$20,000	\$20,800	\$21,632	\$22,497	\$84,929
4. Total Mileage		0.2	0.2	0.2	0.2	0.7
<b>Padmount Transformers (601)</b>						
1. New transformers added	45	20	20	20	20	80
2. Cost per Transformer	\$2,123	\$2,500	\$2,600	\$2,704	\$2,812	
3. Cost of New Transformers	\$95,541	\$50,000	\$52,000	\$54,080	\$56,243	\$212,323
<b>3 PH Padmount Transformers (601)</b>						
1. New transformers added	5	1	1	2	2	6
2. Cost per Transformer	\$14,817	\$16,000	\$16,640	\$17,306	\$17,998	
3. Cost of New Transformers	\$74,085	\$16,000	\$16,640	\$34,611	\$35,996	\$103,247
<b>New OH Transformers (601)</b>						
1. New transformers added	488	225	225	250	250	950
2. Cost per Transformer	\$858	\$950	\$988	\$1,028	\$1,069	
3. Cost of New Transformers	\$418,685	\$213,750	\$222,300	\$256,880	\$267,155	\$960,085
<b>New Meters (601)*</b>						
1. New Meters added	1208	300	300	325	325	1250
2. Cost per Meter	\$45	\$105	\$109	\$114	\$118	
3. Cost of New Meters	\$54,569	\$31,500	\$32,760	\$36,910	\$38,386	\$139,556
<b>New LP Meters (601)</b>						
1. New Meters added	24	12	12	12	12	48
2. Cost per Meter	\$255	\$320	\$333	\$346	\$360	
3. Cost of New Meters	\$6,125	\$3,840	\$3,994	\$4,153	\$4,319	\$16,306
<b>Service Upgrades (602)</b>						
1. Number of Service Upgrades	87	44	44	44	44	176
2. Cost per Service Upgrade	\$2,708	\$2,930	\$3,047	\$3,169	\$3,296	
3. Cost of Service Upgrades	\$235,596	\$128,920	\$134,077	\$139,440	\$145,017	\$547,454
<b>Pole Changes - Replacement (606)</b>						
1. Poles Changed	234	117	117	117	117	468
2. Cost per Pole Change	\$2,021	\$2,185	\$2,272	\$2,363	\$2,458	
3. Cost of Pole Changes	\$472,968	\$255,645	\$265,871	\$276,506	\$287,566	\$1,085,587
<b>Miscellaneous - Replacement (607)#</b>						
1. Cost of Misc. Replacements		\$100,000	\$100,000	\$100,000	\$100,000	\$400,000
<b>Conductor Replacement (608)</b>						
1. Miles of small conductor to be replaced		20	20	20	20	80
2. Cost per mile		\$36,650	\$38,115	\$39,640	\$41,225	
3. Total cost of conductor replacement		\$733,000	\$762,300	\$792,792	\$824,504	\$3,112,596
<b>Outdoor Lighting (701)</b>						
1. New Security Lights Added	274	137	137	137	137	548
2. Cost per Security Light	\$503	\$544	\$566	\$588	\$612	
3. Cost of Security Lights	\$137,730	\$74,528	\$77,509	\$80,609	\$83,834	\$316,480

\*-An amendment is being prepared to convert the entire system to AMR.

#-607 Historical Data is not available. Current projects were coded as 1600.

PROPOSED CONSTRUCTION ITEMS



**SERVICE TO NEW CUSTOMERS – RUS CODE 100**

A total of 1,258 new services are anticipated. The projected cost is \$2,864,078.

Cost history and projections are shown in Table III-B-1.

**SYSTEM IMPROVEMENTS – RUS CODE 300**

***LINE CONVERSION NARRATIVES***

**Logan II Substation**

**Code 301**

Estimated Cost: \$27,910

Year: 2010

**Description of Proposed Construction**

Section 450 - Convert 0.5 mile of single-phase #2 ACSR to V-phase #2 ACSR along Dover Road.

**Reason For Proposed Construction**


Design Criteria 4 is being violated.

**Results of Proposed Construction**

Single-phase overloading will be corrected.

**Alternative Corrective Plan Investigated**

No viable backfeeds to relieve overloading were possible.





**SYSTEM IMPROVEMENTS – RUS CODE 300**

***LINE CONVERSION NARRATIVES***

**Jericho Substation**

**Code 302**

Estimated Cost: \$149,169  
Year: 2010

**Description of Proposed Construction**

Sections 319 & 932 - Convert 1.9 miles of single-phase #4 ACSR to 3-phase 1/0 ACSR along Radcliff Road.

**Reason For Proposed Construction**


Design Criteria 4 is being violated.

**Results of Proposed Construction**

Single-phase overloading will be corrected.

**Alternative Corrective Plan Investigated**

No viable backfeeds to relieve overloading were possible.



**SYSTEM IMPROVEMENTS – RUS CODE 300**

**LINE CONVERSION NARRATIVES**

**Jericho Substation**

**Code 303**

Estimated Cost: \$106,743

Year: 2013

**Description of Proposed Construction**

Section 317 - Convert 1.7 miles of single-phase #4 ACSR to V-phase #2 ACSR along Ballardsville Road.

**Reason For Proposed Construction**


Design Criteria 4 is being violated.

**Results of Proposed Construction**

Single-phase overloading will be corrected.

**Alternative Corrective Plan Investigated**

This is a radial tap so no viable backfeeds to relieve overloading were possible.



**SYSTEM IMPROVEMENTS – RUS CODE 300**

***LINE CONVERSION NARRATIVES***

**Jericho Substation**

**Code 304**

Estimated Cost: \$39,489

Year: 2014

**Description of Proposed Construction**

Section 788 - Convert 0.3 mile of three-phase #4 ACSR to three-phase 336.4 ACSR from Hwy 42 to Martini Lane.

**Reason For Proposed Construction**


Design Criteria 6 is being violated. An important tie between two substations is in poor condition.

**Results of Proposed Construction**

Reliability and primary voltage levels will be improved.

**Alternative Corrective Plan Investigated**

No alternatives were considered due to the condition of the conductor.



**SYSTEM IMPROVEMENTS – RUS CODE 300**

***LINE CONVERSION NARRATIVES***

**Clayvillage Substation  
Code 305**

Estimated Cost: \$50,238  
Year: 2010

**Description of Proposed Construction**

Section 343 - Convert 0.9 mile of single-phase #4 ACSR to V-phase #2 ACSR at Booker Lane.

**Reason For Proposed Construction**


Design Criteria 4 is being violated.

**Results of Proposed Construction**

Single-phase overloading will be corrected.

**Alternative Corrective Plan Investigated**

This is a radial tap so no viable backfeeds to relieve overloading were possible.



**SYSTEM IMPROVEMENTS – RUS CODE 300**

***LINE CONVERSION NARRATIVES***

**Clayvillage Substation**

**Code 306**

Estimated Cost: \$83,730

Year: 2010

**Description of Proposed Construction**

Section 384 - Convert 1.5 miles of single-phase #4 ACSR to V-phase #2 ACSR at Cropper Road to Maddox.

**Reason For Proposed Construction**


Design Criteria 4 is being violated.

**Results of Proposed Construction**

Single-phase overloading will be corrected.

**Alternative Corrective Plan Investigated**

This is a radial tap so no viable backfeeds to relieve overloading were possible.





**SYSTEM IMPROVEMENTS – RUS CODE 300**

***LINE CONVERSION NARRATIVES***

**Clayvillage Substation  
Code 308**

Estimated Cost: \$145,125  
Year: 2011

**Description of Proposed Construction**

Section 417 - Convert 2.5 miles of single-phase #2 ACSR to V-phase #2 ACSR at Bardstown Trail.

**Reason For Proposed Construction**


Design Criteria 4 is being violated.

**Results of Proposed Construction**

Single-phase overloading will be corrected.

**Alternative Corrective Plan Investigated**

No viable backfeeds to relieve overloading were possible.



**SYSTEM IMPROVEMENTS – RUS CODE 300**

***LINE CONVERSION NARRATIVES***

**New Castle Substation**

**Code 309**

Estimated Cost: \$231,230

Year: 2012

**Description of Proposed Construction**

Section 257 - Convert 1.9 miles of three-phase #2 Copper to three-phase 336.4 ACSR at Batts Lane.

**Reason For Proposed Construction**


Design Criteria 6 is being violated. An important tie between two substations is in poor condition.

**Results of Proposed Construction**

Reliability and primary voltage levels will be improved.

**Alternative Corrective Plan Investigated**

No alternatives were considered due to the condition of the conductor.





**SYSTEM IMPROVEMENTS – RUS CODE 300**

***LINE CONVERSION NARRATIVES***

**New Castle Substation**

**Code 310**

Estimated Cost: \$137,124

Year: 2012

**Description of Proposed Construction**

Section 325 - Convert 1.8 miles of three-phase #4 ACSR to three-phase #2 ACSR at Sunnyside Road.

**Reason For Proposed Construction**


Design Criteria 6 is being violated.

**Results of Proposed Construction**

Reliability and primary voltage levels will be improved.

**Alternative Corrective Plan Investigated**

No alternatives were considered due to the condition of the conductor.



**SYSTEM IMPROVEMENTS – RUS CODE 300**

***LINE CONVERSION NARRATIVES***

**New Castle Substation**

**Code 311**

Estimated Cost: \$5,805

Year: 2012

**Description of Proposed Construction**

Section 331 - Convert 0.1 mile of single-phase #4 ACSR to V-phase #2 ACSR at LaGrange Road.

**Reason For Proposed Construction**


Design Criteria 4 is being violated.

**Results of Proposed Construction**

Single-phase overloading will be corrected.

**Alternative Corrective Plan Investigated**

No viable backfeeds to relieve overloading were possible.



**SYSTEM IMPROVEMENTS – RUS CODE 300**

***LINE CONVERSION NARRATIVES***

**New Castle Substation**

**Code 312**

Estimated Cost: \$75,465

Year: 2011

**Description of Proposed Construction**

Sections 300 & 302 - Convert 1.3 miles of single-phase #2 ACSR to V-phase #2 ACSR at S. Property Road to Hwy 421.

**Reason For Proposed Construction**


Design Criteria 4 is being violated.

**Results of Proposed Construction**

Single-phase overloading will be corrected.

**Alternative Corrective Plan Investigated**

No viable backfeeds to relieve overloading were possible.



**SYSTEM IMPROVEMENTS – RUS CODE 300**

**LINE CONVERSION NARRATIVES**

**New Castle Substation**

**Code 313**

Estimated Cost: \$245,613

Year: 2012

**Description of Proposed Construction**

Sections 299 & 726 - Convert 3.1 miles of single-phase #2 ACSR to three-phase #2 ACSR at Point Pleasant.

**Reason For Proposed Construction**


Design Criteria 4 is being violated.

**Results of Proposed Construction**

Single-phase overloading will be corrected.

**Alternative Corrective Plan Investigated**

No viable backfeeds to relieve overloading were possible.



**SYSTEM IMPROVEMENTS – RUS CODE 300**

**LINE CONVERSION NARRATIVES**

**New Castle Substation**

**Code 314**

Estimated Cost: \$24,150

Year: 2012

**Description of Proposed Construction**

Section 297 - Convert 0.4 mile of single-phase #4 ACSR to three-phase #2 ACSR at Point Pleasant.

**Reason For Proposed Construction**


Design Criteria 4 is being violated.

**Results of Proposed Construction**

Single-phase overloading will be corrected.

**Alternative Corrective Plan Investigated**

No viable backfeeds to relieve overloading were possible.



**SYSTEM IMPROVEMENTS – RUS CODE 300**

***LINE CONVERSION NARRATIVES***

**New Castle Substation - CARRYOVER**

**Code 324**

Estimated Cost: \$321,360

Year: 2013

**Description of Proposed Construction**

Sections 306, 308, 929 & 830 - Convert 3.9 miles of single-phase #4 ACSR to three-phase 1/0 ACSR at Raisor Lane.

**Reason For Proposed Construction**


Design Criteria 1 and 6 are being violated. A long feed from Bluegrass will be eliminated except for an emergency tie.

**Results of Proposed Construction**

Aged conductor will be replaced and voltage drop issues will be corrected.

**Alternative Corrective Plan Investigated**

No alternatives were available due to the aged conductor.



**SYSTEM IMPROVEMENTS – RUS CODE 300**

***LINE CONVERSION NARRATIVES***

**New Castle Substation**

**Code 315**

Estimated Cost: \$468,309

Year: 2012

**Description of Proposed Construction**

Sections 303, 294 and 293 - Convert 3.7 miles of three-phase 1/0 ACSR to three-phase 336.4 ACSR at F2 South Property Road.

**Reason For Proposed Construction**


Design Criteria 1 is being violated. A long feed from Bluegrass Energy will be eliminated except for an emergency tie.

**Results of Proposed Construction**

Voltage drop issues will be corrected.

**Alternative Corrective Plan Investigated**

No alternatives were available due to long the distance to other sources.



**SYSTEM IMPROVEMENTS – RUS CODE 300**

**LINE CONVERSION NARRATIVES**

**New Castle Substation**

**Code 316**

Estimated Cost: \$397,868

Year: 2010

**Description of Proposed Construction**

Sections 284, 312, 315 and 316 - Convert 3.4 miles of three-phase #4 ACWC to three-phase 336.4 ACSR at HWY 421 and Union Church Road.

**Reason For Proposed Construction**


Design Criteria 1 and 6 are being violated.

**Results of Proposed Construction**

Aged conductor will be replaced and voltage drop issues will be corrected.

**Alternative Corrective Plan Investigated**

No alternatives were available due to condition of the conductor.





**SYSTEM IMPROVEMENTS – RUS CODE 300**

***LINE CONVERSION NARRATIVES***

**Campbellsburg Substation**

**Code 317**

Estimated Cost: \$261,600

Year: 2012

**Description of Proposed Construction**

Sections 237 and 197 - Convert 1.2 miles of three-phase 1/0 CU to Double Circuit, three-phase 336.4 ACSR at HWY 55.

**Reason For Proposed Construction**


Design Criteria 6 is being violated.

**Results of Proposed Construction**

Aged conductor will be replaced and voltage drop will be improved.

**Alternative Corrective Plan Investigated**

No alternatives were available due to condition of the conductor.



**SYSTEM IMPROVEMENTS – RUS CODE 300**

***LINE CONVERSION NARRATIVES***

**Campbellsburg Substation**

**Code 318**

Estimated Cost: \$118,467

Year: 2014

**Description of Proposed Construction**

Section 236 - Convert 0.9 miles of three-phase 1/0 CU to three-phase 336.4 ACSR at HWY 55 to Munfort Lane.

**Reason For Proposed Construction**


Design Criteria 6 is being violated.

**Results of Proposed Construction**

Aged conductor will be replaced and voltage drop will be improved.

**Alternative Corrective Plan Investigated**

No alternatives were available due to condition of the conductor.



**SYSTEM IMPROVEMENTS – RUS CODE 300**

***LINE CONVERSION NARRATIVES***

**Campbellsburg Substation**

**Code 319**

Estimated Cost: \$460,705

Year: 2014

**Description of Proposed Construction**

Sections 232 and 235- Convert 3.5 miles of three-phase #2 CU to three-phase 336.4 ACSR at Jones Lane.

**Reason For Proposed Construction**


Design Criteria 6 is being violated.

**Results of Proposed Construction**

Aged conductor will be replaced and voltage drop will be improved.

**Alternative Corrective Plan Investigated**

No alternatives were available due to condition of the conductor.



**SYSTEM IMPROVEMENTS – RUS CODE 300**

***LINE CONVERSION NARRATIVES***

**Campbellsburg Substation**  
**Code 320**  
Estimated Cost: \$292,550  
Year: 2010

**Description of Proposed Construction**

Sections 154 and 158- Convert 2.5 miles of three-phase #2 CU to three-phase 336.4 ACSR at Orem Lane.

**Reason For Proposed Construction**


Design Criteria 6 is being violated.

**Results of Proposed Construction**

Aged conductor will be replaced and voltage drop will be improved.

**Alternative Corrective Plan Investigated**

No alternatives were available due to condition of the conductor.



**SYSTEM IMPROVEMENTS – RUS CODE 300**

***LINE CONVERSION NARRATIVES***


**Campbellsburg Substation**  
**Code 321**  
Estimated Cost: \$206,890  
Year: 2011

**Description of Proposed Construction**  
Sections 150 and 153 – Convert 1.7 miles of three-phase #2 CU to three-phase 336.4 ACSR at Hwy 193.

**Reason For Proposed Construction**  
Design Criteria 6 is being violated.

**Results of Proposed Construction**  
Aged conductor will be replaced and voltage drop will be improved.

**Alternative Corrective Plan Investigated**  
No alternatives were available due to condition of the conductor.



**SYSTEM IMPROVEMENTS – RUS CODE 300**

***LINE CONVERSION NARRATIVES***

**Campbellsburg Substation**

**Code 322**

Estimated Cost: \$106,652

Year: 2011

**Description of Proposed Construction**

Section 766 – Convert 1.4 miles of single-phase #2 ACSR to three-phase #2 ACSR at Vance Road.

**Reason For Proposed Construction**


Design Criteria 4 is being violated.

**Results of Proposed Construction**

Current overloading will be corrected.

**Alternative Corrective Plan Investigated**

No viable backfeeds to relieve overloading were possible.



**SYSTEM IMPROVEMENTS – RUS CODE 300**

***LINE CONVERSION NARRATIVES***

**Campbellsburg Substation**

**Code 323**

Estimated Cost: \$118,845

Year: 2012

**Description of Proposed Construction**

Sections 765 and 144 – Convert 1.5 miles of V-phase #2 ACSR to three-phase #2 ACSR at Maddox Ridge.

**Reason For Proposed Construction**


Design Criteria 1 and 4 are being violated.

**Results of Proposed Construction**

Current overloading and voltage drop problems will be corrected.

**Alternative Corrective Plan Investigated**

No viable backfeeds to relieve overloading were possible.



**SYSTEM IMPROVEMENTS – RUS CODE 300**

***LINE CONVERSION NARRATIVES***

**Campbellsburg Substation**

**Code 325**

Estimated Cost: \$328,590

Year: 2011

**Description of Proposed Construction**

Section 196 – Convert 2.7 miles of three-phase #2 CU to three-phase 336.4 ACSR at Lake Road to Industrial Park.

**Reason For Proposed Construction**


Design Criteria 1 and 6 are being violated.

**Results of Proposed Construction**

Aged conductor will be replaced and voltage drop will be improved.

**Alternative Corrective Plan Investigated**

No alternatives were available due to condition of the conductor.





**SYSTEM IMPROVEMENTS – RUS CODE 300**

***LINE CONVERSION NARRATIVES***

**Campbellsburg Substation**  
**Code 326**  
Estimated Cost: \$645,507  
Year: 2012

**Description of Proposed Construction**

Sections 188 and 185 – Convert 5.1 miles of three-phase #4 ACSR to three-phase 336.4 ACSR at Martini Lane back to Jericho Tie point.

**Reason For Proposed Construction**


Design Criteria 1 and 6 are being violated.

**Results of Proposed Construction**

Aged conductor will be replaced. Voltage drop and reliability will be improved.

**Alternative Corrective Plan Investigated**

No alternatives were available due to condition of the conductor.



**SYSTEM IMPROVEMENTS – RUS CODE 300**

***LINE CONVERSION NARRATIVES***

**Bedford Substation**

**Code 327**

Estimated Cost: \$139,550

Year: 2010

**Description of Proposed Construction**

Section 65 – Convert 2.5 miles of single-phase #2 ACSR to V-phase #2 ACSR at Harbor Point.

**Reason For Proposed Construction**


Design Criteria 1 and 4 are being violated.

**Results of Proposed Construction**

Current overloading and voltage drop problems will be corrected.

**Alternative Corrective Plan Investigated**

No viable backfeeds to relieve overloading were possible.



**SYSTEM IMPROVEMENTS – RUS CODE 300**

***LINE CONVERSION NARRATIVES***

**Bedford Substation**

**Code 328**

Estimated Cost: \$339,358

Year: 2010

**Description of Proposed Construction**

Sections 74, 73, 71 and 764 – Convert 2.9 miles of three-phase #2 CU to three-phase 336.4 ACSR at F2 SLAB.

**Reason For Proposed Construction**


Design Criteria 1 and 6 are being violated.

**Results of Proposed Construction**

Aged conductor will be replaced and voltage drop will be improved.

**Alternative Corrective Plan Investigated**

No alternatives were available due to condition of the conductor.



**SYSTEM IMPROVEMENTS – RUS CODE 300**

***LINE CONVERSION NARRATIVES***

**Bedford Substation**

**Code 329**

Estimated Cost: \$460,705

Year: 2014

**Description of Proposed Construction**

Sections 230 and 724 – Convert 3.5 miles of three-phase #2 CU to three-phase 336.4 ACSR at Hwy 316 (SLAB to Providence).

**Reason for Proposed Construction**


Design Criteria 1 and 6 are being violated.

**Results of Proposed Construction**

Aged conductor will be replaced and voltage drop will be improved.

**Alternative Corrective Plan Investigated**

No alternatives were available due to condition of the conductor.



**SYSTEM IMPROVEMENTS – RUS CODE 300**

**LINE CONVERSION NARRATIVES**

**Southville Substation**

**Code 330**

Estimated Cost: \$72,566

Year: 2010

**Description of Proposed Construction**

Section 501 - Convert 1.3 miles of single-phase #2 ACSR to V-phase #2 ACSR at Hwy 395.

**Reason For Proposed Construction**


Design Criteria 4 is being violated.

**Results of Proposed Construction**

Single-phase overloading will be corrected.

**Alternative Corrective Plan Investigated**

No viable backfeeds to relieve overloading were possible.



**SYSTEM IMPROVEMENTS – RUS CODE 300**

***LINE CONVERSION NARRATIVES***

**Southville Substation**

**Code 331**

Estimated Cost: \$7,325

Year: 2010

**Description of Proposed Construction**

Section 864 - Convert 0.1 mile of V-phase #2 ACSR to three-phase #2 ACSR at West Pea Ridge.

**Reason For Proposed Construction**


Design Criteria 1 is being violated.

**Results of Proposed Construction**

Primary voltage drop problems will be corrected.

**Alternative Corrective Plan Investigated**

This project will relieve the Design Criteria 1 violation as well as correct 3-ph feeder current imbalance.



**SYSTEM IMPROVEMENTS – RUS CODE 300**

**LINE CONVERSION NARRATIVES**

**Milton Substation**

**Code 332**

Estimated Cost: \$52,245

Year: 2011

**Description of Proposed Construction**

Section 11 - Convert 0.9 mile of single-phase #2 ACSR to V-phase #2 ACSR at Hwy 421 to McCord Lane.

**Reason For Proposed Construction**


Design Criteria 4 is being violated.

**Results of Proposed Construction**

Single-phase overloading will be corrected.

**Alternative Corrective Plan Investigated**

No viable backfeeds to relieve overloading were possible.



**SYSTEM IMPROVEMENTS – RUS CODE 300**

***LINE CONVERSION NARRATIVES***

**Milton Substation**

**Code 333**

Estimated Cost: \$78,488

Year: 2012

**Description of Proposed Construction**

Section 23 - Convert 1.3 miles of single-phase #2 ACSR to V-phase #2 ACSR at Detmer Lane.

**Reason For Proposed Construction**


Design Criteria 4 is being violated.

**Results of Proposed Construction**

Single-phase overloading will be corrected.

**Alternative Corrective Plan Investigated**

No viable backfeeds to relieve overloading were possible.





**MISCELLANEOUS DISTRIBUTION EQUIPMENT – RUS CODE 600’s**

**Meters and Transformers – RUS Code 601**

Historical data was gathered for meters and transformers and is included in Table III-B-1.

1,298 new meters are projected at a cost of \$155,862.

1,036 new transformers are projected at a cost of \$1,275,655.

**Service Upgrades – RUS Code 602**

There are 176 service upgrades projected at a total cost of \$547,454. Historical data is included in Table III-B-1.

**Sectionalizing – RUS Code 603**

Overcurrent analysis is performed on an ongoing basis. Device changeouts, conductor multiphasing and load shifts require overcurrent device purchases.

Oil circuit reclosers, fuses and switches are included in this category.

The total overall projected cost for sectionalizing is \$400,000.

**Voltage Regulators – RUS Code 604**

Eight sets of voltage regulator upgrades are projected for the CWP as follows:

CFR CODE	SUBSTATION	SECT/RATING	YEAR	COST
604.1	CLAYVILLAGE	395/ (3) 150 A	2011	\$45,700
604.2	CLAYVILLAGE	379/ (3) 150 A	2012	\$47,600
604.3	CLAYVILLAGE	849/ (3) 100 A	2013	\$40,500
604.4	NEW CASTLE	253/ (2) 100 A	2010	\$24,000
604.5	CAMPBELLSBURG	227/ (3) 219 A	2010	\$50,000
604.6	CAMPBELLSBURG	145/(3) 150 A	2011	\$45,700
604.7	CAMPBELLSBURG	186/(1) 50 A	2013	\$9,500
604.8	SOUTHVILLE	500/ (1) 100 A	2012	\$13,000

**Capacitor Banks – RUS Code 605**

Two capacitor bank applications are projected in the CWP

CFR CODE	SUBSTATION	SECT/RATING	YEAR	COST
605.1	BEDFORD	LD50/(3) 300kvar	2010	\$4,000
605.2	SOUTHVILLE	874/(3) 300kvar	2010	\$4,000

**MISCELLANEOUS DISTRIBUTION EQUIPMENT – RUS CODE 600's (cont.)**

**Pole Changes – RUS Code 606 Including Clearance Poles**

There are 468 projected pole changes in the CWP. This includes all maintenance and clearance poles. The cost for the pole changes is projected to be \$1,085,587. Historical cost data for pole changes may be found in Table III-B-1.

**Miscellaneous Replacement – RUS Code 607**

A total of \$400,000 is projected for this code category. Insulators, crossarms, braces, guys, anchors and other pole-associated hardware will be replaced as needed.

**Conductor Replacement – RUS Code 608**

There are 80 miles of aged conductor replacement in the CWP. The projected cost is \$3,112,596. This category allows conductor to be replaced on both a pre-planned and as-needed basis.

**RUS CODE 700**

**Security Lights – RUS Code 701**

A total of 548 new security lights are anticipated. The projected cost is \$316,480.  
Security light cost history and projections are shown in Table III-B-1.

APPENDICES

**APPENDIX A**  
**ECONOMIC CONDUCTOR ANALYSIS**

**Shebly Energy Cooperative, Inc.  
Annual Loss Cost Calculations**

Month	kWh	kW	kW Loss	Load Fact	Loss Fact	kWh Loss
JANUARY	48,668,132	111,048	1.00	0.59	0.39	287
FEBRUARY	39,516,000	102,380	0.85	0.57	0.37	211
MARCH	36,666,241	93,336	0.71	0.53	0.32	167
APRIL	32,110,799	67,575	0.37	0.66	0.47	126
MAY	32,288,835	67,283	0.37	0.65	0.45	124
JUNE	37,800,273	79,762	0.52	0.66	0.47	174
JULY	36,807,342	73,603	0.44	0.67	0.49	159
AUGUST	39,880,336	81,161	0.53	0.66	0.47	188
SEPTEMBER	33,532,826	67,497	0.37	0.69	0.51	136
OCTOBER	32,870,365	66,760	0.36	0.66	0.47	127
NOVEMBER	37,329,357	81,836	0.54	0.63	0.44	171
DECEMBER	44,838,622	101,266	0.83	0.60	0.39	243
<b>TOTAL</b>	<b>452,309,128</b>	<b>993,507</b>	<b>6.89</b>	<b>7.57</b>	<b>5.24</b>	<b>2113</b>

**KW CHARGE = \$5.71/KW**      **\$5.71 x 6.89(KW LOSS)=**      **\$39.33**  
**ENERGY = \$0.040/KWH**      **\$0.04x 2113(KWH LOSS)=**      **\$84.53**  
**TOTAL LOSS COST/KW PEAK**      **\$123.87**  
**"N" = 6.89/12 = 0.57**


Shelby Energy Cooperative Inc  
 12.5 kV, 3-Phase  
 ECONOMIC CONDUCTOR CALCULATIONS

O&M	TAX	INS	INT	\$/KW	\$/KWH	KW
4.40%	0.20%	0.30%	5.00%	5.71	0.040	1000
RMO	RAT	KWI	KWHI	LGR	INF	m
12	0.0%	6.00%	6.00%	3.00%	4.00%	.30
LF	PF	CF	N	KV	P	
49.0%	96.0%	90.0%	0.57	7.2	3	

CONDUCTOR	1/0 ACSR	336.4 ACSR
COST/MI	\$78,520	\$117,020
OHMS/MI	0.885	0.278
TCOST/MI	\$427,375	\$557,264
PWCOST/MI	\$208,301	\$275,051

# ECONOMIC CONDUCTOR CALCULATIONS

Shelby Energy Cooperative 12.5 kV 3-Phase






Shelby Energy Cooperative Inc.  
 25 kV 3-Phase  
 ECONOMIC CONDUCTOR CALCULATIONS

O&M 4.40%	TAX 0.20%	INS. 0.30%	INT 5.00%	\$/KW 5.71	\$/KWH 0.040	KW 1000
RMO 12	RAT 0.0%	KWli 6.00%	KWHI 6.00%	LGR 3.00%	INF 4.00%	m 30
LF 49.0%	PF 96.0%	CF 90.0%	N 0.57	KV 14.4	P 3	

CONDUCTOR	1/0 ACSR	336.4 ACSR
COST/MI	\$78,520	\$117,020
OHMS/MI	0.885	0.278
TCOST/MI	\$376,578	\$541,307
PWCOST/MI	\$185,738	\$267,963

# ECONOMIC CONDUCTOR CALCULATIONS

Shelby Energy Cooperative 25 kV 3-Phase



## **APPENDIX B**

### **EKPC LONG RANGE PLAN REVIEW**

- **The only major EKPC project during the 2010-2014 CWP period is a conductor upgrade from the Owen Switch Station to New Castle. 19.9 miles of 69 kV transmission will be upgraded to 565.5 ACSR conductor by 12/1/2012.**



**SHELBY ENERGY COOPERATIVE INC.**  
**Amendment to Current Approved Construction Work Plan**

<u>Amendment No.</u>	<u>New RUS Code No.</u>	<u>Work Plan Period</u>	<u>Borrower Designation</u>
2010 ~ 1	601 & 705	2010 – 2014	KY 30 Shelby

**Changes Proposed:**

<u>16,000</u>	Meters & related equipment	\$ <u>130.00</u>	Avg per meter
<u>10</u>	Substation packages & related equip	\$ <u>88,000.00</u>	Avg per substation
Total cost:		\$ 2,960,000	

**Reason for Change:**

Implementation of AMI system-wide

**Method of Financing:**

Loan Funds	
General Funds	X
Contributions in Aid	

**Status of BER:** N/A ~ Code 601 and 705 (Meters & Substation Equipment)

**Estimated Cost:** \$ 2,960,000


**Engineering Support Attached:** Discussed with GFR

Registered Engineer: (as required)	<u><i>Gary E Grubbs</i></u>	<u>13008</u> P.E. Number
Requested by:	<u><i>Dellene Martin</i></u> President & CEO	<u>06/23/2010</u> Date
Approved by:	<u><i>Mike Norman</i></u> RUS General Field Representative	<u>6/24/2010</u> Date

**Subject to BER Approval?** Yes: No: X

**Status of Construction:** Proposed 2010

MODEL ANALYSIS



Balanced Voltage Drop Report  
Source: 9999

Detail

Database: C:\MILSOFT\DATA\2014IMPROVED-CWP.WM  
Title: 2014 improved  
Case: Work Plan 2010-2014

07/20/2010 13:43 Page 1

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri KV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	KW Loss	% Loss	mi From Src	Length (mi)	Element KW KVAR	Cons On	Cons Thru	
9999		ABC	FOX CREEK	15.12Y	126.0	0.00	0.00	3.26	5	147	17	99	0.00	0.0	0.000	0.000	0	0	0	157
----- Feeder No. 1 (9991) Beginning with Device 9991 -----																				
9991	9999	A C		15.12Y	126.0	0.00	0.00	4.90	0	147	17	99	0.00	0.0	0.000	0.000	0	0	0	157
930	9991	A C	102-#1/0 A	15.12Y	126.0	0.03	0.03	4.90	2	147	17	99	0.03	0.0	0.551	0.551	1	0	1	157
1022	930	A C	Transforme	7.56Y	125.9	0.05	0.08	4.87	14	146	17	99	-0.00	0.0	0.551	0.551	0	0	0	156
929	1022	A	110-#4 ACS	7.51Y	125.1	0.80	0.90	13.95	10	105	12	99	0.58	0.6	1.992	1.441	27	3	28	113
893	929	A	110-#4 ACS	7.51Y	125.1	0.01	0.90	0.87	1	6	1	99	0.00	0.0	2.292	0.300	6	1	4	4
305	929	A	110-#4 ACS	7.43Y	123.9	1.22	2.11	9.37	7	70	8	99	0.53	0.8	5.832	3.900	37	4	45	81
304	305	A	110-#4 ACS	7.43Y	123.8	0.04	2.15	1.15	1	8	1	99	0.00	0.0	7.392	1.500	8	1	10	10
263	305	A	110-#4 ACS	7.42Y	123.7	0.15	2.27	3.09	2	23	3	99	0.02	0.1	7.493	1.600	14	2	20	26
264	263	A	110-#4 ACS	7.42Y	123.7	0.07	2.34	1.11	1	8	1	99	0.00	0.0	10.293	2.600	8	1	6	6
306	1022	C	110-#4 ACS	7.54Y	125.6	0.35	0.40	5.54	4	42	5	99	0.08	0.2	2.710	2.159	29	3	34	43
307	306	C	110-#4 ACS	7.53Y	125.5	0.05	0.45	1.24	1	9	1	99	0.00	0.0	4.610	1.900	9	1	8	8
830	306	C	110-#4 ACS	7.54Y	125.6	0.00	0.40	0.23	0	2	0	100	0.00	0.0	2.810	0.100	2	0	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

KW	Load	Adjustment	Capacitance	Charging	Gen&Motors	Loops&Metas	Losses	No Load	Losses	Total	Lowest Voltage	Max Accm VoltD	Max Elem VoltD
141	5	0	0	0	0	0	1	0.00	147	123.66	2.34	1.22	
KVAR	16	1	0	0	0	0			17				

Balanced Voltage Drop Report  
Source: 1200

Detail

Database: C:\MILSOFT\DATA\2014IMPROVED-CWP.WM  
Title: 2014 improved  
Case: Work Plan 2010-2014

07/20/2010 13:43 Page 2

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri KV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	KW Loss	% Loss	mi From Src	Length (mi)	Element KW KVAR	Cons On	Cons Thru	
C 1200		ABC	SRC-1200	15.12Y	126.0	0.00	0.00	256.16	33	10860	4132	93	0.00	0.0	0.000	0.000	0	0	0	19 C
----- Feeder No. 1 (1205) Beginning with Device 1205 -----																				
1205	1200	ABC		15.12Y	126.0	0.00	0.00	0.00	0	0	0	100	0.00	0.0	0.000	0.000	0	0	0	0
----- Feeder No. 2 (1206) Beginning with Device 1206 -----																				
C 1206	1200	ABC		15.12Y	126.0	0.00	0.00	182.80	0	7543	3444	91	0.00	0.0	0.000	0.000	0	0	0	9 C
920	1206	ABC	090-#336.4	15.11Y	126.0	0.04	0.04	92.99	18	3838	1750	91	1.01	0.0	0.140	0.140	0	0	0	4
921	920	ABC	090-#336.4	15.11Y	125.9	0.04	0.08	92.99	18	3837	1749	91	0.64	0.0	0.408	0.268	3687	1680	4	4
954	920	ABC	090-#336.4	15.11Y	126.0	0.00	0.04	0.00	0	0	0	100	0.00	0.0	0.222	0.082	0	0	0	0
960	1206	ABC	4/0 SPACER	15.07Y	125.6	0.45	0.45	89.81	34	3705	1694	91	11.10	0.3	1.061	1.061	0	0	1	5
957	960	ABC	4/0 SPACER	15.05Y	125.4	0.17	0.61	89.81	34	3694	1683	91	3.59	0.1	1.553	0.492	1410	642	2	4
961	957	ABC	4/0 SPACER	15.03Y	125.3	0.13	0.74	54.22	20	2228	1014	91	1.94	0.1	2.061	0.508	0	0	0	2
962	961	ABC	4/0 SPACER	15.02Y	125.1	0.13	0.87	54.22	20	2226	1012	91	1.91	0.1	2.560	0.500	0	0	0	2
1449	962	ABC	054-1/0 25	15.01Y	125.1	0.02	0.89	54.22	23	2224	1010	91	0.24	0.0	2.644	0.083	2149	979	2	2
----- Feeder No. 3 (1207) Beginning with Device 1207 -----																				
1207	1200	ABC		15.12Y	126.0	0.00	0.00	74.68	0	3317	689	98	0.00	0.0	0.000	0.083	0	0	0	10
914	1207	ABC	090-#336.4	15.12Y	126.0	0.03	0.03	74.68	14	3317	689	98	0.70	0.0	0.151	0.151	0	0	0	10
955	914	ABC	096-#4/0 A	15.12Y	126.0	0.01	0.04	65.59	19	2930	513	99	0.17	0.0	0.180	0.029	0	0	1	9
922	955	ABC	090-#336.4	15.11Y	125.9	0.02	0.06	65.59	12	2930	513	99	0.44	0.0	0.302	0.121	0	0	0	8
F 1457	922	ABC	054-1/0 25	15.11Y	125.9	0.00	0.06	-0.02	0	0	-1	0	0.00	0.0	0.359	0.058	0	0	1	P
856	922	ABC	090-#336.4	15.10Y	125.8	0.10	0.16	65.59	12	2929	513	99	1.92	0.1	0.902	0.600	330	150	2	7
729	856	ABC	090-#336.4	15.10Y	125.8	0.03	0.20	57.57	11	2584	354	99	0.55	0.0	1.102	0.200	0	0	0	5
916	729	ABC	Cap (750)	15.10Y	125.8	0.00	0.20	57.57	0	2583	353	99	0.00	0.0	1.102	0.200	0	0	0	5
860	916	ABC	090-#336.4	15.09Y	125.8	0.01	0.21	19.02	4	784	357	91	0.03	0.0	1.402	0.300	754	344	4	4
1440	916	ABC	Node	15.10Y	125.8	0.00	0.20	43.67	0	1800	820	91	0.00	0.0	1.102	0.300	1731	789	1	1
1456	914	ABC	054-1/0 25	15.12Y	126.0	0.00	0.03	9.35	4	386	175	91	0.00	0.0	0.173	0.022	371	169	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

KW	Load	Adjustment	Capacitance	Charging	Gen&Motors	Loops&Metas	Losses	No Load	Losses	Total	Lowest Voltage	Max Accm VoltD	Max Elem VoltD
10432	403	0	0	0	0	0	24	0.00	10860	125.11	0.89	0.45	
KVAR	4753	184	-824	-5	0	0	25		4132				

Balanced Voltage Drop Report  
Source: 1010

Detail

Database: C:\MILSOFT\DATA\2014IMPROVED-CWP.WM  
Title: 2014 improved  
Case: Work Plan 2010-2014

07/20/2010 13:43 Page 3

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri KV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	KW Loss	% Loss	mi From Src	Length (mi)	Element KW KVAR	Cons On	Cons Thru	
C 1010		ABC	SRC-1010	15.12Y	126.0	0.00	0.00	188.48	24	8044	2897	94	0.00	0.0	0.000	0.000	0	0	0	835 C
----- Feeder No. 15 (1005) Beginning with Device 1005 -----																				
C 1005	1010	ABC		15.12Y	126.0	0.00	0.00	188.48	0	8044	2897	94	0.00	0.0	0.000	0.000	0	0	0	835 C
468	1005	ABC	090-#336.4	15.10Y	125.8	0.19	0.19	188.48	36	8044	2897	94	7.49	0.1	0.253	0.253	0	0	0	835
802	468	ABC	090-#336.4	15.08Y	125.7	0.15	0.34	188.48	36	8036	2879	94	5.93	0.1	0.453	0.200	1	0	1	835
805	802	ABC	090-#336.4	15.07Y	125.6	0.07	0.41	188.46	36	8030	2865	94	2.96	0.0	0.553	0.100	0	0	0	834
1452	805	ABC	054-1/0 25	15.07Y	125.6	0.00	0.42	9.60	4	391	188	90	0.00	0.0	0.601	0.048	377	183	1	1
759	805	ABC	090-#336.4	15.02Y	125.2	0.42	0.84	178.92	34	7635	2671	94	16.01	0.2	1.153	0.600	7	3	1	833
855	759	ABC	090-#336.4	15.02Y	125.1	0.01	0.85	29.27	6	1188	573	90	0.08	0.0	1.353	0.200	703	358	4	5
1455	855	ABC	Node	15.02Y	125.1	0.00	0.85	11.35	0	460	223	90	0.00	0.0	1.353	0.200	445	215	1	1
850	855	ABC	090-#336.4	15.02Y	125.1	0.00	0.85	0.00	0	0	0	100	0.00	0.0	1.537	0.184	0	0	0	0
854	759	ABC	090-#336.4	15.01Y	125.1	0.05	0.88	149.71	28	6424	2058	95	1.87	0.0	1.253	0.100	0	0	0	827
1454	854	ABC	Node	15.01Y	125.1	0.00	0.88	15.71	0	637	309	90	0.00	0.0	1.253	0.100	616	298	1	1
793	854	ABC	090-#336.4	14.99Y	124.9	0.19	1.07	134.17												

728	793	ABC	090-#336.4	14.97Y	124.7	0.20	1.27	114.85	22	4985	1353	97	5.45	0.1	2.152	0.500	49	21	5	816
843	728	ABC	090-#336.4	14.93Y	124.5	0.27	1.55	113.63	21	4929	1319	97	8.59	0.2	2.952	0.800	13	6	4	811
844	843	ABC	Cap (450)	14.93Y	124.5	0.00	1.55	0.00	0	0	100	0.00	0.0	0.0	2.952	0.800	0	0	0	0
467	843	ABC	090-#336.4	14.89Y	124.1	0.40	1.94	113.31	21	4907	1302	97	10.38	0.2	3.952	1.000	160	69	58	807
778	467	ABC	090-#336.4	14.86Y	123.9	0.19	2.14	109.36	21	4732	1208	97	4.94	0.1	4.452	0.500	49	21	9	749
784	778	ABC	098-#3/O A	14.85Y	123.8	0.11	2.25	58.94	20	2532	704	96	1.71	0.1	4.752	0.300	67	29	15	273
877	784	ABC	098-#3/O A	14.85Y	123.7	0.03	2.28	57.27	19	2461	672	96	0.55	0.0	4.852	0.100	60	4	3	256
878	877	A	052-1/O 15	14.84Y	123.7	0.01	2.29	4.68	2	66	23	94	0.00	0.0	5.252	0.400	64	28	11	11
879	877	ABC	098-#3/O A	14.84Y	123.7	0.03	2.31	55.45	18	2384	644	97	0.51	0.0	4.952	0.100	37	16	6	244
902	879	A	052-1/O 15	14.84Y	123.7	0.03	2.34	5.80	2	82	27	95	0.01	0.0	5.552	0.600	80	34	14	14
851	879	ABC	098-#3/O A	14.81Y	123.5	0.23	2.54	52.61	18	2265	600	97	3.62	0.2	5.752	0.800	70	30	16	224
NODE44	851	ABC	Node	14.81Y	123.5	0.00	2.54	50.89	0	2190	566	97	0.00	0.0	5.752	0.800	500	164	0	208
842	NODE44	ABC	Cap (300)	14.81Y	123.5	0.00	2.54	38.80	0	1678	398	97	0.00	0.0	5.752	0.800	0	0	0	208
459	842	ABC	098-#3/O A	14.79Y	123.2	0.23	2.78	40.76	14	1678	683	93	2.10	0.1	6.752	1.000	516	223	114	208
458	459	B	110-#4 ACS	14.78Y	123.1	0.09	2.87	12.85	9	172	82	90	0.09	0.1	7.352	0.600	168	80	6	6
457	459	ABC	096-#4/O A	14.76Y	123.0	0.18	2.96	23.56	7	977	370	94	0.84	0.1	8.550	1.758	457	197	88	88
NODE45	457	ABC	Node	14.76Y	123.0	0.00	2.96	12.13	0	510	168	95	0.00	0.0	8.550	1.758	500	164	0	0
1021	NODE45	ABC	Transforme	7.38Y	123.0	0.00	2.96	0.00	0	0	0	100	0.00	0.0	8.550	1.758	0	0	0	0
466	778	ABC	090-#336.4	14.82Y	123.5	0.33	2.47	49.25	9	2145	470	98	3.93	0.2	6.552	2.100	170	73	36	467
465	466	C	106-#2 ACS	14.79Y	123.3	0.28	2.75	15.02	8	204	88	92	0.28	0.1	8.652	2.100	200	86	37	37
463	466	ABC	090-#336.4	14.79Y	123.3	0.26	2.73	40.19	8	1762	298	99	2.64	0.1	8.752	2.200	200	86	46	394
833	463	ABC	Cap (450)	14.79Y	123.3	0.00	2.73	35.34	0	1555	203	99	0.00	0.0	8.752	2.200	0	0	0	348
834	833	ABC	090-#336.4	14.79Y	123.3	0.01	2.74	38.22	7	1555	678	92	0.12	0.0	8.852	0.100	0	0	0	348
461	834	ABC	090-#336.4	14.79Y	123.3	0.01	2.75	4.66	1	190	82	92	0.01	0.0	9.352	0.500	33	14	7	38
460	461	A	110-#4 ACS	14.76Y	123.0	0.28	3.03	11.49	8	156	67	92	0.23	0.1	11.352	2.000	153	66	31	31
801	834	ABC	090-#336.4	14.79Y	123.2	0.03	2.77	33.57	6	1365	596	92	0.19	0.0	9.052	0.200	11	5	3	310
1012	801	ABC	Transforme	7.35Y	122.6	0.68	3.45	33.28	48	1353	590	92	-0.00	0.0	9.052	0.200	0	0	0	307
462	1012	ABC	090-#336.4	7.34Y	122.3	0.27	3.72	66.56	13	1353	570	92	1.79	0.1	9.552	0.500	54	23	15	307
453	462	BC	102-#1/O A	7.30Y	121.7	0.55	4.27	41.90	18	572	225	93	2.05	0.4	10.152	0.600	21	9	6	128
452	453	C	110-#4 ACS	7.30Y	121.7	0.01	4.29	1.03	1	7	3	92	0.00	0.0	10.652	0.500	7	3	2	2
451	453	BC	102-#1/O A	7.25Y	120.9	0.87	5.14	39.80	17	542	211	93	2.88	0.5	11.252	1.100	114	49	29	120
449	451	B	118-#8 A-C	7.23Y	120.4	0.43	5.57	13.99	14	93	40	92	0.23	0.2	12.152	0.900	93	40	27	27
573	451	BC	106-#2 ACS	7.23Y	120.6	0.29	5.43	24.20	13	331	118	94	0.69	0.2	11.652	0.400	13	6	2	64
450	573	BC	106-#2 ACS	7.22Y	120.3	0.27	5.70	23.21	13	317	112	94	0.55	0.2	12.152	0.500	146	63	36	62
OH46	450	C	110-#4 ACS	7.19Y	119.9	0.44	6.13	24.39	17	169	48	96	0.39	0.2	12.897	0.744	169	48	26	26
454	462	ABC	090-#336.4	7.30Y	121.7	0.61	4.33	35.93	7	725	317	92	1.91	0.3	11.952	2.400	239	103	53	164
456	454	ABC	106-#2 ACS	7.27Y	121.1	0.55	4.88	19.16	11	385	166	92	1.11	0.3	13.952	2.000	363	157	81	85
641	456	ABC	106-#2 ACS	7.27Y	121.1	0.00	4.88	0.90	1	18	8	91	0.00	0.0	14.252	0.300	18	8	4	4
895	454	ABC	110-#4 ACS	7.30Y	121.6	0.02	4.35	4.76	3	96	41	92	0.02	0.0	12.052	0.100	0	0	0	26
455	895	B	110-#4 ACS	7.29Y	121.5	0.10	4.45	6.03	4	40	17	92	0.02	0.1	12.752	0.701	40	17	9	9
448	895	ABC	110-#4 ACS	7.29Y	121.5	0.10	4.46	2.75	2	55	24	92	0.03	0.1	13.952	1.900	55	24	17	17
1444	793	AB	Node	14.99Y	124.9	0.00	1.07	4.14	0	112	54	90	0.00	0.0	1.653	1.900	108	52	1	1
1446	793	ABC	Node	14.99Y	124.9	0.00	1.07	3.53	0	144	68	90	0.00	0.0	1.653	1.900	139	66	3	3
760	854	ABC	090-#336.4	15.01Y	125.1	0.00	0.88	0.00	0	0	0	100	0.00	0.0	1.453	0.201	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kVAR Limits P = Power Factor Low

KW	7754	193	0	0	0	0	0	98	0.00	8044	Lowest Voltage = 119.87 on Element OH46			
KVAR	3375	86	-760	-16	0	0	0	212		2897	Max Accm VoltD = 6.13 on Element OH46			
											Max Elem VoltD = 0.87 on Element 451			

Balanced Voltage Drop Report  
Source: Bekaaert #3

Detail

Database: C:\MILSOFT\DATA\2014IMPROVED-CWP.WM\

Title: 2014 Improved

Case: Work Plan 2010-2014

07/20/2010 13:43 Page 4

Units Displayed In Volts																				
-Base Voltage:120.0-																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri KV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	KW Loss	% Loss	mi From Src	Length (mi)	Element KW	Cons On	Cons Thru	
C Bekaaert #3	Bekaaert #3	ABC	SRC-9000	15.12Y	126.0	0.00	0.00	234.49	30	10202	3007	96	0.00	0.0	0.000	0.000	0	0	0	3 C
Feeder 1		ABC	Node	15.12Y	126.0	0.00	0.00	234.49	0	10202	3007	96	0.00	0.0	0.000	0.000	0	0	0	3 C
----- Feeder No. 93 (9002) Beginning with Device 9002 -----																				
C 9002	feeder 1	ABC	4/O SPACER	15.12Y	126.0	0.00	0.00	137.91	0	6040	1627	97	0.00	0.0	0.000	0.000	0	0	0	3 C
956	9002	ABC	4/O SPACER	15.04Y	125.4	0.64	0.64	137.91	51	6040	1627	97	26.18	0.4	1.061	1.061	0	0	0	3
959	956	ABC	4/O SPACER	14.97Y	124.8	0.60	1.24	137.91	51	6014	1603	97	24.69	0.4	2.061	1.000	0	0	0	3
799	959	ABC	102-#1/O A	14.90Y	124.1	0.62	1.86	137.91	60	5889	1579	97	25.32	0.4	2.560	0.500	0	0	0	3
800	799	ABC	102-#1/O A	14.87Y	123.9	0.23	2.09	137.91	60	5864	1555	97	9.25	0.2	2.760	0.200	567	254	1	3
917	800	ABC	Cap (1050)	14.87Y	123.9	0.00	2.08	123.84	0	5372	1286	97	0.00	0.0	2.760	0.200	0	0	0	2
C 1447	917	ABC	054-1/O 25	14.87Y	123.9	0.01	2.10	131.96	56	5372	2405	91	4.43	0.0	2.786	0.026	5234	2343	2	2 C
OH41	feeder 1	ABC	336.4 SPRAC	15.08Y	125.7	0.33	0.33	96.68	27	4162	1380	95	7.65	0.2	1.000	1.000	0	0	0	0
Schools	OH41	ABC	Node	15.08Y	125.7	0.00	0.33	96.68	0	4155	1366	95	0.00	0.0	1.000	1.000	4000	1315	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kVAR Limits P = Power Factor Low

KW	9800	308	0	0	0	0	0	94	0.00	10202	Lowest Voltage = 123.90 on Element 1447			
KVAR	3912	120	-1120	-1	0	0	0	95		3007	Max Accm VoltD = 2.10 on Element 1447			
											Max Elem VoltD = 0.64 on Element 956			

Balanced Voltage Drop Report  
Source: 9000

Detail

Database: C:\MILSOFT\DATA\2014IMPROVED-CWP.WM\

Title: 2014 Improved

Case: Work Plan 2010-2014

07/20/2010 13:43 Page 5

Units Displayed In Volts																
-Base Voltage:120.0-																
Element Name	Parent Name	Cnf	Type/ Conductor	Pri KV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	KW Loss	% Loss		



Balanced Voltage Drop Report  
 Source: 5000

Detail

Database: C:\MILSOFT\DATA\2014IMPROVED-CWP.WM\  
 Title: 2014 Improved  
 Case: Work Plan 2010-2014

07/20/2010 13:43 Page 6

Element Name		Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	% KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	Element KW	KVAR	Cons On	Cons Thru
----- Base Voltage: 120.0 -----																					
Units Displayed in Volts																					
C 5000		ABC	SRC-5000		7.56Y 126.0	0.00	0.00	0.00	371.02	25	8079	2450	96	0.00	0.0	0.000	0.000	0	0	0	1668
----- Feeder No. 0 (5008) Beginning with Device 5008 -----																					
C 5008	5000	ABC			7.56Y 126.0	0.00	0.00	166.47	0	3589	1171	95	0.00	0.0	0.000	0.000	0	0	0	0	971
----- Feeder No. 51 (5001) Beginning with Device 5001 -----																					
5001	5008	ABC			7.56Y 126.0	0.00	0.00	98.88	0	2188	493	98	0.00	0.0	0.000	0.000	0	0	0	0	598
45	5001	ABC	090-#336.4		7.54Y 125.7	0.34	0.34	98.88	19	2188	493	98	4.06	0.2	0.500	0.500	9	4	4	4	598
44	45	ABC	090-#336.4		7.46Y 124.4	1.28	1.62	96.20	18	2127	457	98	15.28	0.7	2.500	2.000	22	10	8	584	
42	44	ABC	090-#336.4		7.40Y 123.4	1.00	2.62	95.10	18	2089	411	98	11.92	0.6	4.200	1.700	147	70	33	575	
53	42	ABC	096-#4/O A		7.36Y 122.7	0.64	3.27	87.86	26	1926	312	99	8.03	0.4	5.000	0.800	50	24	14	542	
52	53	ABC	106-#2 ACS		7.26Y 120.9	1.79	5.06	33.65	19	742	51	100	9.74	1.3	7.600	2.600	188	89	54	215	
51	52	C	110-#4 ACS		7.23Y 120.5	0.39	5.45	9.47	7	62	29	91	0.13	0.2	9.300	1.700	62	29	25	25	
50	51	ABC	106-#2 ACS		7.22Y 120.4	0.59	5.65	22.31	12	480	-74	-99	2.63	0.5	8.900	1.300	23	11	9	136	
CDP64	50	ABC	Cap (300)		7.22Y 120.4	0.00	5.65	21.36	0	455	-86	-98	0.00	0.0	8.900	1.300	0	0	0	127	
49	CAP64	BC	106-#2 ACS		7.16Y 119.3	1.08	6.73	28.38	16	370	175	90	2.16	0.6	11.400	2.500	369	175	96	96	
48	CAP64	AB	106-#2 ACS		7.22Y 120.3	0.07	5.72	6.45	4	84	40	90	0.04	0.1	9.299	0.399	13	6	4	31	
46	48	A	110-#4 ACS		7.19Y 119.9	0.38	6.10	6.22	4	41	19	91	0.08	0.2	11.799	2.500	40	19	15	15	
47	48	B	110-#4 ACS		7.20Y 120.0	0.24	5.96	4.73	3	31	15	90	0.04	0.1	11.399	2.100	31	15	12	12	
918	53	ABC	Cap (300)		7.36Y 122.7	0.00	3.27	51.91	0	1125	222	98	0.00	0.0	5.000	2.100	0	0	0	313	
54	918	ABC	106-#2 ACS		7.25Y 120.9	1.82	5.09	56.41	31	1125	536	90	15.71	1.4	6.201	1.201	38	18	14	313	
63	54	ABC	102-#1/O A		7.24Y 120.6	0.27	5.36	47.11	20	926	440	90	1.76	0.2	6.501	0.300	9	4	4	253	
819	63	ABC	Cap (600)		7.24Y 120.6	0.00	5.36	31.66	0	622	295	90	0.00	0.0	6.501	0.300	0	0	0	161	
62	870	ABC	102-#1/O A		7.19Y 119.9	0.75	6.11	31.68	14	622	295	90	2.95	0.5	8.401	1.900	351	166	90	161	
746	62	C	110-#4 ACS		7.17Y 119.5	0.36	6.47	13.39	10	87	41	90	0.17	0.2	9.501	1.100	87	41	16	16	
747	62	AB	106-#2 ACS		7.19Y 119.8	0.12	6.23	13.84	8	180	85	90	0.17	0.1	8.701	0.300	20	10	4	55	
571	747	A	106-#2 ACS		7.18Y 119.7	0.03	6.26	3.22	2	21	10	90	0.00	0.0	9.210	0.510	21	10	7	7	
61	747	B	110-#4 ACS		7.12Y 118.7	1.05	7.27	21.36	15	139	66	90	0.79	0.6	10.701	2.000	139	66	44	44	
60	63	A	110-#4 ACS		7.23Y 120.4	0.20	5.55	22.45	16	294	139	90	0.49	0.2	6.701	0.200	2	1	1	88	
59	60	C	106-#2 ACS		7.18Y 119.7	0.71	6.26	15.69	9	102	49	90	0.38	0.4	9.100	2.400	96	45	29	31	
58	59	C	106-#2 ACS		7.18Y 119.7	0.01	6.27	0.96	1	6	3	89	0.00	0.0	9.399	0.299	6	3	2	2	
57	60	A	106-#2 ACS		7.14Y 119.0	1.46	7.02	29.83	16	188	89	90	1.84	1.0	8.500	1.759	76	36	21	56	
56	57	A	106-#2 ACS		7.13Y 118.8	0.21	7.23	8.49	5	55	26	90	0.06	0.1	9.900	1.400	55	26	17	17	
55	57	A	106-#2 ACS		7.12Y 118.7	0.25	7.26	8.72	5	56	27	90	0.07	0.1	10.100	1.600	57	27	18	18	
881	54	ABC	106-#2 ACS		7.24Y 120.7	0.25	5.34	7.38	4	145	69	90	0.19	0.1	8.701	2.500	144	68	46	46	
43	44	C	110-#4 ACS		7.46Y 124.4	0.00	1.62	0.11	0	1	0	100	0.00	0.0	3.300	0.800	1	0	1	1	
786	45	B	117-#6 A-C		7.53Y 125.6	0.08	0.42	6.81	5	46	22	90	0.02	0.0	1.000	0.500	45	21	10	10	
----- Feeder No. 52 (5002) Beginning with Device 5002 -----																					
5002	5008	ABC			7.56Y 126.0	0.00	0.00	68.64	0	1402	677	90	0.00	0.0	0.000	0.500	0	0	0	0	373
74	5002	ABC	090-#336.4		7.53Y 125.5	0.46	0.46	68.64	13	1402	677	90	2.93	0.2	0.800	0.800	114	54	31	373	
73	74	ABC	090-#336.4		7.51Y 125.2	0.29	0.76	62.86	12	1280	615	90	1.63	0.1	1.400	0.600	276	131	66	342	
71	73	ABC	090-#336.4		7.49Y 124.8	0.48	1.24	46.14	9	938	450	90	2.06	0.2	2.601	1.201	34	16	9	262	
764	71	ABC	090-#336.4		7.48Y 124.7	0.10	1.33	38.90	7	789	375	90	0.36	0.0	2.900	0.299	43	20	14	223	
68	764	ABC	106-#2 ACS		7.48Y 124.6	0.06	1.39	21.07	12	427	203	90	0.19	0.0	3.000	0.100	0	0	0	115	
67	68	AB	106-#2 ACS		7.34Y 122.3	2.32	3.71	28.73	16	388	184	90	6.09	1.6	6.300	3.300	149	70	44	104	
65	67	AB	106-#2 ACS		7.30Y 121.7	0.60	4.31	15.74	9	209	99	90	0.66	0.3	8.780	2.490	205	97	53	53	
66	67	B	110-#4 ACS		7.33Y 122.2	0.04	3.75	3.23	2	21	10	90	0.00	0.0	6.800	0.500	21	10	7	7	
64	68	ABC	106-#2 ACS		7.33Y 122.2	0.03	1.42	13.21	3	18	91	0.01	0.0	9.200	1.300	38	18	11	11		
230	764	ABC	090-#336.4		7.46Y 124.4	0.30	1.64	15.64	3	317	151	90	0.37	0.1	5.900	3.000	165	78	54	94	
873	764	ABC	Cap (600)		7.46Y 124.4	0.00	1.64	7.23	0	146	69	90	0.00	0.0	5.900	3.000	0	0	0	40	
724	873	ABC	090-#336.4		7.46Y 124.4	0.00	1.64	1.67	0	34	16	90	0.00	0.0	6.400	0.500	26	12	7	11	
231	724	B	110-#4 ACS		7.46Y 124.3	0.03	1.66	1.03	1	7	3	92	0.00	0.0	7.400	1.000	7	3	4	4	
725	873	A	106-#2 ACS		7.42Y 123.7	0.62	2.25	16.68	9	112	53	90	0.35	0.3	8.000	2.100	109	52	29	29	
70	71	A	110-#4 ACS		7.47Y 124.5	0.27	1.50	16.46	12	111	53	90	0.16	0.1	3.202	0.600	97	46	26	30	
69	70	A	110-#4 ACS		7.47Y 124.5	0.04	1.54	1.62	1	11	5	91	0.00	0.0	4.201	1.000	11	5	4	4	
72	73	C	110-#4 ACS		7.50Y 124.9	0.30	1.05	8.07	6	55	26	90	0.09	0.2	2.900	1.500	53	25	14	14	
----- Feeder No. 0 (5009) Beginning with Device 5009 -----																					
C 5009	5000	ABC			7.56Y 126.0	0.00	0.00	204.70	0	4490	1182	97	0.00	0.0	0.000	1.500	0	0	0	0	697
----- Feeder No. 53 (5003) Beginning with Device 5003 -----																					
5003	5009	ABC			7.56Y 126.0	0.00	0.00	91.20	0	1846	934	89	0.00	0.0	0.000	1.500	0	0	0	0	362
95	5003	ABC	090-#336.4		7.53Y 125.5	0.49	0.49	91.20	17	1846	934	89	4.14	0.2	0.600	0.600	15	7	3	362	
94	95	ABC	090-#336.4		7.45Y 124.1	1.41	1.90	89.67	17	1810	909	89	11.35	0.6	2.500	1.899	238	113	51	357	
93	94	ABC	090-#336.4		7.38Y 122.9	1.17	3.08	64.02	12	1280	637	90	6.77	0.5	4.700	2.200	154	73	44	220	
875	93	ABC	Cap (600)																		

106	108	C	110-#4 ACS	7.32Y 122.0	0.18	4.00	11.95	9	79	37	91	0.11	0.1	7.046	0.300	0	0	1	29
105	106	C	110-#4 ACS	7.30Y 121.7	0.35	4.35	11.95	9	79	37	91	0.22	0.3	7.646	0.600	0	0	0	28
104	105	C	110-#4 ACS	7.28Y 121.4	0.27	4.62	10.01	7	66	31	91	0.14	0.2	8.246	0.600	11	5	4	24
103	104	C	110-#4 ACS	7.27Y 121.2	0.19	4.81	4.06	3	27	13	90	0.03	0.1	10.146	1.900	27	13	12	12
102	104	C	110-#4 ACS	7.28Y 121.3	0.06	4.68	4.24	3	28	13	91	0.01	0.0	8.846	0.600	28	13	8	8
108	105	C	110-#4 ACS	7.30Y 121.6	0.03	4.38	1.94	1	13	6	91	0.00	0.0	8.346	0.700	13	6	4	4
107	108	C	110-#4 ACS	7.33Y 122.2	0.01	3.83	0.62	0	4	2	89	0.00	0.0	7.145	0.399	4	2	2	2
112	113	ABC	090-#336.4	7.41Y 123.4	0.25	2.57	69.72	13	1507	-370	-97	7.84	0.5	6.946	2.000	51	24	15	101
792	112	ABC	090-#336.4	7.40Y 123.4	0.03	2.60	67.72	13	1447	-413	-96	1.15	0.1	7.246	0.300	0	0	0	86
767	792	ABC	090-#336.4	7.40Y 123.4	0.01	2.61	63.59	12	1336	-459	-95	0.67	0.1	7.446	0.200	0	0	0	51
770	767	ABC	090-#336.4	7.40Y 123.4	0.01	2.62	63.59	12	1335	-461	-95	0.67	0.1	7.645	0.200	0	0	0	51
771	770	ABC	090-#336.4	7.40Y 123.4	-0.01	2.62	62.47	12	1303	-477	-94	1.63	0.1	8.245	0.600	244	118	2	50
810	771	ABC	Cap (450)	7.40Y 123.4	0.00	2.62	54.57	0	1052	-602	-87	0.00	0.0	8.245	0.600	0	0	0	48
811	810	ABC	Cap (600)	7.40Y 123.4	0.00	2.62	47.70	0	1052	-126	-99	0.00	0.0	8.245	0.600	0	0	0	48
812	811	ABC	090-#336.4	7.40Y 123.3	0.04	2.65	52.60	10	1052	508	90	0.23	0.0	8.345	0.100	0	0	0	48
635	812	ABC	096-#4/O A	7.38Y 123.0	0.40	3.05	52.60	15	1052	508	90	1.92	0.2	9.145	0.800	479	229	33	48
84	635	ABC	096-#4/O A	7.36Y 122.7	0.27	3.32	26.15	8	521	252	90	0.74	0.1	10.045	0.900	61	29	8	14
552	84	ABC	096-#4/O A	7.35Y 122.6	0.11	3.43	23.92	7	458	221	90	0.28	0.1	10.445	0.400	0	0	0	6
85	552	ABC	110-#4 ACS	7.31Y 121.9	0.70	4.14	22.32	16	443	214	90	2.62	0.6	11.245	0.800	10	5	2	3
749	85	A	110-#4 ACS	7.31Y 121.9	0.00	4.14	0.00	0	0	0	100	0.00	0.0	11.545	0.300	0	0	0	0
1404	749	ABC	Node	7.31Y 121.9	0.00	4.14	21.79	0	430	208	90	0.00	0.0	11.245	0.300	425	206	1	1
86	552	ABC	096-#4/O A	7.35Y 122.6	0.00	3.44	0.71	0	14	7	89	0.00	0.0	10.745	0.299	14	7	3	3
1400	635	ABC	Node	7.38Y 123.0	0.00	3.05	1.99	0	40	19	90	0.00	0.0	9.145	0.299	39	18	1	1
1441	770	ABC	Node	7.40Y 123.4	0.00	2.62	1.58	0	32	15	91	0.00	0.0	7.645	0.299	31	15	1	1
1442	770	ABC	Node	7.40Y 123.4	0.00	2.62	0.00	0	0	0	100	0.00	0.0	7.645	0.299	0	0	0	0
768	792	B	106-#2 ACS	7.37Y 122.8	0.61	3.21	15.97	9	110	44	93	0.50	0.5	8.345	1.100	0	0	0	35
111	768	B	110-#4 ACS	7.34Y 122.4	0.37	3.58	15.97	11	109	43	93	0.30	0.3	8.845	0.500	11	5	6	35
101	111	B	110-#4 ACS	7.29Y 121.5	0.60	4.52	14.23	10	98	38	93	0.48	0.5	11.546	2.701	96	37	29	29
119	120	B	110-#4 ACS	7.41Y 123.5	0.16	2.46	5.46	4	37	17	91	0.03	0.1	6.046	1.200	36	17	9	9

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (Capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

KW	Load	Adjustment	Capacitance	Charging	GensMotors	Loops&Metas	Losses	No Load	Total	8079	Lowest Voltage = 118.73	on Element 61
KVAR	7759	127	0	0	0	0	192	0.00	2353		Max Acqm VoltD = 7.27	on Element 61
	3680	60	-1726	0	0	0	339				Max Elem VoltD = 2.32	on Element 67

Detail

Balanced Voltage Drop Report  
Source: 3000

Database: C:\MILLSOFT\DATA\2014IMPROVED-CWP.WM  
Title: 2014 Improved  
Case: Work Plan 2010-2014

07/20/2010 13:43 Page 7

Units Displayed In Volts													mi		Element				
-Base Voltage:120.0-																			
Element Name	Parent Name	Cnf	Type/ Conductor	Pri KV	Base Volt	Element Drop	Accum Drop	Thru Amps	Cap %	Thru KVAR	PF	Loss %	From Src	Length (mi)	KW	KVAR	Cons On	Cons Thru	
C 3000		ABC	SRC-3000		7.56Y 126.0	0.00	0.00	289.26	19	6245	2008	95	0.00	0.00	0.000	0.000	0	0	0 1353 C

----- Feeder No. 31 (3001) Beginning with Device 3001 -----

3001	3000	ABC			7.56Y 126.0	0.00	0.00	48.57	0	1096	114	99	0.00	0.0	0.000	0.000	0	0	0 328
262	3001	ABC	090-#336.4		7.53Y 125.6	0.42	0.42	48.57	9	1096	114	99	2.95	0.3	1.600	1.600	68	26	20 328
261	262	C	110-#4 ACS		7.52Y 125.4	0.22	0.64	4.87	3	27	11	93	0.03	0.1	3.900	2.300	26	10	7 7
260	262	ABC	090-#336.4		7.53Y 125.4	0.16	0.58	44.12	8	995	69	100	1.08	0.1	2.295	0.695	42	16	15 301
557	260	ABC	036-#2 COP		7.52Y 125.3	0.13	0.71	7.12	3	150	58	93	0.12	0.1	3.395	1.100	28	11	8 26
734	557	ABC	110-#4 ACS		7.51Y 125.2	0.08	0.79	2.15	0	45	18	93	0.06	0.1	3.895	0.500	73	28	16 18
1432	734	ABC	Node		7.51Y 125.2	0.00	0.79	2.15	0	45	18	93	0.00	0.0	3.895	0.500	44	17	2 2
556	260	ABC	090-#336.4		7.52Y 125.3	0.10	0.68	35.46	7	800	-9	-100	0.68	0.1	2.995	0.700	54	21	12 260
919	556	ABC	Cap (300)		7.52Y 125.3	0.00	0.68	33.01	0	744	-32	-100	0.00	0.0	2.995	0.700	0	0	0 248
258	919	ABC	090-#336.4		7.51Y 125.2	0.11	0.79	33.95	6	712	282	93	0.37	0.1	3.395	0.400	26	10	6 236
257	258	ABC	090-#336.4		7.51Y 125.2	0.04	0.83	5.24	1	110	43	93	0.01	0.0	5.295	1.900	106	41	28 28
256	258	ABC	096-#4/O A		7.48Y 124.6	0.57	1.36	27.44	8	575	228	93	1.70	0.3	5.295	1.900	75	29	29 202
255	256	C	110-#4 ACS		7.46Y 124.4	0.29	1.65	6.09	4	42	17	93	0.08	0.2	6.496	1.201	15	6	6 15
254	255	C	110-#4 ACS		7.45Y 124.2	0.19	1.83	3.81	3	27	10	94	0.03	0.1	8.496	2.000	26	10	10 10
REG70	256	AB	SystemRegu		7.56Y 126.0	-1.36	0.00	32.55	33	453	179	93	percent Boost=	1.08	Tap=	1.7			157
253	REG70	AB	106-#2 ACS		7.43Y 123.9	2.09	2.09	32.20	18	453	179	93	5.21	1.4	7.695	2.400	99	38	39 157
252	253	AB	110-#4 ACS		7.40Y 123.4	0.53	2.62	24.88	18	345	134	93	1.40	0.4	8.195	0.500	15	6	6 118
251	252	AB	106-#2 ACS		7.38Y 123.0	0.38	3.00	12.92	7	178	69	93	0.48	0.3	9.295	1.100	42	16	12 63
250	251	AB	106-#2 ACS		7.37Y 122.8	0.21	3.21	9.78	5	135	52	93	0.21	0.2	9.995	0.700	1	0	3 51
249	250	AB	106-#2 ACS		7.36Y 122.6	0.15	3.35	9.69	5	133	52	93	0.15	0.1	10.495	0.500	0	0	0 48
248	249	B	110-#4 ACS		7.34Y 122.3	0.32	3.67	6.28	4	43	17	93	0.07	0.2	12.595	2.100	42	16	9 9
247	249	AB	106-#2 ACS		7.36Y 122.6	0.04	3.39	6.55	4	90	35	93	0.03	0.0	10.696	0.201	0	0	0 38
246	247	B	110-#4 ACS		7.35Y 122.5	0.09	3.49	1.83	1	13	5	93	0.01	0.0	12.796	2.100	12	5	10 10
245	247	A	106-#2 ACS		7.30Y 121.6	0.98	4.37	11.27	6	77	30	93	0.38	0.5	15.696	5.000	76	29	29 29
244	252	A	110-#4 ACS		7.32Y 122.1	1.32	3.84	21.66	15	149	58	93	1.02	0.7	10.695	2.500	146	57	49 49
259	919	C	110-#4 ACS		7.51Y 125.2	0.17	0.85	4.58	3	32	12	94	0.03	0.1	4.495	1.500	31	12	12 12

----- Feeder No. 32 (3002) Beginning with Device 3002 -----

3002	3000	ABC			7.56Y 126.0	0.00	0.00	91.14	0	2000	524	97	0.00	0.0	0.000	1.500	0	0	0 550
303	3002	ABC	102-#1/O A		7.38Y 123.0	2.96	2.96	91.14	40	2000	524	97	39.37	2.0	1.900	1.900	141	55	30 550
302	303	ABC	106-#2 ACS		7.38Y 122.9	0.10	3.06	9.62	5	199	77	93	0.15	0.1	2.299	0.399	5	2	2 55
300	302	BC	106-#2 ACS		7.34Y 122.3	0.66	3.72	14.07	8	193	75	93	0.66	0.3	5.399	3.100	190	74	53 53
982	302	C	106-#2 ACS		7.38Y 122.9	0.00	3.06	0.00	0	0	0	100	0.00	0.0	3.299	0.999	0	0	0 0
294	303	ABC	096-#4/O A		7.35Y 122.5	0.57	3.54	61.04	18	1330	241	98	4.86	0.4	2.900	1.000	32	13	9 374
301	294	B	110-#4 ACS		7.31Y 121.8	0.66	4.19	24.45	17	167	65	93	0.57	0.3	4.001	1.101	165	64	40 40
293	294	ABC	096-#4/O A		7.33Y 122.1	0.37	3.91	51.52	15	1125	155	99	2.82						

299	303	ABC	106-#2 ACS	7.35Y 122.4	0.61	3.57	13.89	8	287	111	93	1.19	0.4	4.200	2.300	137	53	47	91
726	299	ABC	106-#2 ACS	7.34Y 122.3	0.12	3.69	7.09	4	146	57	93	0.12	0.1	4.999	0.799	55	21	10	44
297	726	AB	106-#2 ACS	7.34Y 122.3	0.06	3.75	5.05	3	69	27	93	0.03	0.0	5.399	0.399	2	1	1	28
296	297	B	110-#4 ACS	7.33Y 122.2	0.00	3.75	0.14	0	1	0	100	0.00	0.0	6.099	0.700	1	0	3	3
295	297	A	110-#4 ACS	7.31Y 121.9	0.40	4.15	9.63	7	66	26	93	0.14	0.2	7.099	1.700	65	25	24	24
298	726	C	110-#4 ACS	7.33Y 122.2	0.14	3.83	2.99	2	20	8	93	0.01	0.1	6.899	1.900	20	8	6	6

----- Feeder No. 33 (3003) Beginning with Device 3003 -----

C 3003	3000	ABC		7.56Y 126.0	0.00	0.00	151.49	0	3150	1371	92	0.00	0.0	0.000	1.900	0	0	0	475 C
336	3003	ABC	090-#336.4	7.37Y 122.8	3.25	3.25	151.49	29	3150	1371	92	48.10	1.5	2.600	2.600	126	49	32	475
1434	336	ABC	Node	7.37Y 122.8	0.00	3.25	0.00	0	0	0	100	0.00	0.0	2.600	2.600	0	0	0	0
632	336	ABC	090-#336.4	7.33Y 122.1	0.62	3.86	145.27	27	2973	1210	93	8.85	0.3	3.127	0.527	166	64	36	443
586	632	A	106-#2 ACS	7.32Y 122.0	0.14	4.01	15.70	9	107	42	93	0.07	0.1	3.667	0.540	106	41	22	22
636	632	ABC	090-#336.4	7.31Y 121.8	0.30	4.16	131.84	25	2689	1083	93	3.93	0.1	3.399	0.272	12	4	3	385
572	636	B	106-#2 ACS	7.30Y 121.7	0.15	4.32	7.40	4	50	20	93	0.04	0.1	4.599	1.200	50	19	15	15
335	636	ABC	090-#336.4	7.30Y 121.6	0.21	4.37	128.80	24	2623	1049	93	2.76	0.1	3.599	0.200	11	4	2	367
334	335	ABC	098-#3/O A	7.26Y 121.0	0.60	4.97	38.23	13	779	306	93	2.75	0.4	4.799	1.200	62	24	15	184
333	334	C	110-#4 ACS	7.25Y 120.9	0.17	5.14	8.15	6	55	21	93	0.05	0.1	5.652	0.852	55	21	14	14
639	333	ABC	106-#2 ACS	7.23Y 120.6	0.47	5.45	20.74	12	421	164	93	1.30	0.3	6.099	1.300	257	100	60	94
640	333	A	106-#2 ACS	7.22Y 120.4	0.14	5.59	13.34	7	90	35	93	0.06	0.1	6.699	0.600	90	35	17	17
868	640	B	110-#4 ACS	7.20Y 120.1	0.44	5.95	10.62	8	72	28	93	0.04	0.1	6.799	0.700	0	0	0	17
325	334	ABC	106-#2 ACS	7.24Y 120.7	0.30	5.27	11.69	6	237	92	93	0.41	0.2	6.599	1.800	208	81	51	61
326	325	A	110-#4 ACS	7.24Y 120.7	0.05	5.32	4.12	3	28	11	93	0.01	0.0	7.099	0.500	28	11	10	10
332	335	ABC	090-#336.4	7.25Y 120.9	0.72	5.09	90.04	17	1830	733	93	6.41	0.4	4.599	1.000	114	44	31	181
737	332	ABC	095-#4/O A	7.24Y 120.6	0.28	5.38	76.95	23	1431	870	85	2.25	0.2	4.883	0.284	0	0	0	85
738	737	ABC	095-#4/O A	7.22Y 120.4	0.24	5.61	62.60	18	1133	750	83	1.48	0.1	5.167	0.284	1	1	1	3
1415	738	ABC	Node	7.22Y 120.4	0.00	5.61	62.53	0	1130	747	83	0.00	0.0	5.167	0.284	1127	745	2	2
774	737	A	106-#2 ACS	7.20Y 120.0	0.65	6.03	21.93	12	296	115	93	1.40	0.5	5.883	1.000	16	6	13	82
775	774	C	106-#2 ACS	7.19Y 119.9	0.07	6.10	16.84	9	113	44	93	0.04	0.0	6.133	0.250	113	44	28	28
331	774	A	106-#2 ACS	7.17Y 119.4	0.54	6.57	12.29	7	165	64	93	0.63	0.4	7.583	1.700	49	19	16	41
740	331	C	110-#4 ACS	7.14Y 119.0	0.40	6.96	17.23	12	115	45	93	0.25	0.2	8.530	0.947	115	45	25	25
903	332	ABC	Cap (300)	7.25Y 120.9	0.00	5.09	15.60	0	277	-196	-82	0.00	0.0	4.599	0.947	0	0	0	65
330	903	ABC	090-#336.4	7.24Y 120.7	0.20	5.30	13.67	3	277	108	93	0.26	0.1	6.599	2.000	53	21	14	65
329	330	A	110-#4 ACS	7.24Y 120.6	0.11	5.41	5.87	4	40	15	94	0.04	0.1	6.999	0.399	0	0	0	10
328	329	A	110-#4 ACS	7.23Y 120.5	0.14	5.55	4.41	3	30	12	93	0.02	0.1	8.298	1.299	30	12	8	8
822	330	ABC	090-#336.4	7.24Y 120.7	0.03	5.32	9.05	2	183	71	93	0.03	0.0	7.099	0.500	26	10	10	41
823	822	C	110-#4 ACS	7.20Y 119.9	0.74	6.06	23.31	17	157	61	93	0.62	0.4	8.399	1.300	156	61	31	31
1433	336	ABC	Node	7.37Y 122.8	0.00	3.25	0.00	0	0	0	100	0.00	0.0	2.600	1.300	0	0	0	0

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

KV	Load	Adjustment	Capacitance	Charging	Gen&Motors	Loops&Metas	Losses	No Load	Losses	Total				
KVAR	5991	78		0	0	0	176		0.00	6245	Lowest Voltage = 119.04 on Element 740			
	2635	31	-931	0	0	0	273			2008	Max Accm VoltD = 6.96 on Element 740			
											Max Elem VoltD = 3.25 on Element 336			

Balanced Voltage Drop Report  
Source: 4000

Database: C:\MILSOFT\DATA\2014IMPROVED-CWP.WM  
Title: 2014 Improved  
Case: Work Plan 2010-2014  
07/20/2010 13:43 Page 8

Units Displayed In Volts																				
-----Element-----																				
Element Name	Parent Name	Cnf	Type/ Conductor	Pri kV	Base Volt	Element Drop	Accum Drop	Thru Amps	Thru Cap	Thru KW	KVAR	% PF	kW Loss	% Loss	From Src	Length (mi)	KW	KVAR	Cons Thru	Cons Thru
C 4000		ABC	SRC-4000	7.56Y	126.0	0.00	0.00	428.65	29	9193	3162	95	0.00	0.0	0.000	0.000	0	0	0	2216 C
----- Feeder No. 0 (4008) Beginning with Device 4008 -----																				
C 4008	4000	ABC		7.56Y	126.0	0.00	0.00	192.41	0	4209	1152	96	0.00	0.0	0.000	0.000	0	0	0	1273 C
----- Feeder No. 41 (4001) Beginning with Device 4001 -----																				
C 4001	4008	ABC		7.56Y	126.0	0.00	0.00	104.79	0	2326	489	98	0.00	0.0	0.000	0.000	0	0	0	649 C
237	4001	ABC	090-#336.4	7.51Y	125.2	0.83	0.83	104.79	20	2326	489	98	10.76	0.5	1.200	1.200	52	16	11	649
236	237	ABC	090-#336.4	7.47Y	124.6	0.59	1.42	102.30	19	2261	447	98	7.63	0.3	2.100	0.900	70	22	16	638
235	236	ABC	090-#336.4	7.47Y	124.5	0.12	1.55	9.13	2	195	61	95	0.10	0.1	4.399	2.299	92	29	28	56
232	235	ABC	090-#336.4	7.47Y	124.5	0.00	1.55	0.79	0	17	5	96	0.00	0.0	5.600	1.201	16	5	4	4
233	235	C	110-#4 ACS	7.46Y	124.4	0.07	1.62	3.05	2	22	7	95	0.01	0.0	5.399	1.000	21	7	8	8
234	235	C	106-#2 ACS	7.45Y	124.2	0.21	1.75	8.71	5	62	19	96	0.06	0.1	5.799	1.400	60	19	16	16
229	236	ABC	096-#4/O A	7.33Y	123.2	1.41	2.83	89.90	26	1986	346	99	17.71	0.9	3.801	1.701	76	24	22	566
228	229	C	110-#4 ACS	7.32Y	123.1	0.09	2.92	2.95	2	21	6	96	0.01	0.0	5.001	1.201	20	6	7	7
227	228	ABC	096-#4/O A	7.37Y	122.9	0.31	3.14	85.31	25	1870	285	99	3.80	0.2	4.200	0.399	44	14	10	537
H REG60	227	ABC	REG-002	7.56Y	126.0	-3.14	-0.00	83.21	36	1821	264	99	percent Boost= 2.50 Tap= 4.0				527 H			
226	REG60	ABC	102-#1/O A	7.55Y	125.8	0.18	0.18	32.92	14	711	228	95	0.86	0.1	4.499	0.299	2	0	1	202
225	226	ABC	102-#1/O A	7.54Y	125.7	0.12	0.30	32.85	14	709	226	95	0.58	0.1	4.700	0.201	0	0	0	201
224	225	C	106-#2 ACS	7.46Y	124.3	1.40	1.70	24.89	14	179	56	95	1.55	0.9	6.800	2.100	75	23	25	57
223	224	C	106-#2 ACS	7.46Y	124.3	0.03	1.74	2.14	1	15	5	95	0.00	0.0	7.700	0.900	15	5	5	5
222	224	C	106-#2 ACS	7.44Y	124.1	0.25	1.95	11.95	7	85	27	95	0.14	0.2	7.500	0.700	24	7	6	27
221	222	C	110-#4 ACS	7.40Y	123.4	0.69	2.64	8.54	6	61	19	95	0.28	0.5	9.500	2.000	19	6	7	21
220	221	C	110-#4 ACS	7.39Y	123.1	0.25	2.89	5.76	4	41	13	95	0.05	0.1	11.300	1.800	40	12	14	14
217	225	AB	102-#1/O A	7.49Y	124.8	0.93	1.23	36.83	16	529	169	95	3.13	0.6	5.901	1.201	25	8	5	144
210	217	AB	106-#2 ACS	7.35Y	122.6	2.21	3.44	34.61	19	494	156	95	7.02	1.4	8.601	2.700	203	63	55	138
209	210	B	106-#2 ACS	7.31Y	121.8	0.73	4.17	23.90	13	168	53	95	0.85	0.5	9.600	1.000	34	11	9	50
208	209	B	110-#4 ACS	7.27Y	121.2	0.59	4.76	16.26	12	113	35	96	0.35	0.3	11.100	1.500	112	35	33	33
555	209	B	106-#2 ACS	7.31Y	121.8	0.02	4.19	2.64	1	18	6	95	0.00	0.0	10.100	0.500	18	6	8	8
212	210	A	106-#2 ACS	7.33Y	122.1	0.41	3.85	15.93	9	112	35	95	0.33	0.3	9.400	0.799	11	3	3	33
211	212	A	106-#2 ACS	7.30Y	121.6	0.54	4.40	14.39	8	101	31	96	0.27	0.3	11.600	2.200	99	31	30	30
216	217	A	106-#2 ACS	7.48Y	124.7	0.02	1.26	0.82	0	6	2	95	0.00							

147	154	ABC	098-#3/O A	7.31Y 121.9	2.39	4.10	67.55	23	1432	484	95	20.22	1.4	5.300	2.800	99	31	31	483
145	147	ABC	098-#3/O A	7.27Y 121.1	0.79	4.89	61.55	21	1285	416	95	6.25	0.5	6.300	1.000	28	9	8	445
REG61	145	ABC	REG-005	7.56Y 126.0	-4.89	0.00	60.18	40	1250	398	95	percent Boost= 3.88 Tap= 6.2							437
144	REG61	ABC	106-#2 ACS	7.52Y 125.0	0.59	0.59	22.76	13	493	155	95	2.02	0.4	7.335	1.035	62	19	13	153
143	144	B	106-#2 ACS	7.51Y 125.2	0.26	0.85	11.75	7	84	26	96	0.11	0.1	8.634	1.299	81	25	22	22
142	143	B	106-#2 ACS	7.51Y 125.2	0.00	0.85	0.00	0	0	0	100	0.00	0.0	9.034	0.399	0	0	0	0
765	144	ABC	106-#2 ACS	7.51Y 125.2	0.21	0.80	15.84	9	341	107	95	0.52	0.2	7.835	0.500	6	2	3	118
141	765	B	110-#4 ACS	7.45Y 124.1	1.06	1.85	13.65	10	98	31	95	0.66	0.7	9.935	2.100	45	14	16	39
140	141	B	110-#4 ACS	7.45Y 124.1	0.01	1.86	0.59	0	4	1	97	0.00	0.0	10.535	0.600	4	1	3	20
139	141	B	110-#4 ACS	7.44Y 123.9	0.21	2.07	6.84	5	47	15	95	0.07	0.1	10.735	0.800	16	5	3	20
135	139	B	110-#4 ACS	7.42Y 123.7	0.19	2.25	4.06	3	29	9	96	0.03	0.1	12.635	1.899	28	9	15	15
138	139	B	110-#4 ACS	7.44Y 123.9	0.00	2.07	0.25	0	2	1	89	0.00	0.0	11.535	0.800	2	1	2	2
766	765	ABC	106-#2 ACS	7.49Y 124.9	0.32	1.11	11.02	6	237	74	95	0.51	0.2	9.235	1.400	86	27	17	76
219	766	A	106-#2 ACS	7.47Y 124.5	0.34	1.46	20.59	11	147	46	95	0.36	0.2	9.735	0.500	6	2	4	59
218	219	A	106-#2 ACS	7.44Y 124.1	0.47	1.93	19.68	11	140	44	95	0.41	0.3	10.635	0.900	61	19	21	55
214	218	A	110-#4 ACS	7.44Y 124.0	0.11	2.04	3.69	3	26	8	96	0.01	0.1	11.835	1.200	26	8	10	10
213	218	A	106-#2 ACS	7.43Y 123.8	0.25	2.18	7.24	4	51	16	95	0.06	0.1	12.635	2.000	50	16	24	24
744	766	A	106-#2 ACS	7.49Y 124.9	0.00	1.11	0.00	0	0	0	100	0.00	0.0	10.035	0.800	0	0	0	0
134	REG61	ABC	098-#3/O A	7.50Y 125.0	1.01	1.01	35.08	12	758	243	95	4.26	0.6	8.800	2.500	161	50	46	284
133	134	A	110-#4 ACS	7.49Y 124.9	0.09	1.11	1.55	1	11	3	96	0.01	0.0	11.300	2.500	11	3	6	6
132	134	ABC	098-#3/O A	7.49Y 124.8	0.24	1.25	26.81	9	575	182	95	0.80	0.1	9.500	0.700	34	11	10	232
630	132	ABC	098-#3/O A	7.48Y 124.7	0.09	1.34	17.94	6	384	121	95	0.22	0.1	9.900	0.399	0	0	0	167
131	630	B	110-#4 ACS	7.33Y 122.2	2.45	3.80	24.09	17	172	54	95	2.74	1.6	12.600	2.700	73	23	22	52
129	131	B	110-#4 ACS	7.30Y 121.6	0.56	4.36	13.58	10	95	30	95	0.32	0.3	13.900	1.300	64	20	19	30
136	129	B	110-#4 ACS	7.28Y 121.4	0.23	4.59	4.31	3	30	9	96	0.04	0.1	16.100	2.200	30	9	11	11
621	630	ABC	098-#3/O A	7.47Y 124.6	0.10	1.44	9.90	3	212	66	95	0.13	0.1	10.700	0.800	4	1	1	115
130	621	A	110-#4 ACS	7.45Y 124.2	0.39	1.83	6.01	4	43	13	96	0.08	0.2	13.400	2.700	42	13	21	21
622	621	ABC	098-#3/O A	7.47Y 124.5	0.02	1.46	7.70	1	165	51	96	0.01	0.0	11.000	0.300	0	0	0	93
561	622	ABC	098-#3/O A	7.46Y 124.4	0.14	1.60	7.70	3	165	51	96	0.14	0.1	12.400	1.400	0	0	0	92
631	561	ABC	106-#2 ACS	7.46Y 124.4	0.04	1.64	7.70	4	165	51	96	0.03	0.0	12.800	0.400	160	50	92	92
865	622	ABC	098-#3/O A	7.47Y 124.5	0.00	1.46	0.00	0	0	0	100	0.00	0.0	11.200	0.200	0	0	0	1
1416	865	ABC	Node	7.47Y 124.5	0.00	1.46	0.00	0	0	0	100	0.00	0.0	11.200	0.200	0	0	1	1
243	132	C	106-#2 ACS	7.47Y 124.5	0.29	1.54	21.66	12	155	49	95	0.33	0.2	9.900	0.400	4	1	1	55
242	243	C	106-#2 ACS	7.43Y 123.8	0.70	2.24	21.11	12	150	47	95	0.70	0.5	11.000	1.100	35	11	11	54
198	242	C	106-#2 ACS	7.42Y 123.7	0.02	2.26	1.19	1	8	3	94	0.00	0.0	12.101	1.100	8	3	6	6
241	242	C	110-#4 ACS	7.40Y 123.4	0.38	2.62	14.84	11	105	33	95	0.08	0.2	11.700	0.700	49	15	13	37
240	241	C	110-#4 ACS	7.40Y 123.3	0.02	2.73	7.81	6	55	17	96	0.04	0.1	11.999	0.299	8	3	1	24
239	240	C	110-#4 ACS	7.39Y 123.1	0.15	2.87	3.02	2	21	7	95	0.02	0.1	13.999	2.000	21	6	11	11
238	240	C	110-#4 ACS	7.39Y 123.1	0.13	2.86	3.59	3	25	8	95	0.02	0.1	12.999	1.000	12	4	5	12
861	238	C	110-#4 ACS	7.39Y 123.1	0.06	2.91	1.81	1	13	4	96	0.00	0.0	14.299	1.300	12	4	7	7
146	147	B	110-#4 ACS	7.31Y 121.8	0.08	4.18	3.66	3	26	8	96	0.01	0.0	6.200	0.900	25	8	7	7
153	154	ABC	098-#336.4	7.45Y 124.2	0.10	1.81	18.28	3	388	128	95	0.19	0.0	3.200	0.700	17	5	6	127
152	153	B	110-#4 ACS	7.40Y 123.3	0.88	2.69	18.12	13	129	40	96	0.58	0.4	5.200	2.000	124	39	46	49
151	152	B	110-#4 ACS	7.40Y 123.3	0.00	2.69	0.13	0	1	0	100	0.00	0.0	6.400	1.200	1	0	3	3
150	153	ABC	098-#336.4	7.45Y 124.1	0.07	1.87	11.41	2	241	82	95	0.07	0.0	4.200	1.000	120	44	24	72
149	150	C	110-#4 ACS	7.38Y 123.0	0.10	2.98	16.67	12	118	37	95	0.94	0.8	5.700	1.500	20	6	10	48
136	149	C	110-#4 ACS	7.38Y 123.0	0.01	2.99	0.97	1	7	2	96	0.00	0.0	6.200	0.500	7	2	3	3
735	736	C	110-#4 ACS	7.38Y 123.0	0.00	2.99	0.00	0	0	0	100	0.00	0.0	6.401	0.201	0	0	0	0
148	149	C	110-#4 ACS	7.36Y 122.7	0.31	3.29	7.15	5	50	16	95	0.08	0.2	7.500	1.800	49	15	18	18
583	149	C	110-#4 ACS	7.37Y 122.8	0.21	3.18	5.68	4	40	12	96	0.04	0.1	7.200	1.500	39	12	17	17

----- Feeder No. 0 (4009) Beginning with Device 4009 -----																			
C 4009	4000	ABC		7.56Y 126.0	0.00	0.00	236.95	0	4984	2010	93	0.00	0.0	0.000	1.500	0	0	0	943 C

----- Feeder No. 43 (4003) Beginning with Device 4003 -----																			
4003	4009	ABC		7.56Y 126.0	0.00	0.00	97.98	0	2095	742	94	0.00	0.0	0.000	1.500	0	0	0	484
178	4003	ABC	096-#4/O A	7.48Y 124.7	1.34	1.34	97.98	29	2095	742	94	15.54	0.7	1.222	1.222	20	6	7	484
595	178	B	106-#2 ACS	7.45Y 124.1	0.52	1.86	18.19	10	130	41	95	0.31	0.2	2.945	1.723	126	39	27	27
596	178	ABC	096-#4/O A	7.46Y 124.3	0.39	1.73	90.96	27	1929	668	94	4.16	0.2	1.600	0.378	5	1	3	450
177	596	A	110-#4 ACS	7.42Y 123.7	0.53	2.26	15.74	11	112	35	95	0.30	0.3	3.000	1.400	109	34	28	28
176	596	ABC	096-#4/O A	7.41Y 123.4	0.85	2.58	85.49	25	1808	624	95	8.58	0.5	2.499	0.999	49	15	16	419
175	176	C	110-#4 ACS	7.40Y 123.3	0.10	2.70	3.07	2	22	7	95	0.01	0.1	4.199	1.700	21	7	7	7
174	176	ABC	096-#4/O A	7.28Y 121.3	2.10	4.67	82.12	24	1727	587	95	20.16	1.2	4.899	2.400	140	44	40	396
H 871	174	ABC	REG-002	7.56Y 126.0	-4.67	-0.00	75.35	32	1565	508	95	percent Boost= 3.71 Tap= 5.9							356 H
173	871	B	110-#4 ACS	7.48Y 124.6	1.39	1.39	21.30	15	1454	48	95	1.07	0.7	7.600	2.701	148	46	48	48
172	871	A	C 110-#4 ACS	7.51Y 125.2	0.76	0.76	13.52	10	195	61	95	0.75	0.4	7.500	2.600	187	58	50	51
1435	172	A	C Node	7.51Y 125.2	0.00	0.76	0.00	0	0	0	100	0.00	0.0	7.500	2.600	0	0	1	1
171	871	ABC	096-#4/O A	7.52Y 125.3	0.68	0.68	56.44	17	1216	399	95	4.66	0.4	6.000	1.100	6	2	4	257
169	171	ABC	096-#4/O A	7.45Y 124.2	1.09	1.77	48.10	14	1032	335	95	6.29	0.6	8.100	2.100	37	11	15	203
168	169	C	110-#4 ACS	7.40Y 123.3	0.94	2.72	23.04	16	164	51	95	0.95	0.5	9.300	1.200	94	29	14	31
167	168	C	110-#4 ACS	7.39Y 123.2	0.13	2.85	9.51	7	67	21	95	0.06	0.1	9.599	0.300	8	3	2	17
151	167	C	110-#4 ACS	7.38Y 122.9	0.22	3.07	8.31	6	59	18	96	0.07	0.1	10.700	1.100	57	18	15	15
165	169	ABC	098-#3/O A	7.42Y 123.7	0.49	2.26	38.66	13	824	261	95	2.42	0.3	9.099	1.000	36	11	8	157
741	165	B	110-#4 ACS	7.40Y 123.4	0.36	2.63	13.62	10	97	30	96	0.18	0.2	10.199	1.100	94	29	23	23
783	165	ABC																	

Element Name	Parent Name	Cnf	Type/ Conductor	Pri KV	Base Volt	Element Drop	-Base Voltage:120.0-			Thru KW	KVAR	% PF	KW Loss	% Loss	mi From Src	Length (mi)	-----Element-----		Cons On	Cons Thru	
Accum Drop	Thru Amps	% Cap																			
C 1000		ABC	SRC-1000	15.12Y	126.0	0.00	0.00	211.82	27	9050	3226	94	0.00	0.0	0.000	0.000	0	0	0	1147	C
----- Feeder No. 0 (1008) Beginning with Device 1008 -----																					
1008	1000	ABC		15.12Y	126.0	0.00	0.00	23.63	0	1011	355	94	0.00	0.0	0.000	0.000	0	0	0	144	
----- Feeder No. 12 (1002) Beginning with Device 1002 -----																					
1002	1008	ABC		15.12Y	126.0	0.00	0.00	23.63	0	1011	355	94	0.00	0.0	0.000	0.000	0	0	0	144	
549	1002	ABC	090-#336.4	15.12Y	126.0	0.02	0.02	23.63	4	1011	355	94	0.12	0.0	0.253	0.253	0	0	0	144	
803	549	ABC	090-#336.4	15.12Y	126.0	0.00	0.02	1.49	0	63	24	93	0.00	0.0	0.453	0.200	0	0	0	8	
806	803	ABC	090-#336.4	15.12Y	126.0	0.00	0.03	1.49	0	63	24	93	0.00	0.0	0.852	0.400	0	0	0	8	
550	806	ABC	106-#2 ACS	15.12Y	126.0	0.01	0.04	1.49	1	63	24	93	0.00	0.0	1.352	0.500	8	2	5	8	
1403	550	ABC	Node	15.12Y	126.0	0.00	0.04	1.31	0	55	22	93	0.00	0.0	1.352	0.500	53	21	3	3	
876	549	ABC	096-#4/O A	15.11Y	126.0	0.02	0.05	22.13	7	948	331	94	0.13	0.0	0.453	0.200	0	0	0	136	
907	876	ABC	106-#2 ACS	15.10Y	125.8	0.11	0.17	12.72	7	948	331	94	0.09	0.0	0.653	0.200	384	144	16	136	
483	807	ABC	106-#2 ACS	15.10Y	125.8	0.11	0.17	12.72	7	948	331	94	0.09	0.0	0.653	0.200	384	144	16	136	
482	483	ABC	106-#2 ACS	15.07Y	125.6	0.22	0.40	10.10	6	438	138	95	0.66	0.1	3.253	1.900	105	33	28	118	
481	482	B	118-#8 A-C	15.06Y	125.5	0.13	0.53	5.06	5	73	23	95	0.05	0.1	4.753	1.500	70	22	20	20	
480	482	ABC	106-#2 ACS	15.05Y	125.5	0.15	0.55	5.90	3	254	80	95	0.26	0.1	5.453	2.200	59	19	19	70	
478	480	ABC	106-#2 ACS	15.05Y	125.4	0.05	0.60	3.95	2	170	54	95	0.04	0.0	7.253	1.800	164	52	44	44	
1020	478	ABC	Transforme	7.52Y	125.4	0.00	0.60	0.00	0	0	0	100	0.00	0.0	7.253	1.800	0	0	0	0	
479	480	B	110-#4 ACS	15.05Y	125.4	0.03	0.57	1.57	1	23	7	96	0.00	0.0	6.853	1.400	22	7	7	7	

----- Feeder No. 0 (1009) Beginning with Device 1009 -----																					
C 1009	1000	ABC		15.12Y	126.0	0.00	0.00	188.19	0	8039	2871	94	0.00	0.0	0.000	1.400	0	0	0	1003	C
----- Feeder No. 13 (1003) Beginning with Device 1003 -----																					
1003	1009	ABC		15.12Y	126.0	0.00	0.00	84.66	0	3598	1341	94	0.00	0.0	0.000	1.400	0	0	0	625	
761	1003	ABC	098-#3/O A	15.05Y	125.4	0.62	0.62	84.66	28	3598	1341	94	12.93	0.4	1.100	1.100	104	33	33	625	
785	761	ABC	098-#3/O A	15.02Y	125.2	0.22	0.84	82.16	27	3477	1288	94	4.51	0.1	1.500	0.400	24	8	6	592	
496	785	ABC	098-#3/O A	14.94Y	124.5	0.65	1.49	11.58	27	3448	1274	94	13.25	0.4	2.700	1.200	53	17	10	586	
490	496	ABC	106-#2 ACS	14.90Y	124.2	0.32	1.81	23.51	13	1000	334	95	2.30	0.2	3.756	1.056	80	25	18	228	
579	490	ABC	106-#2 ACS	14.88Y	124.0	0.19	2.00	19.49	11	826	278	95	1.19	0.1	4.500	0.744	7	2	4	196	
869	579	ABC	106-#2 ACS	14.83Y	123.6	0.39	2.40	19.32	11	817	275	95	2.45	0.3	6.200	1.700	84	27	11	192	
1019	869	AB	Transforme	7.35Y	122.5	1.11	3.50	11.30	65	317	110	94	0.00	0.0	6.200	1.700	0	0	0	71	
489	1019	AB	106-#2 ACS	7.29Y	121.5	1.02	4.52	22.59	13	317	100	95	1.64	0.5	9.200	3.000	311	98	71	71	
1023	869	BC	Transforme	7.38Y	123.0	0.56	2.96	14.64	42	412	137	95	0.00	0.0	6.200	3.000	0	0	0	110	
485	1023	BC	106-#2 ACS	7.32Y	122.0	1.02	3.98	29.28	16	412	131	95	2.61	0.5	7.800	1.600	222	70	52	110	
723	485	BC	106-#2 ACS	7.30Y	121.6	0.40	4.37	13.18	7	184	58	95	0.56	0.3	8.800	1.000	0	0	0	58	
484	723	B	110-#4 ACS	7.30Y	121.6	0.04	4.41	2.07	1	14	5	94	0.00	0.0	9.600	0.800	14	4	2	2	
624	723	C	106-#2 ACS	7.26Y	121.1	0.57	4.94	24.29	13	169	54	95	0.48	0.3	10.160	1.360	167	53	56	56	
578	490	C	106-#2 ACS	14.90Y	124.2	0.03	1.84	6.28	3	89	28	95	0.01	0.0	4.306	0.550	87	27	14	14	
1014	496	ABC	Transforme	7.41Y	123.5	1.01	2.50	56.80	82	2381	903	94	0.00	0.0	2.700	0.550	0	0	0	348	
495	1014	ABC	102-#1/O A	7.33Y	122.2	1.25	3.76	113.61	49	2381	843	94	20.12	0.8	3.300	0.600	69	22	16	348	
543	495	ABC	106-#2 ACS	7.33Y	122.1	0.12	3.88	8.45	5	176	60	95	0.14	0.1	4.077	0.777	91	29	17	26	
494	543	ABC	106-#2 ACS	7.32Y	122.0	0.08	3.96	4.05	2	84	31	94	0.05	0.1	5.021	0.944	28	9	6	9	
925	494	B	110-#4 ACS	7.32Y	122.0	0.00	3.96	0.00	0	0	0	100	0.00	0.0	5.653	0.632	0	0	0	0	
924	494	ABC	106-#2 ACS	7.32Y	122.0	0.00	3.96	0.00	0	0	0	100	0.00	0.0	5.653	0.632	0	0	0	0	
1417	924	ABC	Node	7.32Y	122.0	0.00	3.99	2.63	0	54	21	93	0.00	0.0	5.423	0.402	1	0	1	3	
493	495	ABC	102-#1/O A	7.29Y	121.5	0.76	4.51	101.81	44	2114	742	94	10.96	0.5	3.700	0.400	19	6	4	306	
491	493	ABC	102-#1/O A	7.22Y	120.3	1.18	5.70	65.54	28	1347	489	94	10.13	0.8	4.800	1.100	336	106	45	133	
797	491	ABC	106-#2 ACS	7.19Y	119.9	0.40	6.09	49.26	27	1000	372	94	3.07	0.3	5.100	0.300	4	1	2	88	
798	797	ABC	106-#2 ACS	7.18Y	119.7	0.20	6.29	29.24	16	587	232	93	0.60	0.1	5.600	0.500	587	232	6	6	
727	797	ABC	102-#1/O A	7.19Y	119.8	0.10	6.20	19.85	9	406	138	95	0.21	0.1	5.700	0.600	490	138	80	80	
492	492	ABC	098-#3/O A	7.26Y	121.1	0.41	4.92	35.38	12	736	237	95	1.63	0.2	4.800	1.100	280	88	64	169	
542	492	ABC	098-#3/O A	7.23Y	120.6	0.50	5.42	21.83	7	453	146	95	1.40	0.3	6.600	1.900	16	5	4	105	
487	542	ABC	098-#3/O A	7.22Y	120.4	0.17	5.59	21.06	7	436	138	95	0.43	0.1	7.301	0.701	100	32	20	101	
486	487	B	106-#2 ACS	7.18Y	119.7	0.74	6.33	22.72	13	156	50	95	0.58	0.4	9.201	1.900	156	49	34	34	
488	487	A	106-#2 ACS	7.18Y	119.7	0.75	6.35	25.86	14	178	56	95	0.67	0.4	9.001	1.700	177	56	47	47	

----- Feeder No. 14 (1004) Beginning with Device 1004 -----																					
C 1004	1009	ABC		15.12Y	126.0	0.00	0.00	103.55	0	4441	1530	95	0.00	0.0	0.000	1.700	0	0	0	378	C
439	1004	ABC	102-#1/O A	14.79Y	123.2	2.76	2.76	103.55	45	4441	1530	95	78.21	1.8	3.100	3.100	601	233	22	378	
NODE43	439	ABC	Node	14.79Y	123.2	0.00	2.76	88.74	0	3745	1216	95	0.00	0.0	3.100	3.100	2000	657	0	356	
776	NODE43	ABC	102-#1/O A	14.76Y	123.0	0.22	2.97	40.25	18	1701	544	95	2.46	0.1	3.700	0.600	103	32	17	356	
438	776	ABC	102-#1/O A	14.68Y	122.4	0.65	3.62	33.73	15	1423	454	95	6.16	0.4	5.900	2.200	131	41	34	307	
437	438	AB	106-#2 ACS	14.66Y	122.1	0.24	3.86	17.07	9	478	151	95	0.70	0.1	7.184	1.284	263	83	45	95	
732	437	AB	106-#2 ACS	14.65Y	122.1	0.07															

----- Feeder No. 82 (8002) Beginning with Device 8002 -----

Table with columns for device number (8002, 1024, 804, 915), parent device (8000, 1024, 804), conductor type (ABC), description (Transforme, Cap), voltage (15.12Y 126.0), and various electrical parameters like capacity, loss, and power factor.

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (Capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

Summary table for Feeder No. 82 showing Load (8165 KW, 3955 KVAR), Adjustment (335, 162), Capacitance (0), Charging (0), GenMotors (0), Loops&Metas (0), Losses (0), No Load Losses (0.00), Total (8500 KW, 4117 KVAR), and voltage levels (Lowest Voltage = 126.00, Max Accm VoltD = 0.00, Max Elem VoltD = 0.00) on Element 8000.

Balanced Voltage Drop Report  
Source: 7000

Database: C:\MILSOFT\DATA\2014IMPROVED-CWP.WVA  
Title: 2014 Improved  
Case: Work Plan 2010-2014

07/20/2010 13:43 Page 11

Units Displayed In Volts -Base Voltage:120.0-  
Table with columns: Element Name, Parent Name, Cnf, Conductor, Type/ kv, Pri, Base, Element, Accum, Thru, % Thru, KVAR, PF, KW, % Loss, mi From, Length (mi), KW, KVAR, Cons On, Cons Thru. Row for C 7000.

----- Feeder No. 0 (7008) Beginning with Device 7008 -----

Table row for Feeder No. 0 (7008) showing parent 7000, conductor ABC, voltage 7.56Y 126.0, and various electrical parameters.

----- Feeder No. 71 (7001) Beginning with Device 7001 -----

Table for Feeder No. 71 (7001) listing multiple elements (7001, 4, 3, 2, 1, 1406, 1407) with their parent (7001), conductor type (ABC, A, B, C), descriptions (e.g., 090-#336.4, 110-#4 ACS, BC Node), and electrical parameters.

----- Feeder No. 72 (7002) Beginning with Device 7002 -----

Large table for Feeder No. 72 (7002) listing numerous elements (7002, 617, 11, 9, 10, 17, 16, 15, 13, 12, 866, 629, 35, 36, 37, 38, 39, 40, 745, 117, 116, 114, 880, 41, 6, 13, 14, 17, 8, 7, 562, 563, 564, 809, 5, 791, 808, 18, 59) with their parent (7002), conductor type (ABC, B, C, A), descriptions (e.g., 090-#336.4, 106-#2 ACS, 110-#4 ACS, 4/0 SPACER), and electrical parameters.

----- Feeder No. 0 (7009) Beginning with Device 7009 -----

Table row for Feeder No. 0 (7009) showing parent 7000, conductor ABC, voltage 7.56Y 126.0, and various electrical parameters.

----- Feeder No. 73 (7003) Beginning with Device 7003 -----

Table for Feeder No. 73 (7003) listing elements (7003, 22, 21, 20, 559, 96, 97, 98, 863, 99, 100, 19) with their parent (7003), conductor type (ABC, A, B, C), descriptions (e.g., 098-#3/0 A, 102-#1/0 A, 110-#4 ACS), and electrical parameters.

----- Feeder No. 74 (7004) Beginning with Device 7004 -----

Table for Feeder No. 74 (7004) listing elements (7004, 34, 867, 33, 30, 29, 28, 928, 27, 26, 623, 23, 913, 31, 25) with their parent (7004), conductor type (ABC, A, C), descriptions (e.g., I02-#1/0 A, Cap (450), 110-#4 ACS), and electrical parameters.

24	25	C	106-#2 ACS	7.43Y 123.8	0.33	2.18	19.23	11	134	52	93	0.22	0.2	3.100	1.000	130	50	92	92
----	----	---	------------	-------------	------	------	-------	----	-----	----	----	------	-----	-------	-------	-----	----	----	----

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low

KW	Load	Adjustment	Capacitance	Charging	GenMotors	LoopsMetas	Losses	No Load	Losses	Total	Lowest Voltage = 122.18 on Element 26		
4898	149	0	0	0	0	0	53	0.00	5100	Max Accm VoltD = 3.82 on Element 26			
KVAR	1898	58	-762	0	0	0	57		1250	Max Elem VoltD = 1.75 on Element 28			

Balanced Voltage Drop Report  
Source: 1100

Database: C:\MILSOFT\DATA\2014IMPROVED-CWP.WM\  
Title: 2014 Improved  
Case: Work Plan 2010-2014  
07/20/2010 13:43 Page 12

Element Name		Parent Name	Cnf	Type/ Conductor	Pri kV	Base Element Drop	Accum Drop	Thru kV	Thru KVAR	% PF	kW Loss	% Loss	mi From Src	Length (mi)	kW	KVAR	Cons On	Cons Thru					
C 1100		ABC	JERCHO	SU	7.56Y	126.0	0.00	0.00	428.06	29	9387	2476	97	0.00	0.0	0.000	0.000	0	0	0	1620	C	
----- Feeder No. 1 (1101) Beginning with Device 1101 -----																							
C 1101		1100	ABC	JERCHO	SU	7.56Y	126.0	0.00	0.00	219.07	0	4835	1145	97	0.00	0.0	0.000	0.000	0	0	0	698	C
----- Feeder No. 2 (1102) Beginning with Device 1102 -----																							
C 1102		1100	ABC	JERCHO	SU	7.56Y	126.0	0.00	0.00	124.15	0	2650	952	94	0.00	0.0	0.000	1.200	0	0	0	494	C
----- Feeder No. 3 (1103) Beginning with Device 1103 -----																							
1103		1100	ABC	JERCHO	SU	7.56Y	126.0	0.00	0.00	85.54	0	1903	378	98	0.00	0.0	0.000	0.300	0	0	0	428	C

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvar Limits P = Power Factor Low





373	361	ABC	090-#336.4	7.18Y 119.6	0.68	6.36	140.47	27	2958	710	97	11.32	0.4	4.700	0.700	58	18	19	718
847	373	ABC	098-#3/O A	7.14Y 119.0	0.60	6.96	109.57	37	2300	522	98	10.02	0.4	5.200	0.500	15	5	4	575
848	847	ABC	REG-003	7.56Y 126.0	-6.96	0.00	108.79	109	2275	508	98	percent Boost=	5.52	Tap=	8.8				571
368	848	ABC	098-#3/O A	7.45Y 124.1	1.89	1.89	102.79	34	2275	508	98	26.93	1.2	6.758	1.558	66	21	17	571
528	368	ABC	098-#3/O A	7.44Y 123.9	0.17	2.05	99.62	33	2180	447	98	2.34	0.1	6.900	0.142	33	10	6	554
367	528	ABC	098-#3/O A	7.43Y 123.8	0.12	2.17	98.02	33	2143	433	98	1.61	0.1	7.000	0.100	3	1	1	540
365	367	ABC	098-#3/O A	7.42Y 123.7	0.18	2.35	79.66	27	1749	307	98	2.04	0.1	7.200	0.200	82	26	17	451
363	365	ABC	098-#3/O A	7.34Y 122.4	1.24	3.59	68.02	23	1497	225	99	12.17	0.8	8.999	1.799	219	68	59	382
362	363	ABC	098-#3/O A	7.30Y 121.7	0.66	4.25	57.60	19	1262	138	99	5.90	0.5	10.099	1.100	52	16	13	323
361	362	B	106-#2 ACS	7.26Y 121.0	0.75	5.00	21.56	12	150	47	95	0.58	0.4	11.999	1.900	138	43	43	48
360	361	A	106-#2 ACS	7.26Y 121.0	0.02	5.02	1.48	1	19	3	96	0.00	0.0	12.699	0.700	10	3	5	5
356	362	ABC	098-#3/O A	7.26Y 121.0	0.77	5.02	48.13	16	150	65	100	5.88	0.6	11.899	1.800	191	60	113	262
633	356	ABC	098-#3/O A	7.25Y 120.8	0.14	5.16	38.06	13	829	-11	-100	0.97	0.1	12.299	0.400	0	0	0	147
309	633	C	106-#2 ACS	7.24Y 120.7	0.10	5.26	3.63	2	25	8	95	0.01	0.0	13.899	1.600	25	8	11	11
558	633	ABC	098-#3/O A	7.24Y 120.7	0.19	5.35	36.91	12	803	-21	-100	1.33	0.2	12.899	0.600	27	8	6	136
310	558	ABC	098-#3/O A	7.24Y 120.6	0.07	5.42	21.29	7	431	-167	-93	0.70	0.2	13.899	1.000	47	15	11	128
839	310	ABC	098-#3/O A	7.23Y 120.5	0.03	5.45	19.56	7	383	-182	-90	0.25	0.1	14.299	0.400	14	4	3	117
840	839	ABC	Cap (300)	7.23Y 120.5	0.00	5.45	19.06	0	369	-187	-89	0.00	0.0	14.299	0.400	0	0	0	114
380	840	ABC	098-#3/O A	7.23Y 120.4	0.13	5.58	17.82	6	369	116	95	0.29	0.1	14.899	0.600	38	12	8	114
311	380	ABC	106-#2 ACS	7.20Y 120.0	0.38	5.96	12.45	7	258	81	95	0.68	0.3	16.199	1.300	66	21	22	86
312	311	ABC	106-#2 ACS	7.20Y 119.9	0.11	6.07	4.36	2	90	28	95	0.07	0.1	17.199	1.000	15	5	5	34
315	312	ABC	106-#2 ACS	7.20Y 119.9	0.02	6.08	3.65	2	75	23	96	0.01	0.0	17.399	0.200	22	7	6	29
316	315	ABC	106-#2 ACS	7.19Y 119.9	0.06	6.14	2.58	1	53	17	95	0.02	0.0	18.499	1.100	20	6	5	23
308	316	C	110-#4 ACS	7.19Y 119.9	0.00	6.14	0.00	0	0	0	100	0.00	0.0	18.699	0.200	0	0	0	0
H 829	308	C	REG-005	7.56Y 126.0	-6.14	-0.00	0.00	0	0	0	100	percent Boost=	0.00	Tap=	0.0			0	H
276	316	B	110-#4 ACS	7.18Y 119.7	0.12	6.27	4.88	3	33	10	96	0.03	0.1	19.099	0.600	9	3	4	18
276	276	B	110-#4 ACS	7.18Y 119.7	0.02	6.28	0.49	0	3	1	95	0.00	0.0	19.799	0.700	0	0	0	6
274	276	B	110-#4 ACS	7.18Y 119.7	0.03	6.31	0.49	0	3	1	95	0.00	0.0	22.499	2.700	3	1	6	6
892	276	AB	110-#4 ACS	7.18Y 119.7	0.02	6.29	3.03	2	21	6	96	0.00	0.0	19.399	0.300	21	7	8	8
313	311	A	110-#4 ACS	7.18Y 119.7	0.32	6.28	14.67	10	101	32	95	0.24	0.2	16.699	0.500	19	6	7	30
314	313	A	110-#4 ACS	7.16Y 119.3	0.40	6.68	11.92	9	82	26	95	0.17	0.2	18.099	1.400	82	26	23	23
882	380	ABC	106-#2 ACS	7.22Y 120.4	0.05	5.63	3.52	2	73	23	95	0.02	0.0	15.999	1.100	73	23	20	20
1401	558	ABC	110-#4 ACS	7.22Y 120.3	0.34	5.69	17.00	12	343	136	93	0.65	0.2	13.899	1.000	342	135	2	2
1430	356	ABC	106-#2 ACS	7.26Y 121.0	0.00	5.02	1.21	1	25	8	95	0.00	0.0	12.183	0.284	25	8	2	2
364	364	A	106-#2 ACS	7.35Y 122.5	1.19	3.54	23.43	13	166	52	95	1.17	0.7	9.300	2.100	94	29	30	52
357	364	A	106-#2 ACS	7.34Y 122.3	0.21	3.75	9.76	5	68	21	96	0.10	0.1	10.000	0.700	15	5	4	22
357	357	A	106-#2 ACS	7.33Y 122.2	0.02	3.77	1.13	1	8	2	97	0.00	0.0	11.200	1.200	8	2	5	5
359	357	A	106-#2 ACS	7.33Y 122.1	0.12	3.87	6.48	4	45	14	95	0.03	0.1	11.100	1.100	45	14	13	13
C 366	357	A	106-#2 ACS	7.28Y 121.3	2.52	4.68	55.04	31	390	123	95	4.79	1.2	9.672	2.672	380	118	96	96
REG55	373	ABC	SystemRegu	7.56Y 126.0	-6.36	0.00	28.15	28	589	144	97	percent Boost=	5.05	Tap=	B.1				C
849	REG55	ABC	106-#2 ACS	7.55Y 125.9	0.13	0.13	26.73	15	589	144	97	0.60	0.1	4.900	0.200	7	2	2	124
372	849	ABC	106-#2 ACS	7.50Y 125.0	0.85	0.98	26.40	15	581	142	97	3.28	0.6	6.500	1.600	217	68	55	122
371	372	B	106-#2 ACS	7.49Y 124.9	0.11	1.09	9.38	5	67	21	95	0.04	0.1	7.200	0.700	65	20	14	14
370	372	AB	106-#2 ACS	7.48Y 124.6	0.39	1.37	19.31	11	285	49	99	0.76	0.3	7.300	0.800	68	21	25	53
OH56	370	B	106-#2 ACS	7.43Y 123.8	0.79	2.16	28.96	16	215	27	99	0.85	0.4	9.018	1.718	208	26	28	28
575	370	A	106-#2 ACS	7.48Y 124.6	0.00	1.37	0.00	0	0	0	100	0.00	0.0	8.057	0.757	0	0	0	0
576	575	A	110-#4 ACS	7.48Y 124.6	0.00	1.37	0.00	0	0	0	100	0.00	0.0	8.785	0.728	0	0	0	0
REG54	381	ABC	REG-005	7.56Y 126.0	-6.68	0.00	54.46	36	1122	363	95	percent Boost=	4.51	Tap=	7.2				
379	REG54	ABC	102-#1/O A	7.50Y 125.0	1.04	1.04	52.01	23	1122	363	95	7.34	0.7	5.200	1.200	204	64	45	263
378	379	C	110-#4 ACS	7.49Y 124.9	0.06	1.10	1.19	1	8	3	94	0.00	0.0	7.400	2.200	8	3	3	3
377	379	ABC	102-#1/O A	7.47Y 124.5	0.45	1.49	41.77	18	895	287	95	2.69	0.3	5.800	0.600	39	12	10	215
376	377	ABC	102-#1/O A	7.40Y 123.4	1.16	2.65	39.90	17	852	272	95	6.61	0.8	7.400	1.600	25	8	8	205
756	376	B	110-#4 ACS	7.39Y 123.1	0.22	2.87	8.42	6	59	19	95	0.07	0.1	8.500	1.100	58	18	17	17
755	376	ABC	102-#1/O A	7.39Y 123.2	0.20	2.84	35.88	16	760	239	95	1.03	0.1	7.700	0.300	0	0	0	180
757	755	A	106-#2 ACS	7.38Y 123.0	0.17	3.02	8.40	5	59	19	95	0.05	0.1	8.900	1.200	58	18	15	15
758	755	ABC	102-#1/O A	7.38Y 123.0	0.12	2.96	33.08	14	700	220	95	0.56	0.1	7.900	0.200	35	11	5	165
375	758	B	106-#2 ACS	7.37Y 122.8	0.26	3.22	21.72	12	306	95	95	0.21	0.2	6.300	0.600	19	6	0	73
897	375	AB	106-#2 ACS	7.36Y 122.6	0.19	3.41	21.72	12	305	96	95	0.44	0.1	8.600	0.300	11	3	2	23
369	897	B	106-#2 ACS	7.32Y 122.1	0.53	3.95	28.70	16	201	63	95	0.53	0.3	9.682	1.082	198	62	47	47
374	897	A	106-#2 ACS	7.34Y 122.3	0.32	3.73	13.15	7	92	29	95	0.14	0.2	10.000	1.400	91	28	24	24
128	758	BC	106-#2 ACS	7.35Y 122.4	0.61	3.57	25.36	14	357	112	95	1.30	0.4	9.100	1.200	230	72	60	87
967	128	B	106-#2 ACS	7.32Y 122.1	0.36	3.93	17.36	10	122	38	95	0.21	0.2	10.300	1.200	120	37	27	27

----- Feeder No. 22 (2002) Beginning with Device 2002 -----

C 2002	2008	ABC		7.56Y 126.0	0.00	0.00	104.73	0	2332	452	98	0.00	0.0	0.000	1.200	0	0	0	439	C
545	2002	ABC	090-#336.4	7.51Y 125.2	0.85	0.85	104.73	20	2332	452	98	11.11	0.5	1.300	1.300	165	53	37	439	
403	545	ABC	106-#2 ACS	7.37Y 122.8	2.40	3.24	96.83	54	2149	371	99	37.68	1.8	2.300	1.000	121	39	18	402	
402	403	ABC	106-#2 ACS	7.28Y 121.4	1.36	4.61	91.06	51	1988	308	99	20.47	1.0	2.900	0.600	62	20	11	384	
402	402	ABC	102-#1/O A	7.26Y 121.1	0.31	4.92	16.49	7	343	111	95	0.71	0.2	4.300	1.400	133	43	22	79	
399	400	B	106-#2 ACS	7.26Y 121.0	0.03	4.95	1.65	1	11	4	94	0.00	0.0	5.400	1.100	11	4	5	5	
398	400	ABC	102-#1/O A	7.25Y 120.8	0.23	5.15	9.48	4	197	63	95	0.31	0.2	6.001	1.701	60	19	20	52	
397	398	B	106-#2 ACS	7.25Y 120.8	0.03	5.18	2.26	1	16	5	95	0.00	0.0	6.701	0.700	16	5			

717	712	A	106-#2 ACS	7.46Y 124.3	0.10	1.73	14.63	8	104	34	95	0.05	0.0	2.260	0.400	101	33	42	42
716	423	ABC	102-#1/0 A	7.43Y 123.8	0.55	2.15	41.11	18	847	361	92	2.52	0.3	2.600	1.000	506	196	119	120
1410	716	ABC	106-#2 ACS	7.43Y 123.8	0.03	2.18	16.17	9	324	157	90	0.04	0.0	2.713	0.113	316	153	1	1

KEY-> L = Low Voltage H = High Voltage C = Capacity Over Limit (%capacity or load amps) G = Generator Out of kvAr Limits P = Power Factor Low

KW	Load	Adjustment	Capacitance	Charging	Gen&Motors	Loops&Metas	Losses	No Load Losses	Total	Lowest Voltage	on Element 847					
KVAR	3316	64	-940	0	0	0	481	0.00	11264	119.04	6.96	6.96	4.01	3088	Max Accm VoltD =	Max Elem VoltD =

Balanced Voltage Drop Report  
Source: 6000

Database: C:\MISOFT\DATA\2014IMPROVED-CWP.WM  
Title: 2014 Improved  
Case: Work Plan 2010-2014

07/20/2010 13:43 Page 15

Element Name		Parent Name	Cnf	Type/ Conductor	Pri KV	Base Volt	Element Drop	Accum Drop	Thru Amps	% Cap	Thru KW	KVAR	% PF	KW Loss	% Loss	mi From Src	Length (mi)	KW	KVAR	Cons On	Cons Thru
c 6000			ABC	SRC-6000	7.56Y	126.0	0.00	0.00	352.36	59	7613	2430	95	0.00	0.0	0.000	0.000	0	0	0	1866
----- Feeder No. 61 (6001) Beginning with Device 6001 -----																					
C	6001	6000	ABC	106-#2 ACS	7.56Y	126.0	0.00	0.00	228.48	0	4954	1521	96	0.00	0.0	0.000	0.000	0	0	0	1209
523	6001	6001	ABC	090-#336.4	7.51Y	125.1	0.86	0.86	228.48	43	4954	1521	96	21.66	0.4	0.502	0.502	48	15	11	1209
522	523	523	ABC	090-#336.4	7.44Y	124.0	1.17	2.03	226.18	43	4883	1455	96	29.73	0.6	1.202	0.700	26	8	8	1198
521	522	522	ABC	098-#3/0 A	7.31Y	121.8	2.15	4.18	91.47	30	1926	675	94	24.77	1.3	3.002	1.800	48	15	14	462
520	521	521	B	110-#4 ACS	7.31Y	121.8	0.01	4.20	0.73	1	5	2	93	0.00	0.0	3.802	0.800	5	2	2	2
753	521	521	ABC	098-#3/0 A	7.25Y	120.8	1.03	5.22	88.92	30	1848	622	95	11.66	0.6	3.902	0.900	55	18	12	466
519	753	753	ABC	098-#3/0 A	7.19Y	119.8	0.97	6.18	83.84	28	1731	572	95	10.28	0.6	4.802	0.900	68	22	12	420
899	519	519	ABC	098-#3/0 A	7.18Y	119.7	0.09	6.28	80.54	27	1653	535	95	1.09	0.1	4.902	0.100	8	2	3	408
518	899	899	ABC	098-#3/0 A	7.14Y	119.0	0.72	6.99	80.06	27	1642	531	95	7.33	0.4	5.602	0.700	55	18	18	402
845	518	518	ABC	Cap (300)	7.14Y	119.0	0.00	6.99	77.38	0	1579	503	95	0.00	0.0	5.602	0.700	0	0	0	384
846	845	845	ABC	098-#3/0 A	7.14Y	118.9	0.09	7.08	77.38	26	1579	503	95	0.98	0.1	5.702	0.100	56	18	13	384
634	846	846	ABC	106-#2 ACS	7.10Y	118.4	0.54	7.62	50.31	28	1026	327	95	2.85	0.3	6.502	0.800	1033	328	226	226
754	846	846	ABC	106-#2 ACS	7.12Y	118.7	0.26	7.34	24.32	14	496	158	95	0.67	0.1	6.501	0.799	500	159	145	145
752	899	899	A	110-#4 ACS	7.18Y	119.7	0.01	6.29	0.30	0	2	1	89	0.00	0.0	6.102	1.200	2	1	3	3
751	753	753	B	110-#4 ACS	7.24Y	120.6	0.17	5.39	7.18	5	50	16	95	0.04	0.1	4.902	1.000	49	16	14	14
517	522	522	ABC	090-#336.4	7.36Y	122.6	1.36	3.40	139.73	25	2900	703	97	21.57	0.7	2.702	1.500	116	37	30	728
515	517	517	ABC	095-#4/0 A	7.24Y	120.6	1.96	5.35	70.06	21	1464	498	95	15.70	1.1	5.402	2.700	202	64	51	372
733	515	515	ABC	096-#4/0 A	7.21Y	120.2	0.46	5.81	60.29	18	1245	406	95	3.31	0.3	6.102	0.700	37	12	8	321
409	733	733	ABC	090-#336.4	7.19Y	119.8	0.35	6.16	47.06	9	968	314	95	1.76	0.2	7.102	1.000	55	17	16	253
408	409	409	A	110-#4 ACS	7.19Y	119.8	0.00	6.16	0.00	0	0	0	100	0.00	0.0	7.802	0.700	0	0	0	0
407	409	409	ABC	090-#336.4	7.17Y	119.5	0.30	6.47	44.40	8	912	293	95	1.45	0.2	8.001	0.900	19	6	7	237
406	407	407	ABC	090-#336.4	7.17Y	119.5	0.00	6.47	0.00	0	0	0	100	0.00	0.0	8.301	0.300	0	0	0	0
405	407	407	ABC	106-#2 ACS	7.15Y	119.1	0.44	6.90	43.50	24	892	283	95	2.15	0.2	8.766	0.765	863	274	221	230
565	405	405	B	110-#4 ACS	7.14Y	119.1	0.04	6.94	4.58	3	31	10	95	0.01	0.0	9.109	0.343	31	10	9	9
410	565	565	ABC	090-#336.4	7.21Y	120.1	0.00	5.89	11.43	2	236	75	95	0.07	0.0	6.002	1.300	235	75	60	60
516	517	517	A	110-#4 ACS	7.35Y	122.4	0.16	3.55	8.21	6	58	18	96	0.05	0.1	3.501	0.799	57	18	12	12
514	517	517	ABC	102-#1/0 A	7.33Y	122.2	0.36	3.75	56.32	24	1239	99	100	3.35	0.3	3.102	0.400	11	3	2	314
513	514	514	C	110-#4 ACS	7.32Y	122.0	0.27	4.03	5.98	4	42	13	96	0.06	0.1	5.002	1.900	41	13	11	11
512	514	514	ABC	102-#1/0 A	7.28Y	121.4	0.85	4.60	53.88	23	1183	79	100	7.61	0.6	4.202	1.100	144	46	28	301
904	512	512	ABC	102-#1/0 A	7.25Y	120.8	0.65	5.25	47.14	20	1030	28	100	5.25	0.5	5.202	1.000	136	43	29	273
874	904	904	ABC	102-#1/0 A	7.24Y	120.7	0.06	5.31	40.83	18	887	-19	-100	0.44	0.0	5.302	0.100	4	1	1	244
CAP68	874	874	ABC	Cap (300)	7.24Y	120.7	0.00	5.31	40.64	0	883	-20	-100	0.00	0.0	5.302	0.100	0	0	0	243
511	CAP68	CAP68	ABC	106-#2 ACS	7.22Y	120.3	0.36	5.67	19.38	11	491	128	95	1.10	0.3	6.102	0.800	66	21	21	105
510	511	511	ABC	106-#2 ACS	7.20Y	119.9	0.41	6.08	16.19	9	334	106	95	0.93	0.3	7.402	1.300	156	49	34	84
412	510	510	ABC	106-#2 ACS	7.19Y	119.8	0.08	6.16	8.63	5	178	57	95	0.11	0.1	7.802	0.400	35	11	10	50
413	412	412	B	106-#2 ACS	7.15Y	119.1	0.74	6.89	18.06	10	124	39	95	0.49	0.4	9.902	2.100	107	34	31	35
411	412	412	B	106-#2 ACS	7.15Y	119.1	0.02	6.91	2.42	1	16	5	95	0.00	0.0	10.302	0.400	17	5	4	4
898	413	413	B	106-#2 ACS	7.19Y	119.8	0.02	6.18	2.72	2	19	6	95	0.00	0.0	8.302	0.500	19	6	5	5
509	CAP68	CAP68	ABC	106-#2 ACS	7.19Y	119.8	0.87	6.18	23.29	13	481	155	95	3.05	0.6	6.802	1.500	68	21	25	138
508	509	509	A	106-#2 ACS	7.16Y	119.3	0.52	6.69	29.75	17	407	131	95	1.53	0.4	7.402	0.600	27	9	9	112
501	508	508	A	106-#2 ACS	7.11Y	118.5	0.82	7.51	26.67	15	364	116	95	2.01	0.6	8.702	1.300	155	49	44	98
RE669	501	501	A	RE6-003	7.56Y	126.0	-7.51	0.00	30.64	31	207	66	95	percent Boost=	5.96	Tap=	9.5	199	63	54	54
500	RE669	RE669	A	106-#2 ACS	7.47Y	124.4	1.58	1.58	28.81	16	207	66	95	1.57	0.8	11.502	3.200	199	63	54	54
507	508	508	C	106-#2 ACS	7.16Y	119.3	0.03	6.72	2.24	1	15	5	95	0.00	0.0	8.202	0.800	15	5	5	5
900	509	509	B	106-#2 ACS	7.19Y	119.8	0.00	6.18	0.52	0	4	1	97	0.00	0.0	6.902	0.100	4	1	1	1
----- Feeder No. 62 (6002) Beginning with Device 6002 -----																					
6002	6000	6000	ABC	090-#336.4	7.56Y	126.0	0.00	0.00	36.98	0	797	262	95	0.00	0.0	0.000	0.100	0	0	0	208
532	6002	6002	ABC	090-#336.4	7.55Y	125.8	0.17	0.17	36.98	7	797	262	95	0.68	0.1	0.600	0.600	5	1	1	208
531	532	532	C	118-#8 A-C	7.53Y	125.8	0.00	0.17	0.00	0	0	0	100	0.00	0.0	1.000	0.400	0	0	0	0
530	532	532	A	110-#4 ACS	7.55Y	125.8	0.00	0.17	0.07	0	0	0	100	0.00	0.0	0.800	0.200	0	0	2	2
529	532	532	ABC	090-#336.4	7.53Y	125.5	0.31	0.48	36.74	7	791	258	95	1.24	0.2						

KVAR 2327 12 -303 0 0 0 394

2430 Max Accm VoltD = 7.62 on Element 634  
Max Elem VoltD = 2.15 on Element 521