



# CLARK ENERGY

A Touchstone Energy Cooperative 

# KENTUCKY PUBLIC SERVICE COMMISSION

## Electric Distribution Utility Annual Reliability Report

### SECTION 1: CONTACT INFORMATION

UTILITY NAME	Clark Energy
REPORT PREPARED BY	Jimmy Trimble
E-MAIL ADDRESS OF PREPARER	<a href="mailto:jtrimble@clarkenergy.com">jtrimble@clarkenergy.com</a>
PHONE NUMBER OF PREPARER	859-771-6095

### SECTION 2: REPORTING YEAR

CALENDAR YEAR OF REPORT	01/01/2025 - 12/31/2025
-------------------------	-------------------------

### SECTION 3: MAJOR EVENT DAYS (MED)

$T_{MED}$	16,634,829
FIRST DATE USED TO DETERMINE $T_{MED}$	1/1/2025
LAST DATE USED TO DETERMINE $T_{MED}$	12/31/2025
NUMBER OF MED IN REPORT YEAR	This year

NOTE: Per IEEE 1366  $T_{MED}$  should be calculated using the daily SAIDI values for the five prior years. If five years of data are not available, then utilities should use what is available until five years are accumulated.

### SECTION 4: SYSTEM RELIABILITY INFORMATION AND RESULTS

#### System-wide Information

TOTAL CUSTOMERS	<u>29,554</u>	TOTAL CIRCUITS	<u>74</u>
-----------------	---------------	----------------	-----------

#### Excluding MED

5 YEAR AVERAGE		REPORTING YEAR	
SAIDI	<u>417.24</u>	SAIDI	<u>324.31</u>
SAIFI	<u>2.1</u>	SAIFI	<u>2.8</u>

#### Including MED

5 YEAR AVERAGE		REPORTING YEAR	
SAIDI	<u>1324.66</u>	SAIDI	<u>918.22</u>
SAIFI	<u>3.19</u>	SAIFI	<u>3.45</u>

#### Notes:

- 1) All duration indices (SAIDI) are to be reported in units of minutes.
- 2) Reports are due on the first business day of May of each year
- 3) Reports cover the calendar year ending in the December before the reports are due.
- 4) IEEE 1366 (latest version) is used to define SAIDI, SAIFI, and  $T_{MED}$

# KENTUCKY PUBLIC SERVICE COMMISSION

---

## SECTION 6: VEGETATION MANAGEMENT PLAN REVIEW

### INCLUDE CURRENT VEGETATION MANAGEMENT PLAN

Additional page may be attached as needed.

Clark Energy has been actively focused on maintaining and improving our right-of-way. We have prioritized targeted efforts to reduce outage frequency and improve overall system reliability. In addition, we are conducting a comprehensive system inventory to identify all areas requiring vegetation management, which will support a more efficient and informed bidding process.

We are shifting our focus to address a significant number of dead danger trees that are contributing to outages. The primary concerns are the ash and oak tree population, which have been particularly problematic.

To help mitigate this, we have more than doubled our herbicide usage in an effort to slow tree and underbrush growth. We have also added circuit cut into our rotation. These efforts are aimed at bringing affected areas into a more manageable condition and improving our overall system reliability.

---

## SECTION 7: UTILITY COMMENTS

---

**PSC Report**

Excluding Major Event Day Outages, Power Supply outages, Customer Responsible Outages and Momentary Outages

**Substation: BECKNERVILLE**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

BECKNERVILLE

Substation  
 Substation Location COMBS FERRY RD  
 Circuit 204 Combs Ferry  
 Circuit Location COMBS FERRY  
 Total Circuit Length (miles) 7.71  
 Average Member Count 154  
 Date of last Trim Spot Trim 2025

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
<b>Total Minutes/Frequency</b>	<b>694.45</b>	<b>3.48</b>	<b>150.07</b>	<b>.77</b>
<b>Animals</b>	37.33%	36.57%	2.82%	6.09%
600 Small Animal/Bird	0.36%	1.12%	2.60%	5.41%
601 Squirrel	0%	0%	0.23%	0.68%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	8.21%	13.99%	0%	0%
612 Animal/Large Bird	28.77%	21.46%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
<b>Equipment or Installation/Design</b>	2.12%	2.24%	0.75%	1.69%
300 Material or Equipment Fault/Failure	1.67%	1.49%	0.75%	1.69%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0.46%	0.75%	0%	0%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
<b>Maintenance</b>	40.28%	44.22%	73.98%	63.62%
400 Decay/Age of Material/Equipment	0%	0%	0.33%	0.34%
410 Corrosion/Abrasion of Material/Equipm	0%	0%	0%	0%
420 Tree Growth	0.43%	0.37%	10.12%	3.89%
430 Tree failure from overhang or dead tr	39.85%	43.84%	63.53%	59.39%
440 Trees With Ice/Snow	0%	0%	0%	0%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%

**PSC Report**

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages

**Substation: BECKNERVILLE**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

BECKNERVILLE

Substation  
 Substation Location Combs Ferry Rd  
 Circuit 204 Combs Ferry  
 Circuit Location Combs Ferry  
 Total Circuit Length (miles) 7.71  
 Average Member Count 154  
 Date of last Trim Spot Trim 2025

	Total Minutes/Frequency	Totals		5 Year Average	
		SAIDI 694.45	SAIFI 3.48	SAIDI 150.07	SAIFI 0.77
<b>Maintenance</b>		40.28%	44.22%	73.98%	63.62%
490 Maintenance, Other		0%	0%	0%	0%
<b>Other</b>		0.42%	0.56%	1.78%	0.34%
800 Other		0.42%	0.56%	1.78%	0.34%
801 Supervisor Review		0%	0%	0%	0%
<b>Planned Outage</b>		9.48%	11.19%	3.53%	9.31%
100 Construction		9.48%	11.19%	2.94%	5.58%
110 Maintenance		0%	0%	0.59%	3.72%
190 Other Planned		0%	0%	0%	0%
<b>Power Supply</b>		0%	0%	0%	0%
000 Power Supply		0%	0%	0%	0%
<b>Public</b>		0.47%	0.37%	0.20%	0.68%
700 Customer-Caused		0.47%	0.37%	0%	0%
710 Motor Vehicle		0%	0%	0%	0%
720 Aircraft		0%	0%	0.20%	0.68%
730 Fire		0%	0%	0%	0%
740 Public Cuts Tree		0%	0%	0%	0%
750 Vandalism		0%	0%	0%	0%
760 Switching error or caused by construe		0%	0%	0%	0%
790 Public, Other		0%	0%	0%	0%
<b>Unknown</b>		0%	0%	7.66%	11.84%
999 Cause Unknown		0%	0%	7.66%	11.84%
<b>Weather</b>		9.89%	4.85%	9.28%	6.43%
500 Lightning		3.68%	2.99%	4.52%	5.92%

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages

**Substation: BECKNERVILLE**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

BECKNERVILLE

---

Substation  
Substation Location Combs Ferry Rd  
Circuit 204 Combs Ferry  
Circuit Location Combs Ferry  
Total Circuit Length (miles) 7.71  
Average Member Count 154  
Date of last Trim Spot Trim 2025

	Totals		5 Year Average	
<u>Total Minutes/Frequency</u>	SAIDI	SAIFI	SAIDI	SAIFI
<b>Weather</b>	<b>694.45</b>	<b>3.48</b>	<b>150.07</b>	<b>.77</b>
510 Wind, Not Trees	9.89%	4.85%	9.28%	6.43%
520 Ice, Sleet, Frost, Not Trees	0.08%	0.19%	4.74%	0.34%
530 Flood	6.13%	1.68%	0.02%	0.17%
590 Weather, Other	0%	0%	0%	0%

Printed 4/6/2026 1,44,12 PM

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages

**Substation: BOWEN**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

BOWEN

Substation  
 Substation Location Campton Rd  
 Circuit 114 Natural Bridge  
 Circuit Location Campton Rd and Natural Bridge Rd  
 Total Circuit Length (miles) 48.64  
 Average Member Count 522  
 Date of last Trim Spot Trim 2025

Total Minutes/Frequency	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
	<b>620.79</b>	<b>4.45</b>	<b>433.96</b>	<b>1.98</b>
<b>Animals</b>	0.28%	0.78%	2.92%	11.83%
600 Small Animal/Bird	0%	0%	0.09%	0.23%
601 Squirrel	0.28%	0.78%	2.84%	11.59%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
<b>Equipment or Installation/Design</b>	0.94%	0.22%	1.40%	2.85%
300 Material or Equipment Fault/Failure	0%	0%	1.10%	2.12%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0.94%	0.22%	0.30%	0.72%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
<b>Maintenance</b>	<b>88.58%</b>	<b>81.91%</b>	<b>70.95%</b>	<b>55.00%</b>
400 Decay/Age of Material/Equipment	0.00%	0.04%	0.14%	0.93%
410 Corrosion/Abrasion of Material/Equipm	0%	0%	0.01%	0.04%
420 Tree Growth	5.56%	5.30%	2.01%	2.95%
430 Tree failure from overhang or dead tr	83.01%	76.53%	60.96%	48.52%
440 Trees With Ice/Snow	0.01%	0.04%	7.81%	2.38%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0.02%	0.08%

**PSC Report**

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages

**Substation: BOWEN**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

BOWEN

Substation  
 Substation Location Campton Rd  
 Circuit 114 Natural Bridge  
 Circuit Location Campton Rd & Natural Bridge Rd  
 Total Circuit Length (miles) 48.64  
 Average Member Count 522  
 Date of last Trim Spot Trim 2025

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
<b>Total Minutes/Frequency</b>	<b>620.79</b>	<b>4.45</b>	<b>433.96</b>	<b>1.98</b>
<b>Maintenance</b>	88.58%	81.91%	70.95%	55.00%
490 Maintenance, Other	0%	0%	0.02%	0.08%
<b>Other</b>	0%	0%	0.09%	0.40%
800 Other	0%	0%	0.09%	0.40%
801 Supervisor Review	0%	0%	0%	0%
<b>Planned Outage</b>	9.84%	16.75%	9.10%	21.15%
100 Construction	9.20%	11.28%	7.62%	15.14%
110 Maintenance	0.64%	5.47%	1.48%	6.01%
190 Other Planned	0%	0%	0%	0%
<b>Power Supply</b>	0%	0%	0%	0%
000 Power Supply	0%	0%	0%	0%
<b>Public</b>	0.15%	0.13%	1.12%	2.31%
700 Customer-Caused	0%	0%	0.02%	0.08%
710 Motor Vehicle	0.15%	0.13%	1.01%	2.04%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	0%	0%	0.08%	0.17%
750 Vandalism	0%	0%	0%	0%
760 Switching error      o caused      b construe	0%	0%	0%	0%
790 Public, Other	0%	0%	0.01%	0.02%
<b>Unknown</b>	0.07%	0.13%	1.26%	1.53%
999 Cause Unknown	0.07%	0.13%	1.26%	1.53%
<b>Weather</b>	0.14%	0.09%	13.15%	4.93%
500 Lightning	0.01%	0.04%	0.78%	1.40%

**PSC Report**

Excluding Major Event Day Outages, Power Supply Outages, customer Responsible outages and Momentary Outages

**Substation: BOWEN**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

**BOWEN**

Substation

Substation Location           Campton Rd  
 Circuit                        114 Natural Bridge  
 Circuit Location            Campton Rd & Natural Bridge Rd  
 Total Circuit Length (miles) 48.64  
 Average Member Count       522  
 Date of last Trim            Spot Trim 2025

		<b>Totals</b>		<b>5 Year Average SAIDI</b>		<b>SAIFI</b>
		<b>SAIDI</b>	<b>SAIFI</b>			
		<b>620.79</b>	<b>4.45</b>	<b>433.96</b>	<b>1.98</b>	
		<b>Total Minutes/Frequency</b>				
<b>Weather</b>		0.14%	0.09%	13.15%	4.93%	
510	Wind, Not Trees	0%	0%	0.05%	0.13%	
520	Ice, Sleet, Frost, Not Trees	0.13%	0.04%	0%	0%	
530	Flood	0%	0%	2.89%	0.93%	
590	Weather, Other	0%	0%	9.44%	2.46%	

**PSC Report**

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages

**Substation: BOWEN**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

BOWEN

Substation  
 Substation Location           Campton Rd  
 Circuit                           134 Bowen  
 Circuit Location               Campton Rd  
 Total Circuit Length (miles) 40.47  
 Average Member Count        427  
 Date of last Trim              Spot Trim 2025

	Total Minutes/Frequency	Totals		5 Year Average	
		SAIDI	SAIFI	SAIDI	SAIFI
	<b>475.59</b>	<b>2.52</b>		<b>278.27</b>	<b>1.93</b>
		1.18%	4.00%	2.61%	11.33%
<b>Animals</b>					
600 Small Animal/Bird	0.83%	2.79%		0.15%	0.15%
601 Squirrel	0.36%	1.21%		2.47%	11.19%
610 Large .Animal	0%	0%		0%	0%
611 Cattle Rubbing	0%	0%		0%	0%
612 Animal/Large Bird	0%	0%		0%	0%
620 Animal damage-gnawing or boring	0%	0%		0%	0%
690 Animal, Other	0%	0%		0%	0%
<b>Equipment or Installation/Design</b>	<b>0.03%</b>	<b>0.09%</b>		<b>2.80%</b>	<b>3.82%</b>
300 Material or Equipment Fault/Failure	0.03%	0.09%		2.07%	3.11%
310 Installation Fault	0%	0%		0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%		0%	0%
340 Overload	0%	0%		0.73%	0.71%
350 Miscoordination of Protection Devices	0%	0%		0%	0%
360 Other Equipment Installation/Design	0%	0%		0%	0%
<b>Maintenance</b>	<b>39.40%</b>	<b>27.14%</b>		<b>59.41%</b>	<b>52.16%</b>
400 Decay/Age of Material/Equipment	0.50%	0.28%		0.38%	1.87%
410 Corrosion/Abrasion of Material/Equipm	0%	0%		0%	0%
420 Tree Growth	0%	0%		2.58%	5.25%
430 Tree failure from overhang or dead tr	36.34%	24.91%		46.89%	36.99%
440 Trees With Ice/Snow	2.55%	1.95%		9.54%	8.03%
450 Contamination (leakage/external)	0%	0%		0%	0%
460 Moisture	0%	0%		0%	0%
470 Borrower crew cuts tree	0%	0%		0%	0%

**PSC Report**

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages

**Substation: BOWEN**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

BOWEN

Substation  
 Substation Location           Campton Rd  
 Circuit                           134 Bowen  
 Circuit Location               Campton Rd  
 Total Circuit Length (miles)   40.47  
 Average Member Count        427  
 Date of last Trim               Spot Trim 2025

	Total	Minutes/Frequency	Totals		5 Year Average	
			SAIDI	SAIFI	SAIDI	SAIFI
	<b>475.59</b>		<b>2.52</b>		<b>278.27</b>	<b>1.93</b>
<b>Maintenance</b>			39.40%	27.14%	59.41%	52.16%
490 Maintenance, Other			0%	0%	0.02%	0.02%
<b>Other</b>			0.20%	0.09%	0%	0%
800 Other			0.20%	0.09%	0%	0%
801 Supervisor Review			0%	0%	0%	0%
<b>Planned Outage</b>			12.92%	20.07%	12.49%	15.00%
100 Construction			12.56%	18.31%	11.22%	10.04%
110 Maintenance			0.37%	1.77%	1.27%	4.96%
190 Other Planned			0%	0%	0%	0%
<b>Power Supply</b>			0%	0%	0%	0%
000 Power Supply			0%	0%	0%	0%
<b>Public</b>			0.20%	0.65%	2.69%	2.82%
700 Customer-Caused			0%	0%	0.01%	0.02%
710 Motor Vehicle			0.03%	0.28%	2.20%	1.80%
720 Aircraft			0%	0%	0%	0%
730 Fire			0.02%	0.19%	0%	0%
740 Public Cuts Tree			0%	0%	0.49%	1.00%
750 Vandalism			0%	0%	0%	0%
760 Switching error or		caused by construe	0%	0%	0%	0%
790 Public, Other			0.14%	0.19%	0%	0%
<b>Unknown</b>			0.05%	0.19%	0.83%	2.53%
999 Cause Unknown			0.05%	0.19%	0.83%	2.53%
<b>Weather</b>			46.01%	47.77%	19.16%	12.33%
500 Lightning			1.19%	4.65%	4.44%	5.98%

**PSC Report**

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages

**Substation: BOWEN**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

BOWEN

Substation

Substation Location           Campton Rd  
 Circuit                        134 Bowen  
 Circuit Location            Campton Rd  
 Total Circuit Length (miles) 40.47  
 Average Member Count      427  
 Date of last Trim            Spot Trim 2025

	Total	Totals		5 Year	Average	
		MinutesLFrequency	SAIDI	SAIFI	SAIDI	SAIFI
			<b>475.59</b>	<b>2.52</b>	<b>278.27</b>	<b>1.93</b>
<b>Weather</b>			46.01%	47.77%	19.16%	12.33%
510 Wind, Not Trees			34.01%	39.87%	10.43%	2.85%
520 Ice, Sleet, Frost, Not Trees			0%	0%	0%	0%
530 Flood			10.81%	3.25%	4.29%	3.50%
590 Weather, Other			0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages

**Substation: FRENCHBURG**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

FRENCHBURG

Substation  
 Substation Location Hwy 36  
 Circuit 114 H 460 West  
 Circuit Location Hwy 36 and Hwy 460 West  
 Total Circuit Length (miles) 24.76  
 Average Member Count 463  
 Date of last Trim Spot trim 2025 & Herbicide 2025

Total <u>Minutes/Frequency</u>	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
	597.61	6.87	165.96	1.58
<b>Animals</b>	0.12%	0.13%	0.33%	0.99%
600 Small Animal/Bird	0.12%	0.13%	0.09%	0.19%
601 Squirrel	0%	0%	0.24%	0.79%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animalr Other	0%	0%	0%	0%
<b>Equipment or Installation/Design</b>	0.06%	0.19%	1.24%	2.14%
300 Material or Equipment Fault/Failure	0%	0%	1.13%	1.86%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0.06%	0.19%	0.11%	0.27%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
<b>Maintenance</b>	34.01%	49.34%	74.53%	62.90%
400 Decay/Age of Material/Equipment	11.50%	15.18%	0.08%	0.05%
410 Corrosion/Abrasion of Material/Equipm	0%	0%	0%	0%
420 Tree Growth	1.57%	3.27%	0.82%	0.82%
430 Tree failure from overhang or dead tr	13.74%	30.11%	72.06%	60.66%
440 Trees With Ice/Snow	7.19%	0.75%	0.80%	0.52%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary outages

**Substation: FRENCHBURG**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

FRENCHBURG

Substation  
 Substation Location Hwy 36  
 Circuit 114 Hwy 460 West  
 Circuit Location Hwy 36 & Hwy 460 West  
 Total Circuit Length (miles) 24.76  
 Average Member Count 463  
 Date of last Trim Spot Trim 2025 & Herbicide 2025

	Total	Minutes/Frequency	Totals		5 Year Average	
			SAIDI	SAIFI	SAIDI	SAIFI
			597.61	6.87	165.96	1.58
<b>Maintenance</b>			34.01%	49.34%	74.53%	62.90%
490 Maintenance, Other			0.01%	0.03%	0.77%	0.85%
<b>Other</b>			0%	0%	0.48%	0.30%
800 Other			0%	0%	0.48%	0.30%
801 Supervisor Review			0%	0%	0%	0%
<b>Planned Outage</b>			42.46%	20.71%	15.55%	16.44%
100 Construction			41.56%	16.75%	13.22%	13.51%
110 Maintenance			0.90%	3.96%	2.32%	2.93%
190 Other Planned			0%	0%	0%	0%
<b>Power Supply</b>			0%	0%	0%	0%
000 Power Supply			0%	0%	0%	0%
<b>Public</b>			4.45%	14.68%	6.17%	15.51%
700 Customer-Caused			0.03%	0.03%	1.03%	1.12%
710 Motor Vehicle			4.36%	14.58%	5.14%	14.38%
720 Aircraft			0%	0%	0%	0%
730 Fire			0%	0%	0%	0%
740 Public Cuts Tree			0.07%	0.06%	0%	0%
750 Vandalism			0%	0%	0%	0%
760 Switching error or caused b construe			0%	0%	0%	0%
790 Public, Other			0%	0%	0%	0%
<b>Unknown</b>			0.17%	0.41%	0.55%	0.68%
999 Cause Unknown			0.17%	0.41%	0.55%	0.68%
<b>Weather</b>			18.72%	14.55%	1.15%	1.04%
500 Lightning			0%	0%	0.31%	0.47%

Substation FRENCHBURG  
 Substation Location Hwy 36  
 circuit 114 Hwy 460 West  
 Circuit Location Hwy 36 & Hwy 460 West  
 Total Circuit Length (miles) 24.76  
 Average Member Count 463  
 Date of last Trim Spot Trim 2025 & Herbicide 2025

	Total	Minutes/Frequency	Totals		5 Year	Average
			SAIDI	SAIFI	SAIDI	SAIFI
			597.61	6.87	165.96	1.58
<b>Weather</b>			18.72%	14.55%	1.15%	1.04%
510 Wind, Not Trees			18.72%	14.55%	0.80%	0.55%
520 Ice, Sleet, Frost,		Not Trees	0%	0%	0%	0%
530 Flood			0%	0%	0%	0%

590 Weather, Other		0%	0%	0.04%	0.03%
Substation	FRENCHBURG				
Substation Location	Hwy 36				
Circuit	134 Hwy 1274				
Circuit Location	Hwy 1274				
Total Circuit Length (miles)	<u>69.97</u>				
Average Member Count	1,042				
Date of last Trim	Spot Trim 2025 & Herbicide 2025				

	<b>Totals</b>		<b>5 Year Average</b>	
	<b>SAIDI</b>	<b>SAIFI</b>	<b>SAIDI</b>	<b>SAIFI</b>
<u>Total Minutes/Frequency</u>	<u>1,034.94</u>	<u>7.39</u>	<u>757.22</u>	<u>5.29</u>
<b>Animals</b>	3.08%	15.20%	0.62%	1.37%
600 Small Animal/Bird	2.65%	13.98%	0.17%	0.36%
601 Squirrel	0.44%	1.22%	0.37%	0.87%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0.08%	0.15%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
<b>Equipment or Installation/Design</b>	0.22%	0.38%	1.88%	6.44%
300 Material or Equipment Fault/Failure	0.16%	0.34%	1.84%	6.41%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0.06%	0.04%	0.04%	0.02%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
<b>Maintenance</b>	87.23%	72.52%	85.75%	76.92%
400 Decay/Age of Material/Equipment	5.18%	17.73%	0.09%	0.15%
410 Corrosion/Abrasion of Material/Equipm	0.01%	0.04%	0.00%	0.01%
420 Tree Growth	1.53%	2.03%	0.52%	0.75%
430 Tree failure from overhang or dead tr	63.48%	50.81%	77.56%	67.77%
440 Trees With Ice/Snow	17.03%	1.91%	6.21%	2.51%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	1.36%	5.71%

**PSC Report**

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages

**Substation: FRENCHBURG**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

FRENCHBURG

Substation  
 Substation Location Hwy 36  
 Circuit 134 Hwy 1274  
 Circuit Location Hwy 1274  
 Total Circuit Length (miles) 69.97  
 Average Member Count 1,042  
 Date of last Trim Spot Trim 2025 & Herbicide 2025

	<b>Totals</b>		<b>5 Year Average</b>	
	<b>SAIDI</b>	<b>SAIFI</b>	<b>SAIDI</b>	<b>SAIFI</b>
<b>Total Minutes/Frequency</b>	<b>1,034.94</b>	<b>7.39</b>	<b>757.22</b>	<b>5.29</b>
<b>Maintenance</b>	87.23%	72.52%	85.75%	76.92%
490 Maintenance, Other	0%	0%	0.01%	0.02%
<b>Other</b>	0.45%	0.14%	0.02%	0.03%
800 Other	0.45%	0.14%	0.02%	0.03%
801 Supervisor Review	0%	0%	0%	0%
<b>Planned Outage</b>	5.52%	6.98%	4.65%	5.82%
100 Construction	4.19%	3.08%	4.06%	2.97%
110 Maintenance	1.32%	3.91%	0.58%	2.84%
190 Other Planned	0%	0%	0.00%	0.01%
<b>Power Supply</b>	0%	0%	0%	0%
000 Power Supply	0%	0%	0%	0%
<b>Public</b>	0.00%	0.03%	0.19%	0.31%
700 Customer-Caused	0.00%	0.03%	0%	0%
710 Motor Vehicle	0%	0%	0.07%	0.09%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0.00%	0.01%
740 Public Cuts Tree	0%	0%	0.07%	0.12%
750 Vandalism	0%	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0.04%	0.09%
790 Public, Other	0%	0%	0%	0%
<b>Unknown</b>	0.28%	0.35%	0.83%	3.93%
999 Cause Unknown	0.28%	0.35%	0.83%	3.93%
<b>Weather</b>	3.22%	4.40%	6.06%	5.19%
500 Lightning	3.13%	4.39%	1.69%	0.89%

**PSC Report**

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages

**Substation: FRENCHBURG**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

FRENCHBURG

Substation

Substation Location Hwy 36  
 Circuit 134 Hwy 1274  
 Circuit Location Hwy 1274  
 Total Circuit Length (miles) 69.97  
 Average Member Count 1,042  
 Date of last Trim Spot Trim 2025 & Herbicide 2025

**Totals**

**SAIDI SAIFI**

**5 Year Average SAIDI SAIFI**

**757.22 5.29**

**Total Minutes/Frequency 1J 034.94 7.39**

Weather	3.22%	4.40%	6.06%	5.19%
510 Wind, Not Trees	0.09%	0.01%	2.66%	4.08%
520 Ice, Sleet, Frost, Not Trees	0%	0%	0.07%	0.02%
530 Flood	0%	0%	0%	0%
590 Weather, Other	0%	0%	1.64%	0.20%

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible outages and Momentary Outages

**Substation: FRENCHBURG**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

FRENCHBURG

Substation  
 Substation Location Hwy 36  
 Circuit 144 Hwy 460 East  
 Circuit Location Hwy 460 East  
 Total Circuit Length (miles) \_\_\_\_\_  
 Average Member Count 367  
 Date of last Trim Spot trim 2025 & Herbicide 2025

	Total Minutes/Frequency	Totals		5 Year Average	
		SAIDI	SAIFI	SAIDI	SAIFI
	<b>63.85</b>	<b>.99</b>		<b>7.61</b>	<b>.22</b>
<b>Animals</b>	56.67%	62.47%		31.86%	60.59%
600 Small Animal/Bird	0.20%	0.27%		1.93%	1.07%
601 Squirrel	0%	0%		29.93%	59.52%
610 Large Animal	0%	0%		0%	0%
611 Cattle Rubbing	0%	0%		0%	0%
612 Animal/Large Bird	0%	0%		0%	0%
620 Animal damage-gnawing or boring	0%	0%		0%	0%
690 Animal, Other	56.47%	62.19%		0%	0%
<b>Equipment or Installation/Design</b>	0%	0%	0%	0%	0%
300 Material or Equipment Fault/Failure	0%	0%		0%	0%
310 Installation Fault	0%	0%		0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%		0%	0%
340 Overload	0%	0%		0%	0%
350 Miscoordination of Protection Devices	0%	0%		0%	0%
360 Other Equipment Installation/Design	0%	0%		0%	0%
<b>Maintenance</b>	7.59%	3.84%		22.41%	15.28%
400 Decay/Age of Material/Equipment	0%	0%		1.00%	0.54%
410 Corrosion/Abrasion of Material/Equipm	0%	0%		0%	0%
420 Tree Growth	0%	0%		21.42%	14.75%
430 Tree failure from overhang or dead tr	3.94%	1.37%		0%	0%
440 Trees With Ice/Snow	3.65%	2.47%		0%	0%
450 Contamination (leakage/external)	0%	0%		0%	0%
460 Moisture	0%	0%		0%	0%
470 Borrower crew cuts tree	0%	0%		0%	0%

Substation

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

**FRENCHBURG**

Substation Location Hwy 36  
 Circuit 144 Hwy 460 East  
 Circuit Location Hwy 460 East  
 Total Circuit Length (miles) \_\_\_\_\_  
 Average Member Count 367  
 Date of last Trim Spot Trim 2025 & Herbicide 2025

	Totals		5 Year	Average
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	63.85	0.99	7.61	0.22
<b>Maintenance</b>	7.59%	3.84%	22.41%	15.28%
490 Maintenance, Other	0%	0%	0%	0%
<b>Other</b>	0.23%	3.01%	0%	0%
800 Other	0.23%	3.01%	0%	0%
801 Supervisor Review	0%	0%	0%	0%
<b>Planned Outage</b>	30.76%	27.40%	0.38%	0.54%
100 Construction	29.36%	26.03%	0.25%	0.27%
110 Maintenance	1.40%	1.37%	0.13%	0.27%
190 Other Planned	0%	0%	0%	0%
<b>Power Supply</b>	0%	0%	0%	0%
000 Power Supply	0%	0%	0%	0%
<b>Public</b>	2.79%	1.64%	1.67%	0.27%
700 Customer-Caused	0%	0%	1.67%	0.27%
710 Motor Vehicle	2.79%	1.64%	0%	0%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	0%	0%	0%	0%
750 Vandalism	0%	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0%	0%
790 Public, Other	0%	0%	0%	0%
<b>Unknown</b>	0.23%	0.55%	41.46%	22.79%
999 Cause Unknown	0.23%	0.55%	41.46%	22.79%
<b>Weather</b>	1.72%	1.10%	2.22%	0.54%
500 Lightning	1.72%	1.10%	2.22%	0.54%

Substation

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

FRENCHBURG

Substation Location      Hwy 36  
 Circuit                    144 Hwy 460 East  
 Circuit Location        Hwy 460 East  
 Total Circuit Length (miles) \_\_\_\_\_  
 Average Member Count        367  
 Date of last Trim            Spot Trim 2025 & Herbicide 2025

	<u>Total Minutes/Frequency</u>	<b>Totals</b>		<b>5 Year Average SAIDI</b>	
		<b>SAIDI</b>	<b>SAIFI</b>	<b>SAIFI</b>	<b>SAIDI</b>
		<b>63.85</b>	<b>.99</b>	<b>7.61</b>	<b>.22</b>
<b>Weather</b>		<b>1.72%</b>	<b>1.10%</b>	<b>2.22%</b>	<b>0.54%</b>
510 Wind, Not Trees		0%	0%	0%	0%
520 Ice, Sleet, Frost,      Not Trees		0%	0%	0%	0%
530 Flood		0%	0%	0%	0%
590 Weather, Other		0%	0%	0%	0%

**PSC Report**

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible outages and Momentary Outages

**Substation: HARDWICKS CREEK**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

HARDWICKS CREEK

Substation  
 Substation Location           Hardwicks Creek Rd  
 Circuit                           114 Little Hardwicks Crk  
 Circuit Location               Little Hardwicks Creek  
 Total Circuit Length (miles) 36.10  
 Average Member Count        422  
 Date of last Trim              Spot Trim 2025

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
<b>Total Minutes/Frequency</b>	<b>328.23</b>	<b>3.11</b>	<b>204.46</b>	<b>1.58</b>
<b>Animals</b>	1.22%	1.68%	2.60%	5.64%
600 Small Animal/Bird	0.71%	0.30%	0.60%	1.12%
601 Squirrel	0.51%	1.37%	1.90%	4.29%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0.02%	0.03%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0.08%	0.21%
<b>Equipment or Installation/Design</b>	2.81%	0.38%	4.77%	4.71%
300 Material or Equipment Fault/Failure	2.81%	0.38%	4.77%	4.71%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	0%	0%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
<b>Maintenance</b>	42.51%	27.90%	40.26%	39.15%
400 Decay/Age of Material/Equipment	5.94%	6.10%	0.58%	0.45%
410 Corrosion/Abrasion of Material/Equipm	0%	0%	0%	0%
420 Tree Growth	0.66%	0.23%	0.76%	0.85%
430 Tree failure from overhang or dead tr	35.91%	21.57%	37.97%	37.55%
440 Trees With Ice/Snow	0%	0%	0.96%	0.30%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%

**PSC Report**

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages

**Substation: HARDWICKS CREEK**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

HARDWICKS CREEK

Substation  
 Substation Location           Hardwicks Creek Rd  
 Circuit                           114 Little Hardwicks Crk  
 Circuit Location               Little Hardwicks Creek  
 Total Circuit Length (miles)   36.10  
 Average Member Count         422  
 Date of last Trim               Spot Trim 2025

	Total Minutes/Frequency	Totals		5 Year Average	
		SAIDI	SAIFI	SAIDI	SAIFI
	<u>328.23</u>	<u>3.11</u>		<u>204.46</u>	<u>1.58</u>
<b>Maintenance</b>		42.51%	27.90%	40.26%	39.15%
490 Maintenance, Other		0%	0%	0%	0%
<b>Other</b>		0%	0%	0.06%	0.18%
800 Other		0%	0%	0.06%	0.18%
801 Supervisor Review		0%	0%	0%	0%
<b>Planned Outage</b>		7.84%	4.04%	5.80%	12.22%
100 Construction		0.19%	0.30%	3.56%	7.64%
110 Maintenance		7.64%	3.73%	2.24%	4.59%
190 Other Planned		0%	0%	0%	0%
<b>Power Supply</b>		0%	0%	0%	0%
000 Power Supply		0%	0%	0%	0%
<b>Public</b>		34.14%	42.07%	29.08%	26.05%
700 Customer-Caused		0.03%	0.15%	0%	0%
710 Motor Vehicle		34.11%	41.92%	26.02%	13.25%
720 Aircraft		0%	0%	0%	0%
730 Fire		0%	0%	0.01%	0.03%
740 Public Cuts Tree		0%	0%	3.05%	12.77%
750 Vandalism		0%	0%	0%	0%
760 Switching error       or caused by construe		0%	0%	0%	0%
790 Public, Other		0%	0%	0%	0%
<b>Unknown</b>		10.70%	22.87%	0.91%	1.54%
999 Cause Unknown		10.70%	22.87%	0.91%	1.54%
<b>Weather</b>		0.79%	1.07%	16.52%	10.50%
500 Lightning		0.29%	0.23%	0.59%	0.57%

**PSC Report**

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages

**Substation: HARDWICKS CREEK**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

**HARDWICKS CREEK**

Substation

Substation Location Hardwicks Creek Rd.  
 Circuit 114 Little Hardwicks Crk  
 Circuit Location Little Hardwicks Creek Rd.  
 Total Circuit Length (miles) 36.10  
 Average Member Count 422  
 Date of last Trim Spot Trim 2025

	Total	Minutes/Frequency	Totals		5 Year Average	
			SAIDI	SAIFI	SAIDI	SAIFI
			<b>328.23</b>	<b>3.11</b>	<b>204.46</b>	<b>1.58</b>
<b>Weather</b>			0.79%	1.07%	16.52%	10.50%
510 Wind, Not Trees			0.24%	0.15%	0.27%	0.09%
520 Ice, Sleet, Frost, Not Trees			0.03%	0.23%	0%	0%
530 Flood			0%	0%	15.32%	9.30%
590 Weather, Other		0.22%	0.46%		0.34%	0.54%
Substation		1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM				
			<b>HARDWICKS CREEK</b>			

Substation Location Hardwicks Creek Rd  
 Circuit 134 Happy Top Rd Hwy 201  
 Circuit Location Happy Top and Hwy 201  
 Total Circuit Length (miles) 12.91  
 Average Member Count 157  
 Date of last Trim Spot Trim 2025

	Total	Minutes/Frequency	Totals		5 Year Average	
			SAIDI	SAIFI	SAIDI	SAIFI
			<b>657.80</b>	<b>2.42</b>	<b>130.48</b>	<b>1.18</b>
<b>Animals</b>			0.56%	2.37%	3.78%	10.04%
600 Small Animal/Bird			0%	0%	0.29%	0.66%
601 Squirrel			0.56%	2.37%	3.49%	9.38%
610 Large Animal			0%	0%	0%	0%
611 Cattle Rubbing			0%	0%	0%	0%
612 Animal/Large Bird			0%	0%	0%	0%
620 Animal damage-gnawing or boring			0%	0%	0%	0%
690 Animal, Other			0%	0%	0%	0%
<b>Equipment or Installation/Design</b>			0%	0%	16.12%	16.45%
300 Material or Equipment Fault/Failure			0%	0%	16.12%	16.45%
310 Installation Fault			0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance			0%	0%	0%	0%
340 Overload			0%	0%	0%	0%

350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
<b>Maintenance</b>	<b>90.58%</b>	<b>73.16%</b>	<b>62.94%</b>	<b>53.09%</b>
400 Decay/Age of Material/Equipment	14.03%		18.16%	7.06%
410 Corrosion/Abrasion of Material/Equipm	0%		0%	0%
420 Tree Growth	0%		2.18%	1.77%
430 Tree failure from overhang or dead tr	76.55%		55.00%	44.04%
440 Trees With Ice/Snow	0%		0.16%	0.11%
450 Contamination (leakage/external)	0%		0%	0%
460 Moisture	0%		0%	0%
470 Borrower crew cuts tree	0%		0%	0%

Printed 4/6/2026 2:22:18 PM

Substation

Substation Location Hardwicks Creek Rd  
 Circuit 134 Happy Top Rd Hwy 201  
 Circuit Location Happy Top Rd & Hwy 201  
 Total Circuit Length (miles) 12.91  
 Average Member Count 157  
 Date of last Trim Spot Trim 2025

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
<b>Total Minutes/Frequency</b>	<b>657.80</b>	<b>2.42</b>	<b>130.48</b>	<b>1.18</b>
<b>Maintenance</b>	90.58%	73.16%	62.94%	53.09%
490 Maintenance, Other	0%	0%	0.34%	0.11%
<b>Other</b>	0%	0%	0%	0%
800 Other	0%	0%	0%	0%
801 Supervisor Review	0%	0%	0%	0%
<b>Planned Outage</b>	0.84%	2.89%	2.84%	8.06%
100 Construction	0.74%	2.37%	1.43%	2.43%
110 Maintenance	0.10%	0.53%	1.41%	5.63%
190 Other Planned	0%	0%	0%	0%
<b>Power Supply</b>	0%	0%	0%	0%
000 Power Supply	0%	0%	0%	0%
<b>Public</b>	0%	0%	0.15%	0.33%
700 Customer-Caused	0%	0%	0%	0%
710 Motor Vehicle	0%	0%	0%	0%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0.15%	0.33%
740 Public Cuts Tree	0%	0%	0%	0%
750 Vandalism	0%	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0%	0%
790 Public, Other	0%	0%	0%	0%
<b>Unknown</b>	0.59%	0.79%	6.13%	8.28%
999 Cause Unknown	0.59%	0.79%	6.13%	8.28%
<b>Weather</b>	7.44%	20.79%	8.04%	3.75%
500 Lightning	7.01%	17.63%	2.63%	1.43%

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages  
**Substation: HARDWICKS CREEK**  
 1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
 HARDWICKS CREEK

Substation		Totals		5 Year Average SAIDI		SAIFI
		SAIDI	SAIFI	<u>130.48</u>	<u>1.18</u>	
Substation Location	Hardwicks Creek Rd					
Circuit	134 <u>Happy Top Rd Hwy</u> 201					
Circuit Location	Happy Top & Hwy 201					
Total Circuit Length (miles)	<u>12.91</u>					
Average Member Count	157					
Date of last Trim	Spot Trim 2025					
<b>Total Minutes/Frequency</b>		<b>657.80</b>	<b>2.42</b>			
<b>Weather</b>		7.44%	20.79%	8.04%	3.75%	
510 Wind, Not Trees		0%	0%	1.25%	0.88%	
520 Ice, Sleet, Frost, Not Trees		0%	0%	0%	0%	
530 Flood		0%	0%	0%	0%	
590 Weather, Other		0.43%	3.16%	4.15%	1.43%	

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages

**Substation: HIGH ROCK**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

HIGH ROCK

Substation  
 Substation Location South Fork  
 Circuit 104 High Rock  
 Circuit Location South Fork and High Rock  
 Total Circuit Length (miles) 27.76  
 Average Member Count 221  
 Date of last Trim Spot Trim 2025 & Herbicide 2024

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
<b>Total Minutes/Frequency</b>	<b>669.16</b>	<b>3.43</b>	<b>608.28</b>	<b>3.56</b>
<b>Animals</b>	<b>0.80%</b>	<b>2.11%</b>	<b>0.66%</b>	<b>1.55%</b>
600 Small Animal/Bird	0.18%	0.53%	0.01%	0.03%
601 Squirrel	0.62%	1.58%	0.65%	1.52%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
<b>Equipment or Installation/Design</b>	<b>0%</b>	<b>0%</b>	<b>2.14%</b>	<b>1.46%</b>
300 Material or Equipment Fault/Failure	0%	0%	1.04%	1.04%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	0.10%	0.09%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	1.00%	0.33%
<b>Maintenance</b>	<b>83.49%</b>	<b>68.12%</b>	<b>74.62%</b>	<b>70.39%</b>
400 Decay/Age of Material/Equipment	1.69%	2.11%	0.03%	0.06%
410 Corrosion/Abrasion of Material/Equipm	0%	0%	0%	0%
420 Tree Growth	11.18%	18.18%	3.42%	5.55%
430 Tree failure from overhang or dead tr	70.62%	47.69%	59.91%	60.33%
440 Trees With Ice/Snow	0.01%	0.13%	11.25%	4.45%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages

**Substation: HIGH ROCK**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

HIGH ROCK

Substation  
 Substation Location South Fork  
 Circuit 104 High rock  
 Circuit Location High Rock  
 Total Circuit Length (miles) 27.76  
 Average Member Count 221  
 Date of last Trim Spot Trim 2025 & Herbicide 2024

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
<u>Total Minutes/Frequency</u>	<u>669.16</u>	<u>3.43</u>	<sup>608.28</sup> <u>3.56</u>	
<b>Maintenance</b>	83.49%	68.12%	74.62%	70.39%
490 Maintenance, Other	0%	0%	0%	0%
<b>Other</b>	0%	0%	0%	0%-
800 Other	0%	0%	0%	0%
801 Supervisor Review	0%	0%	0%	0%
<b>Planned Outage</b>	4.41%	13.57%	8.53%	15.40%
100 Construction	4.09%	9.49%	7.55%	12.12%
110 Maintenance	0.32%	4.08%	0.98%	3.28%
190 Other Planned	0%	0%	0%	0%
<b>Power Supply</b>	0%	0%	0%	0%
000 Power Supply	0%	0%	0%	0%
<b>Public</b>	7.90%	12.12%	0.09%	0.18%
700 Customer-Caused	0%	0%	0.00%	0.03%
710 Motor Vehicle	0%	0%	0%	0%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	7.90%	12.12%	0%	0%
750 Vandalism	0%	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0%	0%
790 Public, Other	0%	0%	0.09%	0.15%
<b>Unknown</b>	0.29%	0.92%	9.82%-	7.76%
999 Cause Unknown	0.29%	0.92%	9.82%	7.76%
<b>Weather</b>	3.11%-	3.16%	4.15%	3.25%
500 Lightning	1.73%	0.53%	3.31%	3.01%

**PSC Report**

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages

**Substation: HIGH ROCK**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

HIGH ROCK

Substation

Substation Location            South Fork Rd  
 Circuit                            104 High rock  
 Circuit Location                High Rock Rd  
 Total Circuit Length (miles)   27.76  
 Average Member Count         221  
 Date of last Trim                Spot Trim 2025 & Herbicide 2024

		<b>Totals</b>		<b>5 Year Average</b>	
	<b>Total <u>Minutes/Frequency</u></b>	<b>SAIDI</b>	<b>SAIFI</b>	<b>SAIDI</b>	<b>SAIFI</b>
<b>Weather</b>		<b>669.16</b>	<b>3.43</b>	<b>608.28</b>	<b>3.56</b>
510 Wind, Not Trees		3.11%	3.16%	4.15%	3.25%
520 Ice, Sleet, Frost, Not Trees		0%	0%	0%	0%
530 Flood		0.03%	0.66%	0%	0%
590 Weather, Other		0%	0%	0%	0%
		1.35%	1.98%	0.84%	0.24%

Substation **HINKSTON**  
 Substation Location Hinkston Pike  
 Circuit 214 Langley-Hwy Garage  
 Circuit Location Midland Trail  
 Total Circuit Length (miles) 2.02  
 Average Member Count 29  
 Date of last Trim Spot Trim 2025

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
<b>Total Minutes/Frequency</b>	<b>457.62</b>	<b>2.14</b>	<b>46.95</b>	<b>.26</b>
<b>Animals</b>	33.87%	46.77%	4.06%	8.11%
600 Small Animal/Bird	33.87%	46.77%	0%	0%
601 Squirrel	0%	0%	2.22%	2.70%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	1.72%	2.70%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0.12%	2.70%
<b>Equipment or Installation/Design</b>	0%	0%	13.97%	10.81%
300 Material or Equipment Fault/Failure	0%	0%	13.97%	10.81%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 overload	0%	0%	0%	0%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
<b>Maintenance</b>	56.16%	46.77%	13.14%	5.41%
400 Decay/Age of Material/Equipment	0%	0%	0%	0%
410 Corrosion/Abrasion of Material/Equipm	0%	0%	0%	0%
420 Tree Growth	0%	0%	0%	0%
430 Tree failure from overhang or dead tr	56.16%	46.77%	13.14%	5.41%
440 Trees With Ice/Snow	0%	0%	0%	0%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%

Substation HINKSTON  
 Substation Location Hinkston  
 Circuit 214 Langley-Hwy Garage  
 Circuit Location Midland Trail  
 Total Circuit Length (miles) 2.02  
 Average Member Count 29  
 Date of last Trim Spot Trim 2025

	Totals		5 Year Average		
	n	SAIDI 457.62	SAIFI 2.14	SAIDI 46.95	SAIFI .26
<b>Total Minutes/Frequency</b>					
<b>Maintenance</b>		56.16%	46.77%	13.14%	5.41%
490 Maintenance, Other		0%	0%	0%	0%
<b>Other</b>		0%	0%	0%	0%
800 Other		0%	0%	0%	0%
801 Supervisor Review		0%	0%	0%	0%
<b>Planned Outage</b>		9.83%	4.84%	44.15%	56.76%
100 Construction		0%	0%	36.86%	37.84%
110 Maintenance		9.83%	4.84%	7.29%	18.92%
190 Other Planned		0%	0%	0%	0%
<b>Power Supply</b>		0%	0%	0%	0%
000 Power Supply		0%	0%	0%	0%
<b>Public</b>		0%	0%	12.96%	8.11%
700 Customer-Caused		0%	0%	12.96%	8.11%
710 Motor Vehicle		0%	0%	0%	0%
720 Aircraft		0%	0%	0%	0%
730 Fire		0%	0%	0%	0%
740 Public Cuts Tree		0%	0%	0%	0%
750 Vandalism		0%	0%	0%	0%
760 Switching error or caused by construe		0%	0%	0%	0%
790 Public, Other		0%	0%	0%	0%
<b>Unknown</b>		0.14%	1.61%	6.02%	5.41%
999 Cause Unknown		0.14%	1.61%	6.02%	5.41%
<b>Weather</b>		0%	0%	5.69%	5.41%
500 Lightning		0%	0%	5.69%	5.41%

Substation HINKSTON  
 Substation Location Hinkston Pike  
 Circuit 214 Langley-Hwy Garage  
 Circuit Location Midland Trail  
 Total Circuit Length (miles) 2.02  
 Average Member Count 29  
 Date of last Trim Spot Trim 2025

	Totals		5 Year Average SAIDI		SAIFI
	SAIDI	SAIFI	46.95	.26	
	457.62	2.14			
<b>Weather</b>					
510 Wind, Not Trees	0%	0%	5.69%	5.41%	
520 Ice, Sleet, Frost, Not Trees	0%	0%	0%	0%	
530 Flood	0%	0%	0%	0%	
590 Weather, Other	0%	0%	0%	0%	

**PSC Report**

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages

**Substation: HINKSTON**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

HINKSTON

Substation  
 Substation Location Hinkston Pike  
 Circuit 224 McGinnisville-Hinkston  
 Circuit Location McGinnisville and Hinkston Pike  
 Total Circuit Length (miles) 31.10  
 Average Member Count 467  
 Date of last Trim Spot Trim 2025

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
<b>Total Minutes/Frequency</b>	<b>395.77</b>	<b>2.72</b>	<b>156.18</b>	<b>1.11</b>
<b>Animals</b>	0.50%	1.26%	1.05%	4.00%
600 Small Animal/Bird	0.33%	0.94%	0.76%	3.53%
601 Squirrel	0.02%	0.08%	0.16%	0.20%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0.14%	0.27%
612 Animal/Large Bird	0.15%	0.24%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
<b>Equipment or Installation/Design</b>	<b>0.84%</b>	<b>0.63%</b>	<b>8.23%</b>	<b>10.42%</b>
300 Material or Equipment Fault/Failure	0.84%	0.63%	5.21%	6.58%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	3.03%	3.80%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0.00%	0.04%
<b>Maintenance</b>	<b>60.46%</b>	<b>49.69%</b>	<b>13.83%</b>	<b>11.63%</b>
400 Decay/Age of Material/Equipment	0%	0%	0.91%	1.45%
410 Corrosion/Abrasion of Material/Equipm	7.93%	10.38%	3.12%	2.86%
420 Tree Growth	0%	0%	0.12%	0.12%
430 Tree failure from overhang or dead tr	52.53%	39.31%	9.64%	7.01%
440 Trees With Ice/Snow	0%	0%	0%	0%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%

**PSC Report**

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages

**Substation: HINKSTON**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

INKSTON

Substation  
 Substation Location           Hinkston Pike\_\_\_\_\_

Circuit                           224 McGinnisville-Hinkston

Circuit Location                McGinnisville and Hinkston Pike

Total Circuit Length (miles)   31.10

Average Member Count         467

Date of last Trim               Spot Trim 2025

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
<b>Total Minutes/Frequency</b>	<b>395.77</b>	<b>2.72</b>	<b>156.18</b>	<b>1.11</b>
<b>Maintenance</b>	60.46%	49.69%	13.83%	11.63%
490 Maintenance, Other	0%	0%	0.04%	0.20%
<b>Other</b>	0%	0%	0%	0%
800 Other	0%	0%	0%	0%
801 Supervisor Review	0%	0%	0%	0%
<b>Planned Outage</b>	3.05%	4.48%	42.44%	41.87%
100 Construction	1.39%	1.89%	42.18%	40.54%
110 Maintenance	1.66%	2.59%	0.26%	1.33%
190 Other Planned	0%	0%	0%	0%
<b>Power Supply</b>	0%	0%	0%	0%
000 Power Supply	0%	0%	0%	0%
<b>Public</b>	0.19%	0.08%	9.72%	6.70%
700 Customer-Caused	0%	0%	0.09%	0.08%
710 Motor Vehicle	0.19%	0.08%	9.22%	5.91%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	0%	0%	0.39%	0.67%
750 Vandalism	0%	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0%	0%
790 Public, Other	0%	0%	0.03%	0.04%
<b>Unknown</b>	24.09%	37.58%	17.08%	19.86%
999 Cause Unknown	24.09%	37.58%	17.08%	19.86%
<b>Weather</b>	10.86%	6.29%	7.65%	5.52%
500 Lightning	0.90%	0.79%	7.13%	5.09%

**PSC Report**

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages

**Substation: HINKSTON**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

HINKSTON

Substation

Substation Location Hinkston Pike  
 Circuit 224 McGinisville-Hinkston  
 Circuit Location McGinnisville and Hinkston Pike  
 Total Circuit Length (miles) 31.10  
 Average Member Count 467  
 Date of last Trim Spot Trim 2025

	Total Minutes/Frequency	Totals		5 Year Average	
		SAIDI	SAIFI	SAIDI	SAIFI
		395.77	2.72	156.18	1.11
<b>Weather</b>		10.86%	6.29%	7.65%	5.52%
510 Wind, Not Trees		0%	0%	0%	0%
520 Ice, Sleet, Frost, Not Trees		0%	0%	0.52%	0.43%
530 Flood		0%	0%	0%	0%
590 Weather, Other		9.96%	5.50%	0%	0%

Substation HINKSTON  
 Substation Location Hinkston Pike  
 Circuit 234 Hwy 60-Mtn View  
 Circuit Location Hwy 60 and Stepstone  
 Total Circuit Length (miles) 21.31  
 Average Member Count 191  
 Date of last Trim Spot Trim 2025

	Total Minutes/Frequency	Totals		5 Year Average	
		SAIDI	SAIFI	SAIDI	SAIFI
		617.85	3.07	245.35	1.37
<b>Animals</b>		25.57%	33.79%	5.11%	5.95%
600 Small Animal/Bird		25.57%	33.79%	0.69%	1.17%
601 Squirrel		0%	0%	0%	0%
610 Large Animal		0%	0%	0%	0%
611 Cattle Rubbing		0%	0%	4.43%	4.77%
612 Animal/Large Bird		0%	0%	0%	0%
620 Animal damage-gnawing or boring		0%	0%	0%	0%
690 Animal, Other		0%	0%	0%	0%
<b>Equipment or Installation/Design</b>		1.02%	2.90%	38.38%	35.45%
300 Material or Equipment Fault/Failure		0.28%	0.34%	38.33%	35.29%
310 Installation Fault		0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance		0%	0%	0%	0%
340 Overload		0.74%	2.56%	0.05%	0.16%

350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
<b>Maintenance</b>	<b>2.63%</b>	<b>2.73%</b>	<b>13.06%</b>	<b>16.51%</b>
400 Decay/Age of Material/Equipment	0.49%	0.34%	5.77%	4.46%
410 Corrosion/Abrasion of Material/Equipm	0%	0%	0%	0%
420 Tree Growth	0%	0%	0.04%	0.08%
430 Tree failure from overhang or dead tr	2.14%	2.39%	7.24%	11.97%
440 Trees With Ice/Snow	0%	0%	0%	0%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%

Substation **HINKSTON**  
 Substation Location Hinkston Pike  
 Circuit 234 Hwy 60-Mtn View  
 Circuit Location Hwy 60 & Stepstone  
 Total Circuit Length (miles) 21.31  
 Average Member Count 191  
 Date of last Trim Spot Trim 2025

			Totals		5 Year Average	
			SAIDI	SAIFI	SAIDI	SAIFI
Total	Minutes/Frequency	617.85	3.07		245.35	1.37
<b>Maintenance</b>		2.63%	2.73%		13.06%	16.51%
490 Maintenance, Other		0%	0%		0%	0%
<b>Other</b>		0%	0%		1.98%	1.02%
800 Other		0%	0%		1.98%	1.02%
801 Supervisor Review		0%	0%		0%	0%
<b>Planned Outage</b>		4.32%	13.65%		8.40%	14.16%
100 Construction		3.46%	3.75%		7.19%	8.53%
110 Maintenance		0.86%	9.90%		1.20%	5.63%
190 Other Planned		0%	0%		0%	0%
<b>Power Supply</b>		0%	0%		0%	0%
000 Power Supply		0%	0%		0%	0%
<b>Public</b>		57.66%	32.76%		0.67%	1.25%
700 Customer-Caused		0.96%	0.51%		0.02%	0.08%
710 Motor Vehicle		56.70%	32.25%		0.65%	1.17%
720 Aircraft		0%	0%		0%	0%
730 Fire		0%	0%		0%	0%
740 Public Cuts Tree		0%	0%		0%	0%
750 Vandalism		0%	0%		0%	0%
760 Switching error or	caused by construe	0%	0%		0%	0%
790 Public, Other		0%	0%		0%	0%
<b>Unknown</b>		0.01%	0.34%		27.97%	21.52%
999 Cause Unknown		0.01%	0.34%		27.97%	21.52%
<b>Weather</b>		8.79%	13.82%		4.44%	4.15%
500 Lightning		8.79%	13.82%		4.44%	4.15%

**PSC Report**

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary outages

**Substation: HINKSTON**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

HINKSTON

<u>Substation</u>		<b>Totals</b>		<b>5 Year Average SAIDI</b>		<b>SAIFI</b>
		<b>SAIDI</b>	<b>SAIFI</b>	<b>245.35</b>	<b>1.37</b>	
<b>Total Minutes/Frequency</b>		<b>617.85</b>	<b>3.07</b>			
Substation Location	Hinkston Pike					
Circuit	234 Hwy 60-Mtn View					
Circuit Location	Hwy 60 & Stepstone					
Total Circuit Length (miles)	21.31					
Average Member Count	191					
Date of last Trim	Spot Trim 2025					
<b>Weather</b>		<b>8.79%</b>	<b>13.82%</b>	<b>4.44%</b>	<b>4.15%</b>	
510 Wind, Not Trees		0%	0%	0%	0%	
520 Ice, Sleet, Frost, Not Trees		0%	0%	0%	0%	
530 Flood		0%	0%	0%	0%	
590 Weather, Other		0%	0%	0%	0%	

**PSC Report**

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages

**Substation: HINKSTON**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

**HINKSTON**

Substation  
 Substation Location           Hinkston Pike  
 Circuit                           244 Hanson Plastic  
 Circuit Location  
 Total Circuit Length (miles)   .17    
 Average Member Count        5  
 Date of last Trim             Spot Trim 2025

			Totals		5 Year Average	
			SAIDI	SAIFI	SAIDI	SAIFI
	<b>Total Minutes/Frequency</b>	<b>32.20</b>	<b>.40</b>	<b>17.08</b>	<b>.12</b>	
<b>Animals</b>			95.03%	50%	55.74%	66.67%
600 Small Animal/Bird			95.03%	50%	55.74%	66.67%
601 Squirrel			0%	0%	0%	0%
610 Large Animal			0%	0%	0%	0%
611 Cattle Rubbing			0%	0%	0%	0%
612 Animal/Large Bird			0%	0%	0%	0%
620 Animal damage-gnawing       or boring			0%	0%	0%	0%
690 Animal, Other			0%	0%	0%	0%
<b>Equipment or Installation/Design</b>			0%	0%	0%	0%
300 Material or Equipment Fault/Failure			0%	0%	0%	0%
310 Installation Fault			0%	0%	0%	0%
320 Conductor   Sag or   Inadequate Clearance			0%	0%	0%	0%
340 Overload			0%	0%	0%	0%
350 Miscoordination       of Protection Devices			0%	0%	0%	0%
360 Other Equipment       Installation/Design			0%	0%	0%	0%
<b>Maintenance</b>			0%	0%	0%	0%
400 Decay/Age of Material/Equipment			0%	0%	0%	0%
410 Corrosion/Abrasion of Material/Equipm			0%	0%	0%	0%
420 Tree Growth			0%	0%	0%	0%
430 Tree failure from overhang or dead tr			0%	0%	0%	0%
440 Trees With Ice/Snow			0%	0%	0%	0%
450 Contamination (leakage/external)			0%	0%	0%	0%
460 Moisture			0%	0%	0%	0%
470 Borrower crew cuts tree			0%	0%	0%	0%

**PSC Report**

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages

**Substation: HINKSTON**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

INKSTON

Substation  
 Substation Location Hinkston Pike  
 Circuit 244 Hanson Plastic  
 Circuit Location Hinkston Pike  
 Total Circuit Length (miles) .17  
 Average Member Count 5  
 Date of last Trim Spot Trim 2025

			Totals		5 Year Average	
	Total Minutes/Frequency		SAIDI	SAIFI	SAIDI	SAIFI
	32.20	.40	17.08	.12		
<b>Maintenance</b>		0%	0%		0%	0%
490 Maintenance, Other		0%	0%		0%	0%
<b>Other</b>		0%	0%		0%	0%
800 Other		0%	0%		0%	0%
801 Supervisor Review		0%	0%		0%	0%
<b>Planned Outage</b>		4.97%	50%		44.26%	33.33%
100 Construction		0%	0%		0%	0%
110 Maintenance		4.97%	50%		44.26%	33.33%
190 Other Planned		0%	0%		0%	0%
<b>Power Supply</b>		0%	0%		0%	0%
000 Power Supply		0%	0%		0%	0%
<b>Public</b>		0%	0%		0%	0%
700 Customer-Caused		0%	0%		0%	0%
710 Motor Vehicle		0%	0%		0%	0%
720 Aircraft		0%	0%		0%	0%
730 Fire		0%	0%		0%	0%
740 Public Cuts Tree		0%	0%		0%	0%
750 Vandalism		0%	0%		0%	0%
760 Switching error o caused by construe		0%	0%		0%	0%
790 Public, Other		0%	0%		0%	0%
<b>Unknown</b>		0%	0%		0%	0%
999 Cause Unknown		0%	0%		0%	0%
<b>Weather</b>		0%	0%		0%	0%
500 Lightning		0%	0%		0%	0%

**PSC Report**

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages

**Substation: HINKSTON**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

HINKSTON

Substation

Substation Location           Hinkston Pike  
 Circuit                        244 Hanson Plastic  
 Circuit Location           Hinkston Pike  
 Total Circuit Length (miles) .17  
 Average Member Count       5  
 Date of last Trim           Spot Trim 2025

	Total	MinutesLFrequency	Totals		5 Year	Average
			SAIDI	SAIFI	SAIDI	SAIFI
			32.20	0.40	17.08	0.12
<b>Weather</b>			0%	0%	0%	0%
510 Wind, Not Trees			0%	0%	0%	0%
520 Ice, Sleet, Frost,	No Trees		0%	0%	0%	0%
530 Flood			0%	0%	0%	0%
590 Weather, Other			0%	0%	0%	0%

**PSC Report**

Excluding Major Event Day Outages, Power Supply outages, Customer Responsible outages and Momentary Outages

**Substation: HOPE**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

HOPE

<u>Substation</u>					
Substation Location	Hope Means Rd				
Circuit	224 Stulltown Rd				
Circuit Location	Stulltown Rd				
Total Circuit Length (miles)	<u>13.44</u>				
Average Member Count	137				
Date of last Trim	Spot Trim 2025 & Herbicide 2025				
		Totals		5 Year Average	
		SAIDI	SAIFI	SAIDI	SAIFI
		295.15	3.43	81.46	.69
	<b>Total Minutes/Frequency</b>				
<b>Animals</b>		<b>0.88%</b>	<b>1.06%</b>	<b>1.49%</b>	<b>3.13%</b>
600 Small Animal/Bird		0%	0%	0.27%	0.42%
601 Squirrel		0.38%	0.64%	1.22%	2.71%
610 Large Animal		0%	0%	0%	0%
611 Cattle Rubbing		0%	0%	0%	0%
612 Animal/Large Bird		0.50%	0.43%	0%	0%
620 Animal damage-gnawing or boring		0%	0%	0%	0%
690 Animal, Other		0%	0%	0%	0%
<b>Equipment or Installation/Design</b>		<b>0%</b>	<b>0%</b>	<b>18.43%</b>	<b>16.49%</b>
300 Material or Equipment Fault/Failure		0%	0%	18.43%	16.49%
310 Installation Fault		0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance		0%	0%	0%	0%
340 Overload		0%	0%	0%	0%
350 Miscoordination of Protection Devices		0%	0%	0%	0%
360 Other Equipment Installation/Design		0%	0%	0%	0%
<b>Maintenance</b>		<b>92.44%</b>	<b>87.02%</b>	<b>25.00%</b>	<b>22.13%</b>
400 Decay/Age of Material/Equipment		16.72%	29.36%	2.20%	3.34%
410 Corrosion/Abrasion of Material/Equipm		0%	0%	0%	0%
420 Tree Growth		11.91%	12.34%	2.00%	3.34%
430 Tree failure from overhang or dead tr		63.81%	45.32%	18.44%	15.24%
440 Trees With Ice/Snow		0%	0%	2.37%	0.21%
450 Contamination (leakage/external)		0%	0%	0%	0%
460 Moisture		0%	0%	0%	0%
470 Borrower crew cuts tree		0%	0%	0%	0%

**PSC Report**

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages

**Substation: HOPE**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

**HOPE**

Substation  
 Substation Location Hope Means Rd.  
 Circuit 224 Stulltown Rd  
 Circuit Location Stulltown Rd.  
 Total Circuit Length (miles) 13.44  
 Average Member Count 137  
 Date of last Trim Spot Trim 2025 & Herbicide 2025

	Total Minutes/Frequency	Totals		5 Year Average	
		SAIDI	SAIFI	SAIDI	SAIFI
		<b>295.15</b>	<b>3.43</b>	<b>81.46</b>	<b>0.69</b>
<b>Maintenance</b>		92.44%	87.02%	25.00%	22.13%
490 Maintenance, Other		0%	0%	0%	0%
<b>Other</b>		0%	0%	0%	0%
800 Other		0%	0%	0%	0%
801 Supervisor Review		0%	0%	0%	0%
<b>Planned Outage</b>		6.16%	10.43%	7.45%	19.62%
100 Construction		6.13%	10.21%	5.93%	7.72%
110 Maintenance		0.03%	0.21%	1.51%	11.90%
190 Other Planned		0%	0%	0%	0%
<b>Power Supply</b>		0%	0%	0%	0%
000 Power Supply		0%	0%	0%	0%
<b>Public</b>		0%	0%	35.24%	24.84%
700 Customer-Caused		0%	0%	0%	0%
710 Motor Vehicle		0%	0%	35.24%	24.84%
720 Aircraft		0%	0%	0%	0%
730 Fire		0%	0%	0%	0%
740 Public Cuts Tree		0%	0%	0%	0%
750 Vandalism		0%	0%	0%	0%
760 Switching error or caused by construe		0%	0%	0%	0%
790 Public, Other		0%	0%	0%	0%
<b>Unknown</b>		0.07%	0.85%	0%	0%
999 Cause Unknown		0.07%	0.85%	0%	0%
<b>Weather</b>		0.45%	0.64%	12.39%	13.78%
500 Lightning		0.45%	0.64%	8.98%	12.73%

**PSC Report**

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages

**Substation: HOPE**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

HOPE

<u>Substation</u>		<b>Totals</b>		<b>5 Year Average</b>	
		<b>SAIDI</b>	<b>SAIFI</b>	<b>SAIDI</b>	<b>SAIFI</b>
Substation Location	Hope Means Rd.				
Circuit	224 Stulltown Rd				
Circuit Location	Stulltown Rd.				
Total Circuit Length (miles)	<u>13.44</u>				
Average Member Count	137				
Date of last Trim	<u>Spot Trim 2025 &amp; Herbicide 2025</u>				
<b>Total</b>	<b>Minutes/Frequency</b>	<b>295.15</b>	<b>3.43</b>	<b>81.46</b>	<b>0.69</b>
<b>Weather</b>		0.45%"	0.64%"	12.39%-	13.78%"
510 Wind, Not Trees		0%	0%	3.41%	1.04%
520 Ice, Sleet, Frost,	Not Trees	0%	0%	0%	0%
530 Flood		0%	0%	0%	0%
590 Weather, Other		0%	0%	0%	0%

**PSC Report**

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages

**Substation: HUNT**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

HUNT

Substation  
 Substation Location Muddy Creek Rd  
 Circuit 224 Bybee-Elkin Station  
 Circuit Location Muddy Creek and Bybee Rd  
 Total Circuit Length (miles) 36.45  
 Average Member Count 272  
 Date of last Trim Spot Trim 2025

	Total Minutes/Frequency	Totals		5 Year Average	
		SAIDI	SAIFI	SAIDI	SAIFI
		834.91	3.94	421.51	2.50
<b>Animals</b>		13.46%	25.77%	0.58%	1.20%
600 Small Animal/Bird		0.10%	0.19%	0.12%	0.30%
601 Squirrel		0.07%	0.19%	0.46%	0.90%
610 Large Animal		0%	0%	0%	0%
611 Cattle Rubbing		0%	0%	0%	0%
612 Animal/Large Bird		13.29%	25.40%	0%	0%
620 Animal damage-gnawing or boring		0%	0%	0%	0%
690 Animal, Other		0%	0%	0%	0%
<b>Equipment or Installation/Design</b>		0%	0%	6.53%	11.34%
300 Material or Equipment Fault/Failure		0%	0%	6.40%	11.13%
310 Installation Fault		0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance		0%	0%	0%	0%
340 Overload		0%	0%	0.12%	0.18%
350 Miscoordination of Protection Devices		0%	0%	0%	0%
360 Other Equipment Installation/Design		0%	0%	0.01%	0.03%
<b>Maintenance</b>	12.86%	12.23%	79.57%	70.56%	
400 Decay/Age of Material/Equipment		0.29%	0.37%	6.29%	8.64%
410 Corrosion/Abrasion of Material/Equipm		0%	0%	2.30%	1.26%
420 Tree Growth		0.34%	0.65%	5.83%	5.13%
430 Tree failure from overhang or dead tr		12.23%	11.20%	65.10%	55.43%
440 Trees With Ice/Snow		0%	0%	0%	0%
450 Contamination (leakage/external)		0%	0%	0%	0%
460 Moisture		0%	0%	0%	0%
470 Borrower crew cuts tree		0%	0%	0.02%	0.03%

**PSC Report**

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages

**Substation: HUNT**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

HUNT

Substation  
 Substation Location Muddy Creek Rd  
 Circuit 224 Bybee-Elkin Station  
 Circuit Location Muddy Creek and Bybee  
 Total Circuit Length (miles) 36.45  
 Average Member Count 272  
 Date of last Trim Spot Trim 2025

	Total Minutes/Frequency	Totals		5 Year Average	
		SAIDI 834.91	SAIFI 3.94	SAIDI 421.51	SAIFI 2.50
<b>Maintenance</b>		12.86%	12.23%	79.57%	70.56%
490 Maintenance, Other		0%	0%	0.03%	0.06%
<b>Other</b>		5.99%	25.40%	1.78%	3.99%
800 Other		5.99%	25.40%	1.78%	3.99%
801 Supervisor Review		0%	0%	0%	0%
<b>Planned Outage</b>		57.51%	27.26%	2.91%	5.76%
100 Construction		0.55%	1.49%	1.82%	2.85%
110 Maintenance		56.95%	25.77%	1.10%	2.91%
190 Other Planned		0%	0%	0%	0%
<b>Power Supply</b>		0%	0%	0%	0%
000 Power Supply		0%	0%	0%	0%
<b>Public</b>		0.11%	0.37%	0.08%	0.15%
700 Customer-Caused		0.01%	0.09%	0%	0%
710 Motor Vehicle		0.11%	0.28%	0.04%	0.06%
720 Aircraft		0%	0%	0%	0%
730 Fire		0%	0%	0.03%	0.06%
740 Public Cuts Tree		0%	0%	0.01%	0.03%
750 Vandalism		0%	0%	0%	0%
760 Switching error or caused by construe		0%	0%	0%	0%
790 Public, Other		0%	0%	0%	0%
<b>Unknown</b>		0.09%	0.19%	4.26%	3.33%
999 Cause Unknown		0.09%	0.19%	4.26%	3.33%
<b>Weather</b>		9.98%	8.78%	4.29%	3.66%
500 Lightning		2.17%	2.05%	3.60%	3.27%

Excluding Major Event Day Outages, Power Supply Outages, customer Responsible Outages and Momentary Outages

**Substation: HUNT**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

HUNT

Substation  
 Substation Location Muddy Creek Rd.  
 Circuit 224 Bybee-Elkin Station  
 Circuit Location Muddy Creek & Bybee Rd.  
 Total Circuit Length (miles) 36.45  
 Average Member Count 272  
 Date of last Trim Spot Trim 2025

**Totals**

**SAIDI SAIPI**  
**834.91 3.94**

**5 Year Average**

**SAIDI SAIPI 421.51 2.50**

**Total Minutes/Frequency**

**Weather**

		9.98%	8.78%	4.29%	3.66%
510 Wind, Not Trees		0.22%	0.28%	0.41%	0.21%
520 Ice, Sleet, Frost, No Trees		7.59%	6.44%	0.28%	0.18%
530 Flood		0%	0%	0%	0%
590 Weather, Other		0%	0%	0%	0%

Printed 4/6/2026 2:26:15 PM

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages

**Substation: HUNT**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

HUNT

Substation				Totals		5 Year Average	
Substation Location		Muddy Creek Rd		SAIDI	SAIFI	SAIDI	SAIFI
Circuit		234 Muddy Creek					
Circuit Location		Muddy Creek					
Total Circuit Length (miles)		41.14					
Average Member Count		377					
Date of last Trim		Spot Trim 2025					
		Total Minutes/Frequency	112.07	0.88		74.10	0.60
<b>Animals</b>			2.25%	3.02%		5.45%	9.16%
600 Small Animal/Bird			0%	0%		1.96%	3.47%
601 Squirrel			0%	0%		3.27%	5.43%
610 Large Animal			0%	0%		0%	0%
611 Cattle Rubbing			0%	0%		0.15%	0.18%
612 Animal/Large Bird			0%	0%		0.06%	0.09%
620 Animal damage-gnawing or boring			0%	0%		0%	0%
690 Animal, Other			2.25%	3.02%		0%	0%
<b>Equipment or Installation/Design</b>			0.12%	0.30%		3.78%	4.09%
300 Material or Equipment Fault/Failure			0.12%	0.30%		1.91%	0.98%
310 Installation Fault			0%	0%		0%	0%
320 Conductor Sag or Inadequate Clearance			0%	0%		0.03%	0.09%
340 Overload			0%	0%		0%	0%
350 Miscoordination of Protection Devices			0%	0%		0%	0%
360 Other Equipment Installation/Design			0%	0%		1.84%	3.02%
<b>Maintenance</b>		21.11%	16.01%	57.38%	28.11%		
400 Decay/Age of Material/Equipment			0.28%	0.30%		0.30%	0.18%
410 Corrosion/Abrasion of Material/Equipm			0%	0%		0%	0%
420 Tree Growth			20.11%	14.20%		7.49%	3.74%
430 Tree failure from overhang or dead tr			0.72%	1.51%		49.59%	24.20%
440 Trees With Ice/Snow			0%	0%		0%	0%
450 Contamination (leakage/external)			0%	0%		0%	0%
460 Moisture			0%	0%		0%	0%
470 Borrower crew cuts tree			0%	0%		0%	0%

Substation HUNT  
 Substation Location Muddy Creek Rd.  
 Circuit 234 Muddy Creek  
 Circuit Location Muddy Creek  
 Total Circuit Length (miles) 41.14  
 Average Member Count 377  
 Date of last Trim Spot Trim 2025

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
<b>Total Minutes/Frequency</b>	<b>112.07</b>	<b>.88</b>	<b>74.10</b>	<b>.60</b>
<b>Maintenance</b>	21.11%	16.01%	57.38%	28.11%
490 Maintenance, Other	0%	0%	0%	0%
<b>Other</b>	1.05%	0.30%	0.41%	0.36%
800 Other	1.05%	0.30%	0.41%	0.36%
801 Supervisor Review	0%	0%	0%	0%
<b>Planned Outage</b>	47.35%	49.85%	10.46%	19.13%
100 Construction	46.11%	47.13%	7.06%	9.79%
110 Maintenance	1.23%	2.72%	3.39%	9.34%
190 Other Planned	0%	0%	0%	0%
<b>Power Supply</b>	0%	0%	0%	0%
000 Power Supply	0%	0%	0%	0%
<b>Public</b>	6.62%	2.72%	11.32%	23.40%
700 Customer-Caused	0%	0%	0%	0%
710 Motor Vehicle	6.62%	2.72%	6.64%	20.28%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0.02%	0.09%
740 Public Cuts Tree	0%	0%	4.66%	3.02%
750 Vandalism	0%	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0%	0%
790 Public, Other	0%	0%	0%	0%
<b>Unknown</b>	1.55%	1.81%	2.59%	3.56%
999 Cause Unknown	1.55%	1.81%	2.59%	3.56%
<b>Weather</b>	19.96%	25.98%	8.61%	12.19%
500 Lightning	19.29%	25.68%	1.96%	1.

Substation **HUNT**  
 Substation Location **Muddy Creek Rd.**  
 Circuit **234 Muddy Creek**  
 Circuit Location **Muddy Creek**  
 Total Circuit Length (miles) **41.14**  
 Average Member Count **377**  
 Date of last Trim **Spot Trim 2025**

	Total Minutes/Frequency	Totals		5 Year Average	
		SAIDI	SAIFI	SAIDI	SAIFI
<b>Weather</b>		<b>112.07</b>	<b>0.88</b>	<b>74.10</b>	<b>0.60</b>
510 Wind, Not Trees		19.96%	25.98%	8.61%	12.19%
520 Ice, Sleet, Frost, Not Trees		0%	0%	6.60%	10.59%
530 Flood		0.67%	0.30%	0.06%	0.09%
590 Weather, Other		0%	0%	0%	0%

**Substation: JEFFERSONVILLE**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
JEFFERSONVILLE

---

Substation  
 Substation Location Hwy 1050  
 Circuit 234 Pine Hill-Cream Alley  
 Circuit Location Pine Hill and Cream Alley  
 Total Circuit Length (miles) 66.99  
 Average Member Count 987  
 Date of last Trim Spot Trim 2025 & Herbicide 2025

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
<b>Total Minutes/Frequency</b>	<b>230.84</b>	<b>2.73</b>	<b>94.30</b>	<b>.95</b>
<b>Animals</b>	0.40%	0.56%	1.35%	2.00%
600 Small Animal/Bird	0.09%	0.07%	0.36%	0.59%
601 Squirrel	0.28%	0.41%	0.95%	1.37%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0.03%	0.07%	0.04%	0.04%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
<b>Equipment or Installation/Design</b>	1.19%	0.97%	1.59%	1.61%
300 Material or Equipment Fault/Failure	1.19%	0.97%	1.42%	1.41%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	0.16%	0.20%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
<b>Maintenance</b>	84.03%	51.60%	54.37%	50.85%
400 Decay/Age of Material/Equipment	38.43%	37.01%	1.44%	1.63%
410 Corrosion/Abrasion of Material/Equipm	0%	0%	0.03%	0.02%
420 Tree Growth	1.98%	0.48%	5.70%	2.55%
430 Tree failure from overhang or dead tr	28.28%	11.47%	35.55%	32.46%
440 Trees With Ice/Snow	15.34%	2.64%	11.65%	14.19%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%

**PSC Report**

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages

**Substation: JEFFERSONVILLE**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

JEFFERSONVILLE

Substation  
 Substation Location           Hwy 1050  
 Circuit                           234 Pine Hill-Cream Alley  
 Circuit Location               Pine Hill & Cream Alley  
 Total Circuit Length {miles}   66.99  
 Average Member Count         987  
 Date of last Trim               Spot Trim 2025 & Herbicide 2025

	Total Minutes/Frequency	Totals		5 Year Average	
		SAIDI	SAIFI	SAIDI	SAIFI
	<b>230.84</b>	<b>2.73</b>	<b>94.30</b>	<b>.95</b>	
<b>Maintenance</b>		84.03%	51.60%	54.37%	50.85%
490 Maintenance, Other		0%	0%	0%	0%
<b>Other</b>		0.02%	0.07%	0.03%	0.09%
800 Other		0.02%	0.07%	0.03%	0.09%
801 Supervisor Review		0%	0%	0%	0%
<b>Planned Outage</b>		8.00%	41.76%	9.49%	15.17%
100 Construction		7.69%	40.91%	7.83%	10.45%
110 Maintenance		0.31%	0.85%	1.67%	4.72%
190 Other Planned		0%	0%	0%	0%
<b>Power Supply</b>		0%	0%	0%	0%
000 Power Supply		0%	0%	0%	0%
<b>Public</b>		0.78%	0.22%	13.73%	11.34%
700 Customer-Caused		0.05%	0.04%	0.08%	0.17%
710 Motor Vehicle		0.73%	0.19%	12.89%	9.71%
720 Aircraft		0%	0%	0%	0%
730 Fire		0%	0%	0%	0%
740 Public Cuts Tree		0%	0%	0.67%	1.37%
750 Vandalism		0%	0%	0%	0%
760 Switching error or caused by construe		0%	0%	0%	0%
790 Public, Other		0%	0%	0.10%	0.09%
<b>Unknown</b>		0.76%	0.37%	10.81%	13.13%
999 Cause Unknown		0.76%	0.37%	10.81%	13.13%
<b>Weather</b>		4.82%	4.45%	8.62%	5.81%
500 Lightning		4.82%	4.45%	2.04%	1.31%

**Substation: JEFFERSONVILLE**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
 JEFFERSONVILLE

---

Substation  
 Substation Location Hwy 1050  
 Circuit 234 Pine Hill-Cream Alley  
 Circuit Location Pine Hill & Cream Alley  
 Total Circuit Length (miles) 66.99  
 Average Member Count 987  
 Date of last Trim Spot Trim 2025 & Herbicide 2025

	Total	Minutes/Frequency	Totals		5 Year	Average
			SAIDI	SAIFI	SAIDI	SAIFI
			230.84	2.73	94.30	0.95
<b>Weather</b>			4.82%-	4.45%-	8.62%-	5.81%-
510 Wind, Not Trees			0%	0%	3.23%	4.01%
520 Ice, Sleet, Frost,	Not Trees		0%	0%	3.34%	0.50%
530 Flood			0%	0%	0%	0%
590 Weather, Other			0%	0%	0%	0%

**Substation: MARIBA**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
MARIBA

Substation  
 Substation Location           Kendrick Ridge  
 Circuit                           104 Denniston  
 Circuit Location               Dan Ridge and Hwy 460  
 Total Circuit Length (miles)   85.02  
 Average Member Count         1,025  
 Date of last Trim               Spot Trim 2025

	<b>Totals</b>		<b>5 Year Average</b>	
	SAIDI 225.73	SAIFI 1.93	SAIDI 203.70	SAIFI 1.57
<b>Total Minutes/Frequency</b>				
<b>Animals</b>	9.10%	39.65%	0.91%	1.63%
600 Small Animal/Bird	8.85%	38.63%	0.27%	0.30%
601 Squirrel	0.25%	1.01%	0.54%	1.24%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0.03%	0.06%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0.07%	0.05%
<b>Equipment or Installation/Design</b>	0.44%	0.81%	3.55%	7.48%
300 Material or Equipment Fault/Failure	0.44%	0.81%	3.55%	7.47%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	0.01%	0.01%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
<b>Maintenance</b>	<b>67.62%</b>	<b>27.49%</b>	<b>72.71%</b>	<b>80.60%</b>
400 Decay/Age of Material/Equipment	2.89%	1.72%	0.43%	0.44%
410 Corrosion/Abrasion of Material/Equipm	0%	0%	0%	0%
420 Tree Growth	1.23%	1.52%	1.82%	2.62%
430 Tree failure from overhang or dead tr	24.34%	18.68%	70.04%	77.42%
440 Trees With Ice/Snow	39.16%	5.57%	0.40%	0.10%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages

**Substation: MARIBA**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

**MARIBA**

		<b>Totals</b>		<b>5 Year Average</b>	
		SAIDI	SAIFI	SAIDI	SAIFI
<b>Total Minutes/Frequency</b>		<b>225.73</b>	<b>1.93</b>	<b>203.70</b>	<b>1.57</b>
<b>Substation</b>					
Substation Location	Kendrick Ridge				
Circuit	104 Denniston				
Circuit Location	<u>Dan Ridge and Hwy 460</u>				
Total Circuit Length (miles)	<u>85.02</u>				
Average Member Count	1,025				
Date of last Trim	<u>Spot Trim 2025</u>				
<b>Maintenance</b>		67.62%	27.49%	72.71%	80.60%
490 Maintenance, Other		0%	0%	0.02%	0.01%
<b>Other</b>		0.55%	0.46%	0.16%	0.07%
800 Other		0.55%	0.46%	0.16%	0.07%
801 Supervisor Review		0%	0%	0%	0%
<b>Planned Outage</b>		4.77%	9.01%	2.39%	5.42%
100 Construction		2.32%	3.14%	1.85%	3.42%
110 Maintenance		2.45%	5.87%	0.53%	1.98%
190 Other Planned		0%	0%	0.00%	0.02%
<b>Power Supply</b>		0%"	0%	0%	0%
000 Power Supply		0%	0%	0%	0%
<b>Public</b>		0.47%	0.35%	0.47%"	0.70%"
700 Customer-Caused		0.31%	0.05%	0.08%	0.09%
710 Motor Vehicle		0.16%	0.30%	0.06%	0.21%
720 Aircraft		0%	0%	0%	0%
730 Fire		0%	0%	0.02%	0.01%
740 Public Cuts Tree		0%	0%	0.31%	0.39%
750 Vandalism		0%	0%	0%	0%
760 Switching error or	caused by construe	0%	0%	0%	0%
790 Public, Other		0%	0%	0%	0%
<b>Unknown</b>		7.88%"	15.75%"	0.89%	1.33%
999 Cause Unknown		7.88%	15.75%	0.89%	1.33%
<b>Weather</b>		9.17%"	6.48%"	18.92%	2.76%
500 Lightning		3.77%	3.90%	1.04%	1.22%

Excluding Major Event Day Outages, Power Supply outages, Customer Responsible Outages and Momentary Outages

**Substation: MARIBA**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

**MARIBA**

---

Substation  
 Substation Location           Kendrick Ridge  
 Circuit                           104 Denniston  
 Circuit Location               Dan Ridge and Hwy 460  
 Total Circuit Length (miles) 85.02  
 Average Member Count        1,025  
 Date of last Trim              Spot Trim 2025

	<b>Totals</b>		<b>5 Year Average</b>	
	<b>SAIDI</b>	<b>SAIFI</b>	<b>SAIDI</b>	<b>SAIFI</b>
<b>Total Minutes/Frequency</b>	<b>225.73</b>	<b>1.93</b>	<b>203.70</b>	<b>1.57</b>
<b>Weather</b>	9.17%	6.48%	18.92%	2.76%
510 Wind, Not Trees	0%	0%	0.38%	0.04%
520 Ice, Sleet, Frost, Not Trees	5.34%	2.43%	0.36%	0.07%
530 Flood	0%	0%	0%	0%
590 Weather, Other	0.06%	0.15%	17.15%	1.43%

Substation **MARIBA**  
 Substation Location Kendrick Ridge  
 Circuit 124 Wynn Flatt  
 Circuit Location Wynn Flatt  
 Total Circuit Length (miles) 9.58  
 Average Member Count 125  
 Date of last Trim Spot Trim 2025

	Totals	5 Year Average		
		SAIDI	SAIFI	
<b>Total Minutes/Frequency</b>	<b>376.23</b>	<b>2.58</b>	<b>86.43</b>	<b>.68</b>
<b>Animals</b>	0%	0%	1.80%	6.13%
600 Small Animal/Bird	0%	0%	0.33%	0.53%
601 Squirrel	0%	0%	1.47%	5.60%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
<b>Equipment or Installation/Design</b>	0%	0%	0%	0%
300 Material or Equipment Fault/Failure	0%	0%	0%	0%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	0%	0%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
<b>Maintenance</b>	<b>80.00%</b>	<b>69.88%</b>	<b>15.68%</b>	<b>14.93%</b>
400 Decay/Age of Material/Equipment	0%	0%	0.05%	0.53%
410 Corrosion/Abrasion of Material/Equipm	0%	0%	0%	0%
420 Tree Growth	0%	0%	0.22%	0.27%
430 Tree failure from overhang or dead tr	11.04%	42.86%	15.41%	14.13%
440 Trees With Ice/Snow	68.96%	27.02%	0%	0%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%

Substation MARIBA  
 Substation Location Kendrick Ridge  
 Circuit 124 Wynn Flatt  
 Circuit Location Wynn Flatt  
 Total Circuit Length (miles) 9.58  
 Average Member Count 125  
 Date of last Trim Spot Trim 2025

	Total Minutes	Frequency	Totals		5 Year Average	
			SAIDI	SAIFI	SAIDI	SAIFI
			376.23	2.58	86.43	0.68
<b>Maintenance</b>			80.00%	69.88%	15.68%	14.93%
490 Maintenance, Othe			0%	0%	0%	0%
<b>Other</b>			0%	0%	0%	0%
800 Other			0%	0%	0%	0%
801 Supervisor Review			0%	0%	0%	0%
<b>Planned Outage</b>			11.40%	17.39%	19.76%	24.00%
100 Construction			9.50%	13.66%	19.43%	21.33%
110 Maintenance			1.91%	3.73%	0.32%	2.67%
190 Other Planned			0%	0%	0%	0%
<b>Power Supply</b>			0%	0%	0%	0%
000 Power Supply			0%	0%	0%	0%
<b>Public</b>			0.10%	0.31%	0.73%	2.40%
700 Customer-Caused			0.10%	0.31%	0.62%	2.13%
710 Motor Vehicle			0%	0%	0.11%	0.27%
720 Aircraft			0%	0%	0%	0%
730 Fire			0%	0%	0%	0%
740 Public Cuts Tree			0%	0%	0%	0%
750 Vandalism			0%	0%	0%	0%
760 Switching error or caused by construe			0%	0%	0%	0%
790 Public, Other			0%	0%	0%	0%
<b>Unknown</b>			0%	0%	36.50%	34.67%
999 Cause Unknown			0%	0%	36.50%	34.67%
<b>Weather</b>			8.51%	12.42%	25.54%	17.87%
500 Lightning			8.51%	12.42%	1.57%	6.40%

Substation MARIBA  
 Substation Location Kendrick Ridge  
 Circuit 124 Wynn Flatt  
 Circuit Location Wynn Flatt  
 Total Circuit Length (miles) 9.58  
 Average Member Count 125  
 Date of last Trim Spot Trim 2025

Totals		5 Year Average	
SAIDI	SAIFI	SAIDI	SAIFI
<b>Tota</b>		<b>1 Minutes/Frequency</b>	<b>376.23 2.58</b>
			<b>86.43 .68</b>
<b>Weather</b>		8.51%	12.42%
510 Wind, Not Trees		0%	0%
520 Ice, Sleet, Frost, Not Trees		0%	0%
530 Flood		0%	0%
590 Weather, Other		0%	0%
			23.97% 11.47%

Average Member Count 114  
 Date of last Trim

	Total Minutes/Frequency	Totals		5 Year Average	
		SAIDI	SAIFI	SAIDI	SAIFI
	<b>518.62</b>	<b>4.36</b>		<b>119.62</b>	<b>1.08</b>
<b>Animals</b>	0.38%	1.01%		3.90%	6.64%
600 Small Animal/Bird	0.29%	0.80%		0.37%	1.00%
601 Squirrel	0.09%	0.20%		3.53%	5.65%
610 Large Animal	0%	0%		0%	0%
611 Cattle Rubbing	0%	0%		0%	0%
612 Animal/Large Bird	0%	0%		0%	0%
620 Animal damage-gnawing or boring	0%	0%		0%	0%
690 Animal, Other	0%	0%		0%	0%
<b>Equipment or Installation/Design</b>	19.13%	26.56%		25.46%	21.59%
300 Material or Equipment Fault/Failure	17.84%	22.94%		24.39%	19.44%
310 Installation Fault	0%	0%		0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%		0%	0%
340 Overload	1.29%	3.62%		1.07%	2.16%
350 Miscoordination of Protection Devices	0%	0%		0%	0%
360 Other Equipment Installation/Design	0%	0%		0%	0%
<b>Maintenance</b>	<b>36.68%</b>	<b>27.36%</b>	<b>52.30%</b>	<b>43.85%</b>	
400 Decay/Age of Material/Equipment	0.45%	1.21%		0.13%	0.17%
410 Corrosion/Abrasion of Material/Equipm	0%	0%		0.06%	0.17%
420 Tree Growth	0%	0%		4.44%	1.33%
430 Tree failure from overhang or dead tr	9.37%	3.22%		47.67%	42.19%
440 Trees With Ice/Snow	26.86%	22.94%		0%	0%
450 Contamination (leakage/external)	0%	0%		0%	0%

460 Moisture

470 Borrower crew cuts tree

0%

0%

0%

0%

0%

0%

0%

0%

Substation **MARIBA**  
 Substation Location Kendrick Ridge  
 Circuit 134 Kendrick Ridge-Single  
 Circuit Location Kendrick Ridge  
 Total Circuit Length (miles) 10.95  
 Average Member Count 114  
 Date of last Trim Spot Trim 2025

	Totals	5 Year Average		
		SAIDI	SAIFI	SAIDI
<b>Total Minutes/Frequency</b>	<b>518.62</b>	<b>4.36</b>	<b>119.62</b>	<b>1.08</b>
<b>Maintenance</b>	36.68%	27.36%	52.30%	43.85%
490 Maintenance, Other	0%	0%	0%	0%
<b>Other</b>	0%	0%	0%	0%
800 Other	0%	0%	0%	0%
801 Supervisor Review	0%	0%	0%	0%
<b>Planned Outage</b>	31.54%	30.78%	4.61%	8.97%
100 Construction	30.77%	22.13%	4.05%	4.82%
110 Maintenance	0.77%	8.65%	0.55%	4.15%
190 Other Planned	0%	0%	0%	0%
<b>Power Supply</b>	0%	0%	0%	0%
000 Power Supply	0%	0%	0%	0%
<b>Public</b>	0%	0%	0%	0%
700 Customer-Caused	0%	0%	0%	0%
710 Motor Vehicle	0%	0%	0%	0%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	0%	0%	0%	0%
750 Vandalism	0%	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0%	0%
790 Public, Other	0%	0%	0%	0%
<b>Unknown</b>	0%	0%	2.92%	6.64%
999 Cause Unknown	0%	0%	2.92%	6.64%
<b>Weather</b>	12.27%	14.29%	10.81%	12.29%
500 Lightning	12.27%	14.29%	5.33%	8.64%

Substation MARIPA  
 Substation Location Kendrick Ridge  
 Circuit 134 Kendrick Ridge-Single  
 Circuit Location Kendrick Ridge  
 Total Circuit Length (miles) 10.95  
 Average Member Count 114  
 Date of last Trim Spot Trim 2025

	Total Minutes/Frequency	Totals		5 Year Average	
		SAIDI	SAIFI	SAIDI	SAIFI
		<b>518.62</b>	<b>4.36</b>	<b>119.62</b>	<b>1.08</b>
<b>Weather</b>		12.27%	14.29%	10.81%	12.29%
510 Wind, Not Trees		0%	0%	2.17%	1.99%
520 Ice, Sleet, Frost, Not Trees		0%	0%	3.31%	1.66%
530 Flood		0%	0%	0%	0%
590 Weather, Other		0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply outages, Customer Responsible Outages and Momentary Outages

**Substation: MILLER HUNT**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

MILLER HUNT

---

Substation  
 Substation Location Miller Hunt Rd  
 Circuit 224 Miller Hunt Rd  
 Circuit Location Miller Hunt and Hwy 15  
 Total Circuit Length (miles) 37.34  
 Average Member Count 366  
 Date of last Trim Spot Trim 2025

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
<b>Total Minutes/Frequency</b>	<b>168.48</b>	<b>1.71</b>	<b>159.92</b>	<b>1.26</b>
<b>Animals</b>	1.47%	1.92%	3.12%	7.12%
600 Small Animal/Bird	0.73%	1.44%	2.73%	6.49%
601 Squirrel	0.74%	0.48%	0.15%	0.32%
610 Large Animal	0%	0%	0.07%	0.14%
611 Cattle Rubbing	0%	0%	0.04%	0.05%
612 Animal/Large Bird	0%	0%	0.13%	0.14%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
<b>Equipment or Installation/Design</b>	1.83%	1.76%	34.05%	22.99%
300 Material or Equipment Fault/Failure	1.83%	1.76%	3.46%	3.72%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	2.50%	2.95%
340 Overload	0%	0%	0%	0%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	28.09%	16.33%
<b>Maintenance</b>	59.30%	67.20%	21.07%	17.55%
400 Decay/Age of Material/Equipment	6.78%	4.96%	0.28%	0.27%
410 Corrosion/Abrasion of Material/Equipm	0%	0%	0%	0%
420 Tree Growth	0%	0%	4.73%	4.44%
430 Tree failure from overhang or dead tr	52.41%	62.08%	15.97%	12.56%
440 Trees With Ice/Snow	0.11%	0.16%	0.07%	0.14%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages

**Substation: MILLER HUNT**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

MILLER HUNT

Substation  
 Substation Location Miller Hunt Rd  
 Circuit 224 Miller Hunt Rd  
 Circuit Location Miller Hunt & Hwy 15  
 Total Circuit Length (miles) 37.34  
 Average Member Count 366  
 Date of last Trim Spot Trim 2025

	Total	Minutes/Frequency	Totals		5 Year Average	
			SAIDI	SAIFI	SAIDI	SAIFI
	168.48		1.71		159.92	1.26
<b>Maintenance</b>	59.30%		67.20%		21.07%	17.55%
490 Maintenance, Other	0%		0%		0.02%	0.14%
<b>Other</b>	0%		0%		0.02%	0.18%
800 Other	0%		0%		0.02%	0.18%
801 Supervisor Review	0%		0%		0%	0%
<b>Planned Outage</b>	3.63%		6.24%		3.91%	7.35%
100 Construction	3.20%		5.28%		2.52%	3.95%
110 Maintenance	0.42%		0.96%		1.38%	3.40%
190 Other Planned	0%		0%		0%	0%
<b>Power Supply</b>	0%		0%		0%	0%
000 Power Supply	0%		0%		0%	0%
<b>Public</b>	0.43%		0.48%		3.51%	5.03%
700 Customer-Caused	0.43%		0.48%		0.04%	0.05%
710 Motor Vehicle	0%		0%		0.25%	0.41%
720 Aircraft	0%		0%		0%	0%
730 Fire	0%		0%		0%	0%
740 Public Cuts Tree	0%		0%		3.22%	4.58%
750 Vandalism	0%		0%		0%	0%
760 Switching error or caused by construe	0%		0%		0%	0%
790 Public, Other	0%		0%		0%	0%
<b>Unknown</b>	4.44%		3.04%		4.11%	4.40%
999 Cause Unknown	4.44%		3.04%		4.11%	4.40%
<b>Weather</b>	28.89%		19.36%		30.21%	35.37%
500 Lightning	2.76%		4.16%		5.15%	6.21%

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages

**Substation: MILLER HUNT**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

MILLER HUNT

Substation  
 Substation Location Miller Hunt  
 Circuit 224 Miller Hunt Rd  
 Circuit Location Miller Hunt & Hwy 15  
 Total Circuit Length (miles) 37.34  
 Average Member Count 366  
 Date of last Trim Spot Trim 2025

Total	MinutesLFrequency	Totals		5 Year Average	
		SAIDI	SAIFI	SAIDI	SAIFI
<b>Weather</b>		<b>168.48</b>	<b>1.71</b>	<b>159.92</b>	<b>1.26</b>
510 Wind, Not Trees		28.89%	19.36%	30.21%	35.37%
520 Ice, Sleet, Frost, Not Trees		3.67%	1.12%	14.66%	2.49%
530 Flood		18.36%	12.96%	10.39%	26.67%
590 Weather, Other		0%	0%	0%	0%
		4.11%	1.12%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages

**Substation: MILLER HUNT**

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

**MILLER HUNT**

		<b>Totals</b>		<b>5 Year Average</b>	
		<b>SAIDI</b>	<b>SAIFI</b>	<b>SAIDI</b>	<b>SAIFI</b>
		733.87	2.29	136.34	1.05
<b>Total Minutes/Frequency</b>					
<b>Animals</b>		1.26%	1.85%	0.37%	0.84%
600 Small Animal/Bird		1.26%	1.85%	0.15%	0.21%
601 Squirrel		0%	0%	0.23%	0.63%
610 Large Animal		0%	0%	0%	0%
611 Cattle Rubbing		0%	0%	0%	0%
612 Animal/Large Bird		0%	0%	0%	0%
620 Animal damage-gnawing	or boring	0%	0%	0%	0%
690 Animal, Other		0%	0%	0%	0%
<b>Equipment or Installation/Design</b>		0.19%	0.77%	6.20%	5.48%
300 Material or Equipment Fault/Failure		0.19%	0.77%	6.18%	5.34%
310 Installation Fault		0%	0%	0%	0%
320 Conductor Sag or Inadequate	Clearance	0%	0%	0%	0%
340 Overload		0%	0%	0%	0%
350 Miscoordination of Protection Devices		0%	0%	0%	0%
360 Other Equipment Installation/Design		0%	0%	0.02%	0.14%
<b>Maintenance</b>		14.67%	21.26%	26.13%	22.82%
400 Decay/Age of Material/Equipment		2.38%	3.85%	9.05%	5.06%
410 Corrosion/Abrasion of Material/Equipm		0%	0%	0%	0%
420 Tree Growth		0%	0%	5.02%	5.34%
430 Tree failure from overhang or dead tr		12.29%	17.41%	12.06%	12.43%
440 Trees With Ice/Snow		0%	0%	0%	0%
450 Contamination (leakage/external)		0%	0%	0%	0%
460 Moisture		0%	0%	0%	0%
470 Borrower crew cuts tree		0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages  
**Substation: MILLER HUNT**  
 1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
 MILLER HUNT

Substation  
 Substation Location Miller Hunt  
 Circuit 244 Hwy 89  
 Circuit Location Hwy 89  
 Total Circuit Length (miles) 26.25  
 Average Member Count 283  
 Date of last Trim Spot Trim 2025

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
	<u>733.87</u>	<u>2.29</u>	<u>136.34</u>	<u>1.05</u>
	<b>Total Minutes/Frequency</b>			
<b>Maintenance</b>	14.67%	21.26%	26.13%	22.82%
490 Maintenance, Other	0%	0%	0%	0%
<b>Other</b>	0%	0%	0.06%	0.21%
800 Other	0%	0%	0.06%	0.21%
801 Supervisor Review	0%	0%	0%	0%
<b>Planned Outage</b>	0.47%	2.62%	5.01%	18.26%
100 Construction	0.16%	1.08%	4.11%	7.94%
110 Maintenance	0.32%	1.54%	0.90%	10.32%
190 Other Planned	0%	0%	0%	0%
<b>Power Supply</b>	0%	0%	0%	0%
000 Power Supply	0%	0%	0%	0%
<b>Public</b>	0.88%	0.62%	2.05%	2.53%
700 Customer-Caused	0.80%	0.31%	0.02%	0.14%
710 Motor Vehicle	0.07%	0.31%	0.15%	0.14%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	0%	0%	1.88%	2.25%
750 Vandalism	0%	0%	0%	0%
760 Switching error	0%	0%	0%	0%
790 Public, Other	0%	0%	0%	0%
<b>Unknown</b>	0.00%	0.15%	0.97%	1.26%
999 Cause Unknown	0.00%	0.15%	0.97%	1.26%
<b>Weather</b>	82.53%	72.73%	59.20%	48.60%
500 Lightning	18.03%	58.09%	25.76%	23.74%

or caused by construe

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary outages  
**Substation: MILLER HUNT**  
 1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
 MILLER HUNT

Substation  
 Substation Location Miller Hunt Rd.  
 Circuit 244 Hwy 89  
 Circuit Location Hwy 89  
 Total Circuit Length (miles) 26.25  
 Average Member Count 283  
 Date of last Trim Spot Trim 2025

Total	Minutes/Frequency	Totals		5 Year	Average
		SAIDI	SAIFI	SAIDI	SAIFI
		733.87	2.29	136.34	1.05
<b>Weather</b>		82.53%	72.73%	59.20%	48.60%
510 Wind, Not Trees		0.13%	0.31%	11.91%	7.65%
520 Ice, Sleet, Frost,	Not Trees	64.36%	14.33%	21.54%	17.21%
530 Flood		0%	0%	0%	0%
590 Weather, Other		0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages  
**Substation: MT. STERLING**  
 1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
 MT. STERLING

Substation  
 Substation Location Hwy 11  
 circuit 124 Fuller Est-Fogg Pike  
 Circuit Location Fuller Estates & Fogg Pike  
 Total Circuit Length (miles) 17.44  
 Average Member Count 331  
 Date of last Trim Spot Trim 2025

Totals		5 Year Average	
SAIDI	SAIFI	SAIDI	SAIFI
279.94	2.79	186.76	1.84

<u>Total Minutes/Frequency</u>				
<b>Animals</b>	2.26%	3.47%	2.74%	3.06%
600 Small Animal/Bird	1.72%	2.60%	1.64%	1.68%
601 Squirrel	0.54%	0.87%	0.94%	1.28%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0.16%	0.10%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
<b>Equipment or Installation/Design</b>	0%	0%	6.85%	11.13%
300 Material or Equipment Fault/Failure	0%	0%	6.60%	10.99%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	0.26%	0.13%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
<b>Maintenance</b>	42.94%	36.51%	35.11%	30.74%
400 Decay/Age of Material/Equipment	0%	0%	9.99%	11.26%
410 Corrosion/Abrasion of Material/Equipm	0%	0%	2.95%	2.07%
420 Tree Growth	0.31%	0.54%	0.04%	0.10%
430 Tree failure from overhang or dead tr	42.64%	35.97%	22.13%	17.31%
440 Trees With Ice/Snow	0%	0%	0%	0%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%

**PSC Report**  
 Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages  
 Substation: **MT. STERLING**  
 1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
 MT. STERLING

Substation  
 Substation Location Hwy 11 \_\_\_\_\_  
 Circuit 124 Fuller ~~Est-Fogg~~ Pike  
 Circuit Location Fuller Estates & Fogg Pike  
 Total Circuit Length (miles) 17.44  
 Average Member Count 331  
 Date of last Trim Spot Trim 2025

	Total Minutes/Frequency	Totals		5 Year Average	
		SAIDI	SAIFI	SAIDI	SAIFI
	279.94	2.79		186.76	1.84
<b>Maintenance</b>	42.94%	36.51%		35.11%	30.74%
490 Maintenance, Other	0%	0%		0%	0%
<b>Other</b>	0%	0%		0.07%	0.07%
800 Other	0%	0%		0.07%	0.07%
801 Supervisor Review	0%	0%		0%	0%
<b>Planned Outage</b>	27.02%	41.93%		5.23%	16.69%
100 Construction	8.07%	5.74%		1.95%	1.94%
110 Maintenance	18.95%	36.19%		3.27%	14.75%
190 Other Planned	0%	0%		0%	0%
<b>Power Supply</b>	0%	0%		0%	0%
000 Power Supply	0%	0%		0%	0%
<b>Public</b>	0.44%	2.60%		20.02%	12.41%
700 Customer-Caused	0%	0%		0%	0%
710 Motor Vehicle	0.44%	2.60%		18.85%	11.62%
720 Aircraft	0%	0%		0%	0%
730 Fire	0%	0%		0%	0%
740 Public Cuts Tree	0%	0%		1.17%	0.79%
750 Vandalism	0%	0%		0%	0%
760 Switching error	o caused by construe	0%	0%	0%	0%
790 Public, Other		0%	0%	0%	0%
<b>Unknown</b>	0.62%	1.19%		10.08%	12.90%
999 Cause Unknown	0.62%	1.19%		10.08%	12.90%
<b>Weather</b>	26.71%	14.30%		19.90%	13.00%
500 Lightning	26.71%	14.30%		14.25%	11.78%

Substation

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
MT. STERLING

---

Substation Location Hwy 11  
 Circuit 124 Fuller Est-Fogg Pike  
 Circuit Location Fuller Estates & Fogg Pike  
 Total Circuit Length (miles) 17.44  
 Average Member Count 331  
 Date of last Trim Spot Trim 2025

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
<b>Total Minutes/Frequency</b>	<b>279.94</b>	<b>2.79</b>	<b>186.76</b>	<b>1.84</b>
<b>Weather</b>	26.71%"	14.30%"	19.90%"	13.00%
510 Wind, Not Trees	0%	0%	5.65%	1.22%
520 Ice, Sleet, Frost, Not Trees	0%	0%	0%	0%
530 Flood	0%	0%	0%	0%
590 Weather, Other	0%	0%	0%	0%

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
 MT. STERLING

Substation

Substation Location      Hwy 11  
 Circuit                    Substation Outage  
 Circuit Location \_\_\_\_\_  
 Total Circuit Length (miles) \_\_\_\_\_  
 Average Member Count    511  
 Date of last Trim        \_\_\_\_\_

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
	956.76	3.06	50.60	.58

<u>Total Minutes/Frequency</u>				
<b>Animals</b>	0%	0%	0%	0%
600 Small Animal/Bird	0%	0%	0%	0%
601 Squirrel	0%	0%	0%	0%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing            or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
<b>Equipment or Installation/Design</b>	0%	0%	0%	0%
300 Material or Equipment Fault/Failure	0%	0%	0%	0%
310 Installation Fault	0%	0%	0%	0%
320 Conductor      Sag    or    Inadequate            Clearance	0%	0%	0%	0%
340 Overload	0%	0%	0%	0%
350 Miscoordination                    of Protection Devices	0%	0%	0%	0%
360 Other Equipment                    Installation/Design	0%	0%	0%	0%
<b>Maintenance</b>	100%	100%	0%	0%
400 Decay/Age of Material/Equipment	0%	0%	0%	0%
410 Corrosion/Abrasion of Material/Equipm	0%	0%	0%	0%
420 Tree Growth	0%	0%	0%	0%
430 Tree failure from overhang or dead tr	100%	100%	0%	0%
440 Trees With Ice/Snow	0%	0%	0%	0%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
 MT. STERLING

Substation

Substation Location Hwy 11  
 Circuit Substation Outage  
 Circuit Location \_\_\_\_\_  
 Total Circuit Length (miles) \_\_\_\_\_  
 Average Member Count 511  
 Date of last Trim \_\_\_\_\_

			SAIDI	Totals SAIFI	5 Year Average SAIDI	SAIFI
	Total	Minutes/Frequency	956.76	3.06	50.60	0.58
<b>Maintenance</b>			100%	100%	0%	0%
490 Maintenance, Other			0%	0%	0%	0%
<b>Other</b>			0%	0%	0%	0%
800 Other			0%	0%	0%	0%
801 Supervisor Review			0%	0%	0%	0%
<b>Planned Outage</b>			0%	0%	0%	0%
100 Construction			0%	0%	0%	0%
110 Maintenance			0%	0%	0%	0%
190 Other Planned			0%	0%	0%	0%
<b>Power Supply</b>			0%	0%	0%	0%
000 Power Supply			0%	0%	0%	0%
<b>Public</b>			0%	0%	0%	0%
700 Customer-Caused			0%	0%	0%	0%
710 Motor Vehicle			0%	0%	0%	0%
720 Aircraft			0%	0%	0%	0%
730 Fire			0%	0%	0%	0%
740 Public Cuts Tree			0%	0%	0%	0%
750 Vandalism			0%	0%	0%	0%
760 Switching error		or caused by construe	0%	0%	0%	0%
790 Public, Other			0%	0%	0%	0%
<b>Unknown</b>			0%	0%	0%	0%
999 Cause Unknown			0%	0%	0%	0%
<b>Weather</b>			0%	0%	100%	100%
500 Lightning			0%	0%	0%	0%

Substation

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
MT. STERLING

Substation Location Hwy 11  
Circuit Substation Outage  
Circuit Location \_\_\_\_\_  
Total Circuit Length (miles) \_\_\_\_\_  
Average Member Count 511  
Date of last Trim \_\_\_\_\_

Weather	Total Minutes/Frequency	Totals		5 Year Average	
		SAIDI	SAIFI	SAIDI	SAIFI
		956.76	3.06	50.60	0.58
		0%	0%	100%	100%
510 Wind, Not Trees		0%	0%	0%	0%
520 Ice, Sleet, Frost, Not Trees		0%	0%	0%	0%
530 Flood		0%	0%	0%	0%
590 Weather, Other		0%	0%	100%	100%

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
 REID VILLAGE

Substation

Substation Location Hwy 60  
 Circuit 114 Hwy 60 Clark Co  
 Circuit Location Hwy 60  
 Total Circuit Length (miles) 45.47  
 Average Member Count 426  
 Date of last Trim Spot Trim 2025

Totals		5 Year Average	
SAIDI	SAIFI	SAIDI	SAIFI
282.37	2.42	198.60	1.22

**Total Minutes/Frequency**

<b>Animals</b>		0.35%	0.48%	2.85%	4.12%
600 Small Animal/Bird		0.13%	0.19%	1.69%	2.31%
601 Squirrel		0.21%	0.29%	0.96%	1.45%
610 Large Animal		0%	0%	0%	0%
611 Cattle Rubbing		0%	0%	0.06%	0.08%
612 Animal/Large Bird		0%	0%	0.13%	0.27%
620 Animal damage-gnawing	or boring	0%	0%	0%	0%
690 Animal, Other		0%	0%	0%	0%
<b>Equipment or Installation/Design</b>		23.41%	38.63%	3.75%	7.89%
300 Material or Equipment	Fault/Failure	0.12%	0.10%	3.26%	7.10%
310 Installation Fault		0%	0%	0%	0%
320 Conductor Sag	or Inadequate Clearance	0%	0%	0%	0%
340 Overload		23.29%	38.53%	0.49%	0.78%
350 Miscoordination	of Protection Devices	0%	0%	0%	0%
360 Other Equipment	Installation/Design	0%	0%	0%	0%
<b>Maintenance</b>		24.52%	15.49%	63.71%	51.08%
400 Decay/Age of Material/Equipment		0.39%	0.19%	1.32%	0.43%
410 Corrosion/Abrasion of Material/Equipm		0%	0%	0%	0%
420 Tree Growth		0%	0%	6.57%	7.02%
430 Tree failure from overhang or dead tr		24.13%	15.30%	55.73%	43.59%
440 Trees With Ice/Snow		0%	0%	0%	0%
450 Contamination (leakage/external)		0%	0%	0%	0%
460 Moisture		0%	0%	0%	0%
470 Borrower crew cuts tree		0%	0%	0%	0%

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
 REID VILLAGE

Substation

Substation Location Hwy 60  
 Circuit 114 Hwy 60 Clark Co  
 Circuit Location Hwy 60  
 Total Circuit Length (miles) 45.47  
 Average Member Count 426  
 Date of last Trim Spot Trim 2025

	Total	Minutes/Frequency	Totals		5 Year Average	
			SAIDI	SAIFI	SAIDI	SAIFI
			282.37	2.42	138.60	1.22
<b>Maintenance</b>			24.52%	15.49%	63.71%	51.08%
490 Maintenance, Other			0%	0%	0.09%	0.04%
<b>Other</b>			0%	0%	1.73%	7.69%
800 Other			0%	0%	1.73%	7.69%
801 Supervisor Review			0%	0%	0%	0%
<b>Planned Outage</b>			3.07%	2.61%	6.59%	13.89%
100 Construction			2.40%	2.03%	4.70%	5.14%
110 Maintenance			0.67%	0.58%	1.89%	8.75%
190 Other Planned			0%	0%	0%	0%
<b>Power Supply</b>			0%	0%	0%	0%
000 Power Supply			0%	0%	0%	0%
<b>Public</b>			17.79%	30.30%	0.75%	0.71%
700 Customer-Caused			0.04%	0.19%	0.31%	0.16%
710 Motor Vehicle			17.75%	30.11%	0.13%	0.27%
720 Aircraft			0%	0%	0%	0%
730 Fire			0%	0%	0%	0%
740 Public Cuts Tree			0%	0%	0.31%	0.27%
750 Vandalism			0%	0%	0%	0%
760 Switching error		or caused by construe	0%	0%	0%	0%
790 Public, Other			0%	0%	0%	0%
<b>Unknown</b>			0.01%	0.19%	4.93%	5.69%
999 Cause Unknown			0.01%	0.19%	4.93%	5.69%
<b>Weather</b>			30.86%	12.29%	15.70%	8.94%
500 Lightning			0.62%	0.58%	13.19%	8.40%

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary outages  
**Substation: REID VILLAGE**  
 1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
 REID VILLAGE

Substation  
 Substation Location      Hwy 60\_\_  
 Circuit                      114 Hwy 60 Clark Co  
 Circuit Location          Hwy 60 \_\_\_\_\_  
 Total Circuit Length (miles) 45.47  
 Average Member Count    426  
 Date of last Trim         Spot Trim 2025

	Total	Minutes	Frequency	Totals		5 Year	Average
				SAIDI	SAIFI	SAIDI	SAIFI
				282.37	2.42	138.60	1.22
<b>Weather</b>				30.86%	12.29%	15.70%	8.94%
510 Wind, Not Trees				0%	0%	2.45%	0.47%
520 Ice, Sleet, Frost,	Not	Trees		24.65%	5.91%	0.05%	0.08%
530 Flood				0%	0%	0%	0%
590 Weather, Other				5.59%	5.81%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages  
**Substation: REID VILLAGE**  
 1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
**REID VILLAGE**

Substation  
 Substation Location Hwy 60  
 Circuit 124 Prewitt Pike  
 Circuit Location Prewitt Pike  
 Total Circuit Length (miles) 14.09  
 Average Member Count 408  
 Date of last Trim Spot Trim 2025

Totals		5 Year Average	
SAIDI	SAIFI	SAIDI	SAIFI
116.41	.63	56.68	.48

**Total Minutes/Frequency**

<b>Animals</b>	18.70%	25.48%	5.03%	7.41%
600 Small Animal/Bird	0%	0%	1.35%	1.88%
601 Squirrel	18.70%	25.48%	3.68%	5.53%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
<b>Equipment or Installation/Design</b>	0%	0%	8.53%	10.96%
300 Material or Equipment Fault/Failure	0%	0%	7.59%	9.60%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	0.94%	1.36%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
<b>Maintenance</b>	25.81%	30.89%	67.04%	50.94%
400 Decay/Age of Material/Equipment	3.70%	5.02%	0.35%	0.94%
410 Corrosion/Abrasion of Material/Equipm	0%	0%	0%	0%
420 Tree Growth	0%	0%	1.70%	2.19%
430 Tree failure from overhang or dead tr	22.11%	25.87%	62.52%	45.41%
440 Trees With Ice/Snow	0%	0%	2.47%	2.40%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages  
**Substation: REID VILLAGE**  
 1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
 REID VILLAGE

Substation  
 Substation Location Hwy 60  
 Circuit 124 Prewitt Pike  
 Circuit Location Prewitt Pike  
 Total Circuit Length (miles) 14.09  
 Average Member Count 408  
 Date of last Trim Spot Trim 2025

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
<b>Total Minutes/Frequency</b>	<b>116.41</b>	<b>0.63</b>	<b>56.68</b>	<b>0.48</b>
<b>Maintenance</b>	25.81%	30.89%	67.04%	50.94%
490 Maintenance, Other	0%	0%	0%	0%
<b>Other</b>	0%	0%	0.27%	0.31%
800 Other	0%	0%	0.27%	0.31%
801 Supervisor Review	0%	0%	0%	0%
<b>Planned Outage</b>	41.10%	33.59%	14.27%	26.62%
100 Construction	40.39%	27.80%	9.02%	12.94%
110 Maintenance	0.72%	5.79%	5.25%	13.67%
190 Other Planned	0%	0%	0%	0%
<b>Power Supply</b>	0%	0%	0%	0%
000 Power Supply	0%	0%	0%	0%
<b>Public</b>	0%	0%	0.40%	0.52%
700 Customer-Caused	0%	0%	0.19%	0.21%
710 Motor Vehicle	0%	0%	0.21%	0.31%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	0%	0%	0%	0%
750 Vandalism	0%	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0%	0%
790 Public, Other	0%	0%	0%	0%
<b>Unknown</b>	0%	0%	0.05%	0.10%
999 Cause Unknown	0%	0%	0.05%	0.10%
<b>Weather</b>	14.39%	10.04%	4.41%	3.13%
500 Lightning	0%	0%	4.41%	3.13%

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages  
**Substation: REID VILLAGE**  
 1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
 REID VILLAGE

---

Substation  
 Substation Location           Hwy 60  
 Circuit                         124 Prewitt Pike  
 Circuit Location             Prewitt Pike  
 Total Circuit Length (miles) 14.09  
 Average Member Count       408  
 Date of last Trim             Spot Trim 2025

	Total	Minutes/Frequency	Totals		5 Year	Average
			SAIDI	SAIFI	SAIDI	SAIFI
			116.41	.63	56.68	0.48
<b>Weather</b>			14.39%	10.04%	4.41%	3.13%
510 Wind, Not Trees			14.00%	9.65%	0%	0%
520 Ice, Sleet, Frost, Not Trees			0.39%	0.39%	0%	0%
530 Flood			0%	0%	0%	0%
590 Weather, Other			0%	0%	0%	0%

**PSC Report**  
 Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages  
**Substation: SIDEVIEW**  
 1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
 SIDEVIEW

Substation  
 Substation Location Donaldson Rd  
 Circuit 144 Pretty Run-Hwy 627  
 Circuit Location Pretty Run and Hwy 627  
 Total Circuit Length (miles) 84.46  
 Average Member Count 535  
 Date of last Trim Spot Trim 2025

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
<b>Total Minutes/Frequency</b>	<b>229.09</b>	<b>2.04</b>	<b>163.05</b>	<b>1.36</b>
<b>Animals</b>	2.42%	2.39%	2.82%	4.98%
600 Small Animal/Bird	0.65%	0.92%	2.08%	4.07%
601 Squirrel	1.36%	0.92%	0.59%	0.65%
610 Large Animal	0%	0%	0.04%	0.03%
611 Cattle Rubbing	0.13%	0.37%	0.10%	0.17%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0.27%	0.18%	0.02%	0.06%
<b>Equipment or Installation/Design</b>	28.53%	51.52%	6.80%	4.98%
300 Material or Equipment Fault/Failure	28.36%	51.15%	5.98%	4.10%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0.17%	0.37%	0.82%	0.88%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
<b>Maintenance</b>	10.82%	5.14%	41.78%	29.08%
400 Decay/Age of Material/Equipment	0.05%	0.18%	12.19%	17.09%
410 Corrosion/Abrasion of Material/Equipm	0%	0%	0%	0%
420 Tree Growth	0.17%	0.28%	9.72%	3.37%
430 Tree failure from overhang or dead tr	10.60%	4.68%	19.85%	8.60%
440 Trees With Ice/Snow	0%	0%	0%	0%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%

Substation SIDEVIEW  
 Substation Location Donaldson Rd.  
 Circuit 144 Pretty Run-Hwy 627  
 Circuit Location Pretty Run & Hwy 627  
 Total Circuit Length (miles) 84.46  
 Average Member Count 535  
 Date of last Trim Spot Trim 2025

	Total	Minutes/Frequency	Totals		5 Year Average	
			SAIDI	SAIFI	SAIDI	SAIFI
			229.09	2.04	163.05	1.36
<b>Maintenance</b>			10.82%	5.14%	41.78%	29.08%
490 Maintenance, Other			0%	0%	0.01%	0.03%
<b>Other</b>			0%	0%	1.43%	1.41%
800 Other			0%	0%	1.43%	1.41%
801 Supervisor Review			0%	0%	0%	0%
<b>Planned Outage</b>			47.52%	35.90%	28.41%	35.76%
100 Construction			43.21%	30.58%	24.06%	19.43%
110 Maintenance			4.31%	5.33%	4.36%	16.32%
190 Other Planned			0%	0%	0%	0%
<b>Power Supply</b>			0%	0%	0%	0%
000 Power Supply			0%	0%	0%	0%
<b>Public</b>			2.48%	3.12%	0.89%	1.53%
700 Customer-Caused			0.00%	0.09%	0.12%	0.06%
710 Motor Vehicle			0%	0%	0.62%	1.16%
720 Aircraft			0%	0%	0%	0%
730 Fire			0%	0%	0.01%	0.06%
740 Public Cuts Tree			0%	0%	0.08%	0.20%
750 Vandalism			0%	0%	0%	0%
760 Switching error or caused by construe			0%	0%	0%	0%
790 Public, Other			2.48%	3.03%	0.07%	0.06%
<b>Unknown</b>			0.21%	0.28%	10.77%	19.63%
999 Cause Unknown			0.21%	0.28%	10.77%	19.63%
<b>Weather</b>			8.03%	1.65%	7.08%	2.63%
500 Lightning			6.46%	1.19%	2.55%	1.87%

Substation SIDEVIEW  
 Substation Location Donaldson Rd  
 Circuit 144 Pretty Run-Hwy 627  
 Circuit Location Pretty Run & Hwy 627  
 Total Circuit Length (miles) 84.46  
 Average Member Count 535  
 Date of last Trim Spot Trim 2025

Total	Minutes/Frequency	Totals		5 Year Average	
		SAIDI	SAIFI	SAIDI	SAIFI
		229.09	2.04	163.05	1.36
<b>Weather</b>		8.03%	1.65%	7.08%	2.63%
510 Wind, Not Trees		0.62%	0.37%	4.53%	0.76%
520 Ice, Sleet, Frost,	Not Trees	0.95%	0.09%	0%	0%
530 Flood		0%	0%	0%	0%
590 Weather, Other		0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible outages and Momentary Outages  
 Substation: SIDEVIEW  
 1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
 SIDEVIEW

Substation  
 Substation Location Donaldson Rd  
 Circuit 164 Donaldson  
 Circuit Location Donaldson  
 Total Circuit Length (miles) 39.56  
 Average Member Count 453  
 Date of last Trim Spot Trim 2025

Totals	5 Year Average	
SAIDI	SAIFI	SAIDI SAIFI
374.59	2.06	153.58 1.13

**Total Minutes/Frequency**

	SAIDI	SAIFI	SAIDI	SAIFI
<b>Animals</b>	0.32%	0.54%	1.60%	2.94%
600 Small Animal/Bird	0.15%	0.32%	1.19%	2.13%
601 Squirrel	0.17%	0.21%	0.39%	0.78%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0.02%	0.04%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
<b>Equipment or Installation/Design</b>	1.38%	2.36%	7.35%	12.84%
300 Material or Equipment Fault/Failure	0.01%	0.21%	6.48%	11.17%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	1.37%	2.15%	0.87%	1.68%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
<b>Maintenance</b>	13.92%	23.63%	79.20%	67.89%
400 Decay/Age of Material/Equipment	0.15%	0.32%	7.73%	17.26%
410 Corrosion/Abrasion of Material/Equipm	0%	0%	0%	0%
420 Tree Growth	0.25%	0.32%	15.63%	15.79%
430 Tree failure from overhang or dead tr	13.53%	22.99%	55.84%	34.85%
440 Trees With Ice/Snow	0%	0%	0%	0%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages  
**Substation: SIDEVIEW**  
 1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
 SIDEVIEW

Substation  
 Substation Location Donaldson  
 Circuit 164 Donaldson  
 Circuit Location Donaldson  
 Total Circuit Length (miles) 39.56  
 Average Member Count 453  
 Date of last Trim Spot Trim 2025

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes	374.59	2.06	153.58	1.13
<b>Maintenance</b>	13.92%	23.63%	79.20%	67.89%
490 Maintenance, Other	0%	0%	0%	0%
<b>Other</b>	0.14%	0.21%	0.00%	0.04%
800 Other	0.14%	0.21%	0.00%	0.04%
801 Supervisor Review	0%	0%	0%	0%
<b>Planned Outage</b>	82.65%	71.43%	3.77%	6.54%
100 Construction	25.58%	15.90%	3.58%	6.09%
110 Maintenance	57.08%	55.53%	0.18%	0.45%
190 Other Planned	0%	0%	0%	0%
<b>Power Supply</b>	0%	0%	0%	0%
000 Power Supply	0%	0%	0%	0%
<b>Public</b>	0.33%	0.75%	1.16%	1.72%
700 Customer-Caused	0.19%	0.43%	0%	0%
710 Motor Vehicle	0%	0%	0.92%	1.43%
720 Aircraft	0%	0%	0%	0%
730 Fire	0.14%	0.32%	0%	0%
740 Public Cuts Tree	0%	0%	0%	0%
750 Vandalism	0%	0%	0%	0%
760 Switching error o caused by construe	0%	0%	0%	0%
790 Public, Other	0%	0%	0.23%	0.29%
<b>Unknown</b>	0.85%	0.86%	0.78%	0.98%
999 Cause Unknown	0.85%	0.86%	0.78%	0.98%
<b>Weather</b>	0.40%	0.21%	6.15%	7.03%
500 Lightning	0.40%	0.21%	5.57%	6.22%

Substation                   SIDEVIEW  
 Substation Location       Donaldson Rd  
 Circuit                     164 Donaldson  
 Circuit Location         Donaldson  
 Total Circuit Length (miles) 39.56  
  
 Average Member Count     453  
 Date of last Trim         Spot Trim 2025

	Total	Minutes/Frequency	Totals		5 Year Average	
			SAIDI	SAIFI	SAIDI	SAIFI
	374.59		2.06		153.58	1.13
<b>Weather</b>			0.40%	0.21%	6.15%	7.03%
510 Wind, Not Trees			0%	0%	0.57%	0.82%
520 Ice, Sleet, Frost, Not Trees			0%	0%	0%	0%
530 Flood			0%	0%	0%	0%
590 Weather, Other			0%	0%	0%	0%

Substation                   SIDEVIEW  
Substation Location       Donaldson Rd  
Circuit                     214 Plumlick-Bunker Hill  
Circuit Location         Plumlick and Bunker Hill  
Total Circuit Length (miles) 59.91  
Average Member Count     371  
Date of last Trim         Spot Trim 2025

**Totals**  
**SAIDI     SAIFI**  
**400.71    3.50**

**5 Year Average SAIDI   SAIFI**  
**304.89    2.02**

**Total Minutes/Frequency**

	SAIDI	SAIFI	SAIDI	SAIFI
<b>Animals</b>	3.21%	3.32%	2.90%	3.33%
600 Small Animal/Bird	0.92%	1.16%	2.09%	2.03%
601 Squirrel	1.06%	0.46%	0.29%	0.52%
610 Large Animal	0.76%	1.16%	0.15%	0.22%
611 Cattle Rubbing	0.35%	0.39%	0.06%	0.08%
612 Animal/Large Bird	0%	0%	0.31%	0.47%
620 Animal damage-gnawing           or boring	0%	0%	0%	0%
690 Animal, Other	0.13%	0.15%	0%	0%
<b>Equipment or Installation/Design</b>	32.89%	29.14%	16.94%	11.52%
300 Material or Equipment Fault/Failure	32.89%	29.14%	16.77%	11.30%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	0.17%	0.22%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
<b>Maintenance</b>	12.71%	7.79%	54.59%	60.56%
400 Decay/Age of Material/Equipment	0.29%	0.15%	10.72%	10.67%
410 Corrosion/Abrasion of Material/Equipm	0%	0%	0.02%	0.03%
420 Tree Growth	0.26%	0.08%	8.49%	6.18%
430 Tree failure from overhang or dead tr	12.15%	7.56%	20.43%	13.50%
440 Trees With Ice/Snow	0%	0%	0.03%	0.03%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0.99%	10.01%

Substation SIDEVIEW  
 Substation Location Donaldson Rd.  
 Circuit 214 Plumlick-Bunker Hill  
 Circuit Location Plumlick & Bunker Hill  
 Total Circuit Length (miles) 59.91  
 Average Member Count 371  
 Date of last Trim Spot Trim 2025

Totals		5 Year Average	
SAIDI	SAIFI	SAIDI	SAIFI
400.71	3.50	304.89	2.02

Total Minutes/Frequency

<b>Maintenance</b>		12.71%	7.79%	54.59%	60.56%
490 Maintenance, Other		0%	0%	13.91%	20.15%
<b>Other</b>		2.92%	2.39%	0.47%	2.09%
800 Other		2.92%	2.39%	0.47%	2.09%
801 Supervisor Review		0%	0%	0%	0%
<b>Planned Outage</b>		21.06%	16.04%	4.06%	7.50%
100 Construction		20.54%	11.10%	3.53%	5.66%
110 Maintenance		0.52%	4.93%	0.52%	1.84%
190 Other Planned		0%	0%	0%	0%
<b>Power Supply</b>		0%	0%	0%	0%
000 Power Supply		0%	0%	0%	0%
<b>Public</b>		3.96%	4.16%	5.31%	3.68%
700 Customer-Caused		3.96%	4.16%	0%	0%
710 Motor Vehicle		0%	0%	2.46%	1.68%
720 Aircraft		0%	0%	0%	0%
730 Fire		0%	0%	0.03%	0.05%
740 Public Cuts Tree		0%	0%	2.74%	1.84%
750 Vandalism		0%	0%	0%	0%
760 Switching error or	caused by construe	0%	0%	0%	0%
790 Public, Other		0%	0%	0.08%	0.11%
<b>Unknown</b>		13.49%	28.99%	1.77%	2.06%
999 Cause Unknown		13.49%	28.99%	1.77%	2.06%
<b>Weather</b>		9.76%	8.17%	13.97%	9.26%
500 Lightning		9.72%	7.56%	7.11%	5.50%

Substation SIDEVIEW  
 Substation Location Donaldson Rd.  
 Circuit 214 Plumlick-Bunker Hill  
 Circuit Location Plumlick & Bunker Hill  
 Total Circuit Length (miles) 59.91  
 Average Member Count 371  
 Date of last Trim Spot Trim 2025

Total Minutes/Frequency	Totals		5 Year	Average
	SAIDI	SAIFI	SAIDI	SAIFI
	400.71	3.50	304.89	2.02

<b>Weather</b>	9.76%	8.17%	13.97%	9.26%
510 Wind, Not Trees	0%	0%	0.75%	0.38%
520 Ice, Sleet, Frost, Not Trees	0.04%	0.62%	0.10%	0.08%
530 Flood	0%	0%	0%	0%
590 Weather, Other	0%	0%	6.01%	3.30%

Average Member Count 373  
 Date of last Trim \_\_\_\_\_

Totals	5 Year Average	
	SAIDI	SAIFI
376.46	1.81	233.07 1.70

**Total Minutes/Frequency**

<b>Animals</b>	0.42%	0.44%	0.56%	0.76%
600 Small Animal/Bird	0.42%	0.44%	0.50%	0.67%
601 Squirrel	0%	0%	0.02%	0.06%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0.04%	0.03%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
<b>Equipment or Installation/Design</b>	0%	0%	23.17%	9.94%
300 Material or Equipment Fault/Failure	0%	0%	23.17%	9.94%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	0%	0%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
<b>Maintenance</b>	90.70%	82.96%	35.48%	25.57%
400 Decay/Age of Material/Equipment	0.20%	0.59%	0.56%	0.51%
410 Corrosion/Abrasion of Material/Equipm	0%	0%	0%	0%
420 Tree Growth	33.05%	29.19%	9.80%	7.40%
430 Tree failure from overhang or dead tr	57.45%	53.19%	25.13%	17.66%

440 Trees With Ice/Snow	0%	0%	0%	0%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%

Substation SIDEVIEW  
 Substation Location Donaldson Rd  
 Circuit 224 Judy  
 Circuit Location Judy Pike and Hwy 11  
 Total Circuit Length (miles) 43.93  
 Average Member Count 373  
 Date of last Trim Spot Trim 2025

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
<b>Total Minutes/Frequency</b>	<b>376.46</b>	<b>1.81</b>	<b>233.07</b>	<b>1.70</b>
<b>Maintenance</b>	<b>90.70%</b>	<b>82.96%</b>	<b>35.48%</b>	<b>25.57%</b>
490 Maintenance, Other	0%	0%	0%	0%
<b>Other</b>	<b>0.04%</b>	<b>0.15%</b>	<b>0.05%</b>	<b>0.22%</b>
800 Other	0.04%	0.15%	0.05%	0.22%
801 Supervisor Review	0%	0%	0%	0%
<b>Planned Outage</b>	<b>4.65%</b>	<b>9.33%</b>	<b>7.80%</b>	<b>24.17%</b>
100 Construction	4.64%	8.89%	6.06%	7.56%
110 Maintenance	0.01%	0.44%	1.74%	16.58%
190 Other Planned	0%	0%	0.00%	0.03%
<b>Power Supply</b>	<b>0%</b>	<b>0%</b>	<b>0%</b>	<b>0%</b>
000 Power Supply	0%	0%	0%	0%
<b>Public</b>	<b>2.97%</b>	<b>4.44%</b>	<b>1.55%</b>	<b>5.56%</b>
700 Customer-Caused	0%	0%	0.00%	0.03%
710 Motor Vehicle	2.59%	4%	1.54%	5.53%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	0.38%	0.44%	0%	0%
750 Vandalism	0%	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0%	0%
790 Public, Other	0%	0%	0%	0%
<b>Unknown</b>	<b>0%</b>	<b>0%</b>	<b>1.79%</b>	<b>11.94%</b>
999 Cause Unknown	0%	0%	1.79%	11.94%
<b>Weather</b>	<b>1.22%</b>	<b>2.67%</b>	<b>29.59%</b>	<b>21.82%</b>
500 Lightning	0.69%	0.74%	7.40%	15.79%

Substation **SIDEVIEW**  
 Substation Location Donaldson Rd.  
 Circuit 224 Judy  
 Circuit Location Judy Pike & Hwy 11  
 Total Circuit Length (miles) 43.93

Average Member Count 373  
 Date of last Trim Spot Trim 2025

<b>Totals</b>			
<b>SAIDI</b>	<b>SAIFI</b>		
<b>Total Minutes/Frequency</b>	<b>376.46</b>	<b>1.81</b>	
1.22%	2.67%		

<b>5 Year Average SAIDI</b>	<b>SAIFI 233.07</b>
<u>1.70</u>	
29.59%	21.82%

**Weather**

510 Wind, Not Trees		0.53%	1.93%	22.20%	6.04%
520 Ice, Sleet, Frost,	Not Trees	0%	0%	0%	0%
530 Flood		0%	0%	0%	0%
590 Weather, Other		0%	0%	0%	0%

**PSC Report**

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages

Substation: STANTON

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM

STANTON

Substation  
 Substation Location Hall Ln  
 Circuit 114 Maple St  
 Circuit Location Maple St  
 Total Circuit Length (miles) 8.20  
 Average Member Count 428  
 Date of last Trim Spot Trim 2025

	Totals		5 Year Average		
	SAIDI	SAIFI	SAIDI	SAIFI	
<b>Total Minutes/Frequency</b>	<b>42.51</b>	<b>.42</b>	<b>27.12</b>	<b>.31</b>	
<b>Animals</b>		2.38%	6.63%	2.94%	6.42%
600 Small Animal/Bird		0.18%	0.55%	2.10%	4.59%
601 Squirrel		2.20%	6.08%	0.84%	1.83%
610 Large Animal		0%	0%	0%	0%
611 Cattle Rubbing		0%	0%	0%	0%
612 Animal/Large Bird		0%	0%	0%	0%
620 Animal damage-gnawing	or boring	0%	0%	0%	0%
690 Animal, Other		0%	0%	0%	0%
<b>Equipment or Installation/Design</b>	0%	0%	4.62%	11.01%	
300 Material or Equipment Fault/Failure		0%	0%	4.62%	11.01%
310 Installation Fault		0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance		0%	0%	0%	0%
340 Overload		0%	0%	0%	0%
350 Miscoordination of Protection Devices		0%	0%	0%	0%
360 Other Equipment Installation/Design		0%	0%	0%	0%
<b>Maintenance</b>	60.93%	39.23%	18.60%	28.90%	
400 Decay/Age of Material/Equipment		0.69%	1.10%	0.92%	2.45%
410 Corrosion/Abrasion of Material/Equipm		0%	0%	0%	0%
420 Tree Growth		0%	0%	0.68%	0.76%
430 Tree failure from overhang or dead tr		60.02%	37.02%	16.95%	25.38%
440 Trees With Ice/Snow		0.22%	1.10%	0%	0%
450 Contamination (leakage/external)		0%	0%	0%	0%
460 Moisture		0%	0%	0%	0%
470 Borrower crew cuts tree		0%	0%	0%	0%



Substation STANTON  
 Substation Location Hall Ln  
 Circuit 114 Maple St  
 Circuit Location Rosslyn  
 Total Circuit Length (miles) 27.74  
 Average Member Count 428  
 Date of last Trim Spot Trim 2025

		Totals		5 Year Average	
		SAIDI	SAIFI	SAIDI	SAIFI
<b>Total</b>	<b>Minutes/Frequency</b>	<b>42.51</b>	<b>0.42</b>	<b>27.12</b>	<b>.31</b>
<b>Weather</b>		13.25%	13.81%	1.68%	1.83%
510	Wind, Not Trees	0.33%	1.66%	0.23%	0.31%
520	Ice, Sleet, Frost, Not Trees	0%	0%	0.62%	0.15%
530	Flood	0%	0%	0%	0%
590	Weather, Other	12.43%	10.50%	0.10%	0.31%
Average Member Count	685				
Date of last Trim					

		Totals		5 Year Average	
		SAIDI	SAIFI	SAIDI	SAIFI
<b>Total</b>	<b>Minutes/Frequency</b>	<b>443.16</b>	<b>2.22</b>	<b>59.00</b>	<b>.63</b>
<b>Animals</b>		0.47%	2.30%	3.70%	6.86%
600	Small Animal/Bird	0.08%	0.72%	0.78%	1.54%
601	Squirrel	0.39%	1.58%	2.92%	5.32%
610	Large Animal	0%	0%	0%	0%
611	Cattle Rubbing	0%	0%	0%	0%
612	Animal/Large Bird	0%	0%	0%	0%
620	Animal damage-gnawing or boring	0%	0%	0%	0%
690	Animal, Other	0%	0%	0%	0%
<b>Equipment or Installation/Design</b>		0.62%	2.24%	2.88%	3.64%
300	Material or Equipment Fault/Failure	0.62%	2.24%	2.34%	2.71%
310	Installation Fault	0%	0%	0.13%	0.23%
320	Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340	Overload	0%	0%	0.29%	0.47%
350	Miscoordination of Protection Devices	0%	0%	0%	0%
360	Other Equipment Installation/Design	0%	0%	0.12%	0.23%
<b>Maintenance</b>		<b>78.78%</b>	<b>80.53%</b>	<b>72.97%</b>	<b>64.13%</b>
400	Decay/Age of Material/Equipment	0.06%	0.07%	2.85%	1.63%
410	Corrosion/Abrasion of Material/Equipm	0%	0%	0%	0%
420	Tree Growth	0.11%	0.46%	34.28%	35.73%
430	Tree failure from overhang or dead tr	78.61%	80%	34.52%	25.61%

440 Trees With Ice/Snow	0%	0%	1.31%	1.17%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%

---

Average Member Count

685

Date of last Trim

---

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
	443.16	2.22	59.00	.63
<b>Total Minutes/Frequency</b>				
<b>Maintenance</b>	78.78%	80.53%	72.97%	64.13%
490 Maintenance, Other	0%	0%	0%	0%
<b>Other</b>	0.05%	0.33%	0%	0%
800 Other	0.05%	0.33%	0%	0%
801 Supervisor Review	0%	0%	0%	0%
<b>Planned Outage</b>	19.64%	13.09%	10.92%	18.89%
100 Construction	19.62%	12.76%	8.45%	8.30%
110 Maintenance	0.02%	0.33%	2.47%	10.59%
190 Other Planned	0%	0%	0%	0%
<b>Power Supply</b>	0%	0%	0%	0%
000 Power Supply	0%	0%	0%	0%
<b>Public</b>	0%	0%	1.96%	1.73%
700 Customer-Caused	0%	0%	0.08%	0.19%
710 Motor Vehicle	0%	0%	1.19%	0.75%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	0%	0%	0.39%	0.65%
750 Vandalism	0%	0%	0%	0%
760 Switching error      or caused      by      construe	0%	0%	0%	0%
790 Public, Other	0%	0%	0.30%	0.14%
<b>Unknown</b>	0.38%	1.25%	1.12%	1.96%
999 Cause Unknown	0.38%	1.25%	1.12%	1.96%
<b>Weather</b>	0.05%	0.26%	6.46%	2.80%
500 Lightning	0.03%	0.13%	0.53%	0.61%

Average Member Count 685

Date of last Trim \_\_\_\_\_

Total Minutes/Frequency	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
<b>Weather</b>	<b>443.16</b>	<b>2.22</b>	<b>59.00</b>	<b>0.63</b>
510 Wind, Not Trees	0.05%	0.26%	6.46%	2.80%
520 Ice, Sleet, Frost, Not Trees	0%	0%	1.08%	0.79%
530 Flood	0%	0%	0%	0%
590 Weather, Other	0.02%	0.13%	4.85%	1.40%

Average Member Count 508

Date of last Trim \_\_\_\_\_

Totals		5 Year Average	
SAIDI	SAIFI	SAIDI	SAIFI
107.29	1.93	20.01	.27

Total Minutes/Frequency				
<b>Animals</b>	44.97%	52.66%	12.54%	25.76%
600 Small Animal/Bird	0%	0%	8.76%	18.99%
601 Squirrel	44.97%	52.66%	3.78%	6.76%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
<b>Equipment or Installation/Design</b>	10.77%	5.62%	13.86%	13.09%
300 Material or Equipment Fault/Failure	10.77%	5.62%	9.84%	8.78%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	3.12%	3.45%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0.90%	0.86%
<b>Maintenance</b>	16.38%	7.87%	33.36%	19.14%
400 Decay/Age of Material/Equipment	0%	0%	2.25%	1.44%
410 Corrosion/Abrasion of Material/Equipm	0%	0%	0%	0%
420 Tree Growth	0.42%	0.31%	2.42%	2.45%
430 Tree failure from overhang or dead tr	15.96%	7.57%	23.12%	12.81%
440 Trees With Ice/Snow	0%	0%	5.57%	2.45%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%

Substation STANTON  
 Substation Location Hall Ln  
 Circuit 144 Downtown  
 Circuit Location \_\_\_\_\_  
 Total Circuit Length (miles) 7.21  
 Average Member Count 508  
 Date of last Trim Spot Trim 2025

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
Total Minutes/Frequency	107.29	1.93	20.01	0.27
<b>Maintenance</b>	16.38%	7.87%	33.36%	19.14%
490 Maintenance, Other	0%	0%	0%	0%
<b>Other</b>	0%	0%	0%	0%
800 Other	0%	0%	0%	0%
801 Supervisor Review	0%	0%	0%	0%
<b>Planned Outage</b>	13.29%	14.21%	21.35%	25.47%
100 Construction	7.74%	3.27%	14.77%	8.49%
110 Maintenance	5.54%	10.94%	6.58%	16.98%
190 Other Planned	0%	0%	0%	0%
<b>Power Supply</b>	0%	0%	0%	0%
000 Power Supply	0%	0%	0%	0%
<b>Public</b>	0.01%	0.10%	1.71%	2.45%
700 Customer-Caused	0.01%	0.10%	0%	0%
710 Motor Vehicle	0%	0%	0.17%	0.29%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	0%	0%	1.54%	2.16%
750 Vandalism	0%	0%	0%	0%
760 Switching error	0%	0%	0%	0%
790 Public, Other	0%	0%	0%	0%
<b>Unknown</b>	0.04%	0.31%	2.63%	3.02%
999 Cause Unknown	0.04%	0.31%	2.63%	3.02%
<b>Weather</b>	14.54%	19.22%	14.54%	11.08%
500 Lightning	14.54%	19.22%	8.60%	5.32%

Substation STANTON  
 Substation Location Hall Ln.  
 Circuit 144 Downtown  
 Circuit Location \_\_\_\_\_  
 Total Circuit Length (miles) 7.21  
 Average Member Count 508  
 Date of last Trim Spot Trim 2025

	Total	Minutes/Frequency	Totals		5 Year		Average	
			SAIDI	SAIFI	SAIDI	SAIFI		
			107.29	1.93	20.01		0.27	
<b>Weather</b>			14.54%	19.22%	14.54%		11.08%	
510 Wind, Not Trees			0%	0%	5.80%		5.32%	
520 Ice, Sleet, Frost, Not Trees			0%	0%	0%		0%	
530 Flood			0%	0%	0%		0%	
590 Weather, Other			0%	0%	0.14%		0.43%	

Average Member Count 570

Date of last Trim \_\_\_\_\_

Totals		5 Year Average	
SAIDI	SAIFI	SAIDI	SAIFI
381.86	5.56	166.28	1.91

Total Minutes/Frequency

<b>Animals</b>	0.22%	0.47%	5.91%	12.66%
600 Small Animal/Bird	0%	0%	0.10%	0.15%
601 Squirrel	0.22%	0.47%	5.81%	12.50%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
<b>Equipment or Installation/Design</b>	11.61%	4.16%	1.97%	3.19%
300 Material or Equipment Fault/Failure	11.61%	4.16%	1.23%	1.48%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	0.74%	1.71%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
<b>Maintenance</b>	13.02%	9.27%	44.40%	40.44%
400 Decay/Age of Material/Equipment	0.20%	0.13%	0.15%	0.15%
410 Corrosion/Abrasion of Material/Equipm	0%	0%	0%	0%
420 Tree Growth	1.76%	0.91%	0.46%	0.42%
430 Tree failure from overhang or dead tr	11.06%	8.23%	40.58%	35.42%
440 Trees With Ice/Snow	0%	0%	2.92%	3.44%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0.30%	1.01%

Average Member Count

570

Date of last Trim

	Total	Minutes/Frequency	Totals		5 Year Average	
			SAIDI	SAIFI	SAIDI	SAIFI
			381.86	5.56	166.28	1.91
<b>Maintenance</b>			13.02%	9.27%	44.40%	40.44%
490 Maintenance,	Other		0%	0%	0%	0%
<b>Other</b>			0.23%	0.09%	0.03%	0.06%
800 Other			0.23%	0.09%	0.03%	0.06%
801 Supervisor Review			0%	0%	0%	0%
<b>Planned Outage</b>			6.20%	20.82%	22.71%	17.71%
100 Construction			5.05%	19.94%	19.39%	9.35%
110 Maintenance			1.15%	0.88%	2.78%	6.63%
190 Other Planned			0%	0%	0.54%	1.73%
<b>Power Supply</b>			0%	0%	0%	0%
000 Power Supply			0%	0%	0%	0%
<b>Public</b>			19.43%	18.55%	4.64%	9.20%
700 Customer-Caused			0.01%	0.03%	0%	0%
710 Motor Vehicle			19.42%	18.52%	4.44%	9.08%
720 Aircraft			0%	0%	0%	0%
730 Fire			0%	0%	0.13%	0.06%
740 Public Cuts Tree			0%	0%	0.06%	0.06%
750 Vandalism			0%	0%	0%	0%
760 Switching error or	caused by construe		0%	0%	0%	0%
790 Public, Other			0%	0%	0%	0%
<b>Unknown</b>			45.76%	44.89%	7.77%	11.97%
999 Cause Unknown			45.76%	44.89%	7.77%	11.97%
<b>Weather</b>			3.52%	1.74%	12.57%	4.77%
500 Lightning			1.18%	1.36%	1.70%	1.54%

Substation: STANTON  
 1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
 STANTON

Substation  
 Substation Location Hall Ln  
 Circuit 154 Hatton Crk-Furnance  
 Circuit Location Hatton Creek and Furnace Rd  
 Total Circuit Length (miles) 42.16  
 Average Member Count 570  
 Date of last Trim Spot Trim 2025 & Herbicide 2025

	Total	Minutes/Frequency	Totals		5 Year Average	
			SAIDI	SAIFI	SAIDI	SAIFI
	381.86		5.56		166.28	1.91
<b>Weather</b>			3.52%	1.74%	12.57%	4.77%
510 Wind, Not Trees			2.34%	0.38%	0.14%	0.06%
520 Ice, Sleet, Frost, Not Trees			0%	0%	9.42%	2.03%
530 Flood			0%	0%	0.18%	0.99%
590 Weather, Other			0%	0%	1.14%	0.15%

Printed 4/6/2026 2:36:16 PM

Substation: THREE FORKS  
 1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
 THREE FORKS

Substation  
 Substation Location Three Forks Rd  
 Circuit 214 Madison Village  
 Circuit Location Madison Village  
 Total Circuit Length (miles) 12.39  
 Average Member Count 463  
 Date of last Trim Spot Trim 2025 & Herbicide 2024

Totals		5 Year Average	
SAIDI	SAIFI	SAIDI	SAIFI
229.37	1.42	158.08	1.47

Total Minutes/Frequency

	SAIDI	SAIFI	SAIDI	SAIFI
<b>Animals</b>	3.55%	4.86%	10.59%	14.88%
600 Small Animal/Bird	2.51%	4.25%	10.04%	13.86%
601 Squirrel	1.04%	0.61%	0.55%	1.02%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
<b>Equipment or Installation/Design</b>	0.31%	0.30%	12.35%	14.82%
300 Material or Equipment Fault/Failure	0.31%	0.30%	12.16%	14.62%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	0.19%	0.20%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
<b>Maintenance</b>	14.88%	11.53%	64.14%	61.03%
400 Decay/Age of Material/Equipment	0.61%	0.46%	19.97%	14.35%
410 Corrosion/Abrasion of Material/Equipm	0%	0%	0%	0%
420 Tree Growth	1.23%	2.58%	4.48%	3.62%
430 Tree failure from overhang or dead tr	13.04%	8.50%	39.60%	42.85%
440 Trees With Ice/Snow	0%	0%	0%	0%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%

Substation THREE FORKS  
 Substation Location Three Forks Rd.  
 Circuit 214 Madison Village  
 Circuit Location Madison Village  
 Total Circuit Length (miles) 12.39  
 Average Member Count 463  
 Date of last Trim Spot Trim 2025 & Herbicide 2024

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
<b>Total Minutes/Frequency</b>	<b>229.37</b>	<b>1.42</b>	<b>158.08</b>	<b>1.47</b>
<b>Maintenance</b>	14.88%	11.53%	64.14%	61.03%
490 Maintenance, Other	0%	0%	0.08%	0.20%
<b>Other</b>	0.68%	0.76%	0.09%	0.18%
800 Other	0.68%	0.76%	0.09%	0.18%
801 Supervisor Review	0%	0%	0%	0%
<b>Planned Outage</b>	0.78%	2.58%	2.83%	3.92%
100 Construction	0.28%	0.76%	1.43%	1.70%
110 Maintenance	0.50%	1.82%	1.39%	2.22%
190 Other Planned	0%	0%	0%	0%
<b>Power Supply</b>	0%	0%	0%	0%
000 Power Supply	0%	0%	0%	0%
<b>Public</b>	0.06%	0.46%	0.59%	0.23%
700 Customer-Caused	0.06%	0.46%	0.08%	0.09%
710 Motor Vehicle	0%	0%	0.51%	0.15%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	0%	0%	0%	0%
750 Vandalism	0%	0%	0%	0%
760 Switching error	0%	0%	0%	0%
790 Public, Other	0%	0%	0%	0%
<b>Unknown</b>	76.12%	77.39%	1.51%	1.87%
999 Cause Unknown	76.12%	77.39%	1.51%	1.87%
<b>Weather</b>	3.62%	2.12%	7.91%	3.07%
500 Lightning	3.22%	1.52%	3.76%	2.75%

Substation **THREE FORKS**  
 Substation Location **Three Forks Rd.**  
 Circuit **214 Madison Village**  
 Circuit Location **Madison Village**  
 Total Circuit Length (miles) **12.39**  
 Average Member Count **463**  
 Date of last Trim **Spot Trim 2025 & Herbicide 2024**

	Total	Totals		5 Year	Average	
		Minutes/Frequency	SAIDI	SAIFI	SAIDI	SAIFI
			<b>229.37</b>	<b>1.42</b>	<b>158.08</b>	<b>1.47</b>
<b>Weather</b>			<b>3.62%</b>	<b>2.12%</b>	<b>7.91%</b>	<b>3.07%</b>
510 Wind, Not Trees			<b>0%</b>	<b>0%</b>	<b>0.17%</b>	<b>0.06%</b>
520 Ice, Sleet, Frost, Not Trees			<b>0.41%</b>	<b>0.61%</b>	<b>0%</b>	<b>0%</b>
530 Flood			<b>0%</b>	<b>0%</b>	<b>0%</b>	<b>0%</b>
590 Weather, Other			<b>0%</b>	<b>0%</b>	<b>3.97%</b>	<b>0.26%</b>

Substation THREE FORKS  
 Substation Location Three Forks Rd  
 Circuit 224 Ford  
 Circuit Location Ford  
 Total Circuit Length (miles) 45.46  
 Average Member Count 330  
 Date of last Trim Spot Trim 2025

Totals		5 Year Average	
SAIDI	SAIFI	SAIDI	SAIFI
685.92	4.50	231.43	1.50

**Total Minutes/Frequency**

	SAIDI	SAIFI	SAIDI	SAIFI
<b>Animals</b>	0.65%	0.40%	3.18%	4.99%
600 Small Animal/Bird	0.65%	0.40%	1.17%	1.65%
601 Squirrel	0%	0%	1.36%	2.37%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0.58%	0.85%
612 Animal/Large Bird	0%	0%	0.07%	0.12%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
<del>Equipment or Installation/Design</del>	<del>0.12%</del>	<del>0.13%</del>	10.04%	13.96%
300 Material or Equipment Fault/Failure	0.12%	0.13%	9.86%	13.76%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	0.18%	0.20%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
<b>Maintenance</b>	45.85%	28.22%	29.36%	31.23%
400 Decay/Age of Material/Equipment	0.76%	0.67%	16.61%	18.67%
410 Corrosion/Abrasion of Material/Equipm	0%	0%	0%	0%
420 Tree Growth	0.84%	1.55%	1.94%	2.25%
430 Tree failure from overhang or dead tr	44.25%	25.99%	10.68%	10.22%
440 Trees With Ice/Snow	0%	0%	0%	0%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%

Substation THREE FORKS  
 Substation Location Three Forks Rd.  
 Circuit 224 Ford  
 Circuit Location Ford  
 Total Circuit Length (miles) 45.46  
 Average Member Count 330  
 Date of last Trim Spot Trim 2025

<b>Totals</b>	<b>5 Year Average</b>	
<b>SAIDI</b>	<b>SAIFI</b>	<b>SAIDI SAIFI</b>
685.92	4.50	231.43 1.50

	<u>Total Minutes/Frequency</u>			
<b>Maintenance</b>	45.85%	28.22%	29.36%	31.23%
490 Maintenance, Other	0%	0%	0.13%	0.08%
<b>Other</b>	5.30%	16.16%	0.20%	0.16%
800 Other	5.30%	16.16%	0.20%	0.16%
801 Supervisor Review	0%	0%	0%	0%
<b>Planned Outage</b>	2.65%	4.44%	6.99%	12.07%
100 Construction	2.16%	3.16%	5.94%	8.73%
110 Maintenance	0.49%	1.28%	1.05%	3.34%
190 Other Planned	0%	0%	0%	0%
<b>Power Supply</b>	0%	0%	0%	0%
000 Power Supply	0%	0%	0%	0%
<b>Public</b>	0.32%	0.61%	28.39%	19.07%
700 Customer-Caused	0.27%	0.40%	3.52%	4.55%
710 Motor Vehicle	0.05%	0.20%	24.84%	14.45%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	0%	0%	0.00%	0.04%
750 Vandalism	0%	0%	0.02%	0.04%
760 Switching error	0%	0%	0%	0%
790 Public, Other	0%	0%	0%	0%
<b>Unknown</b>	24.90%	22.96%	9.31%	9.34%
999 Cause Unknown	24.90%	22.96%	9.31%	9.34%
<b>Weather</b>	20.20%	27.07%	12.53%	9.18%
500 Lightning	20.13%	27.00%	3.62%	2.37%

Substation THREE FORKS  
 Substation Location Three Forks Rd.  
 Circuit 224 Ford  
 Circuit Location Ford  
 Total Circuit Length (miles) 45.46  
 Average Member Count 330  
 Date of last Trim Spot Trim 2025

	Total	Totals		5 Year	Average
		SAIDI	SAIFI	SAIDI	SAIFI
	Minutes/Frequency	685.92	4.50	231.43	1.50
<b>Weather</b>		20.20%	27.07%	12.53%	9.18%
510 Wind, Not Trees		0.06%	0.07%	3.99%	1.21%
520 Ice, Sleet, Frost,	Not Trees	0%	0%	4.92%	5.59%
530 Flood		0%	0%	0%	0%
590 Weather, Other		0%	0%	0%	0%

**PSC Report**  
 Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages  
 Substation: THREE FORKS  
 1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
 THREE FORKS

Substation  
 Substation Location Three Forks Rd  
 Circuit 234 Three Forks-Pineur Rd  
 Circuit Location Pineur Rd  
 Total Circuit Length (miles) 14.51  
 Average Member Count 155  
 Date of last Trim Spot Trim 2025

<b>Totals</b>		<b>5 Year Average</b>	
<b>SAIDI</b>	<b>SAIFI</b>	<b>SAIDI</b>	<b>SAIFI</b>
845.33	5.52	287.87	1.42

	<u>Total Minutes/Frequency</u>			
<b>Animals</b>				
	1.09%	1.75%	3.97%	8.08%
600 Small Animal/Bird	1.09%	1.75%	0.54%	1.02%
601 Squirrel	0%	0%	3.44%	7.06%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
<b>Equipment or Installation/Design</b>	1.47%	2.69%	7.46%	8.64%
300 Material or Equipment Fault/Failure	1.30%	1.64%	7.06%	7.99%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0.17%	1.05%	0.39%	0.65%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
<b>Maintenance</b>	31.15%	26.29%	70.35%	49.77%
400 Decay/Age of Material/Equipment	2.10%	1.52%	0.53%	1.11%
410 Corrosion/Abrasion of Material/Equipm	0%	0%	9.38%	10.96%
420 Tree Growth	3.38%	5.02%	1.91%	4.18%
430 Tree failure from overhang or dead tr	25.67%	19.74%	58.52%	33.52%
440 Trees With Ice/Snow	0%	0%	0%	0%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
 THREE FORKS

Substation

Substation Location Three Forks Rd.

Circuit 234 Three Forks-Pineur Rd

Circuit Location Three Forks & Pineur Rd.

Total Circuit Length (miles) 14.51

Average Member Count 155

Date of last Trim Spot Trim 2025

	Total	Minutes/Frequency	Totals		5 Year Average	
			SAIDI 845.33	SAIFI 5.52	SAIDI 287.87	SAIFI 1.42
<b>Maintenance</b>			31.15%	26.29%	70.35%	49.77%
490 Maintenance, Other			0%	0%	0%	0%
<b>Other</b>			0%	0%	0%	0%
800 Other			0%	0%	0%	0%
801 Supervisor Review			0%	0%	0%	0%
<b>Planned Outage</b>			1.18%	1.64%	8.47%	26.37%
100 Construction			1.02%	1.17%	8.28%	25.53%
110 Maintenance			0.15%	0.47%	0.19%	0.84%
190 Other Planned			0%	0%	0%	0%
<b>Power Supply</b>			0%	0%	0%	0%
000 Power Supply			0%	0%	0%	0%
<b>Public</b>			0%	0%	0.08%	0.19%
700 Customer-Caused			0%	0%	0.05%	0.09%
710 Motor Vehicle			0%	0%	0.03%	0.09%
720 Aircraft			0%	0%	0%	0%
730 Fire			0%	0%	0%	0%
740 Public Cuts Tree			0%	0%	0%	0%
750 Vandalism			0%	0%	0%	0%
760 Switching error		or caused by construe	0%	0%	0%	0%
790 Public, Other			0%	0%	0%	0%
<b>Unknown</b>			20.22%	18.46%	1.77%	3.44%
999 Cause Unknown			20.22%	18.46%	1.77%	3.44%
<b>Weather</b>			44.89%	49.18%	7.91%	3.53%
500 Lightning			44.89%	49.18%	1.68%	2.69%

Substation

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
THREE\_FORKS

---

Substation Location Three Forks Rd.  
Circuit 234 Three Forks-Pineur Rd  
Circuit Location Three Forks Rd & Pineur Rd.  
Total Circuit Length (miles) 14.51  
Average Member Count 155  
Date of last Trim Spot Trim 2025

	Total Minutes/Frequency	Totals		5 Year Average	
		SAIDI	SAIFI	SAIDI	SAIFI
<b>Weather</b>		<b>845.33</b>	<b>5.52</b>	<b>287.87</b>	<b>1.42</b>
510 Wind, Not Trees		44.89%	49.18%	7.91%	3.53%
520 Ice, Sleet, Frost, Not Trees		0%	0%	6.23%	0.84%
530 Flood		0%	0%	0%	0%
590 Weather, Other		0%	0%	0%	0%

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
 TRAPP

Substation

Substation Location Trapp Goff Corner Rd  
 Circuit 114 Trapp Goffs Corner Rd  
 Circuit Location Trapp Goffs Corner  
 Total Circuit Length (miles) 23.85  
 Average Member Count 228  
 Date of last Trim Spot Trim 2025 & Herbicide 2024

	Totals		5 Year Average	
	SAIDI	SAIFI	SAIDI	SAIFI
<b>Total Minutes/Frequency</b>	<b>925.13</b>	<b>5.46</b>	<b>267.33</b>	<b>1.89</b>
<b>Animals</b>	<b>3.86%</b>	<b>8.03%</b>	<b>1.27%</b>	<b>2.88%</b>
600 Small Animal/Bird	0.02%	0.08%	0.40%	0.82%
601 Squirrel	3.84%	7.95%	0.87%	2.06%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0%	0%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
<b>Equipment or Installation/Design</b>	<b>2.93%</b>	<b>4.58%</b>	<b>3.27%</b>	<b>3.94%</b>
300 Material or Equipment Fault/Failure	2.93%	4.58%	3.25%	3.89%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	0.02%	0.05%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
<b>Maintenance</b>	<b>36.89%</b>	<b>35.26%</b>	<b>76.03%</b>	<b>66.83%</b>
400 Decay/Age of Material/Equipment	0%	0%	2.43%	3.84%
410 Corrosion/Abrasion of Material/Equipm	0.01%	0.08%	0%	0%
420 Tree Growth	1.39%	2.01%	2.26%	4.46%
430 Tree failure from overhang or dead tr	22.75%	23.13%	71.31%	58.47%
440 Trees With Ice/Snow	12.74%	10.04%	0%	0%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
 TRAPP

Substation

Substation Location Trapp Goffs Corner Rd.  
 Circuit 114 Trapp Goffs Corner Rd  
 Circuit Location Trapp Goff Corner  
 Total Circuit Length (miles) 23.85  
 Average Member Count **228**  
 Date of last Trim Spot Trim 2025 & Herbicide 2024

Totals		5 Year Average	
SAIDI	SAIFI	SAIDI	SAIFI
925.13	5.46	267.33	1.89

Total Minutes/Frequency

	Totals SAIDI	Totals SAIFI	5 Year Average SAIDI	5 Year Average SAIFI
<b>Maintenance</b>	36.89%	35.26%	76.03%	66.83%
490 Maintenance, Other	0%	0%	0.03%	0.05%
<b>Other</b>	31.52%	18.71%	0%	0%
800 Other	31.52%	18.71%	0%	0%
801 Supervisor Review	0%	0%	0%	0%
<b>Planned Outage</b>	15.72%	22.81%	1.62%	3.70%
100 Construction	3.68%	6.99%	1.34%	1.97%
110 Maintenance	12.04%	15.82%	0.28%	1.73%
190 Other Planned	0%	0%	0%	0%
<b>Power Supply</b>	0%	0%	0%	0%
000 Power Supply	0%	0%	0%	0%
<b>Public</b>	0%	0%	0.73%	1.44%
700 Customer-Caused	0%	0%	0%	0%
710 Motor Vehicle	0%	0%	0.15%	0.19%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	0%	0%	0.30%	0.58%
750 Vandalism	0%	0%	0%	0%
760 Switching error	0%	0%	0%	0%
790 Public, Other	0%	0%	0.28%	0.67%
<b>Unknown</b>	9.09%	10.60%	6.62%	7.49%
999 Cause Unknown	9.09%	10.60%	6.62%	7.49%
<b>weather</b>	0%	0%	10.46%	13.73%
500 Lightning	0%	0%	5.11%	4.99%

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
 TRAPP

Substation

Substation Location Trapp Goffs Corner Rd.  
 Circuit 114 Trapp Goffs Corner Rd  
 Circuit Location Trapp Goffs Corner  
 Total Circuit Length (miles) 23.85  
 Average Member Count 228  
 Date of last Trim Spot Trim 2025 & Herbicide 2024

Totals  
 SAIDI 925.13  
 SAIFI 5.46

5 Year Average SAIDI 267.33  
 SAIFI 1.89

Total Minutes/Frequency

Weather		0%	0%	10.46%	13.73%
510 Wind, Not Trees		0%	0%	5.35%	8.74%
520 Ice, Sleet, Frost,	Not Trees	0%	0%	0%	0%
530 Flood		0%	0%	0%	0%
590 Weather, Other		0%	0%	0%	0%

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
 TRAPP

Substation

Substation Location Trapp Goff Corner  
 Circuit 134 Log Lick Rd  
 Circuit Location Log Lick Rd  
 Total Circuit Length (miles) 37.21  
 Average Member Count 358  
 Date of last Trim Spot Trim 2025 & Herbicide 2024

<b>Totals</b>	<b>5 Year Average</b>	
SAIDI	SAIFI	SAIDI SAIFI
222.66	.84	95.37 .66

Total Minutes/Frequency

	Totals	SAIFI	5 Year Average SAIDI	5 Year Average SAIFI
<b>Animals</b>	0.58%	2.01%	3.63%	8.46%
600 Small Animal/Bird	0.25%	0.67%	0.42%	0.96%
601 Squirrel	0.33%	1.34%	3.18%	7.33%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	0.03%	0.17%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
<b>Equipment or Installation/Design</b>	8.55%	12.71%	3.05%	2.97%
300 Material or Equipment Fault/Failure	0%	0%	2.98%	2.88%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	8.55%	12.71%	0.07%	0.09%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
<b>Maintenance</b>	77.39%	60.20%	42.95%	27.05%
400 Decay/Age of Material/Equipment	0.10%	0.33%	1.09%	0.96%
410 Corrosion/Abrasion of Material/Equipm	0%	0%	0%	0%
420 Tree Growth	1.78%	4.68%	0.65%	0.70%
430 Tree failure from overhang or dead tr	75.50%	55.18%	40.97%	24.96%
440 Trees With Ice/Snow	0%	0%	0.25%	0.44%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%

**PSC Report**  
 Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages  
 Substation: TRAPP  
 1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
 TRAPP

Substation  
 Substation Location Trapp Goffs Corner Rd.  
 Circuit 134 Log Lick Rd  
 Circuit Location Log Lick Rd.  
 Total Circuit Length (miles) 37.21  
 Average Member Count 358  
 Date of last Trim Spot Trim 2025 & Herbicide 2024

Totals	5 Year Average	
	SAIDI	SAIFI
222.66	.84	95.37
		.66

	Total Minutes/Frequency			
<b>Maintenance</b>	77.39%	60.20%	42.95%	27.05%
490 Maintenance, Other	0%	0%	0%	0%
<b>Other</b>	0%	0%	0.27%	0.17%
800 Other	0%	0%	0.27%	0.17%
801 Supervisor Review	0%	0%	0%	0%
<b>Planned Outage</b>	6.94%	14.05%	9.42%	21.03%
100 Construction	2.28%	8.03%	8.60%	14.22%
110 Maintenance	4.67%	6.02%	0.71%	6.72%
190 Other Planned	0%	0%	0.11%	0.09%
<b>Power Supply</b>	0%	0%	0%	0%
000 Power Supply	0%	0%	0%	0%
<b>Public</b>	1.94%	3.01%	10.14%	5.24%
700 Customer-Caused	0%	0%	1.66%	1.75%
710 Motor Vehicle	0%	0%	8.20%	3.14%
720 Aircraft	0%	0%	0%	0%
730 Fire	1.94%	3.01%	0%	0%
740 Public Cuts Tree	0%	0%	0.18%	0.17%
750 Vandalism	0%	0%	0%	0%
760 Switching error or caused by construe	0%	0%	0%	0%
790 Public, Other	0%	0%	0.10%	0.17%
<b>Unknown</b>	2.80%	4.01%	11.23%	15.71%
999 Cause Unknown	2.80%	4.01%	11.23%	15.71%
<b>Weather</b>	1.81%	4.01%	19.30%	19.37%
500 Lightning	1.13%	3.34%	18.08%	12.83%

**PSC Report**  
 Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages  
**Substation: TRAPP**  
 1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
TRAPP

---

**Substation**  
 Substation Location Trapp Goffs Corner Rd.  
 Circuit 134 Log Lick Rd  
 Circuit Location Log Lick Rd.  
 Total Circuit Length (miles) 37.21  
 Average Member Count 358  
 Date of last Trim Spot Trim 2025 & Herbicide 2024

	Total Minutes	Totals		5 Year Average	
		SAIDI	SAIFI	SAIDI	SAIFI
	222.66	.84		95.37	0.66
<b>Weather</b>		1.81%	4.01%	19.30%	19.37%
510 Wind, Not Trees		0%	0%	1.04%	6.20%
520 Ice, Sleet, Frost, Not Trees		0.68%	0.67%	0%	0%
530 Flood		0%	0%	0%	0%
590 Weather, Other		0%	0%	0.18%	0.35%

Substation UNION CITY  
 Substation Location Union City \_\_\_\_\_  
 Circuit 214 Hampton Rdg-Four Mile  
 Circuit Location Hampton Ridge  
 Total Circuit Length (miles) 13.36  
 Average Member Count 614  
 Date of last Trim Spot Trim 2025

			Totals		5 Year Average	
	Total Minutes/Frequency		SAIDI	SAIFI	SAIDI	SAIFI
	301.47	2.43	29.65	.42		
<b>Animals</b>			0%	0%	0%	0%
600 Small Animal/Bird			0%	0%	0%	0%
601 Squirrel			0%	0%	0%	0%
610 Large Animal			0%	0%	0%	0%
611 Cattle Rubbing			0%	0%	0%	0%
612 Animal/Large Bird			0%	0%	0%	0%
620 Animal damage-gnawing or boring			0%	0%	0%	0%
690 Animal, Other			0%	0%	0%	0%
<b>Equipment or Installation/Design</b>	36.12% 12.78%	17.42% 11.26%				
300 Material or Equipment Fault/Failure			4.79%	2.01%	1.85%	0.84%
310 Installation Fault			0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance			0%	0%	0%	0%
340 Overload			0.76%	0.54%	15.57%	10.42%
350 Miscoordination of Protection Devices			0%	0%	0%	0%
360 Other Equipment Installation/Design			30.58%	10.24%	0%	0%
<b>Maintenance</b>	44.28% 29.99%	62.57% 63.28%				
400 Decay/Age of Material/Equipment			43.74%	29.45%	23.95%	46.55%
410 Corrosion/Abrasion of Material/Equipm			0%	0%	0%	0%
420 Tree Growth			0.42%	0.47%	1.64%	0.59%
430 Tree failure from overhang or dead tr			0.13%	0.07%	36.97%	16.13%
440 Trees With Ice/Snow			0%	0%	0%	0%
450 Contamination (leakage/external)			0%	0%	0%	0%
460 Moisture			0%	0%	0%	0%
470 Borrower crew cuts tree			0%	0%	0%	0%



Substation **UNION CITY**  
 Substation Location Union City Rd.  
 circuit 214 Hampton Rdg-Four Mile  
 Circuit Location Hampton Ridge & Four Mile  
 Total Circuit Length (miles) 13.36  
 Average Member Count 614  
 Date of last Trim Spot Trim 2025

	Total	Totals		5 Year	Average
		SAIDI	SAIFI	SAIDI	SAIFI
	<b>Minutes/Freguency</b>	<b>301.47</b>	<b>2.43</b>	<b>29.65</b>	<b>0.42</b>
<b>Weather</b>		0.11%	0.20%	3.11%	1.43%
510 Wind, Not Trees		0%	0%	0.74%	0.34%
520 Ice, Sleet, Frost, Not Trees		0%	0%	2.13%	0.84%
530 Flood		0%	0%	0%	0%
590 Weather, Other		0%	0%	0%	0%

Substation UNION CITY  
 Substation Location Union City Rd  
 Circuit 224 Hackett Pk-Hampton Rdg  
 Circuit Location Hackett Pike and Hampton Ridge  
 Total Circuit Length (miles) 44.71  
 Average Member Count 547  
 Date of last Trim Spot Trim 2025

Totals	5 Year Average	
SAIDI	SAIFI	SAIDI SAIFI
424.13	1.65	130.78 1.20

**Total Minutes/Frequency**

<b>Animals</b>	1.24%	5.08%	1.45%	2.47%
600 Small Animal/Bird	0.09%	0.55%	0.14%	0.12%
601 Squirrel	1.15%	4.53%	0.77%	1.73%
610 Large Animal	0%	0%	0.24%	0.25%
611 Cattle Rubbing	0%	0%	0.30%	0.37%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
<b>Equipment or Installation/Design</b>	91.71%	67.85%	30.36%	20.30%
300 Material or Equipment Fault/Failure	5.43%	6.52%	30.34%	20.27%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	1.17%	1.88%	0.02%	0.03%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	85.11%	59.45%	0%	0%
<b>Maintenance</b>	0.13%	0.22%	47.24%	57.77%
400 Decay/Age of Material/Equipment	0%	0%	0.60%	0.12%
410 Corrosion/Abrasion of Material/Equipm	0%	0%	0%	0%
420 Tree Growth	0%	0%	1.76%	2.31%
430 Tree failure from overhang or dead tr	0.13%	0.22%	44.87%	55.31%
440 Trees With Ice/Snow	0%	0%	0%	0%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary outages  
 Substation: UNION CITY  
 1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
 UNION CITY

Substation  
 Substation Location Union City Rd.  
 Circuit 224 Hackett Pk-Hampron Rdg  
 Circuit Location Hackett Pike & Hampton Ridge  
 Total Circuit Length (miles) 44.71  
 Average Member Count 547  
 Date of last Trim Spot Trim 2025

	Totals SAIDI	SAIFI	5 Year Average SAIDI	SAIFI
<b>Total Minutes/Frequency</b>	<b>424.13</b>	<b>1.65</b>	<b>130.78</b>	<b>1.20</b>
<b>Maintenance</b>	0.13%	0.22%	47.24%	57.77%
490 Maintenance, Other	0%	0%	0.00%	0.03%
<b>Other</b>	0.01%	0.22%	0%	0%
800 Other	0.01%	0.22%	0%	0%
801 Supervisor Review	0%	0%	0%	0%
<b>Planned Outage</b>	3.58%	6.96%	3.85%	8.05%
100 Construction	3.36%	6.30%	2.83%	3.05%
110 Maintenance	0.22%	0.66%	1.01%	4.94%
190 Other Planned	0%	0%	0.02%	0.06%
<b>Power Supply</b>	0%	0%	0%	0%
000 Power Supply	0%	0%	0%	0%
<b>Public</b>	1.20%	2.43%	0.23%	0.49%
700 Customer-Caused	0%	0%	0.01%	0.09%
710 Motor Vehicle	0.49%	0.44%	0%	0%
720 Aircraft	0%	0%	0%	0%
730 Fire	0%	0%	0%	0%
740 Public Cuts Tree	0%	0%	0.22%	0.40%
750 Vandalism	0%	0%	0%	0%
760 Switching error      or caused      by      construe	0.71%	1.99%	0%	0%
790 Public, Other	0%	0%	0%	0%
<b>Unknown</b>	0.49%	1.55%	15.10%	8.82%
999 Cause Unknown	0.49%	1.55%	15.10%	8.82%
<b>Weather</b>	1.64%	15.69%	1.76%	2.10%
500 Lightning	1.64%	15.69%	1.67%	2.00%

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages  
**Substation: UNION CITY**  
 1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
 UNION CITY

Substation  
 Substation Location Union City Rd.  
 Circuit 224 Hackett Pk-Hampton Rd  
 Circuit Location Hackett Pike & Hampton Ridge  
 Total Circuit Length (miles) 44.71  
 Average Member Count 547  
 Date of last Trim Spot Trim 2025

	Total Minutes	Totals		5 Year Average	
		SAIDI	SAIFI	SAIDI	SAIFI
<b>Weather</b>	<b>424.13</b>	<b>1.64%</b>	<b>15.69%</b>	<b>1.76%</b>	<b>2.10%</b>
510 Wind, Not Trees		0%	0%	0.09%	0.09%
520 Ice, Sleet, Frost, Not Trees		0%	0%	0%	0%
530 Flood		0%	0%	0%	0%
590 Weather, Other		0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages  
**Substation: UNION CITY**  
 1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
 UNION CITY

Substation  
 Substation Location Union City Rd  
 Circuit 234 Doylesville  
 Circuit Location Doylesville  
 Total Circuit Length (miles) 50.38  
 Average Member Count 443  
 Date of last Trim Spot Trim 2025

<b>Totals</b>		<b>5 Year Average</b>		
SAIDI	SAIFI	SAIDI	SAIFI	319.52 2.30 251.21 1.43

<u>Total Minutes/Frequency</u>				
<b>Animals</b>	1.66%	1.86%	1.93%	5.63%
600 Small Animal/Bird	0.94%	1.08%	0.23%	0.23%
601 Squirrel	0.37%	0.69%	1.12%	4.79%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0.35%	0.10%	0.18%	0.23%
612 Animal/Large Bird	0%	0%	0.08%	0.10%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0.32%	0.29%
<b>Equipment or Installation/Design</b>	8.20%	3.82%	18.80%	19.00%
300 Material or Equipment Fault/Failure	8.20%	3.82%	18.62%	18.90%
310 Installation Fault	0%	0%	0.18%	0.10%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	0%	0%	0%	0%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
<b>Maintenance</b>	77.00%	80.51%	48.63%	31.21%
400 Decay/Age of Material/Equipment	3.77%	2.84%	0.68%	0.61%
410 Corrosion/Abrasion of Material/Equipm	0%	0%	5.60%	3.92%
420 Tree Growth	0.31%	0.20%	0.85%	0.87%
430 Tree failure from overhang or dead tr	72.91%	77.47%	41.50%	25.81%
440 Trees With Ice/Snow	0%	0%	0%	0%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%

Excluding Major Event Day Outages, Power Supply Outages, Customer Responsible Outages and Momentary Outages  
**Substation: UNION CITY**  
 1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
 UNION CITY

Substation  
 Substation Location Union City Rd.  
 Circuit 234 Doylestown  
 Circuit Location Doylestown  
 Total Circuit Length (miles) 50.38  
 Average Member Count 443  
 Date of last Trim Spot Trim 2025

	Total	Minutes/Frequency	Totals		5 Year Average	
			SAIDI	SAIFI	SAIDI	SAIFI
			319.52	2.30	251.21	1.43
<b>Maintenance</b>			77.00%	80.51%	48.63%	31.21%
490 Maintenance, Other			0%	0%	0%	0%
<b>Other</b>			0%	0%	0.05%	0.06%
800 Other			0%	0%	0.05%	0.06%
801 Supervisor Review			0%	0%	0%	0%
<b>Planned Outage</b>			6.01%	7.05%	5.39%	11.41%
100 Construction			5.79%	6.37%	3.82%	6.27%
110 Maintenance			0.22%	0.69%	1.57%	5.14%
190 Other Planned			0%	0%	0%	0%
<b>Power Supply</b>			0%	0%	0%	0%
000 Power Supply			0%	0%	0%	0%
<b>Public</b>			0.09%	0.10%	0.20%	0.29%
700 Customer-Caused			0%	0%	0.04%	0.06%
710 Motor Vehicle			0.09%	0.10%	0.16%	0.23%
720 Aircraft			0%	0%	0%	0%
730 Fire			0%	0%	0%	0%
740 Public Cuts Tree			0%	0%	0%	0%
750 Vandalism			0%	0%	0%	0%
760 Switching error or caused by construe			0%	0%	0%	0%
790 Public, Other			0%	0%	0%	0%
<b>Unknown</b>			0.39%	0.59%	19.88%	24.78%
999 Cause Unknown			0.39%	0.59%	19.88%	24.78%
<b>Weather</b>			6.65%	6.07%	5.13%	7.62%
500 Lightning			5.58%	4.90%	2.16%	2.48%

Substation: UNION CITY  
 1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
 UNION CITY

---

Substation  
 Substation Location Union City Rd.  
 Circuit 234 Doyleville  
 Circuit Location Doyleville Rd.  
 Total Circuit Length (miles) 50.38

Average Member Count 443  
 Date of last Trim Spot Trim 2025

Totals		5 Year Average		
SAIDI	SAIFI	SAIDI	SAIFI	
		Tota	1 Minutes/Frequency	319.52 2.30 251.21 1.43

Weather	SAIDI	SAIFI	SAIDI	SAIFI
510 Wind, Not Trees	6.65%	6.07%	5.13%	7.62%
520 Ice, Sleet, Frost, Not Trees	0%	0%	2.14%	1.54%
530 Flood	0.26%	0.10%	0.83%	3.54%
590 Weather, Other	0%	0%	0%	0%
	0.81%	1.08%	0.00%	0.06%

Printed 4/6/2026 2,41:50 PM

Substation

Substation Location Van Meter Rd  
 Circuit 134 Van Meter Rd-Single  
 Circuit Location Van Meter Rd.  
 Total Circuit Length (miles) 9.62  
 Average Member Count 52  
 Date of last Trim Spot Trim 2025

Totals		5 Year Average	
SAIDI	SAIFI	SAIDI	SAIFI
222.44	1.25	38.17	.54

	Total Minutes/Frequency			
<b>Animals</b>	6.22%	9.23%	11.46%	8.45%
600 Small Animal/Bird	6.22%	9.23%	9.74%	7.04%
601 Squirrel	0%	0%	0%	0%
610 Large Animal	0%	0%	0%	0%
611 Cattle Rubbing	0%	0%	1.72%	1.41%
612 Animal/Large Bird	0%	0%	0%	0%
620 Animal damage-gnawing or boring	0%	0%	0%	0%
690 Animal, Other	0%	0%	0%	0%
<b>Equipment or Installation/Design</b>	2.14%	6.15%	3.48%	2.82%
300 Material or Equipment Fault/Failure	0.78%	3.08%	1.08%	0.70%
310 Installation Fault	0%	0%	0%	0%
320 Conductor Sag or Inadequate Clearance	0%	0%	0%	0%
340 Overload	1.37%	3.08%	2.40%	2.11%
350 Miscoordination of Protection Devices	0%	0%	0%	0%
360 Other Equipment Installation/Design	0%	0%	0%	0%
<b>Maintenance</b>	59.95%	32.31%	21.90%	23.24%
400 Decay/Age of Material/Equipment	0%	0%	0%	0%
410 Corrosion/Abrasion of Material/Equipm	0%	0%	0%	0%
420 Tree Growth	2.06%	3.08%	4.67%	9.86%
430 Tree failure from overhang or dead tr	10.31%	4.62%	17.23%	13.38%
440 Trees With Ice/Snow	47.58%	24.62%	0%	0%
450 Contamination (leakage/external)	0%	0%	0%	0%
460 Moisture	0%	0%	0%	0%
470 Borrower crew cuts tree	0%	0%	0%	0%

1/1/2025 12:00:00 AM to 12/31/2025 11:59:59 PM  
 VAN METER

Substation

Substation Location Van Meter Rd.  
 Circuit 134 Van Meter Rd-Single  
 Circuit Location Van Meter Rd.  
 Total Circuit Length (miles) 9.62  
 Average Member Count 52  
 Date of last Trim Spot Trim 2025

	Total	Minutes/Frequency	Totals		5 Year Average	
			SAIDI	SAIFI	SAIDI	SAIFI
			222.44	1.25	38.17	0.54
<b>Maintenance</b>			59.95%	32.31%	21.90%	23.24%
490 Maintenance, Other			0%	0%	0%	0%
<b>Other</b>			0%	0%	0%	0%
800 Other			0%	0%	0%	0%
801 Supervisor Review			0%	0%	0%	0%
<b>Planned Outage</b>			25.61%	47.69%	10.86%	28.17%
100 Construction			25.43%	44.62%	7.29%	19.72%
110 Maintenance			0.17%	3.08%	3.58%	8.45%
190 Other Planned			0%	0%	0%	0%
<b>Power Supply</b>			0%	0%	0%	0%
000 Power Supply			0%	0%	0%	0%
<b>Public</b>			0%	0%	0%	0%
700 Customer-Caused			0%	0%	0%	0%
710 Motor Vehicle			0%	0%	0%	0%
720 Aircraft			0%	0%	0%	0%
730 Fire			0%	0%	0%	0%
740 Public Cuts Tree			0%	0%	0%	0%
750 Vandalism			0%	0%	0%	0%
760 Switching error		or caused by construe	0%	0%	0%	0%
790 Public, Other			0%	0%	0%	0%
<b>Unknown</b>			0%	0%	16.98%	14.79%
999 Cause Unknown			0%	0%	16.98%	14.79%
<b>Weather</b>			6.08%	4.62%	35.32%	22.54%
500 Lightning			6.08%	4.62%	35.32%	22.54%

Substation

1/1/2025 12:00:00 A[V] to 12/31/2025 11:59:59 PM  
VAN METER

---

Substation Location Van Meter Rd.  
Circuit 134 Van Meter Rd-Single  
Circuit Location Van Meter Rd.  
Total Circuit Length (miles) 9.62  
Average Member Count 52  
Date of last Trim Spot Trim 2025

Totals		5 Year Average	
SAIDI	SAIFI	SAIDI	SAIFI
<u>222.44</u>	<u>1.25</u>	<u>38.17</u>	<u>.54</u>

---

Total Minutes/Frequency					
Weather		6.08%	4.62%	35.32%	22.54%
510 Wind, Not Trees		0%	0%	0%	0%
520 Ice, Sleet, Frost,	Not Trees	0%	0%	0%	0%
530 Flood		0%	0%	0%	0%
590 Weather, Other		0%	0%	0%	0%