

KENTUCKY PUBLIC SERVICE COMMISSION

Electric Distribution Utility Annual Reliability Report

SECTION 1: CONTACT INFORMATION

| | |
|----------------------------|--|
| UTILITY NAME | Farners Rural Electric Cooperative |
| REPORT PREPARED BY | Chuck Bishop |
| E-MAIL ADDRESS OF PREPARER | cbishop@farmersrecc.net |
| PHONE NUMBER OF PREPARER | 270-651-2191 Ext 8150 |

SECTION 2: REPORT YEAR

| | |
|-------------------------|------|
| CALENDAR YEAR OF REPORT | 2024 |
|-------------------------|------|

SECTION 3: MAJOR EVENT DAYS

| | |
|--|------------|
| T_{MED} | 10.27 |
| FIRST DATE USED TO DETERMINE T_{MED} | 1/1/2019 |
| LAST DATE USED TO DETERMINE T_{MED} | 12/31/2023 |
| NUMBER OF MED IN REPORT YEAR | 8 |

NOTE: Per IEEE 1366 T_{MED} should be calculated using the daily SAIDI values for the five prior years. If five years of data are not available, then utilities should use what is available until five years are accumulated.

SECTION 4: SYSTEM RELIABILITY INFORMATION AND RESULTS

System-wide Information

| | | | |
|-----------------|-------|----------------|----|
| TOTAL CUSTOMERS | 26452 | TOTAL CIRCUITS | 67 |
|-----------------|-------|----------------|----|

Excluding MED

| | 5 YEAR AVERAGE | | REPORTING YEAR |
|-------|----------------|-------|----------------|
| SAIDI | 359.91 | SAIDI | 146.26 |
| SAIFI | 1.21 | SAIFI | 1.35 |

Including MED

| | 5 YEAR AVERAGE | | REPORTING YEAR |
|-------|----------------|-------|----------------|
| SAIDI | 854.81 | SAIDI | 396.41 |
| SAIFI | 2.07 | SAIFI | 1.99 |

Notes:

- 1) All duration indices (SAIDI, CAIDI) are to be reported in units of minutes.
- 2) Reports are due on the first business day of May of each year
- 3) Reports cover the calendar year ending in the December before the reports are due.
- 4) IEEE 1366 (latest version) is used to define SAIDI, SAIFI, CAIDI, and T_{MED}

KENTUCKY PUBLIC SERVICE COMMISSION

Electric Distribution Utility Annual Reliability Report

SECTION 5: CIRCUIT REPORTING

(CIRCUIT WITH SAIDI AND/OR SAIFI EXCEEDING 5 YEAR AVERAGE
(CIRCUIT NUMBERS SHOULD BE REPORTED EXCLUDING MED)

Circuit # 0101

1. SUBSTATION NAME AND NUMBER

Goodnight (1)

2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN)

Barren County - Hwy 31E (N Jackson Hwy) - Goodnight

3. CIRCUIT NAME AND NUMBER

Hiseville (1)

4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA)

Hiseville (1)

5. TOTAL CIRCUIT MILES (MILES)

76.59

6. CUSTOMER COUNT FOR THIS CIRCUIT

482

7. DATE OF LAST CIRCUIT TRIM (VM)

2022

**8. LIST OUTAGE FOR CIRCUIT ALONG WITH PERCENTAGE OF TOTAL OUTAGE
NUMBERS REPRESENTED BY EACH CAUSE**

| | |
|---------------------|--------|
| Tree Related On R/W | 92.57% |
| Weather | 6.64% |
| Planned | 0.68% |
| Unknown | 0.11% |

9. CIRCUIT 5 YEAR AVERAGE (SAIDI)

119.04

10. REPORTING YEAR (SAIDI)

175.98

11. CIRCUIT 5 YEAR AVERAGE (SAIFI)

1.644

12. REPORTING YEAR (SAIFI)

1.33

13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN

None taken or to be taken. The largest SAIDI and SAIFI contributor was On R/W trees during storm events.

KENTUCKY PUBLIC SERVICE COMMISSION

Electric Distribution Utility Annual Reliability Report

SECTION 5: CIRCUIT REPORTING

(CIRCUIT WITH SAIDI AND/OR SAIFI EXCEEDING 5 YEAR AVERAGE
(CIRCUIT NUMBERS SHOULD BE REPORTED EXCLUDING MED)

Circuit # 0105

1. SUBSTATION NAME AND NUMBER

Goodnight (1)

2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN)

Barren County - Hwy 31E (N Jackson Hwy) - Goodnight

3. CIRCUIT NAME AND NUMBER

Cave City (5)

4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA)

Cave City (5)

5. TOTAL CIRCUIT MILES (MILES)

11.09

6. CUSTOMER COUNT FOR THIS CIRCUIT

88

7. DATE OF LAST CIRCUIT TRIM (VM)

2022

**8. LIST OUTAGE FOR CIRCUIT ALONG WITH PERCENTAGE OF TOTAL OUTAGE
NUMBERS REPRESENTED BY EACH CAUSE**

| | |
|----------------------|--------|
| Tree Related Off R/W | 57.83% |
| Tree Related On R/W | 18.62% |
| Public | 15.51% |
| Animal | 8.04% |

9. CIRCUIT 5 YEAR AVERAGE (SAIDI)

10.07

10. REPORTING YEAR (SAIDI)

41.26

11. CIRCUIT 5 YEAR AVERAGE (SAIFI)

0.126

12. REPORTING YEAR (SAIFI)

0.45

13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN

None taken or to be taken. The largest SAIDI contributor was a single Off R/W tree related outage and a single On R/W tree related outage. Both were during storm events.

KENTUCKY PUBLIC SERVICE COMMISSION

Electric Distribution Utility Annual Reliability Report

SECTION 5: CIRCUIT REPORTING

(CIRCUIT WITH SAIDI AND/OR SAIFI EXCEEDING 5 YEAR AVERAGE
(CIRCUIT NUMBERS SHOULD BE REPORTED EXCLUDING MED)

Circuit # 0202

1. SUBSTATION NAME AND NUMBER

Munfordville (2)

2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN)

Hart County - Hwy 31W (Main St) - Munfordville

3. CIRCUIT NAME AND NUMBER

Northtown (2)

4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA)

Northtown (2)

5. TOTAL CIRCUIT MILES (MILES)

79.34

6. CUSTOMER COUNT FOR THIS CIRCUIT

466

7. DATE OF LAST CIRCUIT TRIM (VM)

2024

**8. LIST OUTAGE FOR CIRCUIT ALONG WITH PERCENTAGE OF TOTAL OUTAGE
NUMBERS REPRESENTED BY EACH CAUSE**

| | |
|---------------------|--------|
| Unknown | 25.17% |
| Tree Related On R/W | 21.40% |
| Public | 21.27% |
| Weather | 13.94% |
| Planned | 10.64% |
| Animal | 7.58% |

9. CIRCUIT 5 YEAR AVERAGE (SAIDI)

104.48

10. REPORTING YEAR (SAIDI)

264.69

11. CIRCUIT 5 YEAR AVERAGE (SAIFI)

0.94

12. REPORTING YEAR (SAIFI)

2.1

13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN

None taken or to be taken. This circuit had very few outages with very little outage time.

KENTUCKY PUBLIC SERVICE COMMISSION

Electric Distribution Utility Annual Reliability Report

SECTION 5: CIRCUIT REPORTING

(CIRCUIT WITH SAIDI AND/OR SAIFI EXCEEDING 5 YEAR AVERAGE
(CIRCUIT NUMBERS SHOULD BE REPORTED EXCLUDING MED)

Circuit # 0205

1. SUBSTATION NAME AND NUMBER

Munfordville (2)

2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN)

Hart County - Hwy 31W (Main St) - Munfordville

3. CIRCUIT NAME AND NUMBER

Jonesville (5)

4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA)

Jonesville (5)

5. TOTAL CIRCUIT MILES (MILES)

10.48

6. CUSTOMER COUNT FOR THIS CIRCUIT

53

7. DATE OF LAST CIRCUIT TRIM (VM)

2024

**8. LIST OUTAGE FOR CIRCUIT ALONG WITH PERCENTAGE OF TOTAL OUTAGE
NUMBERS REPRESENTED BY EACH CAUSE**

| | |
|---------------------|--------|
| Unknown | 25.17% |
| Tree Related On R/W | 21.40% |
| Public | 21.27% |
| Weather | 13.94% |
| Planned | 10.64% |
| Animal | 7.58% |

9. CIRCUIT 5 YEAR AVERAGE (SAIDI)

66.242

10. REPORTING YEAR (SAIDI)

186.25

11. CIRCUIT 5 YEAR AVERAGE (SAIFI)

0.844

12. REPORTING YEAR (SAIFI)

2.68

13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN

None taken or to be taken. This circuit had very few outages with very little outage time.

KENTUCKY PUBLIC SERVICE COMMISSION

Electric Distribution Utility Annual Reliability Report

SECTION 5: CIRCUIT REPORTING

(CIRCUIT WITH SAIDI AND/OR SAIFI EXCEEDING 5 YEAR AVERAGE
(CIRCUIT NUMBERS SHOULD BE REPORTED EXCLUDING MED)

Circuit # 0206

1. SUBSTATION NAME AND NUMBER

Munfordville (2)

2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN)

Hart County - Hwy 31W (Main St) - Munfordville

3. CIRCUIT NAME AND NUMBER

Cub Run (6)

4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA)

Cub Run (6)

5. TOTAL CIRCUIT MILES (MILES)

177.68

6. CUSTOMER COUNT FOR THIS CIRCUIT

1837

7. DATE OF LAST CIRCUIT TRIM (VM)

2021

8. LIST OUTAGE FOR CIRCUIT ALONG WITH PERCENTAGE OF TOTAL OUTAGE NUMBERS REPRESENTED BY EACH CAUSE

| | |
|----------------------|--------|
| Public | 47.18% |
| Tree Related On R/W | 24.58% |
| Tree Related Off R/W | 11.91% |
| Equipment Failure | 6.96% |
| Animal | 3.07% |
| Weather | 2.81% |
| Planned | 2.79% |
| Unknown | 0.69% |

9. CIRCUIT 5 YEAR AVERAGE (SAIDI)

168.3

10. REPORTING YEAR (SAIDI)

279.82

11. CIRCUIT 5 YEAR AVERAGE (SAIFI)

1.746

12. REPORTING YEAR (SAIFI)

2.92

13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN

The largest SAIDI and SAIFI contributors were due to Public, On R/W trees, and Off R/W trees. Many of the tree-related outages were during storm events. Due to this circuit's large number of miles, large member count, and resulting poor reliability, a substation is being constructed by the end of 2026.

KENTUCKY PUBLIC SERVICE COMMISSION

Electric Distribution Utility Annual Reliability Report

SECTION 5: CIRCUIT REPORTING

(CIRCUIT WITH SAIDI AND/OR SAIFI EXCEEDING 5 YEAR AVERAGE
(CIRCUIT NUMBERS SHOULD BE REPORTED EXCLUDING MED)

Circuit # 0302

1. SUBSTATION NAME AND NUMBER

Temple Hill (3)

2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN)

Barren County, Hwy 63 (Temple Hill Rd) - Temple Hill

3. CIRCUIT NAME AND NUMBER

Morrison Park (2)

4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA)

Morrison Park (2)

5. TOTAL CIRCUIT MILES (MILES)

19.92

6. CUSTOMER COUNT FOR THIS CIRCUIT

179

7. DATE OF LAST CIRCUIT TRIM (VM)

2017

**8. LIST OUTAGE FOR CIRCUIT ALONG WITH PERCENTAGE OF TOTAL OUTAGE
NUMBERS REPRESENTED BY EACH CAUSE**

| | |
|----------------------|--------|
| Tree Related Off R/W | 53.58% |
| Weather | 36.73% |
| Tree Related On R/W | 5.78% |
| Public | 2.88% |
| Animal | 1.02% |

9. CIRCUIT 5 YEAR AVERAGE (SAIDI)

50.12

10. REPORTING YEAR (SAIDI)

89.91

11. CIRCUIT 5 YEAR AVERAGE (SAIFI)

0.634

12. REPORTING YEAR (SAIFI)

0.72

13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN

None taken or to be taken. The largest SAIDI and SAIFI contributors were due to Off R/W trees and lightning during extraordinary storm events.

KENTUCKY PUBLIC SERVICE COMMISSION

Electric Distribution Utility Annual Reliability Report

SECTION 5: CIRCUIT REPORTING

(CIRCUIT WITH SAIDI AND/OR SAIFI EXCEEDING 5 YEAR AVERAGE
(CIRCUIT NUMBERS SHOULD BE REPORTED EXCLUDING MED)

Circuit # 0303

1. SUBSTATION NAME AND NUMBER

Temple Hill (3)

2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN)

Barren County, Hwy 63 (Temple Hill Rd) - Temple Hill

3. CIRCUIT NAME AND NUMBER

Glover Creek / 44 Mkt (3)

4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA)

Glover Creek / 44 Mkt (3)

5. TOTAL CIRCUIT MILES (MILES)

65.63

6. CUSTOMER COUNT FOR THIS CIRCUIT

553

7. DATE OF LAST CIRCUIT TRIM (VM)

2017

**8. LIST OUTAGE FOR CIRCUIT ALONG WITH PERCENTAGE OF TOTAL OUTAGE
NUMBERS REPRESENTED BY EACH CAUSE**

| | |
|---------------------|--------|
| Weather | 39.06% |
| Unknown | 21.82% |
| Tree Related On R/W | 18.72% |
| Animal | 13.61% |
| Equipment Failure | 6.36% |
| Planned | 0.43% |

9. CIRCUIT 5 YEAR AVERAGE (SAIDI)

130.92

10. REPORTING YEAR (SAIDI)

236.55

11. CIRCUIT 5 YEAR AVERAGE (SAIFI)

1.706

12. REPORTING YEAR (SAIFI)

2.88

13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN

None taken or to be taken. The largest SAIDI and SAIFI contributors were due to lightning during extraordinary storm events and an Unknown outage. We investigate any Unknown outage searching for a cause and found none in this case.

KENTUCKY PUBLIC SERVICE COMMISSION

Electric Distribution Utility Annual Reliability Report

SECTION 5: CIRCUIT REPORTING

(CIRCUIT WITH SAIDI AND/OR SAIFI EXCEEDING 5 YEAR AVERAGE
(CIRCUIT NUMBERS SHOULD BE REPORTED EXCLUDING MED)

Circuit # 0304

1. SUBSTATION NAME AND NUMBER

Temple Hill (3)

2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN)

Barren County, Hwy 63 (Temple Hill Rd) - Temple Hill

3. CIRCUIT NAME AND NUMBER

Etoile (4)

4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA)

Etoile (4)

5. TOTAL CIRCUIT MILES (MILES)

18.1

6. CUSTOMER COUNT FOR THIS CIRCUIT

107

7. DATE OF LAST CIRCUIT TRIM (VM)

2018

**8. LIST OUTAGE FOR CIRCUIT ALONG WITH PERCENTAGE OF TOTAL OUTAGE
NUMBERS REPRESENTED BY EACH CAUSE**

| | |
|----------------------|--------|
| Tree Related Off R/W | 98.47% |
| Animal | 1.53% |

9. CIRCUIT 5 YEAR AVERAGE (SAIDI)

160.45

10. REPORTING YEAR (SAIDI)

183.32

11. CIRCUIT 5 YEAR AVERAGE (SAIFI)

1.672

12. REPORTING YEAR (SAIFI)

1.02

13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN

None taken or to be taken. The largest SAIDI contributor was due to a single Off R/W trees related outage during a storm event.

KENTUCKY PUBLIC SERVICE COMMISSION

Electric Distribution Utility Annual Reliability Report

SECTION 5: CIRCUIT REPORTING

(CIRCUIT WITH SAIDI AND/OR SAIFI EXCEEDING 5 YEAR AVERAGE
(CIRCUIT NUMBERS SHOULD BE REPORTED EXCLUDING MED)

Circuit # 0306

1. SUBSTATION NAME AND NUMBER

Temple Hill (3)

2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN)

Barren County, Hwy 63 (Temple Hill Rd) - Temple Hill

3. CIRCUIT NAME AND NUMBER

Temple Hill (6)

4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA)

Temple Hill (6)

5. TOTAL CIRCUIT MILES (MILES)

34.95

6. CUSTOMER COUNT FOR THIS CIRCUIT

269

7. DATE OF LAST CIRCUIT TRIM (VM)

2017

**8. LIST OUTAGE FOR CIRCUIT ALONG WITH PERCENTAGE OF TOTAL OUTAGE
NUMBERS REPRESENTED BY EACH CAUSE**

| | |
|----------------------|--------|
| Planned | 55.63% |
| Weather | 22.03% |
| Public | 14.29% |
| Animal | 5.38% |
| Tree Related Off R/W | 1.98% |
| Equipment Failure | 0.36% |
| Unknown | 0.32% |

9. CIRCUIT 5 YEAR AVERAGE (SAIDI)

94.668

10. REPORTING YEAR (SAIDI)

88.25

11. CIRCUIT 5 YEAR AVERAGE (SAIFI)

0.998

12. REPORTING YEAR (SAIFI)

1.33

13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN

None taken or to be taken. The largest SAIFI contributors were Planned (safely change a pole), due to Weather (lightning), and a Public cause outage.

KENTUCKY PUBLIC SERVICE COMMISSION

Electric Distribution Utility Annual Reliability Report

SECTION 5: CIRCUIT REPORTING

(CIRCUIT WITH SAIDI AND/OR SAIFI EXCEEDING 5 YEAR AVERAGE
(CIRCUIT NUMBERS SHOULD BE REPORTED EXCLUDING MED)

Circuit # 0403

1. SUBSTATION NAME AND NUMBER

Knob Lick (4)

2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN)

Metcalfe County - Hwy 70 (Sulphur Well Knob Lick Rd) - Knob Lick

3. CIRCUIT NAME AND NUMBER

Hiseville (3)

4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA)

Hiseville (3)

5. TOTAL CIRCUIT MILES (MILES)

22.19

6. CUSTOMER COUNT FOR THIS CIRCUIT

166

7. DATE OF LAST CIRCUIT TRIM (VM)

2019

8. LIST OUTAGE FOR CIRCUIT ALONG WITH PERCENTAGE OF TOTAL OUTAGE NUMBERS REPRESENTED BY EACH CAUSE

| | |
|----------------------|--------|
| Tree Related On R/W | 71.99% |
| Public | 10.11% |
| Tree Related Off R/W | 8.38% |
| Weather | 5.68% |
| Animal | 2.76% |
| Planned | 1.08% |

9. CIRCUIT 5 YEAR AVERAGE (SAIDI)

64.586

10. REPORTING YEAR (SAIDI)

94.56

11. CIRCUIT 5 YEAR AVERAGE (SAIFI)

0.486

12. REPORTING YEAR (SAIFI)

0.67

13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN

None taken or to be taken. The largest SAIDI contributors were due to On R/W trees and Public caused outages. We examined the circuit and found the issues to be isolated and not systemic. Specific conditions were related to storm events, yard trees with limited ability to trim, etc.

KENTUCKY PUBLIC SERVICE COMMISSION

Electric Distribution Utility Annual Reliability Report

SECTION 5: CIRCUIT REPORTING

(CIRCUIT WITH SAIDI AND/OR SAIFI EXCEEDING 5 YEAR AVERAGE
(CIRCUIT NUMBERS SHOULD BE REPORTED EXCLUDING MED)

Circuit # 0404

1. SUBSTATION NAME AND NUMBER

Knob Lick (4)

2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN)

Metcalfe County - Hwy 70 (Sulphur Well Knob Lick Rd) - Knob Lick

3. CIRCUIT NAME AND NUMBER

Center (4)

4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA)

Center (4)

5. TOTAL CIRCUIT MILES (MILES)

110.01

6. CUSTOMER COUNT FOR THIS CIRCUIT

701

7. DATE OF LAST CIRCUIT TRIM (VM)

2019

**8. LIST OUTAGE FOR CIRCUIT ALONG WITH PERCENTAGE OF TOTAL OUTAGE
NUMBERS REPRESENTED BY EACH CAUSE**

| | |
|----------------------|--------|
| Equipment Failure | 74.38% |
| Tree Related On R/W | 10.07% |
| Tree Related Off R/W | 8.62% |
| Animal | 3.01% |
| Weather | 1.98% |
| Planned | 1.75% |
| Public | 0.17% |
| Other | 0.02% |

9. CIRCUIT 5 YEAR AVERAGE (SAIDI)

45.252

10. REPORTING YEAR (SAIDI)

147.94

11. CIRCUIT 5 YEAR AVERAGE (SAIFI)

0.492

12. REPORTING YEAR (SAIFI)

0.97

13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN

None taken or to be taken. The largest SAIDI contributor was due to Equipment Failure (broken insulator). This coupled with lightning during extraordinary storm events were the largest SAIFI contributors.

KENTUCKY PUBLIC SERVICE COMMISSION

Electric Distribution Utility Annual Reliability Report

SECTION 5: CIRCUIT REPORTING

(CIRCUIT WITH SAIDI AND/OR SAIFI EXCEEDING 5 YEAR AVERAGE
(CIRCUIT NUMBERS SHOULD BE REPORTED EXCLUDING MED)

Circuit # 0503

1. SUBSTATION NAME AND NUMBER

Beckton (5)

2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN)

Barren County - Hwy 1297 (Old Bowling Green Rd) - Beckton

3. CIRCUIT NAME AND NUMBER

Railton (3)

4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA)

Railton (3)

5. TOTAL CIRCUIT MILES (MILES)

75.5

6. CUSTOMER COUNT FOR THIS CIRCUIT

670

7. DATE OF LAST CIRCUIT TRIM (VM)

2020

**8. LIST OUTAGE FOR CIRCUIT ALONG WITH PERCENTAGE OF TOTAL OUTAGE
NUMBERS REPRESENTED BY EACH CAUSE**

| | |
|---------------------|--------|
| Equipment Failure | 28.67% |
| Unknown | 23.85% |
| Weather | 16.98% |
| Tree Related On R/W | 16.72% |
| Public | 8.51% |
| Animal | 4.33% |
| Planned | 0.95% |

9. CIRCUIT 5 YEAR AVERAGE (SAIDI)

66.252

10. REPORTING YEAR (SAIDI)

84.62

11. CIRCUIT 5 YEAR AVERAGE (SAIFI)

0.802

12. REPORTING YEAR (SAIFI)

0.81

13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN

None taken or to be taken. The largest SAIDI contributors were due to Equipment Failure and Unknown causes. We investigate any Unknown outage searching for a cause and found none in this case.

KENTUCKY PUBLIC SERVICE COMMISSION

Electric Distribution Utility Annual Reliability Report

SECTION 5: CIRCUIT REPORTING

(CIRCUIT WITH SAIDI AND/OR SAIFI EXCEEDING 5 YEAR AVERAGE
(CIRCUIT NUMBERS SHOULD BE REPORTED EXCLUDING MED)

Circuit # 0704

1. SUBSTATION NAME AND NUMBER

Parkway 1 (7)

2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN)

Barren County - Aberdeen Dr - Glasgow

3. CIRCUIT NAME AND NUMBER

Haywood (4)

4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA)

Haywood (4)

5. TOTAL CIRCUIT MILES (MILES)

47.73

6. CUSTOMER COUNT FOR THIS CIRCUIT

891

7. DATE OF LAST CIRCUIT TRIM (VM)

2017

**8. LIST OUTAGE FOR CIRCUIT ALONG WITH PERCENTAGE OF TOTAL OUTAGE
NUMBERS REPRESENTED BY EACH CAUSE**

| | |
|---------------------|--------|
| Tree Related On R/W | 41.56% |
| Animal | 31.35% |
| Weather | 18.07% |
| Unknown | 4.56% |
| Public | 4.41% |
| Planned | 0.06% |

9. CIRCUIT 5 YEAR AVERAGE (SAIDI)

60.794

10. REPORTING YEAR (SAIDI)

65.17

11. CIRCUIT 5 YEAR AVERAGE (SAIFI)

0.702

12. REPORTING YEAR (SAIFI)

0.72

13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN

The largest SAIDI contributors were due to On R/W trees (mainly storm related) and Animal relate causes. No systemic issues were identified and the circuit is scheduled for clearing in 2026. This coupled with lightning during extraordinary storm events were the largest SAIFI contributors.

KENTUCKY PUBLIC SERVICE COMMISSION

Electric Distribution Utility Annual Reliability Report

SECTION 5: CIRCUIT REPORTING

(CIRCUIT WITH SAIDI AND/OR SAIFI EXCEEDING 5 YEAR AVERAGE
(CIRCUIT NUMBERS SHOULD BE REPORTED EXCLUDING MED)

Circuit # 0801

1. SUBSTATION NAME AND NUMBER

Galloway (8)

2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN)

Metcalfe County - Hwy 68-80 (Glasgow Rd) - Cave Ridge

3. CIRCUIT NAME AND NUMBER

Edmonton (1)

4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA)

Edmonton (1)

5. TOTAL CIRCUIT MILES (MILES)

177.81

6. CUSTOMER COUNT FOR THIS CIRCUIT

1406

7. DATE OF LAST CIRCUIT TRIM (VM)

2018

8. LIST OUTAGE FOR CIRCUIT ALONG WITH PERCENTAGE OF TOTAL OUTAGE NUMBERS REPRESENTED BY EACH CAUSE

| | |
|----------------------|--------|
| Tree Related On R/W | 45.44% |
| Tree Related Off R/W | 22.20% |
| Equipment Failure | 16.40% |
| Weather | 6.41% |
| Unknown | 4.32% |
| Animal | 3.34% |
| Planned | 0.82% |
| Public | 0.69% |
| Other | 0.38% |

9. CIRCUIT 5 YEAR AVERAGE (SAIDI)

170.32

10. REPORTING YEAR (SAIDI)

208.84

11. CIRCUIT 5 YEAR AVERAGE (SAIFI)

1.386

12. REPORTING YEAR (SAIFI)

1.75

13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN

The largest SAIDI contributors were due to On R/W and Off R/W trees. Many of these were related to storm events. This circuit is scheduled for clearing in 2026. This coupled with lightning during extraordinary storm events were the largest SAIFI contributors.

KENTUCKY PUBLIC SERVICE COMMISSION

Electric Distribution Utility Annual Reliability Report

SECTION 5: CIRCUIT REPORTING

(CIRCUIT WITH SAIDI AND/OR SAIFI EXCEEDING 5 YEAR AVERAGE
(CIRCUIT NUMBERS SHOULD BE REPORTED EXCLUDING MED)

Circuit # 0802

1. SUBSTATION NAME AND NUMBER

Galloway (8)

2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN)

Metcalfe County - Hwy 68-80 (Glasgow Rd) - Cave Ridge

3. CIRCUIT NAME AND NUMBER

Randolph (2)

4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA)

Randolph (2)

5. TOTAL CIRCUIT MILES (MILES)

110.94

6. CUSTOMER COUNT FOR THIS CIRCUIT

855

7. DATE OF LAST CIRCUIT TRIM (VM)

2019

8. LIST OUTAGE FOR CIRCUIT ALONG WITH PERCENTAGE OF TOTAL OUTAGE NUMBERS REPRESENTED BY EACH CAUSE

| | |
|----------------------|--------|
| Weather | 39.13% |
| Equipment Failure | 17.96% |
| Public | 17.27% |
| Tree Related Off R/W | 9.86% |
| Tree Related On R/W | 5.39% |
| Animal | 5.25% |
| Unknown | 3.38% |
| Planned | 1.76% |

9. CIRCUIT 5 YEAR AVERAGE (SAIDI)

130.99

10. REPORTING YEAR (SAIDI)

123.67

11. CIRCUIT 5 YEAR AVERAGE (SAIFI)

1.596

12. REPORTING YEAR (SAIFI)

1.68

13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN

None taken or to be taken. The largest SAIDI and SAIFI contributor was due to lightning during extraordinary storm events.

KENTUCKY PUBLIC SERVICE COMMISSION

Electric Distribution Utility Annual Reliability Report

SECTION 5: CIRCUIT REPORTING

(CIRCUIT WITH SAIDI AND/OR SAIFI EXCEEDING 5 YEAR AVERAGE
(CIRCUIT NUMBERS SHOULD BE REPORTED EXCLUDING MED)

Circuit # 0901

1. SUBSTATION NAME AND NUMBER

Bonnieville (9)

2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN)

Hart County - Hwy 31W (N Dixie Hwy) - Bonnieville

3. CIRCUIT NAME AND NUMBER

Priceville (1)

4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA)

Priceville (1)

5. TOTAL CIRCUIT MILES (MILES)

44.41

6. CUSTOMER COUNT FOR THIS CIRCUIT

366

7. DATE OF LAST CIRCUIT TRIM (VM)

2016

**8. LIST OUTAGE FOR CIRCUIT ALONG WITH PERCENTAGE OF TOTAL OUTAGE
NUMBERS REPRESENTED BY EACH CAUSE**

| | |
|---------------------|--------|
| Tree Related On R/W | 75.60% |
| Unknown | 14.50% |
| Equipment Failure | 8.94% |
| Weather | 0.63% |
| Planned | 0.19% |
| Public | 0.11% |
| Animal | 0.04% |

9. CIRCUIT 5 YEAR AVERAGE (SAIDI)

87.716

10. REPORTING YEAR (SAIDI)

408.08

11. CIRCUIT 5 YEAR AVERAGE (SAIFI)

0.532

12. REPORTING YEAR (SAIFI)

3.23

13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN

The largest SAIDI and SAIFI contributor was due to On R/W trees. This circuit is scheduled for clearing in 2025. We investigate any Unknown outage searching for a cause. For this circuit, we just had an abnormal amount that no cause was found.

KENTUCKY PUBLIC SERVICE COMMISSION

Electric Distribution Utility Annual Reliability Report

SECTION 5: CIRCUIT REPORTING

(CIRCUIT WITH SAIDI AND/OR SAIFI EXCEEDING 5 YEAR AVERAGE
(CIRCUIT NUMBERS SHOULD BE REPORTED EXCLUDING MED)

Circuit # 0902

1. SUBSTATION NAME AND NUMBER

Bonnieville (9)

2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN)

Hart County - Hwy 31W (N Dixie Hwy) - Bonnieville

3. CIRCUIT NAME AND NUMBER

Mundfordville (2)

4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA)

Mundfordville (2)

5. TOTAL CIRCUIT MILES (MILES)

51.1

6. CUSTOMER COUNT FOR THIS CIRCUIT

374

7. DATE OF LAST CIRCUIT TRIM (VM)

2015

**8. LIST OUTAGE FOR CIRCUIT ALONG WITH PERCENTAGE OF TOTAL OUTAGE
NUMBERS REPRESENTED BY EACH CAUSE**

| | |
|----------------------|--------|
| Tree Related On R/W | 53.14% |
| Tree Related Off R/W | 26.74% |
| Unknown | 7.24% |
| Other | 6.12% |
| Animal | 2.86% |
| Public | 2.32% |
| Weather | 0.79% |
| Planned | 0.73% |
| Equipment Failure | 0.06% |

9. CIRCUIT 5 YEAR AVERAGE (SAIDI)

202.54

10. REPORTING YEAR (SAIDI)

230.41

11. CIRCUIT 5 YEAR AVERAGE (SAIFI)

1.748

12. REPORTING YEAR (SAIFI)

3.35

13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN

The largest SAIDI and SAIFI contributors were due to On R/W and Off R/W trees. This circuit is scheduled for clearing in 2025.

KENTUCKY PUBLIC SERVICE COMMISSION

Electric Distribution Utility Annual Reliability Report

SECTION 5: CIRCUIT REPORTING

(CIRCUIT WITH SAIDI AND/OR SAIFI EXCEEDING 5 YEAR AVERAGE
(CIRCUIT NUMBERS SHOULD BE REPORTED EXCLUDING MED)

Circuit # 1202

1. SUBSTATION NAME AND NUMBER

Fox Hollow (12)

2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN)

Barren County - Hwy 63 (Temple Hill Rd) - Glasgow

3. CIRCUIT NAME AND NUMBER

44 Market (2)

4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA)

44 Market (2)

5. TOTAL CIRCUIT MILES (MILES)

38.56

6. CUSTOMER COUNT FOR THIS CIRCUIT

484

7. DATE OF LAST CIRCUIT TRIM (VM)

2020

8. LIST OUTAGE FOR CIRCUIT ALONG WITH PERCENTAGE OF TOTAL OUTAGE NUMBERS REPRESENTED BY EACH CAUSE

| | |
|----------------------|--------|
| Animal | 90.38% |
| Equipment Failure | 3.45% |
| Weather | 2.54% |
| Tree Related On R/W | 1.54% |
| Unknown | 0.77% |
| Tree Related Off R/W | 0.73% |
| Planned | 0.57% |
| Public | 0.02% |

9. CIRCUIT 5 YEAR AVERAGE (SAIDI)

50.416

10. REPORTING YEAR (SAIDI)

307.2

11. CIRCUIT 5 YEAR AVERAGE (SAIFI)

0.54

12. REPORTING YEAR (SAIFI)

2.41

13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN

None taken or to be taken. The largest SAIDI contributor was due to Animal related outages. The largest SAIFI contributor was due to lightning during extraordinary storm events.

KENTUCKY PUBLIC SERVICE COMMISSION

Electric Distribution Utility Annual Reliability Report

SECTION 5: CIRCUIT REPORTING

(CIRCUIT WITH SAIDI AND/OR SAIFI EXCEEDING 5 YEAR AVERAGE
(CIRCUIT NUMBERS SHOULD BE REPORTED EXCLUDING MED)

Circuit # 1203

1. SUBSTATION NAME AND NUMBER

Fox Hollow (12)

2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN)

Barren County - Hwy 63 (Temple Hill Rd) - Glasgow

3. CIRCUIT NAME AND NUMBER

Lecta (3)

4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA)

Lecta (3)

5. TOTAL CIRCUIT MILES (MILES)

77.63

6. CUSTOMER COUNT FOR THIS CIRCUIT

1051

7. DATE OF LAST CIRCUIT TRIM (VM)

2020

**8. LIST OUTAGE FOR CIRCUIT ALONG WITH PERCENTAGE OF TOTAL OUTAGE
NUMBERS REPRESENTED BY EACH CAUSE**

| | |
|----------------------|--------|
| Tree Related On R/W | 49.91% |
| Tree Related Off R/W | 38.11% |
| Weather | 6.18% |
| Animal | 2.63% |
| Public | 2.16% |
| Unknown | 0.79% |
| Planned | 0.12% |
| Equipment Failure | 0.10% |

9. CIRCUIT 5 YEAR AVERAGE (SAIDI)

63.412

10. REPORTING YEAR (SAIDI)

109.91

11. CIRCUIT 5 YEAR AVERAGE (SAIFI)

0.684

12. REPORTING YEAR (SAIFI)

0.63

13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN

The largest SAIDI contributors were due to On R/W and Off R/W trees. We examined the circuit and found the issues to be isolated and not systemic. Specific conditions were related to storm events, yard trees with limited ability to trim, etc.

KENTUCKY PUBLIC SERVICE COMMISSION

Electric Distribution Utility Annual Reliability Report

SECTION 5: CIRCUIT REPORTING

(CIRCUIT WITH SAIDI AND/OR SAIFI EXCEEDING 5 YEAR AVERAGE
(CIRCUIT NUMBERS SHOULD BE REPORTED EXCLUDING MED)

Circuit # 1601

1. SUBSTATION NAME AND NUMBER

Bon Ayr (16)

2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN)

Barren County - Hwy 68-80 (Bowling Green Rd) - Bon Ayr

3. CIRCUIT NAME AND NUMBER

Dripping Springs Rd (1)

4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA)

Dripping Springs Rd (1)

5. TOTAL CIRCUIT MILES (MILES)

22.83

6. CUSTOMER COUNT FOR THIS CIRCUIT

331

7. DATE OF LAST CIRCUIT TRIM (VM)

2021

**8. LIST OUTAGE FOR CIRCUIT ALONG WITH PERCENTAGE OF TOTAL OUTAGE
NUMBERS REPRESENTED BY EACH CAUSE**

| | |
|---------------------|--------|
| Weather | 98.70% |
| Unknown | 0.74% |
| Equipment Failure | 0.29% |
| Tree Related On R/W | 0.26% |

9. CIRCUIT 5 YEAR AVERAGE (SAIDI)

35.312

10. REPORTING YEAR (SAIDI)

79.08

11. CIRCUIT 5 YEAR AVERAGE (SAIFI)

0.492

12. REPORTING YEAR (SAIFI)

1.1

13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN

None taken or to be taken. The largest SAIDI and SAIFI contributor was due to lightning during extraordinary storm events.

KENTUCKY PUBLIC SERVICE COMMISSION

Electric Distribution Utility Annual Reliability Report

SECTION 5: CIRCUIT REPORTING

(CIRCUIT WITH SAIDI AND/OR SAIFI EXCEEDING 5 YEAR AVERAGE
(CIRCUIT NUMBERS SHOULD BE REPORTED EXCLUDING MED)

Circuit # 1603

1. SUBSTATION NAME AND NUMBER

Bon Ayr (16)

2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN)

Barren County - Hwy 68-80 (Bowling Green Rd) - Bon Ayr

3. CIRCUIT NAME AND NUMBER

Park City (3)

4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA)

Park City (3)

5. TOTAL CIRCUIT MILES (MILES)

51.24

6. CUSTOMER COUNT FOR THIS CIRCUIT

413

7. DATE OF LAST CIRCUIT TRIM (VM)

2021

**8. LIST OUTAGE FOR CIRCUIT ALONG WITH PERCENTAGE OF TOTAL OUTAGE
NUMBERS REPRESENTED BY EACH CAUSE**

| | |
|----------------------|--------|
| Tree Related Off R/W | 57.33% |
| Equipment Failure | 28.10% |
| Weather | 13.44% |
| Unknown | 0.80% |
| Tree Related On R/W | 0.33% |

9. CIRCUIT 5 YEAR AVERAGE (SAIDI)

107.88

10. REPORTING YEAR (SAIDI)

138.88

11. CIRCUIT 5 YEAR AVERAGE (SAIFI)

0.934

12. REPORTING YEAR (SAIFI)

1.24

13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN

None taken or to be taken. The largest SAIDI contributors were due to Off R/W trees and Equipment Failure. The largest SAIFI contributor was due to lightning during extraordinary storm events.

KENTUCKY PUBLIC SERVICE COMMISSION

Electric Distribution Utility Annual Reliability Report

SECTION 5: CIRCUIT REPORTING

(CIRCUIT WITH SAIDI AND/OR SAIFI EXCEEDING 5 YEAR AVERAGE
(CIRCUIT NUMBERS SHOULD BE REPORTED EXCLUDING MED)

Circuit # 1702

1. SUBSTATION NAME AND NUMBER

Jonesville (17)

2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN)

Hart County - Hwy 357 (Hammonsville Rd) - Munfordville

3. CIRCUIT NAME AND NUMBER

Jonesville (2)

4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA)

Jonesville (2)

5. TOTAL CIRCUIT MILES (MILES)

96.14

6. CUSTOMER COUNT FOR THIS CIRCUIT

649

7. DATE OF LAST CIRCUIT TRIM (VM)

2014

**8. LIST OUTAGE FOR CIRCUIT ALONG WITH PERCENTAGE OF TOTAL OUTAGE
NUMBERS REPRESENTED BY EACH CAUSE**

| | |
|----------------------|--------|
| Tree Related On R/W | 60.36% |
| Weather | 21.48% |
| Equipment Failure | 6.09% |
| Animal | 4.38% |
| Tree Related Off R/W | 3.74% |
| Unknown | 3.49% |
| Public | 0.27% |
| Planned | 0.18% |

9. CIRCUIT 5 YEAR AVERAGE (SAIDI)

159.56

10. REPORTING YEAR (SAIDI)

272.13

11. CIRCUIT 5 YEAR AVERAGE (SAIFI)

1.684

12. REPORTING YEAR (SAIFI)

2.25

13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN

The largest SAIDI contributor was due to On R/W trees. A large portion of these outages occurred during storm events. This circuit's next cycle trim is scheduled for late 2025 or early 2026.

KENTUCKY PUBLIC SERVICE COMMISSION

Electric Distribution Utility Annual Reliability Report

SECTION 5: CIRCUIT REPORTING

(CIRCUIT WITH SAIDI AND/OR SAIFI EXCEEDING 5 YEAR AVERAGE
(CIRCUIT NUMBERS SHOULD BE REPORTED EXCLUDING MED)

Circuit # 1801

1. SUBSTATION NAME AND NUMBER

Roseville (18)

2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN)

Barren County - Roseville Rd - Roseville

3. CIRCUIT NAME AND NUMBER

Etoile (1)

4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA)

Etoile (1)

5. TOTAL CIRCUIT MILES (MILES)

111.97

6. CUSTOMER COUNT FOR THIS CIRCUIT

609

7. DATE OF LAST CIRCUIT TRIM (VM)

2018

**8. LIST OUTAGE FOR CIRCUIT ALONG WITH PERCENTAGE OF TOTAL OUTAGE
NUMBERS REPRESENTED BY EACH CAUSE**

| | |
|----------------------|--------|
| Tree Related Off R/W | 61.77% |
| Tree Related On R/W | 31.33% |
| Unknown | 2.82% |
| Weather | 2.78% |
| Animal | 0.95% |
| Equipment Failure | 0.36% |

9. CIRCUIT 5 YEAR AVERAGE (SAIDI)

113.48

10. REPORTING YEAR (SAIDI)

235.31

11. CIRCUIT 5 YEAR AVERAGE (SAIFI)

1.132

12. REPORTING YEAR (SAIFI)

1.83

13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN

None taken or to be taken. The largest contributors were due to Off R/W and On R/W trees. A large portion of these outages occurred during storm events. The largest SAIFI contributor was due to lightning during extraordinary storm events.

KENTUCKY PUBLIC SERVICE COMMISSION

Electric Distribution Utility Annual Reliability Report

SECTION 5: CIRCUIT REPORTING

(CIRCUIT WITH SAIDI AND/OR SAIFI EXCEEDING 5 YEAR AVERAGE
(CIRCUIT NUMBERS SHOULD BE REPORTED EXCLUDING MED)

Circuit # 1802

1. SUBSTATION NAME AND NUMBER

Roseville (18)

2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN)

Barren County - Roseville Rd - Roseville

3. CIRCUIT NAME AND NUMBER

State Park (2)

4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA)

State Park (2)

5. TOTAL CIRCUIT MILES (MILES)

50.99

6. CUSTOMER COUNT FOR THIS CIRCUIT

432

7. DATE OF LAST CIRCUIT TRIM (VM)

2018

**8. LIST OUTAGE FOR CIRCUIT ALONG WITH PERCENTAGE OF TOTAL OUTAGE
NUMBERS REPRESENTED BY EACH CAUSE**

| | |
|---------------------|--------|
| Public | 30.00% |
| Equipment Failure | 24.56% |
| Weather | 24.42% |
| Unknown | 11.85% |
| Tree Related On R/W | 6.44% |
| Planned | 1.49% |
| Animal | 1.24% |

9. CIRCUIT 5 YEAR AVERAGE (SAIDI)

99.994

10. REPORTING YEAR (SAIDI)

103.61

11. CIRCUIT 5 YEAR AVERAGE (SAIFI)

1.01

12. REPORTING YEAR (SAIFI)

1.86

13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN

None taken or to be taken. The largest SAIDI contributors were Public caused and Equipment Failure related. The largest SAIFI contributor was due to lightning during extraordinary storm events.

KENTUCKY PUBLIC SERVICE COMMISSION

Electric Distribution Utility Annual Reliability Report

SECTION 5: CIRCUIT REPORTING

(CIRCUIT WITH SAIDI AND/OR SAIFI EXCEEDING 5 YEAR AVERAGE
(CIRCUIT NUMBERS SHOULD BE REPORTED EXCLUDING MED)

Circuit # 1804

1. SUBSTATION NAME AND NUMBER

Roseville (18)

2. SUBSTATION LOCATION (COUNTY-ROAD-TOWN)

Barren County - Roseville Rd - Roseville

3. CIRCUIT NAME AND NUMBER

Temple Hill (4)

4. CIRCUIT LOCATION (TOWN-ROAD-GENERAL AREA)

Temple Hill (4)

5. TOTAL CIRCUIT MILES (MILES)

34.21

6. CUSTOMER COUNT FOR THIS CIRCUIT

227

7. DATE OF LAST CIRCUIT TRIM (VM)

2018

**8. LIST OUTAGE FOR CIRCUIT ALONG WITH PERCENTAGE OF TOTAL OUTAGE
NUMBERS REPRESENTED BY EACH CAUSE**

| | |
|----------------------|--------|
| Equipment Failure | 34.77% |
| Tree Related On R/W | 31.63% |
| Tree Related Off R/W | 29.44% |
| Weather | 4.15% |

9. CIRCUIT 5 YEAR AVERAGE (SAIDI)

53.322

10. REPORTING YEAR (SAIDI)

224.33

11. CIRCUIT 5 YEAR AVERAGE (SAIFI)

0.57

12. REPORTING YEAR (SAIFI)

2.43

13. LIST OF CORRECTIVE ACTION, IF ANY, TAKEN OR TO BE TAKEN

None taken or to be taken. The largest SAIDI contributors were Equipment Failure, On R/W trees, and Off R/W trees. A large portion of these outages occurred during storm events.

Electric Distribution Utility Annual Reliability Report

SECTION 6: VEGETATION MANAGEMENT PLAN REVIEW

In 2025, Farmers RECC will work to clear the circuits listed below. We have contracts with Townsend Tree Service, WA Kendall to perform all work, and Steel Rock Services.

Right-of-way clearing planned (392 miles)

- Munfordville (2) - Priceville (3)
- Munfordville (2) - Bonnieville (4)
- Munfordville (2) - Munfordville (7)
- Bonnieville (9) - Priceville (1)
- Bonnieville (9) -Munfordville (2)
- Jonesville (17) - Jonesville (2)
- Jonesville (17) - Seymour (3)
- Jonesville (17) - Munfordville (4)

In 2025, Farmers RECC will work to spray with herbicide the following circuits.

Right-of-way herbicide spraying (6289 miles)

- Munfordville (2) -Seymour (1)
- Munfordville (2) - Northtown (2)
- Munfordville (2) - Jonesville (5)
- Munfordville (2) - Cub Run (6)
- Jonesville (17) - Hammons ville (1)
- Seymour (11) - Uno (2)
- Seymour (11) - Bearwallow (3)
- Seymour (11) - Monroe (4)

In 2025, Farmers RECC will continue to perform hot spot clearing, trimming yard trees, and clearing for new work orders with the contractors listed above.

Electric Distribution Utility Annual Reliability Report

SECTION 7: UTILITY COMMENTS