

**COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION**

In the Matter of:

**AN EXAMINATION OF THE APPLICATION OF THE)
FUEL ADJUSTMENT CLAUSE OF LOUISVILLE GAS) CASE NO.
AND ELECTRIC COMPANY FROM NOVEMBER 1,) 2013-00264
2012 THROUGH APRIL 30, 2013)**


**RESPONSE OF
LOUISVILLE GAS AND ELECTRIC COMPANY
TO STAFF'S
POST HEARING REQUEST FOR INFORMATION
HEARING DATE OCTOBER 16, 2013**

FILED: OCTOBER 30, 2013

VERIFICATION

COMMONWEALTH OF KENTUCKY)
) SS:
COUNTY OF JEFFERSON)

The undersigned, **Eileen L. Saunders**, being duly sworn, deposes and says that she is Director, Generation Services for LG&E and KU Services Company, and that she has personal knowledge of the matters set forth in the responses for which she is identified as the witness, and the answers contained therein are true and correct to the best of her information, knowledge and belief.


Eileen L. Saunders

Subscribed and sworn to before me, a Notary Public in and before said County and State, this 30th day of October 2013.

 (SEAL)
Notary Public

My Commission Expires:

7/21/2015

LOUISVILLE GAS AND ELECTRIC COMPANY

**Response to Staff's Post Hearing Request for Information
Hearing Date October 16, 2013**

Case No. 2013-00264

Question No. 1

Witness: Eileen Saunders

- Q-1. Refer to LG&E's Response to Staff's Request for Information, Question No. 7, page 16 of 23. Please explain why the outage for unit inspection of Paddy's Run Unit 13, which was scheduled to last 207 hours, instead lasted only 78 ½ hours
- A-1. It was anticipated that more tiles would be required to be replaced, however the actual inspection of the Tile and Combustion Chamber showed that not as much work was needed in that area. The Unit was returned to service on February 28, 2013.