

**COMMONWEALTH OF KENTUCKY  
BEFORE THE PUBLIC SERVICE COMMISSION**

**In the Matter of:**

<b>AN EXAMINATION OF THE APPLICATION</b>	)	
<b>OF THE FUEL ADJUSTMENT CLAUSE OF</b>	)	<b>CASE NO.</b>
<b>KENTUCKY UTILITIES COMPANY FROM</b>	)	<b>2013-00446</b>
<b>MAY 1, 2013 THROUGH OCTOBER 31, 2013</b>	)	


**RESPONSE OF  
KENTUCKY UTILITIES COMPANY  
TO STAFF'S  
POST HEARING REQUEST FOR INFORMATION  
HEARING DATE APRIL 10, 2014**

**FILED: APRIL 14, 2014**


VERIFICATION

COMMONWEALTH OF KENTUCKY )  
 ) SS:  
COUNTY OF JEFFERSON )

The undersigned, **Eileen L. Saunders**, being duly sworn, deposes and says that she is Director, Generation Services for LG&E and KU Services Company, and that she has personal knowledge of the matters set forth in the responses for which she is identified as the witness, and the answers contained therein are true and correct to the best of her information, knowledge and belief.

  
\_\_\_\_\_  
Eileen L. Saunders

Subscribed and sworn to before me, a Notary Public in and before said County and State, this 14<sup>th</sup> day of April 2014.

 (SEAL)

Notary Public

My Commission Expires:

**SUSAN M. WATKINS**  
Notary Public, State at Large, KY  
My Commission Expires Mar. 19, 2017  
Notary ID # 485723

**KENTUCKY UTILITIES COMPANY**

**Response to Staff's Post Hearing Request for Information  
Hearing Date April 10, 2014**

**Case No. 2013-00446**

**Question No. 1**

**Witness: Eileen Saunders**

- Q-1. Refer to KU's Response to Staff's Request for Information, Question No. 7, page 26 of 27. Please explain why the outage reasons are different for KU and LG&E.
- A-1. There was an error in preparing the KU response for filing. The outage reasons should be identical for KU and LG&E. Please see revised page 26 of 27 attached.

Kentucky Utilities Company  
 Trimble County Unit #9 - Gas CT - 157 MW (jointly owned with LG&E)  
 In-service July 2004  
 May 2013 through October 2013

Schedule vs Actual

MONTH	MAINTENANCE				HOURS OF DURATION			REASON FOR DEVIATION FROM SCHEDULED MAINTENANCE OR REASON FOR FORCED OUTAGE AS APPROPRIATE	
	Scheduled		Actual		Scheduled	Forced	Actual		
	FROM	TO	FROM	TO					
May	No outages > or = 6 hours								
June	S	6/7/2013 6:50	6/7/2013 17:10	6/7/2013 6:50	6/7/2013 17:10	10:20		10:20	Compressor Washing
	F			6/19/2013 20:29	6/20/2013 5:18		8:49		Gas Turbine - Hydraulic Oil System
July	No outages > or = 6 hours								
August	S	8/15/2013 3:00	8/15/2013 18:30	8/15/2013 3:00	8/15/2013 18:30	15:30		15:30	Starting System 89SS Switch inspection and adjustment.
	F			8/22/2013 13:00	8/22/2013 19:52		6:52		Starting System 89SS switch failure to disengage, inspection, and adjustment
	F			8/26/2013 13:39	8/26/2013 21:47		8:08		Starting System 89SS switch failure to open, inspection, and adjustment.
September	No outages > or = 6 hours								
October	S	10/18/2013 22:00	10/21/2013 0:00	10/18/2013 22:00	10/21/2013 0:00	50:00		50:00	Switchyard Equipment
	S	10/21/2013 0:00	10/22/2013 15:53	10/21/2013 0:00	10/22/2013 15:53	39:53		39:53	Gas Turbine - Inlet Air Filters