

Cannonsburg Water District
1606 Cannonsburg Road
Ashland, KY 41102
Office: (606) 928-9808
Fax: (606) 928-4788



August 24, 2026

Public Service Commission
Attn: Justin M. McNeil - Executive Director
211 Sower Blvd.
PO Box 615
Frankfort, KY 40602

RE: Case No. 2014-00267 – Water Loss Report

Mr. McNeil,

Please see the attached Water Use Report for the month of July 2026. Please take notice of the following numbers:

June 2026 Water Loss (in gallons) – 5,254,327
July 2026 Water Loss (in gallons) – 2,217,010
Single Month Water Loss **Decrease (in gallons) – 3,037,317**
Resulting in an **7.44% Water Loss for the month of July 2026**
2026 Annual Water Loss of **13.36%**

Due to Ashland replacing flow meters I believe our water to loss to be marginally higher than this report reflects. Unable to verify due to our flow meter being in an area affected by an ongoing waterline project. I based our total consumption off of bills sent to us by Ashland.

If at any time, you have any questions or concerns regarding this report please, do not hesitate to contact me for further information.

Sincerely,

Jacob Travis
District Manager

PUBLIC SERVICE COMMISSION

Monthly Water Loss Report

Water Utility:

For the Month of: Year:

LINE #	ITEM	GALLONS (Omit 000's)
1	WATER PRODUCED AND PURCHASED	
2	Water Produced	
3	Water Purchased	29,811,200
4	TOTAL PRODUCED AND PURCHASED	29,811,200
5		
6	WATER SALES	
7	Residential	13,355,300
8	Commercial	5,233,000
9	Industrial	2,005,000
10	Bulk Loading Stations	-
11	Wholesale	6,935,800
12	Public Authorities	-
13	Other Sales (explain) _____	-
14	TOTAL WATER SALES	27,529,100
15		
16	OTHER WATER USED	
17	Utility and/or Water Treatment Plant	65,000
18	Wastewater Plant	-
19	System Flushing	120,000
20	Fire Department	3,000
21	Other Usage (explain) _____	
22	TOTAL OTHER WATER USED	188,000
23		
24	WATER LOSS	
25	Tank Overflows	-
26	Line Breaks	125,000
27	Line Leaks	1,969,100
28	Excavation Damages	-
29	Theft	-
30	Other Loss	-
31	TOTAL WATER LOSS	2,094,100
32		
33	Note: Line 14 + Line 22 + Line 31 MUST Equal Line 4	
34		
35	WATER LOSS PERCENTAGE	
36	(Line 31 divided by Line 4)	7.02%