

**Cannonsburg Water District**  
**1606 Cannonsburg Road**  
**Ashland, KY 41102**  
**Office: (606) 928-9808**  
**Fax: (606) 928-4788**



November 28, 2018

Public Service Commission  
Attn: Talina Mathews-Executive Director  
211 Sower Blvd.  
PO Box 615  
Frankfort, KY 40602

RE: Case No. 2014-00267 – Surcharge Activity Report

Ms. Mathews,

Please take a moment to review the status and actions Cannonsburg Water District has taken this month to further gain control of its water loss.

Water loss has risen since the prior month. CWD has found one area that seems to be losing water by use of valve sounding and flow monitoring. However, no leaks have reached the surface. We will be borrowing a leak noise correlating device from CI Thornburg and deploying it in the field once B.U.D. locates are complete. The area of concern is approximately 3,000 feet in length and parallels 2 major gas transmission lines and a network of sanitary sewer lines. It is believed at this time, the water is entering these areas and draining elsewhere. Noise correlation should be able to determine this and locate the leak area.

If at any time, you have any questions or concerns regarding this report please, do not hesitate to contact me for further information.

Sincerely,

A handwritten signature in black ink, appearing to read "Tim Webb". The signature is fluid and cursive, with the first name being more prominent.

Tim Webb  
General Manager