

February 27, 2019

Public Service Commission Attn: Gwen Pinson-Executive Director 211 Sower Blvd. PO Box 615 Frankfort, KY 40602

RE: Case No. 2014-00267 - Water Loss Report

Ms. Pinson,

Please see the attached Water Use Report for the month of December 2018 and for the entire year 2018.

If at any time, you have any questions or concerns regarding this report please, do not hesitate to contact me for further information.

Sincerely,

う 1_

Tim Webb General Manager

Cannonsburg Water District is an Equal Opportunity Employer and Provider

PUBLIC SERVICE COMMISSION

Monthly Water Loss Report

Water Utility:	Cannonsburg Water District			
For the Month of:	December	Year:	2018	

.INE #	ITEM	GALLONS (Omit 000's)	
1	WATER PRODUCED, PURCHASED & DISTRIBUTED		
2	Water Produced	-	
3	Water Purchased	32,685,000	
4	TOTAL PRODUCED AND PURCHASED	32,685,000	
5			
6	WATER SALES		
7	Residential	11,968,000	
8	Commercial	3,934,000	
9	Industrial	1,676,000	
10	Bulk Loading Stations	6,500	
11	Wholesale	5,468,000	
12	Other Sales	-	
13	TOTAL WATER SALES	23,052,500	70.59
14			
15	OTHER WATER USED		
16	Utility and/or Water Treatment Plant	31,000	
17	Wastewater Plant	, _	
18	System Flushing	65,000	
19	Fire Department	1,000	
20	Other	-	
21	TOTAL OTHER WATER USED	97,000	0.3%
22			
23	WATER LOSS		
24	Tank Overflows	-	
25	Line Breaks	384,000	
26	Line Leaks	9,151,500	
27	Other	-	
28	TOTAL LINE LOSS	9,535,500	29.2 ⁰
29		.,,	
30	Note: Line 13 + Line 21 + Line 28 Must Equal Line 4		
31	'		
32	WATER LOSS PERCENTAGE		
33	Unaccounted-For Water (Line 28 divided by Line 4)	29.2%	

PUBLIC SERVICE COMMISSION

Annual Water Loss Summary

Water Utility:

Cannonsburg Water District

2018

For the Year:

MONTH	WATER LOSS %
JANUARY	29.9
FEBRUARY	38.9
MARCH	34.9
APRIL	28.9
MAY	24.0
JUNE	21.9
JULY	24.9
AUGUST	18.1
SEPTEMBER	28.1
OCTOBER	29.1
NOVEMBER	25.7
DECEMBER	29.2
TOTAL ANNUAL WATER LOSS %	27.9

The highest water loss was	38.9 and occurred in the month o	DECEMBER
The lowest water loss was	18.1 and occurred in the month o	#N/A
	LEGEND	
	Water Loss is less that 15	<mark>%</mark>
	Water Loss is between 15% -	30%

Water Loss is greater than 30%