Cannonsburg Water District 1606 Cannonsburg Road Ashland, KY 41102 Office: (606) 928-9808

Fax: (606) 928-4788

Quality on Tap

April 29, 2021

Public Service Commission
Attn: Linda C. Bridwell - Executive Director
211 Sower Blvd.
PO Box 615
Frankfort, KY 40602

RE: Case No. 2014-00267 – Water Loss Report

Ms. Bridwell,

Please see the attached Water Use Report for the month of March 2021. Please take notice of the following numbers:

February 2021 Water Loss (in gallons) – 5,372,000 March 2021 Water Loss (in gallons) – 5,764,000 Single Month Water Loss Increase – 392,000

Resulting in a 23.47% Water Loss, (please note that there are three addition days of water purchase and usage in March as to February. The loss per day in March decreased by 5,922 gallons per day compared to February.

If at any time, you have any questions or concerns regarding this report please, do not hesitate to contact me for further information.

Sincerely,

Tim Webb

General Manager

PUBLIC SERVICE COMMISSION

Monthly Water Loss Report

Water Utility:		Cannonsburg Water District		
For the	Month of:	March	Year:	2021
LINE#		ITEM	GAL	LONS (Omit 000's)
1	WATER PRODUCED	AND PURCHASED		
2	Water Produced			-
3	Water Purchased			24,562,000
4		TOTAL PRODUCED AND PURCH	ASED	24,562,000
5				
6	WATER SALES			
7	Residential			11,927,000
8	Commercial			3,934,000
9	Industrial			1,222,000
10	Bulk Loading Stations	5		-
11	Wholesale			1,357,000
12	Public Authorities			-
13	Other Sales (explain)			-
14		TOTAL WATER S	ALES	18,440,000
15				
16	OTHER WATER USE			
17	Utility and/or Water T	reatment Plant		87,000
18	Wastewater Plant			-
19	System Flushing			20,000
20	Fire Department			3,000
21	Other Usage (explain	DBP Flushing		248000
22		TOTAL OTHER WATER	USED	358,000
23				
24	WATER LOSS			
25	Tank Overflows			-
26	Line Breaks			250,000
27	Line Leaks			5,514,000
28	Excavation Damages			-
29	Theft			-
30	Other Loss			_
31		TOTAL WATER	LOSS	5,764,000
32	N 4 11 44 11	00 . 1 . 0407		
33	Note: Line 14 + Line	22 + Line 31 MUST Equal Line 4		
34	14/4	N=N=40=		
35	WATER LOSS PERC			
36	(Line 31 divided by Li	ne 4)		23.47%