

Cannonsburg Water District
1606 Cannonsburg Road
Ashland, KY 41102
Office: (606) 928-9808
Fax: (606) 928-4788



December 28, 2018

Public Service Commission
Attn: Gwen Pinson – Executive Director
211 Sower Blvd.
PO Box 615
Frankfort, KY 40602

RE: Case No. 2014-00267 – Surcharge Activity Report

Ms. Pinson,

Please take a moment to review the status and actions Cannonsburg Water District has taken this month to further gain control of its water loss.

Water Loss has increased due to rising number of leaks, however, as of December 21st we were able to locate and repair 2 major leaks that were difficult to locate. One leak was in a creek crossing and one in an area that holds runoff water. Both leaks were difficult to locate due to the locations and the amount of rainfall in recent weeks.

If at any time, you have any questions or concerns regarding this report please, do not hesitate to contact me for further information.

Sincerely,

A handwritten signature in black ink, appearing to read "Tim Webb".

Tim Webb
General Manager