

Company Name: Kentucky Power
 Station Name - Unit Number: Big Sandy Unit No. 2
 For the Months of November 1, 2013 to April 30, 2014

MONTH	MAINTENANCE				HOURS OF DURATION			REASON FOR DEVIATIONS FROM SCHEDULED MAINTENANCE OR REASON FOR FORCED OUTAGE, AS APPROPRIATE
	Scheduled		Actual ^{1/}		Scheduled	Forced	Actual	
	From	To	From	To				
November			1-Nov	30-Nov		714.5	714.5	Turbine Rotor Replacement
December			1-Dec	1-Dec		0.53	0.53	Turbine Overspeed Protection Check
December			18-Dec	23-Dec		122.77	122.77	Boiler Water Chemistry Upset
December	23-Dec	31-Dec	23-Dec	31-Dec	192		192	Maintenance Outage- Boiler Casing Repairs
December	31-Dec	1-Jan	31-Dec	1-Jan	25.27		25.27	Reserve Shutdown
February			25-Feb	12-Mar		367.72	367.72	Boiler Tube Leak
March	12-Mar	14-Mar	12-Mar	14-Mar	56.8		56.8	Maintenance Outage - Boiler Casing Repairs
March	14-Mar	15-Mar	14-Mar	15-Mar	12.3		12.3	Reserve Shutdown
March			24-Mar	2-Apr		206.55	206.55	Boiler Tube Leak
April	2-Apr	4-Apr	2-Apr	4-Apr	44.02		44.02	Maintenance Outage - Boiler Casing Repairs
April	4-Apr	4-Apr	4-Apr	4-Apr	13.58		13.58	Reserve Shutdown