

**COMMONWEALTH OF KENTUCKY  
BEFORE THE  
KENTUCKY PUBLIC SERVICE COMMISSION**

In the Matter of:

The Application of Duke Energy Kentucky, )  
Inc., for a Certificate of Public )  
Convenience and Necessity Authorizing )  
the Implementation of an Accelerated )  
Service Line Replacement Program, ) Case No. 2015-00210  
Approval of Ownership of Service Lines, )  
and a Gas Pipeline Replacement Surcharge )

---

**DIRECT TESTIMONY OF**

**JOHN A. HILL JR.**

**ON BEHALF OF**

**DUKE ENERGY KENTUCKY, INC.**

---

July 6, 2015

**TABLE OF CONTENTS**

	<b><u>PAGE</u></b>
<b>I. INTRODUCTION AND PURPOSE .....</b>	<b>1</b>
<b>II. DISTRUBUTION INTEGRITY MANAGEMENT PROGRAMS .....</b>	<b>3</b>
<b>III. DUKE ENERGY KENTUCKY'S CAPITAL BUDGETING AND EXPENDITURES .....</b>	<b>10</b>
<b>IV. ASRP .....</b>	<b>13</b>
<b>V. FILING REQUIREMENT SPONSORED BY WITNESS .....</b>	<b>21</b>
<b>VI. CONCLUSION .....</b>	<b>21</b>

**ATTACHMENT**

Attachment JH-1 - Risk Summary

**I. INTRODUCTION AND PURPOSE**

1 **Q. PLEASE STATE YOUR NAME AND BUSINESS ADDRESS.**

2 A. My name is John A. Hill Jr., and my business address is 139 East Fourth Street,  
3 Cincinnati, Ohio 45202.

4 **Q. BY WHOM ARE YOU EMPLOYED AND IN WHAT CAPACITY?**

5 A. I am employed by the Duke Energy Business Services LLC (DEBS) as Director,  
6 Gas Engineering for Duke Energy Kentucky, Inc., (Duke Energy Kentucky or  
7 Company) and Duke Energy Ohio, Inc. (Duke Energy Ohio). DEBS provides  
8 various administrative and other services to Duke Energy Kentucky and other  
9 affiliated companies of Duke Energy Corporation (Duke Energy).

10 **Q. PLEASE BRIEFLY SUMMARIZE YOUR EDUCATIONAL  
11 BACKGROUND AND PROFESSIONAL EXPERIENCE.**

12 A. I graduated from the University of Cincinnati with a Bachelor of Science in Civil  
13 & Environmental Engineering and later obtained an MBA from the University of  
14 Kentucky. In 1996, I obtained my license as a Professional Engineer in the  
15 Commonwealth of Kentucky and, by reciprocity, later in the State of Ohio. I  
16 started my career as an engineering consultant focused mainly on completing  
17 geotechnical and environmental projects for various companies and public  
18 agencies. I then worked for an investor-owned water utility, overseeing new  
19 development and pipeline extension projects as well as asset mapping/records. I  
20 joined Cinergy Corp. in 2001 and held various management/leadership positions  
21 in Generation and Environmental, Health & Safety and, in 2010, joined the Gas  
22 Engineering Department as Director of Engineering.

1 **Q. PLEASE SUMMARIZE YOUR RESPONSIBILITIES AS DIRECTOR,**  
2 **GAS ENGINEERING.**

3 A. As Director, Gas Engineering, I oversee multiple engineering disciplines (Civil,  
4 Mechanical, Electrical/Controls, and Corrosion) and technical functions  
5 responsible for gas pipeline activities such as design, system monitoring, system  
6 design, meter/regulator design, integrity management and corrosion services. I  
7 also provide planning and oversight for the Gas Operations capital budget. In  
8 addition, I represent Gas Operations on Corporate and Industry  
9 initiatives/committees. Importantly, I provide subject matter expertise for Duke  
10 Energy Kentucky and Duke Energy Ohio's integrity management programs.

11 **Q. HAVE YOU PREVIOUSLY TESTIFIED BEFORE THE KENTUCKY**  
12 **PUBLIC SERVICE COMMISSION?**

13 A. No.

14 **Q. WHAT IS THE PURPOSE OF YOUR TESTIMONY IN THIS**  
15 **PROCEEDING?**

16 A. The purpose of my testimony is to discuss Duke Energy Kentucky's natural gas  
17 distribution integrity management program (DIMP) and the federal and state  
18 regulations that drive the Company's mission to provide safe, reliable, and  
19 affordable natural gas distribution service to its customers. I will also provide an  
20 overview of Duke Energy Kentucky's annual capital expenditures for current gas  
21 system integrity, safety, and reliability projects and how the associated capital  
22 expenditures are categorized and prioritized. I then discuss how Duke Energy

1 Kentucky’s proposed Accelerated Service Line Replacement Program (ASRP) is  
2 necessary to fulfill that mission and to comply with state and federal regulations.

**II. DISTRIBUTION INTEGRITY MANAGEMENT PROGRAMS**

3 **Q. PLEASE EXPLAIN WHO REGULATES DISTRIBUTION INTEGRITY**  
4 **MANAGEMENT FOR NATURAL GAS UTILITIES.**

5 A. The DIMP is part of the Pipeline Safety Regulations, CFR Part 192, administered  
6 by the Department of Transportation, Pipeline and Hazardous Materials Safety  
7 Administration (PHMSA).

8 **Q. PLEASE IDENTIFY THE REGULATIONS THAT DRIVE DUKE**  
9 **ENERGY KENTUCKY’S DISTRIBUTION INTEGRITY MANAGEMENT**  
10 **INITIATIVES.**

11 A. CFR 192 Subpart P – Gas Distribution Pipeline Integrity Management defines the  
12 required Integrity Management Program as “an overall approach by an operator to  
13 ensure the integrity of its gas distribution system.

14 **Q. WHY IS DISTRIBUTION INTEGRITY MANAGEMENT IMPORTANT?**

15 A. As stated previously, distribution integrity management is an overall approach to  
16 ensure the integrity (*i.e.* safety) of the gas distribution system. These regulations  
17 impose upon the Company an obligation to continuously evaluate the reliability of  
18 its distribution system and to maintain and improve its safety and performance.

19 **Q. PLEASE DESCRIBE DUKE ENERGY KENTUCKY’S CURRENT DIMP.**

20 A. Duke Energy Kentucky’s DIMP is summarized in a written document that meets  
21 all the requirements of CFR 192 Subpart P – Gas Distribution Pipeline Integrity  
22 Management and follows the following seven elements outlined in the regulation:

- 1           1)     Knowledge of the gas distribution system;
- 2           2)     Identify threats;
- 3           3)     Evaluate and rank risk;
- 4           4)     Identify and implement measures to address risks;
- 5           5)     Measure performance, monitor results, and evaluate effectiveness;
- 6           6)     Periodic evaluation and improvement; and
- 7           7)     Report results.

8           These elements support the basis of the DIMP and provide direction in evaluating  
9           initiatives to reduce risks in the distribution system.

10   **Q.   PLEASE EXPLAIN HOW DUKE ENERGY KENTUCKY IDENTIFIES,**  
11       **DESIGNS, PRIORITIZES, AND IMPLEMENTS PROJECTS BASED ON**  
12       **ITS DIMP.**

13   **A.**   Duke Energy Kentucky identifies, evaluates, and ranks risks in its distribution  
14       system and prioritizes measures to address these risks based on a relative risk  
15       model that takes into consideration threats to the system as defined in CFR  
16       192.1007, which include corrosion, natural forces, excavation damage, material,  
17       weld or joint failure, incorrect operation, and other concerns that would threaten  
18       the integrity of the pipeline. The method used to determine the risk in Duke  
19       Energy Kentucky's distribution system is based on the relative risk associated  
20       with repaired leaks. This risk is then aggregated for the entire system. The model  
21       is configured to utilize consequence values and a probability of one for each  
22       individual leak repair. Risk is calculated for each repair along with the inclusion  
23       of facility and location data. Individual leak risk is then summed up to develop

1 risk scores at a system level. Threats with the highest total risk scores are then  
2 reviewed to determine appropriate measures to reduce and/or eliminate the risk.

3 Attachment JH-1 is a true and accurate copy of a summary of how the  
4 relative risk is developed under the DIMP.

5 **Q. HAS DUKE ENERGY KENTUCKY IMPLEMENTED ANY OTHER**  
6 **PROGRAMS DESIGNED TO IMPROVE SAFETY AND RELIABILITY?**

7 A. Yes.

8 **Q. PLEASE DESCRIBE THE COMPANY'S OTHER PROGRAMS THAT**  
9 **ADDRESS DISTRIBUTION SYSTEM RELIABILITY.**

10 A. Duke Energy Kentucky has implemented several programs over time to improve  
11 the safety and reliability of our distribution system. The most noteworthy of these  
12 programs was its accelerated main replacement program (AMRP). The AMRP  
13 began in 2001, when Duke Energy Kentucky, with the approval of the Kentucky  
14 Public Service Commission, implemented a ten-year replacement program for  
15 certain of its gas mains that were considered high risk for leak or failure (cast iron  
16 and bare steel). The AMRP initiative also included certain leak-prone service  
17 lines that were attached to the gas mains targeted for replacement. The AMRP  
18 however, did not include replacement of all leak-prone service lines. Only those  
19 service lines that were directly attached to mains targeted for replacement under  
20 the AMRP were replaced.

21 The Company has also implemented a riser replacement program to  
22 replace service head adapters that had a high likelihood of leakage. Additionally,  
23 the Company has several other initiatives to enhance the safety of its delivery


1 system, as well as public education campaigns to increase customer awareness of  
2 natural gas safety.

3 **Q. PLEASE QUANTIFY THE IMPACT DUKE ENERGY KENTUCKY'S**  
4 **DISTRIBUTION INTEGRITY MANAGEMENT PROGRAMS, AND ITS**  
5 **PREVIOUS AMRP INITIATIVE, HAVE HAD UPON THE COMPANY'S**  
6 **SAFETY AND RELIABILITY.**


7 A. In 2010, Duke Energy Kentucky completed its AMRP as predicted, on time and  
8 on budget. As expected, as a direct result of the AMRP, Duke Energy Kentucky  
9 experienced a decrease in the number of leaks on its gas mains. However, the  
10 Company did not see a similar decrease in the number of leaks in either the main-  
11 to-curb or curb-to-meter distribution service lines.

12 As described previously, the risk model for the distribution integrity  
13 program provides a relative basis to compare risk in the distribution system.  
14 These system risks over time are quantified in the table following:






1                    Although the total risk score for the Duke Energy Kentucky system has  
 2                    dropped significantly since 2002, mainly due to the reduction of leaks associated  
 3                    with cast iron and bare steel that was replaced as part of AMRP, the continued  
 4                    leaks related to corrosion (mainly copper services) place it as the second highest  
 5                    threat behind excavation damage as shown in the following table:



1           The need to address this issue from a safety, reliability, and overall  
 2 integrity management perspective is the driver of the Company's application in  
 3 this proceeding.

4 **Q. ARE THERE RISKS ASSOCIATED WITH A SERVICE LINE LEAK?**

5 A. Yes. As described previously, Duke Energy Kentucky uses a risk model to  
 6 determine the relative risk and rank of each threat. Using this process as outlined  
 7 in the Company's Distribution Integrity Plan, the threat of corrosion related leaks  
 8 on services ranks in the top three categories of system risks along with excavation  
 9 damage and leaks on equipment.



1                   Based on this information and as required by DIMP regulations, Duke  
 2                   Energy Kentucky has already begun a program to replace these leak-prone service  
 3                   lines.

4                   Anytime there is a natural gas leak, there is a potential hazardous  
 5                   condition. Service lines operate at the same pressure as gas mains and are  
 6                   generally physically located closer in proximity to a customer premises. Although  
 7                   actual incidents of a catastrophic failure attributed to a service line may be fewer  
 8                   than those associated with a natural gas main, the possibility of damage and risk  
 9                   to life and property in the event of a catastrophic failure is the same. In Duke  
 10                  Energy Kentucky’s opinion, just because statistics may show that on a national  
 11                  level, the number of catastrophic events attributed to a service line failure is less  
 12                  than that of a gas main, one should not diminish or disregard the prudence of  
 13                  taking immediate action for the elimination or mitigation of these risks or any  
 14                  such risk. Duke Energy Kentucky values its customers and its goal is to take  
 15                  necessary steps to provide safe natural gas service in all facets of its operations.

**III. DUKE ENERGY KENTUCKY'S CAPITAL BUDGETING AND EXPENDITURES**

1 **Q. HOW DOES THE GAS OPERATIONS GROUP DETERMINE WHAT**  
2 **CAPITAL EXPENDITURES WILL BE MADE IN ANY GIVEN YEAR?**

3 A. Duke Energy Kentucky prepares a range of budget forecasts as part of the overall  
4 capital planning process. The projects are prioritized by year based on input from  
5 sources across Gas Operations, including Project Sponsors, Field & System  
6 Operations and Integrity Management. The capital planning process is updated  
7 annually and approved by executive management.

8 **Q. ONCE DUKE ENERGY KENTUCKY HAS DECIDED ON A BUDGET**  
9 **FOR CAPITAL EXPENDITURES, HOW ARE THOSE EXPENDITURES**  
10 **CATEGORIZED?**

11 A. The capital budget is generally categorized into four main groups: 1) Expansion,  
12 2) Maintenance, 3) Recoverables, and 4) Major Projects. The general definitions  
13 are as follows:

14 1) Expansion: Generally includes projects with Allowance of Funds  
15 Used During Construction (AFUDC) that are not included in 'Recoverable' and  
16 have limited regulatory lag or deferral opportunities. Includes projects adding  
17 Mega Watts, revenue producing projects, and acquisitions.

18 2) Maintenance: Includes all non-Recoverable, non-Expansion, and  
19 non-Major Projects capital. Maintenance would generally include minimal to no  
20 AFUDC and carries regulatory lag implications.

21 3) Recoverables: Defined as items that are recovered outside of  
22 normal base rates that (a) have a specific clause/rider/tracker or (b) are deemed

1           probable for future regulatory treatment that would result in a clause/rider/tracker  
2           where there is often no or limited regulatory lag.

3                     4)     Major Projects: Includes large projects (greater than \$25 Million)  
4           that are garnering AFUDC that are not in Recoverable or Expansion.

5   **Q.   EXPLAIN HOW THE COMPANY PLANS AND PRIORITIZES ITS**  
6   **CAPITAL PROJECTS.**

7   A.   Projects are prioritized based upon the Company's risk assessment and in  
8       consideration of the category or nature of projects such as safety and system  
9       integrity, customer request and general maintenance.

10 **Q.   PLEASE SUMMARIZE THE COMPANY'S RECENT ANNUAL**  
11 **BUDGETS FOR CAPITAL PROJECTS.**

12 A.   The Company's recent budgets for capital projects are summarized in the  
13       following table:

<b>Kentucky Capital</b>			
	<b>Actual</b>	<b>Budget</b>	<b>Variance</b>
Recoverable	-	-	-
Expansion	1,870,878.80	4,151,714.00	2,280,835.20
Maintenance	11,357,890.20	8,553,982.00	(2,803,908.20)
Investment	-	-	-
<b>2011 Total</b>	<b>13,228,769.00</b>	<b>12,705,696.00</b>	<b>(523,073.00)</b>
Recoverable	-	-	-
Expansion	2,082,739.80	3,187,942.00	1,105,202.20
Maintenance	11,862,080.20	9,811,759.00	(2,050,321.20)
Investment	-	-	-
<b>2012 Total</b>	<b>13,944,820.00</b>	<b>12,999,701.00</b>	<b>(945,119.00)</b>
Recoverable	-	-	-
Expansion	2,219,494.38	3,502,602.19	1,283,107.81
Maintenance	8,550,709.41	6,265,910.68	(2,284,798.73)
Investment	-	-	-
<b>2013 Total</b>	<b>10,770,203.79</b>	<b>9,768,512.87</b>	<b>(1,001,690.92)</b>
Recoverable	-	-	-
Expansion	2,589,341.39	3,275,111.12	685,769.73
Maintenance	5,768,082.20	10,943,239.27	5,175,157.07
Investment	-	-	-
<b>2014 Total</b>	<b>8,357,423.59</b>	<b>14,218,350.39</b>	<b>5,860,926.80</b>
Recoverable	-	-	-
Expansion	866,045.51	865,303.68	(741.83)
Maintenance	1,263,427.81	2,764,723.23	1,501,295.42
Investment	-	-	-
<b>April 2015 YTD</b>	<b>2,129,473.32</b>	<b>3,630,026.91</b>	<b>1,500,553.59</b>

1 Q. HAVE DUKE ENERGY KENTUCKY'S ACTUAL CAPITAL  
2 EXPENDITURES BEEN CONSISTENT WITH THE COMPANY'S  
3 BUDGETS?

4 A. Yes.

5 Q. PLEASE EXPLAIN.

6 A. Duke Energy Kentucky's annual budgeted versus actual expenditures have been  
7 consistent and within 10% each year except 2014, when several large projects  
8 were delayed, cancelled, or rebudgeted to be Duke Energy Ohio only projects.

#### IV. ASRP

1 **Q. PLEASE PROVIDE A BRIEF OVERVIEW OF THE COMPANY'S ASRP**  
2 **PROPOSAL.**

3 A. Based upon the risks I previously discussed and in recognition of federal integrity  
4 management requirements for natural gas distribution systems, most notably rules  
5 promulgated by PHMSA, Duke Energy Kentucky is proposing to implement a  
6 five-year ASRP initiative to immediately and expeditiously address a safety risk  
7 identified in the DIMP. As discussed previously, the second highest relative risk  
8 is associated with corrosion leaks (2012 - 2014) with a majority occurring on  
9 service lines. The Company proposes to address this risk through a targeted and  
10 deliberate replacement of these at-risk facilities for the benefit of all customers  
11 and the public.


12 **Q. IF THE ASRP IS THE SECOND HIGHEST RELATIVE RISK**  
13 **IDENTIFIED IN THE DIMP, WHAT WAS THE FIRST, AND IS THE**  
14 **COMPANY CURRENTLY ADDRESSING THAT RISK?**

15 A. The highest relative risk to the Company's gas delivery system that was identified  
16 through the DIMP are leaks associated with damage done to the gas delivery  
17 system due to third-party excavations. Duke Energy Kentucky is, in fact, already  
18 taking steps to proactively address this risk and appreciates the attention the  
19 Commission has given this issue through public service announcements and other  
20 outreach efforts over the years. For each excavation incident, Duke Energy  
21 Kentucky has an investigator who arrives at the incident site to determine fault  
22 and provide education on how to prevent reoccurrence. The Company has

1 increased its public awareness program outreach to include education on  
2 excavation laws and regulations such as "Call Before You Dig." Duke Energy  
3 Kentucky also reaches out to individual contractors and provides specific  
4 education related to excavations near gas facilities. Duke Energy Kentucky meets  
5 monthly with its locating company and contractors to discuss their at-fault  
6 damages and locate issues to avoid repeat occurrences. Duke Energy Kentucky  
7 responds to untoneable services/mains to work toward making them toneable and  
8 has an Inspector on site when an excavator is digging within 25 feet of a  
9 transmission line. Duke Energy Kentucky also promotes April as national Safe  
10 Digging Month by setting up a display table in front of our office to provide  
11 education. The Company participates in excavator seminars and emergency  
12 responder seminars throughout the year to provide education on natural gas mains  
13 and services and safe work practices.

14 These efforts have been fruitful as the number of incidents or leaks due to a third-  
15 party excavation have declined over the last few years. This decrease can be seen  
16 in the graph following which depicts the events per year on M-C and C-M service  
17 piping in each category:





1

2

However, the Company can only do so much in this regard. Local law enforcement authorities must also be willing to enforce the laws and regulations of the Commonwealth, which include any penalties associated with these third-party excavators failing to follow the rules and causing hazardous situations when they damage the gas facilities.

7

While the incidents due to third-party excavation are declining; the leaks related to corrosion continue. These metallic type pipe materials will continue to corrode overtime unless replaced.

9

1 **Q. PLEASE EXPLAIN THE NEED FOR THE ASRP FROM A SAFETY AND**  
2 **RELIABILITY PERSPECTIVE.**

3 A. The ASRP is the proposed measure to address risks to the natural gas delivery  
4 system identified in the Company's DIMP. As required in the regulations, once a  
5 risk is identified, the Company must respond to and address the risk. The ASRP is  
6 the Company's preferred method to address the risk to the delivery system created  
7 by these leak-prone services. Replacing these services in an accelerated and  
8 targeted manner will reduce the number of incidents by eliminating the root cause  
9 of the leaks and reduce the exposure to increased failures as these services  
10 continue to age. An accelerated approach allows the Company to manage costs in  
11 a way to perform the work over the next few years, rather than decades, and in an  
12 efficient manner by targeting an entire area at once, as opposed to a more  
13 expensive reactive approach.

14 **Q. IS THE ASRP ACTUALLY REQUIRED UNDER BY PHMSA OR UNDER**  
15 **ITS DIMP REGULATIONS?**

16 A. PHMSA does not mandate any specific remedial actions. PHMSA is the federal  
17 agency that, among other things, oversees transportation of natural gas through  
18 pipelines. To do this, PHMSA establishes national policy, sets and enforces  
19 standards, educates, and conducts research to prevent incidents. The DIMP  
20 procedural regulation is the tool used by PHMSA to require utilities to develop,  
21 maintain, and follow an integrity management program to maintain the safety and  
22 integrity of their gas delivery systems. The DIMP regulation essentially requires  
23 utilities to continually evaluate their delivery systems for risks and to develop

1 immediate strategies to address those risks. The evaluation is done in accordance  
2 with the seven factors I previously discussed. So, while neither DIMP nor  
3 PHMSA require any specific type of action or replacement activity, nonetheless,  
4 under DIMP, once a utility identifies a risk using the DIMP evaluation or  
5 “elements,” it must then manage its system accordingly, which includes  
6 addressing and correcting the identified risk(s). Therefore, now that the Company  
7 has identified the risks associated with these service lines, the Company must  
8 address these risks under DIMP. The ASRP is the safest and most cost-effective  
9 way to respond to these identified risks and protect customers by methodically  
10 replacing these services and taking ownership as soon as possible.

11 **Q. IN YOUR OPINION, DOES REPLACING THESE AT RISK SERVICE**  
12 **LINES UNDER THE CURRENT TIME LINE ADEQUATELY RESPOND**  
13 **TO THE IDENTIFIED RISK UNDER DIMP?**

14 **A.** No. These services are already identified as a system risk as the leaks identified  
15 are increasing. Under DIMP, the Company must now take action. However, it  
16 cannot do so on a widespread basis without Commission approval. The identified  
17 pattern of service line leaks will only increase as time goes on and these systems  
18 continue to age and are exposed to corrosive forces. Replacing these services  
19 under the current schedule of approximately 200 per year is, and will continue to  
20 be, inadequate to respond to this growing level of risk. At that rate, it would take  
21 approximately 50 years for the Company to replace these services. As a Kentucky  
22 resident, and Duke Energy Kentucky customer, I want my utility to be proactive

1 to address potential weaknesses on its system before a hazardous situation  
2 develops.

3 **Q. PLEASE EXPLAIN HOW THE ASRP IS CONSISTENT WITH**  
4 **INDUSTRY INITIATIVES AND BEST PRACTICES.**

5 A. The 2012 report by the American Gas Foundation titled “Gas Distribution  
6 Infrastructure: Pipeline Replacements and Upgrades” describes then United States  
7 Secretary of Transportation Ray LaHood’s “Pipeline Safety Action Plan” calling  
8 for pipeline operators, including local natural gas distribution companies, to  
9 accelerate their efforts to replace pipeline facilities and take other actions that will  
10 enhance the integrity of network facilities This ASRP aligns with the “Call to  
11 Action” for the industry, as well as similar programs undertaken by other natural  
12 gas local distribution companies.

13 **Q. IS THERE ANY QUANTATIVE ANALYSIS THAT SUPPORTS THE**  
14 **NEED FOR THE COMPANY’S ASRP INITIATIVE?**

15 A. Yes. Duke Energy Kentucky performed a detailed review of its own operation and  
16 maintenance practices, including the leak rates for the different types of service  
17 materials. Duke Energy Kentucky has also retained Lummus Consultants  
18 (Lummus) to independently review the background, operation, and maintenance  
19 of the Company’s proposed ASRP program. As explained in the Lummus Study  
20 (Application, Exhibit 4) and Direct Testimony of Edward A. McGee, Duke  
21 Energy Kentucky has seen an increase in the number of leaks along its natural gas  
22 delivery system associated with service lines. This increase in service leaks and  
23 decrease in main leaks attributable to the successful implementation of the

1 AMRP, is highlighted in successive DIMP risk assessment results. In other  
2 words, service leak rates are increasing and must be addressed as required by the  
3 DIMP.

4 The Lummus Study shows that, upon completion of the Company's  
5 AMRP in 2010, the Company did experience a reduction in the number of leaks  
6 along its gas mains. However, the Company is now seeing an increase in the  
7 number of leaks along its distribution system that are located within the curb-to-  
8 main and main-to-curb service lines.

9 **Q. PLEASE EXPLAIN HOW THE ASRP IS BOTH CONSISTENT AND IN**  
10 **COMPLIANCE WITH THE REGULATIONS YOU PREVIOUSLY**  
11 **DISCUSSED.**

12 A. As stated earlier, the Company's DIMP is consistent with CFR 192 Subpart P –  
13 Gas Distribution Pipeline Integrity Management, that defines the required  
14 Integrity Management Program as “an overall approach by an operator to ensure  
15 the integrity of its gas distribution system.” Leak rates on non-protected metallic  
16 services have been identified as a risk in the Company's distribution system and  
17 the ASRP is the proposed measure to address this risk as required in the  
18 regulations.

19 **Q. WHAT IS THE ESTIMATED COST OF CONSTRUCTION FOR THE**  
20 **ASRP PER YEAR AND IN TOTAL?**

21 A. The current estimated cost of construction is \$50M broken down as follows: 2016  
22 (\$5M), 2017 (\$12M), 2018 (\$13M), 2019 (\$13M), and 2020 (\$7M).

1 **Q. WHAT IS THE ESTIMATED COST OF OPERATION OF THE NEW**  
2 **SERVICES ONCE THE PROGRAM IS COMPLETED?**

3 A. In terms of Operations and Maintenance expense, there are no incremental  
4 operating costs associated with ASRP once the program is completed. Once  
5 installed, these new service lines will constitute new plant in service and  
6 eventually will be rolled into base rates at the time of the Company's next base  
7 natural gas rate case.

8 **Q. HOW WERE THESE ESTIMATES DERIVED?**

9 A. Duke Energy Kentucky has estimated that approximately 10,000 service lines will  
10 need to be replaced during the five-year ASRP. The approximate cost per service  
11 replacement is, on average, \$5,000 over the five year program. The number of  
12 services is based upon Company records and is depicted in the Lummus Study.  
13 Estimated costs for replacing services are based upon current actual costs for  
14 similar replacements completed as part of AMRP in Ohio and current service  
15 replacement programs in Ohio and Kentucky.

16 **Q. HOW DOES THE COMPANY PROPOSE TO MANAGE THE COSTS OF**  
17 **THE PROGRAM?**

18 A. Work will be performed by both internal and external resources. The external  
19 work will be competitively bid in packages (by communities) to pre-qualified  
20 contractors. The bids are reviewed against historical costs and other factors by  
21 Duke Energy Kentucky's sourcing department, the Project Manager, and the  
22 Manager of Contractor Construction, with a final approval from me as the

1 Director of Engineering. The costs are then tracked on a monthly basis to ensure  
2 actual expenditures are in line with budgets.

**V. FILING REQUIREMENT SPONSORED BY WITNESS**

3 **Q. PLEASE DESCRIBE THE FILING REQUIREMENTS CONTAINED IN**  
4 **THE COMPANY'S APPLICATION FOR A CERTIFICATE OF PUBLIC**  
5 **CONVENIENCE AND NECESSITY THAT YOU ARE SPONSORING**  
6 **AND SUPPORTING.**

7 A. I sponsor the need for the program in response to 807 KAR 5:001, Section  
8 15(2)(a) and the estimated annual cost of the operation upon completion of  
9 construction.

**VI. CONCLUSION**

10 **Q. DO YOU HAVE AN OPINION AS TO WHETHER THE ASRP IS**  
11 **REASONABLE AND NECESSARY FROM A DISTRIBUTION**  
12 **INTEGRITY MANAGEMENT STANDPOINT?**

13 A. Yes, as stated previously, the DIMP regulations require natural gas operators such  
14 as Duke Energy Kentucky to implement the seven required program elements,  
15 which include among other tasks, evaluating/ranking risks and then implementing  
16 measures to address these risks. The ASRP will significantly reduce the risk of  
17 corrosion leaks which has been identified as the second highest relative risk in the  
18 DIMP based on a three-year (2012-2014) review of leak data.

19 **Q. WAS ATTACHMENT JH-1 PREPARED BY YOU OR UNDER YOUR**  
20 **DIRECTION AND CONTROL?**

21 A. Yes.

1 Q. DOES THIS CONCLUDE YOUR PRE-FILED DIRECT TESTIMONY?


2 A. Yes.



**VERIFICATION**

STATE OF OHIO )  
 ) SS:  
COUNTY OF HAMILTON )

The undersigned, John A. Hill Jr., in his capacity as Director of Engineering, Gas Operations for Duke Energy Kentucky, Inc., being duly sworn, deposes and says that he has personal knowledge of the matters set forth in the foregoing testimony, and that the answers contained therein are true and correct to the best of his knowledge, information and belief.

  
\_\_\_\_\_  
John A. Hill, Jr., P.E. Affiant  
Director of Engineering  
Gas Operations  
for Duke Energy Kentucky, Inc.

Subscribed and sworn to before me by John Hill on this 30 day of June 2015.

  
\_\_\_\_\_  
NOTARY PUBLIC

My Commission Expires:





Distribution Integrity Management Plan  
APPENDIX A

RISK MODEL CONFIGURATION

APPENDIX A – RISK MODEL CONFIGURATION

**Risk Model**

- A. The method used to determine the risk in Duke Energy's distribution system is based on the relative risk associated with repaired leaks. This risk is then aggregated for the entire system. The model is configured to utilize the consequence values detailed below and a probability of one for each individual leak repair. Risk is calculated for each repair along with the inclusion of facility and location data. As an example: if a leak occurred on an intermediate pressure main that was a grade 1 leak, then the risk associated with the pressure would be 40 and the grade would be 10. Individual leak risk is then summed up to develop risk scores at a system level.
- B. The total risk associated with a specific leak is calculated using the equation below. The weight factors in the risk model are assigned by SME's to give the more hazardous items greater influence on the final score.
- C. Risk Formula

Duke Energy risk model is based on the following risk formula:

$$R_T = 1 + \sum_{i=0}^n (R_{(i)})$$

$$R_{(i)} = P_{(i)} * C_{(i)} \text{ where,}$$

$R_T$  = Risk score per threat

$R_{(i)}$  = Risk score per event

$n$  = Number of events per threat for the reporting year

$P_{(i)}$  = Probability of the event

$C_{(i)}$  = Consequence of the event

$$\text{Risk\_Raw} = ([C\_EventMetric] * [P\_Material] * ((([C\_Pressure] + [C\_Grade] + [C\_Diameter]) * [C\_Proximity]) * [C\_InjuryFatalityRatio]) / 1000)$$

- D. Weight Factors for Threat Probability

The Pipeline Integrity DIMP database contains the count and cause of events experienced by Duke Energy. The weight factors assigned to each cause are determined by SME's based on the likelihood of the cause to result in a serious incident (injury or fatality) per national averages as provided by the Pipeline Hazardous Materials Safety Administration (PHMSA). Additionally, a second probability factor has been established based on material type with values assigned by SME's based upon operating experience. These relative weights were assigned based on the potential for a material to play a significant role in the occurrence of an event.

WHEN [Cause] = 'Excavation Damage' THEN 70

WHEN [Cause] = 'Other' THEN 60

WHEN [Cause] = 'Other Outside Force Damage' THEN 20

WHEN [Cause] = 'Natural Forces' THEN 20

WHEN [Cause] = 'Incorrect Operations' THEN 30

WHEN [Cause] = 'Material and Welds' THEN 20



Distribution Integrity Management Plan  
APPENDIX A

RISK MODEL CONFIGURATION

```
WHEN [Cause] = 'Equipment' THEN 20
WHEN [Cause] = 'Corrosion' THEN 20
WHEN [Cause] = 'Company or Agent Excavation' THEN 70
ELSE 70 END)
```

```
WHEN [Material] = 'Bare Steel' THEN 70
WHEN [Material] = 'Cast Iron' THEN 90
WHEN [Material] = 'Coated Steel' THEN 15
WHEN [Material] = 'Copper' THEN 40
WHEN [Material] = 'Copper Tubing' THEN 40
WHEN [Material] = 'Ductile Iron' THEN 70
WHEN [Material] = 'Plastic' THEN 20
WHEN [Material] = 'Steel' THEN 70
WHEN [Material] = 'Steel Tubing' THEN 15
WHEN [Material] = 'Unknown' THEN 90
ELSE 90 END)
```

E. Weight Factors for Consequence

The factors selected to represent the relative consequence of an event are based on Duke Energy and Industry experience. The master dataset generated in System Knowledge includes a number of attributes associated with each hazardous and non-hazardous leak. Selected attributes have been utilized to derive the consequence associated with the threat determined to be the root cause. The following attributes and incident results were utilized in the determination of consequence.

F. Fatality/Injury ( $F_{VF}$ ): Fatalities and injury data provide a relative representation as to the potential consequence associated with the various cause. National data as provided by PHMSA will be utilized as a means of weighting the potential consequence associated with each cause.

```
WHEN [Cause] = 'Other' THEN 0.25
WHEN [Cause] = 'Other Outside Force Damage' THEN 0.28
WHEN [Cause] = 'Excavation Damage' THEN 0.22
WHEN [Cause] = 'Material and Welds' THEN 0.09
WHEN [Cause] = 'Natural Forces' THEN 0.23
WHEN [Cause] = 'Corrosion' THEN 0.15
WHEN [Cause] = 'Equipment' THEN 0.09
WHEN [Cause] = 'Incorrect Operations' THEN 0.06
WHEN [Cause] = 'Company or Agent Excavation' THEN 0.22
ELSE 0.35 END)
```

G. Code Factor ( $F_c$ ): This factor is used to consider the leak grade in terms of the higher grade leaks releasing more gas to the environment. Grade 1 leaks with pipe wall breaks will be given the highest weight value.

```
WHEN [Class] = 'Grade 1' AND [Pipe Wall Break?]= 'Yes' THEN 75
WHEN [Class] = 'Grade 1' THEN 25
```



## Distribution Integrity Management Plan APPENDIX A

### RISK MODEL CONFIGURATION

```
WHEN [Class] = 'Grade 2' THEN 10  
ELSE 75 END)
```

- H. **Proximity Factor ( $F_{PR}$ ):** This factor is used to consider the proximity of the gas facility to structures where migration from a leak could result in the collection of gas in an enclosed space at explosive concentrations. Mains were considered to be the highest risk due to potential migration under paving and into sewers, service main to curbs were considered to have some of this risk as well. A meter and regulator set, although located in closer proximity to structures than a service, was assigned a lower weight factor as they are generally located above ground which allows any leaks to immediately vent to atmosphere.

```
WHEN [Tier 1 Facility] = 'MAIN' THEN 75  
WHEN [Tier 1 Facility] = 'SERVICE CM' THEN 50  
WHEN [Tier 1 Facility] = 'SERVICE MC' THEN 60  
WHEN [Tier 1 Facility] = 'AGF' THEN 5  
WHEN [Tier 1 Facility] = 'Other' THEN 75  
ELSE 75 END)
```

- I. **Pressure Factor ( $F_p$ ):** This factor is considered as having a direct effect on the consequences associated with any threat based on the operating pressure.

```
WHEN [Pressure] = 'Feeder' THEN 60  
WHEN [Pressure] = 'HP' THEN 40  
WHEN [Pressure] = 'MP' THEN 20  
WHEN [Pressure] = 'SP' THEN 5  
WHEN [Pressure] = 'IP' THEN 40  
ELSE 60 END)
```

- J. **Diameter Factor (FD):** The factor is used to consider the pipe diameter in terms of the larger diameters releasing a larger volume of gas to the environment. The weight factors will be scaled by diameter from smallest to largest.

```
WHEN [Diameter] = '0.25' THEN 10  
WHEN [Diameter] = '0.375' THEN 10  
WHEN [Diameter] = '0.5' THEN 10  
WHEN [Diameter] = '0.75' THEN 10  
WHEN [Diameter] = '1' THEN 20  
WHEN [Diameter] = '1.25' THEN 20  
WHEN [Diameter] = '1.5' THEN 20  
WHEN [Diameter] = '1.75' THEN 20  
WHEN [Diameter] = '2' THEN 30  
WHEN [Diameter] = '2.5' THEN 30  
WHEN [Diameter] = '3' THEN 40  
WHEN [Diameter] = '4' THEN 50  
WHEN [Diameter] = '5' THEN 60  
WHEN [Diameter] = '6' THEN 70  
WHEN [Diameter] = '8' THEN 80
```



Distribution Integrity Management Plan  
APPENDIX A

RISK MODEL CONFIGURATION

---

```
WHEN [Diameter] = '10' THEN 90  
WHEN [Diameter] = '12' THEN 100  
WHEN [Diameter] = '16' THEN 110  
WHEN [Diameter] = '20' THEN 120  
WHEN [Diameter] = '24' THEN 130  
WHEN [Diameter] = '30' THEN 140  
ELSE 140 END)
```

**COMMONWEALTH OF KENTUCKY  
BEFORE THE  
KENTUCKY PUBLIC SERVICE COMMISSION**

In the Matter of:

The Application of Duke Energy Kentucky, )  
Inc., for a Certificate of Public )  
Convenience and Necessity Authorizing )  
the Implementation of an Accelerated )  
Service Line Replacement Program, ) Case No. 2015-00210  
Approval of Ownership of Service Lines, )  
and a Gas Pipeline Replacement Surcharge )

---

**DIRECT TESTIMONY OF**

**EDWARD A. McGEE**

**ON BEHALF OF**

**DUKE ENERGY KENTUCKY, INC.**

---

July 6, 2015

## TABLE OF CONTENTS

	<u>PAGE</u>
<b>I. INTRODUCTION AND PURPOSE .....</b>	<b>1</b>
<b>II. SUMMARY OF FINDINGS AND CONCLUSIONS .....</b>	<b>3</b>
<b>III. OVERVIEW OF SERVICE CONDITION STUDY .....</b>	<b>5</b>
<b>IV. COMPOSITION OF DUKE ENERGY KENTUCKY'S SERVICE LINES ..</b>	<b>6</b>
<b>V. ANALYSIS OF CONDITION OF SERVICE LINES.....</b>	<b>9</b>
<b>VI. COMPARISON OF SAFETY RISK FACTORS ON SERVICE LINES AGAINST RISK FACTORS ON MAINS .....</b>	<b>12</b>
<b>VII. ANALYSIS OF PHMSA RECOMMENDATIONS FOR PIPE REPLACEMENT .....</b>	<b>16</b>
<b>VIII. FINDINGS AND CONCLUSIONS.....</b>	<b>19</b>

### **LIST OF FIGURES**

EAM-1: Number of Services by Material Type for Duke Energy Kentucky (2005-2014).....	7
EAM-2: Duke Energy Kentucky's Leak Rates for Services by Material Type (2014-2014).....	8
EAM-3: Duke Energy Kentucky's Repaired Leaks on Services (repairs per year).....	10
EAM-4: Duke Energy Kentucky's Repaired Leaks on Services (due to corrosion).....	11
EAM-5: Duke Energy Kentucky's Repaired Leaks on Services (due to material and welds).....	12

### **ATTACHMENTS**

Attachment EAM-1 - Ed McGee Academic Vita

**I. INTRODUCTION AND PURPOSE**

1 **Q. PLEASE STATE YOUR FULL NAME, ADDRESS, AND OCCUPATION.**

2 A. My name is Edward A. McGee. My business address is P.O. Box 1659, Bethany  
3 Beach, Delaware. I am a Principal Consultant of McGee Consulting, LLC, and I  
4 am currently working as a Gas Utility Consultant with Lummus Consultants  
5 International, Inc. (Lummus).

6 **Q. COULD YOU PLEASE DESCRIBE LUMMUS?**

7 A. Lummus is an independent company in Chicago Bridge & Iron's (CB&I)  
8 Lummus Technology operating group. Predecessor companies absorbed into the  
9 present-day Lummus include Stone & Webster Management Consultants, Inc.,  
10 and Shaw Consultants International, Inc., both with extensive experience in the  
11 utility consulting industry.

12 **Q. DO YOU HOLD ANY ACADEMIC DEGREES?**

13 A. Yes. I graduated from the University of Notre Dame with Bachelor and Master  
14 Degrees in Chemical Engineering. I also graduated from the University of  
15 Chicago with a Master's Degree in Business Administration (MBA). Attachment  
16 EAM-1 provides my academic vita that includes a listing of my experience as a  
17 gas practice consultant and related positions in the energy industry.

18 **Q. WHAT IS THE SCOPE OF YOUR TESTIMONY IN THIS**  
19 **PROCEEDING?**

20 A. Duke Energy Kentucky, Inc., (Duke Energy Kentucky or the Company) requested  
21 that I provide an expert opinion to the Kentucky Public Service Commission  
22 (Commission) on the current condition of the Company's service lines following



1 an analysis of the service lines conducted by Lummus. I was also asked to render  
2 an opinion on whether a portion of the service lines should be replaced, and if so,  
3 whether they would qualify for an Accelerated Service Replacement Program  
4 (ASRP) where these services are replaced in a more rapid fashion, and whether  
5 the selected service lines are consistent with the examples, recommendations, and  
6 rules provided by the Department of Transportation (DOT) for expeditious  
7 replacement.

8 **Q. WAS THE LUMMUS STUDY OF THE CURRENT CONDITION OF THE**  
9 **COMPANY'S SERVICE LINES CONDUCTED BY YOU?**

10 A. Yes. I directly participated in the Lummus study, called Condition Analysis of  
11 Kentucky Service Lines (Lummus Study), along with the assistance of others  
12 under my direct supervision. A true and accurate copy of the Lummus Study is  
13 included as Exhibit 4 to Duke Energy Kentucky's Application in this proceeding.

14 **Q. HOW IS THE REMAINDER OF YOUR TESTIMONY ORGANIZED?**

15 A. Following the above Introduction, my testimony is organized into the following  
16 sections:

- 17 • Section II: Summary of Findings and Conclusions
- 18 • Section III: Overview of the Service Condition Study
- 19 • Section IV: Composition of Duke Energy Kentucky's Service Lines
- 20 • Section V: Analysis of Condition of Service Lines
- 21 • Section VI: Comparison of Number of Risk Factors on Services Against  
22 Number of Risk Factors on Mains

- 1           • Section VII: Analysis of Pipeline and Hazardous Materials Safety
- 2           Administration (PHMSA) Recommendations for Pipe Replacement
- 3           • Section VIII: Findings and Conclusions

**II.     SUMMARY OF FINDINGS AND CONCLUSIONS**

4   **Q.   PLEASE SUMMARIZE YOUR FINDINGS AND CONCLUSIONS**  
5   **REGARDING THE COMPANY’S SERVICE LINES.**

6   A.   The primary conclusion contained in the Lummus Study is that a small portion  
7       (10,027 services or 10.4% of the total 96,746 services) of the Company’s service  
8       lines require replacement, which consists of services that are the metallic types of  
9       pipe materials.  Additionally, services without adequate records of their type of  
10      material should also be replaced.  This amounts to an additional 689 services, or  
11      0.7% of the total Kentucky service lines.

12 **Q.   CAN YOU STATE THE PRIMARY REASONS WHY THESE SERVICES**  
13 **REQUIRE REPLACEMENT?**

14 A.   A key finding by Lummus was that the number of service line leaks has far  
15      exceeded the number of leaks on mains in recent years.  Also, service leaks  
16      caused by factors such as corrosion or materials and welds have not necessarily  
17      been declining as expected, following the accelerated main replacement program  
18      (AMRP).  These factors directly relate to metallic types of pipe materials that  
19      continue to corrode over time.  The corrosion can result in pinhole leaks on the  
20      wall of the service line, as well as joint leaks where sections of the service line are  
21      fastened together.  For safety reasons, services whose material type cannot be  
22      ascertained require replacement.

1 **Q. ARE THERE OTHER REASONS WHY THESE SERVICES REQUIRE**  
2 **REPLACEMENT?**

3 A. Yes. The proportion of “hazardous”<sup>1</sup> leaks is increasing on service lines,  
4 especially on the portion of the service lines that is closest to buildings.  
5 Accordingly, we conclude that Duke Energy Kentucky has service-line safety  
6 risks that need to be addressed.

7 **Q. HOW ARE RISKS DEFINED?**

8 A. Safety risks include risks to the general public, Company employees, and first  
9 responders. Risks to the general public arise primarily through risks to building  
10 occupants.

11 **Q. CAN THE RISK FACTORS ON SERVICE LINES IN DUKE ENERGY**  
12 **KENTUCKY’S SYSTEM BE COMPARED TO THE RISK FACTORS ON**  
13 **MAINS?**

14 A. Yes. Overall, the Lummus analysis found the number of factors that contribute to  
15 risks on service lines to be:

- 16 • Greater than the number of risk factors on mains in five areas since service  
17 lines have thinner pipe walls, higher frequencies of leaks, higher  
18 frequency of hazardous leaks, closeness to buildings and their occupants,  
19 and incomplete records of age and material types;
- 20 • Less in one area since mains have larger pipe sizes, which contain more  
21 gas; and

---

<sup>1</sup> Hazardous leaks are classified Grade 1 leaks, which represents an indication of leakage presenting an existing or probable hazard to persons or property, and requires immediate repair or continuous action until the conditions are no longer hazardous.

- 1           • About equal in three areas since mileage, age, and pressure levels are  
2           nearly the same for both services and mains.

3   **Q. DID THE LUMMUS STUDY CONTAIN ANY FINDINGS REGARDING**  
4   **THE APPLICABILITY OF AN ACCELERATED SERVICE**  
5   **REPLACEMENT PROGRAM?**

6   A. Yes. We compared the six characteristics of pipes that the Department of  
7   Transportation (DOT) recommends for accelerated replacement programs against  
8   the composition of Duke Energy Kentucky's service lines. Duke Energy  
9   Kentucky's current service lines, particularly their metallic service lines, contain  
10   five of the six characteristics that would suggest that these service lines should  
11   be replaced on a rapid basis.

**III. OVERVIEW OF SERVICE CONDITION STUDY**

12   **Q. CAN YOU DESCRIBE LUMMUS' OBJECTIVES FOR THE SERVICE**  
13   **LINE STUDY?**

14   A. Yes. Lummus was retained by Duke Energy Kentucky to analyze the current  
15   inventory and leak history of service lines in the Company's service territory in  
16   order to develop an independent opinion regarding:

- 17           • Whether Duke Energy Kentucky is having integrity issues with its service  
18           lines;
- 19           • The cause of any identified service line issues;
- 20           • The extent of the identified service line issues especially whether safety is  
21           a concern; and
- 22           • The need for an ASRP.

1 **Q. HOW WAS THE LUMMUS STUDY CONDUCTED?**

2 A. Primarily the study encompassed a detailed analysis of leak repairs contained in  
3 Duke Energy Kentucky's Enterprise Geographical Information System (EGIS)  
4 data base. Leak repairs were categorized by year and by type of material  
5 composing the pipe; cause of each leak requiring repair; portion of the service line  
6 where the leak occurred; and age and pressure of the pipes upon which the leaks  
7 occurred. Additionally, Lummus reviewed Duke Energy Kentucky's Distribution  
8 Integrity Management Plan (DIMP) and the data base of annual gas distribution  
9 reports maintained by the DOT from reports submitted by all gas distribution  
10 utilities, including Duke Energy Kentucky. Lummus also analyzed the  
11 recommendations of the DOT for the development of ASRPs in order to  
12 determine whether the materials that we specified for replacement, were included  
13 in DOT's list of materials to be replaced under accelerated programs.

**IV. COMPOSITION OF DUKE ENERGY KENTUCKY'S SERVICE LINES**


14 **Q. HOW MANY SERVICE LINES ARE IN DUKE ENERGY KENTUCKY'S**  
15 **SERVICE TERRITORY?**

16 A. Duke Energy Kentucky currently operates just over 96,000 service lines in the  
17 Commonwealth of Kentucky. The vast majority of these lines (over 80,000) are  
18 composed of plastic (polyethylene), many of which were installed during Duke  
19 Energy Kentucky's ten-year AMRP program, which ended in 2010.

1 Q. HAS THE COMPOSITION OF MATERIALS USED FOR SERVICE  
2 LINES CHANGED IN RECENT YEARS?

3 A. Yes. Many of Duke Energy Kentucky's metallic service lines were removed from  
4 its system in the ten-year period ending in 2010. This was accomplished  
5 primarily through replacement of service lines that were attached to mains that  
6 were replaced under Duke Energy Kentucky's AMRP. A smaller number of  
7 services have also been removed under Duke Energy Kentucky's annual  
8 replacement policy based on their condition and judged level of obsolescence.  
9 However, a number of service lines (just over 10,000) composed of metallic  
10 materials remain since these were not associated with the replaced mains. The  
11 change in composition in the past ten years is pictured in Figure EAM-1 shown  
12 below:

**EAM-1: Number of Services by Material Type for Duke Energy Kentucky (2005-2014)**




Data Source: Annual DOT Reports, PHMSA Form 7100.1-1

1 Q. DOES EACH MATERIAL TYPE EXHIBIT SIMILAR NUMBERS OF  
2 LEAKS?

3 A. No. Each material has exhibited a separate leak rate. For instance plastic, which  
4 is the predominant service-line material installed by Duke Energy Kentucky in  
5 recent years, has the lowest leak rate and bare steel has the highest leak rate. A  
6 comparison of leak rates over the past five years for each material is shown below  
7 in Figure EAM-2:

**EAM-2: Duke Energy Kentucky's Leak Rates for Services by Material Type (2010-2014)  
(Leaks per Mile per Year)**



Data Source: EGIS Leak Repairs-Grade-State-Suburb-Collection.xlsx

1 Note: The relative order of leak rates by material type shown above is in good  
2 agreement with Federal EPA Greenhouse Gas Emissions data for methane  
3 releases from all U.S. gas distribution service lines.<sup>2</sup>

V. ANALYSIS OF CONDITION OF SERVICE LINES

4 **Q. HAS THE NUMBER OF LEAKS ON THE COMPANY'S SERVICE LINES**  
5 **DECREASED SIGNIFICANTLY FOLLOWING DUKE ENERGY**  
6 **KENTUCKY'S AMRP PROGRAM?**


7 A. No. Leaks on service lines have not shown the significant decrease that has been  
8 accomplished for mains leaks (Please refer to Tables 8 and 9 in the Lummus  
9 Study). Figure EAM-3 shows the history of leaks repaired between 2003 and  
10 2014 on the underground portions of the service lines. Leaks are identified  
11 separately as M-C (leaks that developed on the underground portion of the service  
12 line stretching from the main to the curb box) and C-M (leaks that developed on  
13 the underground portion of the service line leading from the curb box toward the  
14 meter).

---

<sup>2</sup> Reference: [http://www.ecfr.gov/cgi-bin/text-idx?SID=265f0267789d99416d22a4085fdbdc9a%20&node=ap40.21.98\\_1238.10&rgn=div9](http://www.ecfr.gov/cgi-bin/text-idx?SID=265f0267789d99416d22a4085fdbdc9a%20&node=ap40.21.98_1238.10&rgn=div9)



**EAM-3: Duke Energy Kentucky's Repaired Leaks on Services (Repairs per Year)**



Data Source: EGIS Leak Repairs-Grade-State-Suburb-Collection.xlsx

1 Q. DOES FIGURE EAM-3 INDICATE ANY OTHER LEAK TRENDS?

2 A. Yes. Figure EAM-3 also demonstrates that in particular the number of leaks on  
3 the C-M portion of service lines, which is closest to buildings and their occupants,  
4 has grown in proportion to the number of leaks on the M-C portion of service  
5 lines, which is furthest from the buildings.


6 Q. ARE THERE ANY FACTORS CAUSING THE CONTINUING  
7 OCCURRENCE OF LEAKS ON SERVICE LINES?

8 A. Yes. The results indicated that there are two causes of continuing leaks: 1) leaks  
9 due to corrosion and 2) leaks due to materials & welds. Both of these causes may  
10 be related to metallic pipes.

1 Q. CAN YOU SHOW THE CORROSION TRENDS?

2 A. Yes. The latest ten-year trend of corrosion-caused leaks is shown in Figure EAM-  
3 4. In this figure, leaks seem to be increasing in recent years particularly on the C-  
4 M portion of the service-line, which is closest to buildings and their occupants.

**EAM-4: Duke Energy Kentucky's Repaired Leaks on Services  
(due to Corrosion)**




Data Source: EGIS Leak Repairs-Grade-State-Suburb-Collection.xlsx

5 Q. CAN YOU ALSO SHOW THE TRENDS FOR MATERIALS & WELDS?

6 A. Yes. The latest ten-year trend of material & welds-caused leaks is shown in  
7 Figure EAM-5. This figure shows an unstable pattern of leaks over the ten-year  
8 period shown. The number of leaks from this cause of leak did not decline during  
9 the period the AMRP program was undertaken. In the latest two or three years,  
10 leaks from this cause may be starting to decline, but a longer time period may be  
11 required to be certain, due to the unstable patterns exhibited in earlier years.

**EAM-5: Duke Energy Kentucky Repaired Leaks on Services  
(due to Material and Welds)**



Data Source: EGIS Leak Repairs-Grade-State-Suburb-Collection.xlsx

**VI. COMPARISON OF SAFETY RISK FACTORS ON SERVICE LINES  
AGAINST RISK FACTORS ON MAINS**

1 Q. CAN THE NUMBER OF RISK FACTORS ON SERVICE LINES IN DUKE  
2 ENERGY KENTUCKY'S SYSTEM BE COMPARED AGAINST THE  
3 NUMBER OF RISK FACTORS ON MAINS?

4 A. Yes. Overall, the Lummus analysis found the number of risk factors on service  
5 lines to be greater than the number of risk factors on mains in five areas. The  
6 number of risk factors on mains was higher in one area. And the number of risk  
7 factors was about equal in three areas. These risk factors are discussed in the next  
8 four questions.

1 **Q. PLEASE IDENTIFY THE FIVE FACTORS FOUND TO CONTRIBUTE**  
2 **TO A GREATER NUMBER OF RISKS ON SERVICES.**

3 A. Service line risks were found to be greater due to:

- 4 1. Pipe walls are thinner on service lines;
- 5 2. Annual number of leaks is higher on service lines;
- 6 3. Annual number of hazardous leaks is higher on service lines;
- 7 4. Service line piping is closer to buildings than mains piping; and
- 8 5. There are a number of services having unknown ages and unknown  
9 material types.

10 **Q. PLEASE ELABORATE ON THE SIGNIFICANCE OF LUMMUS'S**  
11 **FINDING THAT THERE ARE SEVERAL FACTORS THAT INDICATE**  
12 **SERVICES POSE A GREATER RISK THAN THAT OF GAS MAINS.**

13 A. While all of the aforementioned factors are significant, the location of services to  
14 that of an actual building structure is perhaps the most noteworthy insofar as  
15 potential impact to the general public. These services are attached directly to  
16 homes and businesses such as hospitals, nursing homes, or movie theaters and  
17 therefore, in my mind, pose an even greater potential for harm if a catastrophic  
18 failure occurs. The risk posed by the failure of these services not only affects  
19 Company employees working on the system, but also first responders (fire/police  
20 departments), families, and the unsuspecting public.

1 **Q. PLEASE IDENTIFY THE ONE FACTOR FOUND TO CONTRIBUTE TO**  
2 **GREATER RISKS ON MAINS.**

3 A. Risks on mains were found to be greater due to the greater size (diameter) of the  
4 mains, allowing more gas to be released from a leak in a given amount of time.

5 **Q. PLEASE ALSO IDENTIFY THE THREE FACTORS FOUND TO**  
6 **CONTRIBUTE NEARLY EQUAL RISKS ON BOTH SERVICES AND**  
7 **MAINS.**

8 A. Risks were found to be comparable on both mains and services due to:

- 9 1. Pipe mileage for service lines is comparable to mileage of mains;
- 10 2. Age of service lines is comparable to age of mains; and
- 11 3. Pressure levels are identical on mains and on service lines that are  
12 connected to them.

13 **Q. PLEASE EXPLAIN WHY THIS COMPARISON OF SERVICE LINE RISK**  
14 **FACTORS TO GAS MAIN RISKS FACTORS IS SIGNIFICANT IN YOUR**  
15 **OPINION.**

16 A. This comparison is significant since it helps explain why the majority of leaks  
17 (and the majority of hazardous leaks) are occurring on services as opposed to  
18 mains. Therefore, it is important to not overlook services when replacement  
19 programs are being considered or implemented.

20 **Q. ARE YOU AWARE OF ANY REPORTED INCIDENTS THAT**  
21 **ILLUSTRATE SAFETY PROBLEMS THAT OCCURED WHEN OLDER**  
22 **METALLIC SERVICES WERE NOT REPLACED?**

1 A. Yes. There have been several reported incidents involving hazardous accidents  
2 that occurred on steel service lines. Most noteworthy are recent events in the  
3 greater Dallas/Fort Worth area over a period of several years.<sup>3</sup> These accidents, all  
4 attributed to corrosion on the couplings used in older installations of steel service  
5 lines, reportedly occurred in Wylie, Texas in 2006, in Cleburne, Texas in 2007, in  
6 Mesquite, Texas in 2009, in Irving, Texas in May 2009, in again in Irving in  
7 August, 2010. Two building occupants reportedly died in the Wylie incident, two  
8 more in the Cleburne incident, and two residents were hospitalized with extensive  
9 burns in the most recent Irving explosion. These incidents prompted response by  
10 both the state legislature and regulatory authorities.<sup>4</sup> In fact, the Texas Railroad  
11 Commission, recognizing the risks associated with the failure of natural gas  
12 service lines, adopted a new pipeline safety rule applicable to all regulated natural  
13 gas utilities in the state. The new rule directly addresses the potential risks  
14 associated with service lines and is even more stringent than the federal  
15 government's Gas Distribution Integrity Management rule (49 CFR Subpart P) in  
16 that it mandates the replacement of pipelines or facilities that pose the greatest  
17 potential threats for failure.<sup>5</sup>

18 **Q. FROM A STATISTICAL STANDPOINT, ARE THE NUMBER OF**  
19 **HAZARDOUS LEAKS ATTRIBUTED TO SERVICE LINE FAILURES**  
20 **ON DUKE ENERGY KENTUCKY'S SYSTEM SIGNIFICANT?**

21 A. Yes. Figure 10 in the Lummus Study depicts this.

---

<sup>3</sup> Source: <http://www.wfaa.com/story/news/local/investigates/2014/08/06/13490520/>

<sup>4</sup> *Id.*

<sup>5</sup> <http://www.rrc.state.tx.us/all-news/022511c/>

1 **Q. DO YOU BELIEVE THE LIKELY GAINS IN TERMS OF SAFETY,**  
2 **RELIABILITY AND OVERALL REDUCTION OF NUMBER OF LEAKS**  
3 **ACHIEVABLE THROUGH A FIVE-YEAR REPLACEMENT PROGRAM**  
4 **IS CONSISTENT WITH DOT AND PHMSA RECOMMENDATIONS?**

5 A. Yes. From a risk perspective, considering that the proportion of hazardous leaks  
6 occurring on services is growing and is moving toward the buildings, the sooner  
7 the Company replaces these services, the better. From a pure timing perspective, a  
8 five-year replacement period seems reasonable and within the spirit of DOT and  
9 PHMSA regulations and guidance and is consistent with the Company's prior  
10 capabilities. The services that have been identified and are now targeted for  
11 replacement, would likely be similar in material and age to those replaced as part  
12 of the Company's previous ten-year accelerated main replacement program. The  
13 number of services identified and targeted for replacement currently (approx.  
14 10,000) are less than half of the number of services that were replaced under the  
15 AMRP (approx. 25,000), so a comparable reduction in time would be consistent.

**VII. ANALYSIS OF PHMSA RECOMMENDATIONS FOR PIPE**  
**REPLACEMENT**

16 **Q. DID THE LUMMUS STUDY CONTAIN ANY FINDINGS REGARDING**  
17 **THE APPLICABILITY OF AN ACCELERATED SERVICE**  
18 **REPLACEMENT PROGRAM?**

19 A. Yes. We compared the six characteristics of pipes that the DOT recommends for  
20 accelerated replacement programs against the composition of the service lines we  
21 recommend for replacement by Duke Energy Kentucky. Duke Energy

1 Kentucky's service lines that are proposed for replacement contain five of the six  
2 characteristics recommended for expeditious replacement by the DOT.

3 **Q. WHAT IS PHMSA'S POSITION ON PIPE REPLACEMENT?**

4 A. PHMSA has stated: "We believe that the timely repair, rehabilitation, and  
5 replacement of high-risk gas pipeline infrastructure are critical to ensuring public  
6 safety."<sup>6</sup>

7 **Q. DOES PHMSA APPLY THIS POSITION ON PIPE REPLACEMENT TO  
8 INCLUDE SERVICE LINES?**

9 A. Yes. PHMSA specifically uses the word "infrastructure" – rather than mains or  
10 any other subcategory of infrastructure.

11 **Q. DOES PHMSA ONLY CONSIDER PIPELINE INFRASTRUCTURE THAT  
12 HAS ACTUALLY EXPERIENCED SOME SORT OF LEAK TO  
13 CONSTITUTE A HIGH RISK PIPELINE INFRASTRUCTURE THAT  
14 SHOULD BE REPLACED?**

15 A. No. In general, PHMSA's recommendations and regulations are designed to  
16 identify gas integrity risks and address them before a catastrophic event occurs.  
17 Key to that evaluation is consideration of all aspects of the risks, including, but  
18 not limited to, history of integrity of the system. A thorough review of the history  
19 of piping failures helps guide the response.

20 **Q. HOW DOES PHMSA DEFINE THE TERM "HIGH-RISK GAS PIPELINE  
21 INFRASTRUCTURE" THAT SHOULD BE REPLACED?**

---

<sup>6</sup> <http://opsweb.phmsa.dot.gov/pipelineforum/docs/PHMSA%20111011-002%20NARUC.pdf>



1 A. PHMSA has stated: “High-risk pipeline infrastructure is piping or equipment  
2 that is no longer fit for service. As discussed below, that lack of fitness can be  
3 the product of a variety of factors.

4 1. Cast iron gas mains and service lines can be prone to failure as a result  
5 of graphitization or brittleness.

6 2. Certain vintages of plastic pipe are susceptible to premature failures as a  
7 result of brittle-like cracking.

8 3. Mechanical coupling installations are devices that are used for the  
9 joining and pressure sealing of two pieces of pipe. These devices are  
10 prone to failure under certain conditions.

11 4. Pipelines lacking adequate construction records or assessment results to  
12 verify their integrity.

13 5. Other kinds of pipe installations, including bare steel pipe without  
14 adequate corrosion control (*i.e.*, cathodic protection or coating) and  
15 copper piping, are also more susceptible to failure.

16 6. Age of pipe should be considered in determining whether pipeline  
17 infrastructure is vulnerable to failure from time-dependent forces, like  
18 corrosion, stress corrosion cracking, settlement, embrittlement, or cyclic  
19 fatigue.”<sup>7</sup>

20 These factors are key to evaluating not only the integrity risk itself, but also the  
21 urgency of the need for replacement.

---

<sup>7</sup> Ibid 2.

1 **Q. WHICH OF PHMSA'S SIX CRITERIA FOR REPLACEMENT APPLY TO**  
2 **DUKE ENERGY KENTUCKY'S SERVICE LINES?**

3 A. Our analysis found that the following five of PHMSA's criteria for replacement  
4 apply to Duke Energy Kentucky's service lines:

- 5 1. Cast iron service lines (Duke Energy has one in Kentucky);
- 6 2. Mechanical coupling installations;
- 7 3. Pipelines lacking adequate construction records;
- 8 4. Bare steel pipe without adequate corrosion control (*i.e.*, cathodic  
9 protection or coating) and copper piping; and
- 10 5. Age of pipe.

#### **VIII. FINDINGS AND CONCLUSIONS**

11 **Q. PLEASE STATE YOUR OVERALL FINDINGS AND CONCLUSIONS.**

12 A. The primary conclusion is that a small portion (10,027 services or 10.4% of the  
13 total 96,746 services) of the Company's service lines require replacement. The  
14 services that require replacement are comprised of the metallic types of pipe  
15 materials. Additionally, services without adequate records of their type of  
16 material should be replaced. This amounts to an additional 689 services, or 0.7%  
17 of the total Kentucky service lines.

18 **Q. CAN YOU STATE THE PRIMARY REASONS WHY THESE SERVICES**  
19 **REQUIRE REPLACEMENT?**

20 A. A key finding by Lummus was that the number of service line leaks has far  
21 exceeded the number of leaks on mains in recent years. Also, service leaks  
22 caused by factors such as corrosion or materials and welds, have not necessarily

1           been declining as expected, following the AMRP. These factors directly relate to  
2           metallic types of pipe materials that continue to corrode over time. The corrosion  
3           can result in pinhole leaks on the wall of the service line, as well as joint leaks  
4           where sections of the service line are fastened together. For safety reasons,  
5           services whose material type cannot be ascertained also require replacement.

6   **Q.   ARE THERE OTHER REASONS WHY THESE SERVICES REQUIRE**  
7   **REPLACEMENT?**

8   A.   Yes. We compared the number of safety risk factors for services against the  
9           number for mains and determined that the number of risk factors on services is  
10          greater than the number on mains. Specifically, risks were greater for services in  
11          five safety areas:

- 12           1. Pipe walls are thinner on service lines;
- 13           2. Annual number of leaks is higher on service lines;
- 14           3. Annual number of hazardous leaks is higher on service lines;
- 15           4. Service line piping is closer to buildings than mains piping; and
- 16           5. There are a number of services having unknown ages and unknown  
17           material types.

18           These five factors compare against only one risk factor that is greater for mains  
19           due to the larger main pipe sizes; and three risk factors that are about equal for  
20           services and mains for mileage, age, and pressure levels.

21   **Q.   IN YOUR OPINION WOULD DUKE ENERGY KENTUCKY'S**  
22   **PROPOSED REPLACEMENT PROGRAM FOR KENTUCKY SERVICE**  
23   **LINES BE CONSISTENT WITH PHMSA'S RECOMMENDATIONS?**

1 A. Yes. Lummus Consultants found that the following five PHMSA criteria for  
2 replacement would apply to Duke Energy Kentucky's proposed service line  
3 replacement program:

- 4 1. Cast iron service lines (Duke Energy has one in Kentucky);
- 5 2. Mechanical coupling installations;
- 6 3. Pipelines lacking adequate construction records;
- 7 4. Bare steel pipe without adequate corrosion control (i.e., cathodic  
8 protection or coating) and copper piping; and
- 9 5. Age of pipe.

10 Additionally, considering that hazardous leaks are increasing on the portion of  
11 services nearest a building and its occupants, the sooner these service lines are  
12 replaced, the better. Given these factors and for the reasons articulated throughout  
13 the Lummus Study, a customized response, where these services are replaced in  
14 an expeditious manner is appropriate, warranted and supportable under federal  
15 regulations and guidance in the interests of safety and from an overall integrity  
16 management perspective.

17 **Q. WAS ATTACHMENT EAM-1 AND THE LUMMUS STUDY CONTAINED**  
18 **IN EXHIBIT 4 TO THE COMPANY'S APPLICATION PREPARED BY**  
19 **YOU OR UNDER YOUR DIRECTION AND CONTROL?**

20 A. Yes.


21 **Q. DOES THIS CONCLUDE YOUR PRE-FILED DIRECT TESTIMONY?**

22 A. Yes.


VERIFICATION

STATE OF DELAWARE )  
 )  
COUNTY OF SUSSSEX ) SS:

The undersigned, Edward A. McGee, being duly sworn, deposes and says that he has personal knowledge of the matters set forth in the foregoing testimony, and that the answers contained therein are true and correct to the best of his knowledge, information and belief.

  
Edward A. McGee, Affiant

Subscribed and sworn to before me by Edward A. McGee on this 26<sup>th</sup> day of June 2015.

  
NOTARY PUBLIC

My Commission Expires:

JOHN A. BARRETT  
Notary Public  
State of Delaware  
My Commission Expires on Oct. 31, 2017

**PROFESSIONAL CAREER**

2012 - present      **Lummus Consulting International, Inc.**  
Gas Utility Consultant

As a Gas Utility Consultant for Lummus Consulting, I am responsible for assisting in studies performed in the gas utility and other energy areas.

1999 - present      **McGee Consulting**  
Principal Consultant and Engineer – Energy Industry

As Principal Consultant and Engineer I am responsible for assisting larger consulting firms in their studies performed in the utility field.

1985 - 1999      **Stone & Webster Management Consultants, Inc.**  
Vice President/Director

As Vice President of Stone & Webster Management Consultants, I was responsible for consulting studies in the Gas Practice area, where I performed consulting analyses in the gas planning and gas operations areas for gas utility companies and public utility commissions.

1982 - 1985      **Stone & Webster Engineering Corporation**  
Business Development Manager

As Business Development Manager at Stone & Webster Engineering Corp., I was responsible for the construction of investment models for feasibility studies on large-scale chemical and refining complexes.

1982 & earlier      **W. R. Grace & Co.**  
Director of Energy Resources  
Manager of Chemical Development

As Director of Energy Resources for W. R. Grace, I advised the Chief Operating Officer on corporate energy consumption and production. I also assisted operating divisions in securing long-term energy resources.

As Manager of Chemical Development at W. R. Grace, I analyzed potential acquisition targets in specialty chemical and high technology fields, developing corporate strategies for selected expansions.

**AMOCO Oil**

Supervisor of Technical Computer Programming  
Internal Operations Research Consultant

In a variety of engineering and computer modeling capacities at AMOCO Oil, directed a staff of professionals in the development of technical programs in the refining, distribution and marketing areas.

**EDUCATION**

**University of Chicago**, Master of Business Administration, Quantitative Analysis and Computers

**University of Notre Dame**, Master of Science in Chemical Engineering

**University of Notre Dame**, Bachelor of Science in Chemical Engineering

**LICENSES & CERTIFICATES**

Licensed Professional Engineer - State of Indiana (Expired)

U.S. Patent Holder - Refinery Treating Process

**PROFESSIONAL AFFILIATIONS**

American Institute of Chemical Engineers

The Institute of Management Sciences

**SAMPLE PUBLICATIONS AND PAPERS**

"Using a Personal Computer as a Gas Supply Planning Tool." Gas Industries lead article.

"Personal Computers and the Natural Gas Industry." Public Utilities Fortnightly.

"Personal Computer-Based Long-Range Planning for Natural Gas Development and Supply Management." Presented at the International Gas Union's 18th World Gas Conference, Berlin, Germany.

"Role of Optimization Models in Dispatching Gas Supplies." Presented at AGA Distribution/Transmission Conference, Toronto, Canada.

"Experience With Gas Supply Optimization Models at Inland Natural Gas." Presented at IGT symposium on Personal Computers in the Gas Industry, Chicago, Illinois.