COMMONWEALTH OF KENTUCKY

BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

AN EXAMINATION OF THE APPLICATION OF)
THE FUEL ADJUSTMENT CLAUSE OF) CASE NO.
KENTUCKY UTILITIES COMPANY FROM) 2017-00003
NOVEMBER 1, 2014 THROUGH OCTOBER 31, 2016)

RESPONSE OF KENTUCKY UTILITIES COMPANY TO COMMISSION STAFF'S SECOND REQUEST FOR INFORMATION IN COMMISSION'S ORDER DATED MARCH 6, 2017

FILED: March 20, 2017

VERIFICATION

COMMONWEALTH OF KENTUCKY

COUNTY OF JEFFERSON

The undersigned, Charles R. Schram, being duly sworn, deposes and says that he

is Director - Power Supply, for LG&E and KU Services Company, and that he has

personal knowledge of the matters set forth in the responses for which he is identified as

the witness, and the answers contained therein are true and correct to the best of his

information, knowledge and belief.

Murles A Ochn

Subscribed and sworn to before me, a Notary Public in and before said County

and State, this Ath day of March 2017.

Jelly Schooler (SEAL)

Notary Public

My Commission Expires: JUDY SCHOOLER

Notary Public, State at Large, KY

My commission expires July 11, 2018

Notary ID # 512743

KENTUCKY UTILITIES COMPANY

Response to Commission Staff's Second Request for Information in Commission's Order Dated March 6, 2017

Case No. 2017-00003

Question No. 1

Witness: Charles R. Schram

- Q-1. Refer to KU's response to the Commission's February 6, 2017, Request for Information, Item 42.
 - a. Refer to pages 1-2. Confirm that KU classifies an outage meeting the definition of "Maintenance Outage" as a scheduled outage.
 - b. Refer to page 2. Confirm that KU classifies an outage meeting the definition of any of the three "Unplanned (Forced) Outage" categories listed on this page as a forced outage.
- A-1. a. Confirmed. Consistent with the Generating Availability Data System ("GADS") guidelines, KU classifies an outage meeting the GADS definition of "Maintenance Outage" as a scheduled outage.
 - b. Confirmed. KU classifies an outage meeting the definition of any of the three GADS categories for "Unplanned (Forced) Outage" as a forced outage.