



Attachment 7

WESTERN LEWIS-RECTORVILLE WATER AND GAS DISTRICT
FLUSHING/LEAK REPORT

Date	Time	Location/Description	Gallons Leaked/Flushed	Minutes Flushed	Chlorine Reading	Additional Information
5-15-18	9:30 AM	Kelly Walker Garage Fire hydrant			F1.63	
5-15-18	9:45	Davenport Rd Fire hydrant			F1.66	
5-15-18		8232 Orangeburg Rd Fire hydrant				
5-15-18	10:15	Stone Lick 8298 Fire hydrant				
5-15-18	10:30	Stone Lick 8373 Fire hydrant				
5-15-18	10:45	Mt. Carmel Rd 7135 Fire Hydrant				
5-15-18	11:20	Hill Hill Rd Fire hydrant			1.22	
5-15-18	12:00	Marathon Double A Fire hydrant				
5-15-18	13:30	Emerson Drive Hydrant				
5-15-18	13:30	9501 Meson Lewis Fire hydrant				
5-15-18	14:00	9022 Spring Dale Fire hydrant				
5-15-18	14:10	9595 Meson Lewis Rd				
5-15-18	14:20	Top of Owl Hill Fire hydrant				
5-16-18	10:45	Locust Drive Fire hydrant				
5-16-18	11:10	Bluff St Andrew Place				
5-16-18		Shura Hampton Fire hydrant				
5-16-18		7032 Dwyer Lane Bluff St-P				



Attachment

UNITED STATES DEPARTMENT OF THE INTERIOR
BUREAU OF LAND MANAGEMENT

Section	Range	Township	County	State	Acres	Notes
36	12N	23E	Garfield	CO	40.00	Section 36, Range 12 North, Township 23 East, Garfield County, Colorado. Containing 40.00 acres of land.
37	12N	23E	Garfield	CO	40.00	Section 37, Range 12 North, Township 23 East, Garfield County, Colorado. Containing 40.00 acres of land.

APPROVED FOR THE SECRETARY OF THE INTERIOR
BY: [Signature]

DATE: 10/10/2007

FILE NO. 100-100000-1000

SECTION 36 & 37, RANGE 12 NORTH, TOWNSHIP 23 EAST, GARFIELD COUNTY, COLORADO

40.00 ACRES

10

**WESTERN LEWIS-RECTORVILLE WATER AND GAS DISTRICT
FLUSHING/LEAK REPORT**

Date	Time	Location/Description	Gallons Leaked/Flushed	Minutes Flushed	Chlorine Reading	Additional Information
5-21-18	10:45	3490 Bucklick Blow off				
5-21-18	11:00	the Mashtown Hollow Rd Blow off			.89	
5-21-18	11:30	End of Happy Hollow			.85	
5-22-18		End of May Hollow Blow off	1110		.80	
5-22-18		Fire hydrant May hollow	1110			
5-22-18		May Hollow Sp. Blow off	1130			
5-23-18	11:00	Koger Ferguson Blow off				
5-23-18	11:15	Hydrant Simmons Rd				
5-23-18	11:30	Rutens in E. Hill Blow off				
5-23-18	11:45	Wes Thomas Blow off				
5-23-18	12:00	Scott Osborne Fire hydrant				
5-23-18	14:00	sand hill Blow off			.90	
5-23-18	14:50	Blow off End of concrete				
5-23-18	15:00	Highfield lane Blow off			1.02	

**WESTERN LEWIS-RECTORVILLE WATER AND GAS DISTRICT
FLUSHING/LEAK REPORT**

Date	Time	Location/Description	Gallons Leaked/Flushed	Minutes Flushed	Chlorine Reading	Additional Information
10-26-16	1:30	Halfhill Fire hydrant		60 min	1.70	
10-27-16	11:23	Olivet church Rd Blow off		40 min	1.21	
10-27-16	11:40	Davis lane Blow off		35 min	1.46	
10-31-16	1400	Half hill Fire Hydrant		40 min	1.34	
11-1-16	1430	Sandhill Blow off		40 min	.75	
11-3-16	1350	Osborne lane Blow off		40 min	1.45	
11-3-16	1400	Delane Hydrant		30 min	.99	
11-3-16	1430	TRinity school Fire Hydrant		30 min	1.27	
11-3-16	1445	Sullivan Ridge Hydrant		30 min	1.03	
11-7-16	1420	Coker street Blow off		45 min	1.61	
11-7-16	1455	Blow off Walter Rd Coker vic.		45 min	.68	
12-2-16	14:00	Simmons Rd 2 inch Blow off		20 min	1.25	
12-2-16	1425	Melvin Lancaster Blow off 2 inch		30 min	1.30	
12-2-16	1430	Laura's Rd Blow		30 min	1.45	

LINE BREAK LOGBOOK

Required by 401 KAR 8:150, Section 4(2)

DATE	LOCATION OF BREAK	TIME IT WAS DISCOVERED	POPULATION AFFECTED	LENGTH OF TIME TO REPAIR	DATE & TIME OF CL2 RESIDUALS DETECTED	DATE & TIME OF BACT SAMPLES TAKEN	TURNED WATER OFF (yes or no)	BWA REQUIRED (yes or no)	OTHER COMMENTS
2-8-17	Dale Pike	10:00	40	1.5	2-8-17	2-8-17	Yes	Yes	12:00 Checked numbers for Dale Pike 2-23-17
2-2-17	Dale May Farm Concord	5:30 pm 2-2-17	25	1.00	2-2-17	2-2-17	N#	N#	Upon clamp

LINE BREAK LOGBOOK

Required by 401 KAR 8:150, Section 4(2)

DATE	LOCATION OF BREAK	TIME IT WAS DISCOVERED	POPULATION AFFECTED	LENGTH OF TIME TO REPAIR	DATE & TIME OF CL2 RESIDUALS DETECTED	DATE & TIME OF BACT SAMPLES TAKEN	TURNED WATER OFF (yes or no)	BWA REQUIRED (yes or no)	OTHER COMMENTS
03/29/2016	R#57 / (C4)	8:00 AM		9 HRS	03/29/2016	03/30/2016	YES	YES	REPAIR TO 6" PIRE (2) BACTS CHANGE B.W. LITTED @ 9:22 AM / 03/31/2016
03/03/2016	KEVIN FUGLES AT HWY	4:44 AM	10	2 HRS.	03/03/2016	03/09/2016	YES	YES	4" MAIN PULLED AT HWY

Plumb w/ln

4" MAIN PULLED AT HWY

Plumb w/ln

Required by 401 KAR 8:150, Section 4(2)

LINE BREAK LOGBOOK

DATE	LOCATION OF BREAK	TIME IT WAS DISCOVERED	POPULATION AFFECTED	LENGTH OF TIME TO REPAIR	DATE & TIME OF CL2 RESIDUALS DETECTED	DATE & TIME OF BACT SAMPLES TAKEN	TURNED WATER OFF (yes or no)	BWA REQUIRED (yes or no)	OTHER COMMENTS
03/03/2016	5122 WCK #10	3:00 03/02/2016	35	4 HRS					03/09/2016 YES YES BOLIC WATER LIFTED 02/14 @ 9:48 SAMPLES RUN OFF
02/10/2016	BROKE 2" MAIN DRAINING HUBS BUTLH	11:00	3	5 HRS					BOLIC WATER LIFTED 02/12

Fusiod
LIFTED

LINE BREAK LOGBOOK

Required by 401 KAR 8:150, Section 4(2)

DATE	LOCATION OF BREAK	TIME IT WAS DISCOVERED	POPULATION AFFECTED	LENGTH OF TIME TO REPAIR	DATE & TIME OF CL2 RESIDUALS DETECTED	DATE & TIME OF BACT SAMPLES TAKEN	TURNED WATER OFF (yes or no)	BWA REQUIRED (yes or no)	OTHER COMMENTS
11-23-18	Dixon Pike Jack Apple w/2	3:00 PM	30	1 hr	11-23-18	11-28-18	Yes	Yes	Drive fence post in line & flushed water

1 house
1 water
11-27-18
4:30 pm
Dixon Pike

DATE	LOCATION OF BREAK	TIME IT WAS DISCOVERED	POPULATION AFFECTED	LENGTH OF TIME TO REPAIR	DATE & TIME OF CL2 RESIDUAL	DATE & TIME OF BACT SAMPLES	TURNED WATER OFF (yes or no)	BWA REQUIRED (yes or no)	OTHER COMMENTS
11-21-18	Kansas	11:00 pm			11-23-18	11-21-18	Yes	Yes	Flushed water

Be 1 water
11-21-18
8:35 AM
11-21-18
11:00 pm

LINE BREAK LOGBOOK

Required by 401 KAR 8:150, Section 4(2)

DATE	LOCATION OF BREAK	TIME IT WAS DISCOVERED	POPULATION AFFECTED	LENGTH OF TIME TO REPAIR	DATE & TIME OF CL2 RESIDUALS DETECTED	DATE & TIME OF BACT SAMPLES TAKEN	TURNED WATER OFF (yes or no)	BWA REQUIRED (yes or no)	OTHER COMMENTS
10-3-18	Kansas Creek	10:00	15	1 hr	10-4-18	10-4-18	Yes	Yes	flushed with water
6-18-18	R: half - To Blounting	10:30 AM	10	2 hrs	6-20-18	6-20-18	Yes	Yes	electric

11:00 AM
6-18

10
L: f...
W...
10:00 AM

10
L: f...
10:00 AM

10
L: f...
10:00 AM

LINE BREAK LOGBOOK

Required by 401 KAR 8:150, Section 4(2)

DATE	LOCATION OF BREAK	TIME IT WAS DISCOVERED	POPULATION AFFECTED	LENGTH OF TIME TO REPAIR	DATE & TIME OF CL2 RESIDUALS DETECTED	DATE & TIME OF BACT SAMPLES TAKEN	TURNED WATER OFF (yes or no)	BWA REQUIRED (yes or no)	OTHER COMMENTS
2-1-18	At connection	12:00 PM	50	3 hrs		2-6-18	Yes	Yes	10:00h PVC split
2-1-18	At connection						Yes	Yes	

Boiler water level
2-7-18
1:40 PM

DATE	LOCATION OF BREAK	TIME IT WAS DISCOVERED	POPULATION AFFECTED	LENGTH OF TIME TO REPAIR	DATE & TIME OF CL2 RESIDUAL	DATE & TIME OF BACT SAMPLES	TURNED WATER OFF (yes or no)	BWA REQUIRED (yes or no)	OTHER COMMENTS
5-2-18	At Hillside Circle Plumville	3:00 PM	40	1 1/2		5-3-18	Yes	Yes	Boiler water level 5-4-18

10:10 AM

LINE BREAK LOGBOOK

Required by 401 KAR 8:150, Section 4(2)

DATE	LOCATION OF BREAK	TIME IT WAS DISCOVERED	POPULATION AFFECTED	LENGTH OF TIME TO REPAIR	DATE & TIME OF CL2 RESIDUALS DETECTED	DATE & TIME OF BACT SAMPLES TAKEN	TURNED WATER OFF (yes or no)	BWA REQUIRED (yes or no)	OTHER COMMENTS
11-17-17	9581 Mason Lewis Rd	8:30 AM	75	2 hrs	11-17-17	11-21-17	yes	yes	Boil water 11-22-17 trip blown off

DATE	LOCATION OF BREAK	TIME IT WAS DISCOVERED	POPULATION AFFECTED	LENGTH OF TIME TO REPAIR	DATE & TIME OF CL2 RESIDUALS	DATE & TIME OF BACT SAMPLES	TURNED WATER OFF (yes or no)	BWA REQUIRED (yes or no)	OTHER COMMENTS
12-18-17	Stonelick	9:00 AM	30 customers	1 hr	12-18-17	12-19-17 12:00 PM	yes	yes	8 inch PVC connection hit Flooded with 12-22 Flood 12-22

LINE BREAK LOGBOOK

Required by 401 KAR 8:150, Section 4(2)

DATE	LOCATION OF BREAK	TIME IT WAS DISCOVERED	POPULATION AFFECTED	LENGTH OF TIME TO REPAIR	DATE & TIME OF CL2 RESIDUALS DETECTED	DATE & TIME OF BACT SAMPLES TAKEN	TURNED WATER OFF (yes or no)	BWA REQUIRED (yes or no)	OTHER COMMENTS
10-19-17	Blythe Springdale Hill	11:00 AM	2	4 hrs	10-24-17	10-25-17	Yes	Yes	Let several thousand gallons into the system. Several water meters in Park
									Boiler water Listed 10-27-17 1:30 PM KID-adding water to system in Park

Boiler water
Listed
10-27-17
1:30 PM
KID-adding
water
to
system
in
Park

Let several thousand gallons into the system. Several water meters in Park

LINE BREAK LOGBOOK

Required by 401 KAR 8:150, Section 4(2)

DATE	7-25-17
LOCATION OF BREAK	across from Tony Flame
TIME IT WAS DISCOVERED	9:00 PM
POPULATION AFFECTED	50
LENGTH OF TIME TO REPAIR	2.5 hrs
DATE & TIME OF CL2 RESIDUALS DETECTED	7-26-17
DATE & TIME OF BACT SAMPLES TAKEN	8-2-17
TURNED WATER OFF (yes or no)	Yes
BWA REQUIRED (yes or no)	Yes
OTHER COMMENTS	<p>AC hole through pipe</p> <p style="text-align: right;">Boil up filter lifted 1230 PM 8-3-17 Denny Fraley</p>

DATE	8-29-17
LOCATION OF BREAK	Charles Toller ST South
TIME IT WAS DISCOVERED	10:00 AM
POPULATION AFFECTED	4
LENGTH OF TIME TO REPAIR	1 hour
DATE & TIME OF CL2 RESIDUAL	8-29-17
DATE & TIME OF BACT SAMPLES	9-6-17
TURNED WATER OFF (yes or no)	Yes
BWA REQUIRED (yes or no)	Yes
OTHER COMMENTS	<p>Boil water lifted 12:00 9-7-17 Denny Fraley</p>

LINE BREAK LOGBOOK

Required by 401 KAR 8:150, Section 4(2)

DATE	LOCATION OF BREAK	TIME IT WAS DISCOVERED	POPULATION AFFECTED	LENGTH OF TIME TO REPAIR	DATE & TIME OF CL2 RESIDUALS DETECTED	DATE & TIME OF BACT SAMPLES TAKEN	TURNED WATER OFF (yes or no)	BWA REQUIRED (yes or no)	OTHER COMMENTS
05/23/2016	CDB TOLLESDALE	8:00	150	6 HRS	05/25/2016	05/25/2016	YES	YES	3/4" SERVICE & 2" TAP ABANDONED Flushed with 1000 05/26/2016 BELL WATER LITTS
04/13/2016	ORANGEBURG	3:00		4 HRS.	04/15/2016	04/20/2016	YES	YES	NO BWA NOTIFICATION STATE HANDED PROPOSED POST INTO B... NOTIFICATION 04/22/2016 Flushed with
									Water. Bill History Water 9:16 AM 4-22-16 Checks Cashed Loans

CASH EXPRESS
888-899-0399

LINE BREAK LOGBOOK

Required by 401 KAR 8:150, Section 4(2)

DATE	LOCATION OF BREAK	TIME IT WAS DISCOVERED	POPULATION AFFECTED	LENGTH OF TIME TO REPAIR	DATE & TIME OF CL2 RESIDUALS DETECTED	DATE & TIME OF BACT SAMPLES TAKEN	TURNED WATER OFF (yes or no)	BWA REQUIRED (yes or no)	OTHER COMMENTS
06/01/2016	DANFORTH LANE	8:00	15 CUSTOMERS	3 HRS	06/08/2016	11 11 11	YES	YES	4" LINE SPILT / ROCK AIR @ 10:00 FIN WITH closed water 06/09/2016
06/20/2016	HAPPY HILL	4:00	10	2 HRS	06/22/16	06/22/16	YES	YES	10:20 Happy Hill Lured out TRF CL2 RESIDUALS FROM 4" W/L
06/20/2016	HAPPY HILL	4:00	10	2 HRS	06/22/16	06/22/16	YES	YES	TRF CL2 RESIDUALS FROM 4" W/L closed water

LINE BREAK LOGBOOK

150, Section 4(2)

CHAD
 BOIL WATER
 @ 11:15

016
 OLD T.
 07/25

2010
 000,42
 24,000
 08/24/10
 10:06
 PEIL Water
 000,91
 16,000

DATE	LOCATION OF BREAK	TIME IT WAS DISCOVERED	POPULATION AFFECTED	LENGTH OF TIME TO REPAIR	DATE & TIME OF CL2 RESIDUAL	DATE & TIME OF BACT SAMPLES	TURNUED WATER OFF (yes or no)	BWA REQUIRED (yes or no)	OTHER COMMENTS

PEIL WATER 10:00
 TAP CLOSED OFF @ 11:15
 08/09/2010
 FIVE MIN

DATE	LOCATION OF BREAK	TIME IT WAS DISCOVERED	POPULATION AFFECTED	LENGTH OF TIME TO REPAIR	DATE & TIME OF CL2 RESIDUAL	DATE & TIME OF BACT SAMPLES	TURNUED WATER OFF (yes or no)	BWA REQUIRED (yes or no)	OTHER COMMENTS
							YES	YES	

LINE BREAK LOGBOOK

Required by 401 KAR 8:150, Section 4(2)

DATE	LOCATION OF BREAK	TIME IT WAS DISCOVERED	POPULATION AFFECTED	LENGTH OF TIME TO REPAIR	DATE & TIME OF CL2 RESIDUALS DETECTED	DATE & TIME OF BACT SAMPLES TAKEN	TURNED WATER OFF (yes or no)	BWA REQUIRED (yes or no)	OTHER COMMENTS
10-12-16	Ton's IGA	10-12-16	1	2 hrs	10-19-16 1.00 ppm	10-19-16	N/A	N/A	Service line repaired Flushed system

DATE	LOCATION OF BREAK	TIME IT WAS DISCOVERED	POPULATION AFFECTED	LENGTH OF TIME TO REPAIR	DATE & TIME OF CL2 RESIDUAL	DATE & TIME OF BACT SAMPLES	TURNED WATER OFF (yes or no)	BWA REQUIRED (yes or no)	OTHER COMMENTS
11-25-16	Madras house	9:30	40-7050	2 hrs	10-26-16 ± 1.80	10-26-16 8:00	Y	Y	7:45 AM 10:25 AM Don Conroy 10-27-16

LINE BREAK LOGBOOK

Required by 401 KAR 8:150, Section 4(2)

DATE	LOCATION OF BREAK	TIME IT WAS DISCOVERED	POPULATION AFFECTED	LENGTH OF TIME TO REPAIR	DATE & TIME OF CL2 RESIDUAL	DATE & TIME OF BACT SAMPLES	TURND WATER OFF (yes or no)	BWA REQUIRED (yes or no)	OTHER COMMENTS
09/08/2016	STONE CREEK	9:00		2 HRS.	09/19/2016	09/19/2016	YES	YES	TURND WATER OFF TO INSTANT HYDRANT & VALVE

DATE	LOCATION OF BREAK	TIME IT WAS DISCOVERED	POPULATION AFFECTED	LENGTH OF TIME TO REPAIR	DATE & TIME OF CL2 RESIDUALS DETECTED	DATE & TIME OF BACT SAMPLES TAKEN	TURND WATER OFF (yes or no)	BWA REQUIRED (yes or no)	OTHER COMMENTS
08/22/2016	CENTRE RIVER RD.	8:00	35	3 HRS			YES	YES	3/4" SERVICE CAP @ MAIN

LINE BREAK LOGBOOK

Required by 401 KAR 8:150, Section 4(2)

DATE	LOCATION OF BREAK	TIME IT WAS DISCOVERED	POPULATION AFFECTED	LENGTH OF TIME TO REPAIR	DATE & TIME OF CL2 RESIDUALS DETECTED	DATE & TIME OF BACT SAMPLES TAKEN	TURNUED WATER OFF (yes or no)	BWA REQUIRED (yes or no)	OTHER COMMENTS
1-18-17	Biscobin Creek	9:00 AM	50	3 hrs	1-25-17	1-25-17	yes	yes	New P.V.P. installed flushed with 30:1 water 1-26-17 Down counter
1-29-16	Dark Kill Subst.ion	10:10 AM	15	2 hr	1-4-17	1-4-17	yes	yes	Danny Finley 12-4-17 9:35 flushed

LINE BREAK LOGBOOK

Required by 401 KAR 8:150, Section 4(2)

DATE	LOCATION OF BREAK	TIME IT WAS DISCOVERED	POPULATION AFFECTED	LENGTH OF TIME TO REPAIR	DATE & TIME OF CL2 RESIDUALS DETECTED	DATE & TIME OF BACT SAMPLES TAKEN	TURNUED WATER OFF (yes or no)	BWA REQUIRED (yes or no)	OTHER COMMENTS
1-31-17	Seddon Lane	3:00	10	15	1-31-17	2-1-17	Yes	Yes	Lifted 2-2-17 11:50
1-31-17	Seddon Lane	3:00	10	15	1-31-17	2-1-17	Yes	Yes	Lifted 2-2-17 11:50
1-7-16	Little Cobe cck pav p.A	9:30	40	3 hrs	2-1-17	2-1-17	Yes	Yes	Lifted 2-2-17 11:50

Tom Thomas Nelson

Tom Thomas Nelson

LINE BREAK LOGBOOK

Required by 401 KAR 8:150, Section 4(2)

DATE	LOCATION OF BREAK	TIME IT WAS DISCOVERED	POPULATION AFFECTED	LENGTH OF TIME TO REPAIR	DATE & TIME OF CL2 RESIDUALS DETECTED	DATE & TIME OF BACT SAMPLES TAKEN	TURNED WATER OFF (yes or no)	BWA REQUIRED (yes or no)	OTHER COMMENTS
5-8-17	Byron foreman	2:00 PM	100	45 min	5-8-17	5-10-17 1:30	Yes	Yes	Tap blown off 6:00 AM 10:00 AM Damm 1:00 PM
7-22-17	Springdale Creek Crossings	.	15	2 hrs	.	.	Yes	Yes	Crack Crossings washed out PVC Boil water fitted 8-3-17 12:30 PM Damm 1:00 PM
8-2-17							Yes	Yes	Crack Crossings washed out PVC Boil water fitted 8-3-17 12:30 PM Damm 1:00 PM

LINE BREAK LOGBOOK

DATE	LOCATION OF BREAK	TIME IT WAS DISCOVERED	POPULATION AFFECTED	LENGTH OF TIME TO REPAIR	DATE & TIME OF CL2 RESIDUALS DETECTED	DATE & TIME OF BACT SAMPLES TAKEN	TURNED WATER OFF (yes or no)	BWA REQUIRED (yes or no)	OTHER COMMENTS
3-29-17	Out hollow Rd	10:00 AM	8	2 hrs	3-29-17	4-5-17	yes	yes	Lifted 11:17 8:20 Demolition
3-30-17	Jackson Street Concret	9:00 AM	10	1 hr	3-24-17 3:00 PM	3-29-17	yes	yes	Lifted 3-30-17 10:15 Thomas Nelson