

Date	Input Pressure	Output Pressure	Oderant Pounds in Tank	Oderant Drips Per Second	Operator Signature
4-1-23	—	—	—	—	B. Jones
4-2-23	840	113	6.5	58 seconds	B. Jones
4-3-23	760	112	6.5	1:31	
4-4-23	800	115	6.5	1:03	
4-5-23	800	115	6.5	1:11	
4-6-23	840	111	6.5	1:18	
4-7-23	840	111	6.25	1:24	
4-8-23	820	112	6.25	59 seconds	
4-9-23	820	115	6.25	48 seconds	
4-10-23	820	110	6.0	56 seconds	
4-11-23	—	—	—	—	
4-12-23	820	110	6.0	58 seconds	
4-13-23	800	110	6.0	54 seconds	
4-14-23	800	115	6.0	46 seconds	
4-15-23	840	112	6.0	1:12	
4-16-23	720	115	6.0	48 seconds	
4-17-23	820	115	5.75	1:21	
4-18-23	—	—	—	—	
4-19-23	800	115	5.75	49 seconds	
4-20-23	—	—	—	—	
4-21-23	—	—	—	—	
4-22-23	800	110	5.50	1:10	
4-23-23	800	114	5.25	34 seconds	
4-24-23	—	—	—	—	
4-25-23	820	116	5.0	31 seconds	
4-26-23	840	115	5.0	53 seconds	
4-27-23	820	115	5.0	58 seconds	
4-28-23	810	115	5.0	1:18	
4-29-23	820	112	5.0	1:11	
4-30-23	820	113	5.0	33 seconds	