

PATROLLING OF PIPELINE SYSTEM

FORM 4

COMPANY: DRAKESBORO GAS

Period Covered: Began 11/22/21 Ended 11/22/21

Areas Covered: DITCH LINE @ 431 / W&R HEATING

Map References: \_\_\_\_\_

Leakage Indications Discovered (describe locations and indications, such as a condition of vegetation):  
NO LEAKS FOUND

Describe any unusual conditions at highway and railroad crossings: \_\_\_\_\_

Other Factors noted which could affect present or future safety or operations of the gas system: \_\_\_\_\_

Follow-up (repairs, maintenance or test resulting from this inspection): LINE IS BEING COVERED WITH LARGE ROCK

Comments: \_\_\_\_\_

Number of Persons in Patrol Party: 2

Signature of Person in Charge of Patrol Party: By [Signature]

Date: 11/22/21

PATROLLING OF PIPELINE SYSTEM

FORM 4

COMPANY: DRAKES BORO GAS

Period Covered: Began 11/22/21 Ended 11/22/21

Areas Covered: PIPE CROSSING DITCH ACROSS FROM DOLLAR GENERAL / WESTER ST.

Map References: \_\_\_\_\_

Leakage Indications Discovered (describe locations and indications, such as a condition of vegetation):  
NO LEAKS FOUND. PIPE IS WAX WRAPPED

Describe any unusual conditions at highway and railroad crossings: \_\_\_\_\_

Other Factors noted which could affect present or future safety or operations of the gas system: \_\_\_\_\_

Follow-up (repairs, maintenance or test resulting from this inspection): REPAIRS ARE BEING DISCUSSED

Comments: \_\_\_\_\_

Number of Persons in Patrol Party: 2

Signature of Person in Charge of Patrol Party: By Alled

Date: 11/22/21

PATROLLING OF PIPELINE SYSTEM

FORM 4

COMPANY: DRAKESBORO GAS

Period Covered: Began 11/22/21 Ended 11/22/21

Areas Covered: OLD DOLLAR STORE DITCH, BEECHMONT

Map References: \_\_\_\_\_

Leakage Indications Discovered (describe locations and indications, such as a condition of vegetation):

NO LEAKS FOUND. GAS LINE IS PROTECTED BY CASING

Describe any unusual conditions at highway and railroad crossings: N/A

Other Factors noted which could affect present or future safety or operations of the gas system:

Follow-up (repairs, maintenance or test resulting from this inspection): LINE HAS BEEN COVERED WITH LARGE ROCK / CONCRETE

Comments: \_\_\_\_\_

Number of Persons in Patrol Party: 2

Signature of Person in Charge of Patrol Party: By Alled

Date: 11/22/21