

COMMONWEALTH OF KENTUCKY  
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

CITY OF DRAKESBORO D/B/A	)	
DRAKESBORO NATURAL GAS	)	
COMPANY	)	
_____	)	
ELECTRONIC INVESTIGATION OF ALLEGED	)	CASE NO.
FAILURE TO COMPLY WITH	)	2019-00065
KRS 278.495, 807 KAR 5:027, AND	)	
49 C.F.R. PART 192	)	

**NOTICE OF GAS LINE PENETRATION**

Comes now, the City of Drakesboro (hereafter the “City”), by counsel, and hereby serves notice of penetration or cutting of a line in its system.

The City states that the line cut was at 160 Woodruff Lane, Beech Creek, Kentucky 42321 by the customer, Christopher Steele. The line was cut when the customer dug out an area for the purpose of performing construction work.

The meter number for the location is 20744152 and the meter reading was 0066.


The line was a ½ Polly with Tracer Wire.

The line was fixed with 2 x ½ Stab couplings, approximately 12 inches of ½ polly pipe and 16 inches of tracer wire, as well as 2 silicone filled sealed wire nuts and wrapped with black electrical tape.

For further information, the City may be contacted.

Respectfully submitted,

YONTS, SHERMAN & DRISKILL, P.S.C.



---

Ryan Driskill  
P.O. Box 370  
Greenville, KY 42345  
[rdrisk@hotmail.com](mailto:rdrisk@hotmail.com)  
Phone: 270.338.0816  
Fax: 270.338.0816

CERTIFICATE OF SERVICE

This is to certify that the above notice was filed electronically on this the 9<sup>th</sup> day of May, 2019 and served upon the Honorable John Parks by electronic mail at [John.Park@ky.gov](mailto:John.Park@ky.gov).



---

Ryan Bennett Driskill