

City of Drakesboro

ATMOSPHERIC CORROSION CONTROL INSPECTION

This form to be completed when above ground piping is inspected for corrosion from atmospheric conditions or corrosive conditions that cannot be controlled by cathodic protection. Inspect all exposed piping every three years for atmospheric corrosion.\*

192.479, 192.481, 192.491

Date: 8-22, 2019

1. Location: City of Drakesboro

2. Name of Inspector: Donald Sims

3. Designation of Line: Main \_\_\_\_\_ Service

4. Line Size: 1"

5. Area of Corrosion: Pipe \_\_\_\_\_ Meter Set  Fitting   
Regulator \_\_\_\_\_ Support \_\_\_\_\_ Vent \_\_\_\_\_  
Other \_\_\_\_\_

6. Corrective measures taken: Painted  Coated \_\_\_\_\_ Other \_\_\_\_\_  
Type of paint or coating used: Gray Rustoleum

7. If General Painting of exposed Piping is undertaken, list addresses:

- |                              |                              |
|------------------------------|------------------------------|
| <u>301 Christian Street</u>  | <u>306 Kennedy Jones Ave</u> |
| <u>305 Christian Street</u>  | <u>106 Bicedale Circle</u>   |
| <u>806 Jones Ave.</u>        | <u>108 Bicedale Circle</u>   |
| <u>74 Harpers Circle</u>     | <u>109 Bicedale Circle</u>   |
| <u>14 Harpers Circle</u>     | <u>114 Bicedale Circle</u>   |
| <u>88 crossing</u>           | <u>116 Bicedale Circle.</u>  |
| <u>84 crossing</u>           | <u>117 Tom Eresh</u>         |
| <u>305 Kennedy Jones Ave</u> | <u>503 Mose Rager Blvd.</u>  |