

DRAKESBORO WORK ORDER

Work Order #: _____

DATE: 10-15-19 Time: _____ Gas Water WW Acct #: _____

NAME: Gerrit Chaplic Meter Number: _____

ADDRESS: 80 ~~Myers~~ Myers Chapel Rd
Belton

WORK TO BE DONE:

NEW METER # _____ NEW READING 270-987-0422
TURN ON & READ _____ OLD READING _____
READ and LOCK _____ SET METER and LOCK _____
READING ONLY _____ LOCATE LINE _____ (SEE BELOW)
READ and LOCK (NON PAYMENT) _____ GET METER NUMBER _____
CHECK PRESSURE _____ FLUSH LINE _____ CHECK f. LEAK _____
UNLOCK ONLY and READ (DO NOT TURN ON) _____

SPECIAL INSTRUCTIONS:

wants gas service reinstalled. Please look at what needs to be done and a price please. Thank You.

WORK DONE:

FLUSHED: Yes No GPM: _____ How Long: _____ Water Loss: _____
WATER LEAK: Yes No GPM: _____ How Long: _____ Water Loss: _____

PARTS USED TO COMPLETE JOB:

COMMENTS: Building must be dried in, and a pressure test must be shown.

WORK COMPLETED BY: [Signature] DATE COMPLETED: 10-14-19
TIME STARTED: _____ TIME FINISHED: _____

DRAKESBORO WORK ORDER

Work Order #: _____

DATE: 10-15-19

Time: _____

Gas

Water

WW

Acct #: _____

NAME: Henny Fulkerson

Meter Number: _____

ADDRESS: 3010 St Rt 70

WORK TO BE DONE:

NEW METER # 19M215029

NEW READING 0000

TURN ON & READ _____

OLD READING _____

READ and LOCK _____

SET METER and LOCK _____

READING ONLY _____

LOCATE LINE _____

(SEE BELOW)

READ and LOCK (NON PAYMENT) _____

GET METER NUMBER _____

CHECK PRESSURE _____

FLUSH LINE _____

CHECK f. LEAK _____

UNLOCK ONLY and READ (DO NOT TURN ON) _____

SPECIAL INSTRUCTIONS:

Install meter

old meter # 215051

Old reading - 7617

WORK DONE:

FLUSHED: Yes No

GPM: _____

How Long: _____

Water Loss: _____

WATER LEAK: Yes No

GPM: _____

How Long: _____

Water Loss: _____

PARTS USED TO COMPLETE JOB:

COMMENTS:

New Meter installed. No one home to light pilot. Gas still off until someone is home.

WORK COMPLETED BY: [Signature]

DATE COMPLETED: 10-15-19

TIME STARTED: _____

TIME FINISHED: _____

DRAKESBORO WORK ORDER

Work Order #: _____

DATE: _____

Time: _____

Gas

Water

WW

Acct #: _____

NAME: _____

~~James~~ Robert Williams

Meter Number: _____

ADDRESS: _____

81 Meyford Rd

WORK TO BE DONE:

NEW METER # _____

NEW READING _____

TURN ON & READ _____

OLD READING _____

READ and LOCK _____

SET METER and LOCK _____

READING ONLY _____

8273

LOCATE LINE _____

(SEE BELOW)

READ and LOCK (NON PAYMENT) _____

GET METER NUMBER _____

CHECK PRESSURE _____

FLUSH LINE _____

CHECK f. LEAK _____

UNLOCK ONLY and READ (DO NOT TURN ON) _____

SPECIAL INSTRUCTIONS: _____

Read meter

WORK DONE:

FLUSHED: Yes No

GPM: _____

How Long: _____

Water Loss: _____

WATER LEAK: Yes No

GPM: _____

How Long: _____

Water Loss: _____

PARTS USED TO COMPLETE JOB:

COMMENTS:

WORK COMPLETED BY: _____

[Signature]

DATE COMPLETED: _____

10-16-99

TIME STARTED: _____

TIME FINISHED: _____

DRAKESBORO WORK ORDER

Work Order #: _____

DATE: 10-15-19

Time: _____

Gas

Water

WW

Acct #: _____

NAME: Eddie Brake

Meter Number: _____

ADDRESS: 3970 Riverside Road

WORK TO BE DONE:

NEW METER # 19M215037

NEW READING Ø

TURN ON & READ Ø

OLD READING 0192

READ and LOCK _____

SET METER and LOCK _____

READING ONLY _____

LOCATE LINE _____

(SEE BELOW)

READ and LOCK (NON PAYMENT) _____

GET METER NUMBER _____

CHECK PRESSURE _____

FLUSH LINE _____

CHECK f. LEAK _____

UNLOCK ONLY and READ (DO NOT TURN ON) _____

SPECIAL INSTRUCTIONS:

index replaced, will pay \$30⁰⁰ reconnect fee.

WORK DONE:

FLUSHED: Yes No

GPM: _____

How Long: _____

Water Loss: _____

WATER LEAK: Yes No

GPM: _____

How Long: _____

Water Loss: _____

PARTS USED TO COMPLETE JOB:

Replace with NEW Meter

COMMENTS:

WORK COMPLETED BY: Bill Go

DATE COMPLETED: 10-16-19

TIME STARTED: _____

TIME FINISHED: _____

DRAKESBORO WORK ORDER

Work Order #: _____

DATE: 10-16-19 Time: _____ Gas Water WW Acct #: _____

NAME: James Tipton Meter Number: _____

ADDRESS: 3721 Hwy 431

WORK TO BE DONE: 270-543-4012 Beechmont

NEW METER # _____ NEW READING _____
TURN ON & READ 7894 OLD READING 7894
READ and LOCK _____ SET METER and LOCK _____
READING ONLY _____ LOCATE LINE _____ (SEE BELOW)
READ and LOCK (NON PAYMENT) _____ GET METER NUMBER _____
CHECK PRESSURE _____ FLUSH LINE _____ CHECK f. LEAK _____
UNLOCK ONLY and READ (DO NOT TURN ON) _____

SPECIAL INSTRUCTIONS:

needs gas meter hooked back up. He is finished putting water heater in.

WORK DONE:

FLUSHED: Yes No GPM: _____ How Long: _____ Water Loss: _____
WATER LEAK: Yes No GPM: _____ How Long: _____ Water Loss: _____

PARTS USED TO COMPLETE JOB:

COMMENTS:

Turned gas on. Pilite pilot on hot water heater, and 1st stove

WORK COMPLETED BY: Will Do DATE COMPLETED: 10-16-19
TIME STARTED: _____ TIME FINISHED: _____

DRAKESBORO WORK ORDER

Work Order #: _____

DATE: 10-16-19

Time: _____

Gas

Water

WW

Acct #: _____

NAME: Beechmont Missionary Church ^{Baptist} Meter Number: _____

ADDRESS: old firedept.

Steve Ingram

270-977-5404

WORK TO BE DONE:

NEW METER # _____

NEW READING _____

α TURN ON & READ 0353

OLD READING _____

READ and LOCK _____

SET METER and LOCK _____

READING ONLY _____

LOCATE LINE _____

(SEE BELOW)

READ and LOCK (NON PAYMENT) _____

GET METER NUMBER _____


CHECK PRESSURE _____

FLUSH LINE _____

CHECK f. LEAK _____

UNLOCK ONLY and READ (DO NOT TURN ON) _____

SPECIAL INSTRUCTIONS:

turn on meter. 

WORK DONE:

FLUSHED: Yes No

GPM: _____

How Long: _____

Water Loss: _____

WATER LEAK: Yes No

GPM: _____

How Long: _____

Water Loss: _____

PARTS USED TO COMPLETE JOB:

COMMENTS: Turned Furnaces back on. Everything works fine

WORK COMPLETED BY: RLH

DATE COMPLETED: 10-16-19

TIME STARTED: _____

TIME FINISHED: _____

DRAKESBORO WORK ORDER

Work Order #: _____

DATE: 10-16-19

Time: _____

Gas

Water

WW

Acct #: _____

NAME: Cecil Stroud

Meter Number: _____

ADDRESS: 110 Steed Ave

270 820-0559

WORK TO BE DONE:

NEW METER # _____

NEW READING _____

TURN ON & READ _____

OLD READING _____

READ and LOCK _____

SET METER and LOCK _____

READING ONLY _____

LOCATE LINE _____

(SEE BELOW)

READ and LOCK (NO METER) 3968

GET METER NUMBER _____

CHECK PRESSURE _____

FLUSH LINE _____

CHECK f. LEAK _____

UNLOCK ONLY and READ (DO NOT TURN ON) _____

SPECIAL INSTRUCTIONS:

Customer moved.

WORK DONE:

FLUSHED: Yes No

GPM: _____

How Long: _____

Water Loss: _____

WATER LEAK: Yes No

GPM: _____

How Long: _____

Water Loss: _____

PARTS USED TO COMPLETE JOB:

COMMENTS:

Already off & locked

WORK COMPLETED BY: All Sec

DATE COMPLETED: 10-16-19

TIME STARTED: _____

TIME FINISHED: _____

DRAKESBORO WORK ORDER

Work Order #: _____

DATE: 10-14-19 Time: _____ **Gas** Water WW Acct #: _____

NAME: Kevin Brooks (Hardison Glendal) Meter Number: _____

ADDRESS: 618 Masonic Drive Beechmont
270-602-7005

WORK TO BE DONE:

NEW METER # _____ NEW READING _____
 TURN ON & READ 6403 OLD READING _____
READ and LOCK _____ SET METER and LOCK _____
READING ONLY _____ LOCATE LINE _____ (SEE BELOW)
READ and LOCK (NON PAYMENT) _____ GET METER NUMBER _____
CHECK PRESSURE _____ FLUSH LINE _____ CHECK f. LEAK _____
UNLOCK ONLY and READ (DO NOT TURN ON) _____

SPECIAL INSTRUCTIONS:

Reconnect gas customer knows about \$30⁰⁰ reconne
fee.

WORK DONE:

FLUSHED: Yes No GPM: _____ How Long: _____ Water Loss: _____
WATER LEAK: Yes No GPM: _____ How Long: _____ Water Loss: _____

PARTS USED TO COMPLETE JOB:

COMMENTS: Turned on, made sure pilot lit.

WORK COMPLETED BY: Ali So DATE COMPLETED: 10-16-19
TIME STARTED: _____ TIME FINISHED: _____

DRAKESBORO WORK ORDER

Work Order #: _____

DATE: 10-17-19

Time: _____

Gas

Water

WW

Acct #: _____

NAME: Glenn Pendley

Meter Number: _____

ADDRESS: 4044 St Rt 2270 East

WORK TO BE DONE:

270-754-7113

NEW METER # _____

NEW READING _____

TURN ON & READ

0000

OLD READING

4098

READ and LOCK _____

SET METER and LOCK _____

READING ONLY _____

LOCATE LINE _____

(SEE BELOW)

READ and LOCK (NON PAYMENT) _____

GET METER NUMBER _____

CHECK PRESSURE _____

FLUSH LINE _____

CHECK f. LEAK _____

UNLOCK ONLY and READ (DO NOT TURN ON) _____

SPECIAL INSTRUCTIONS:

New meter was installed but locked? Reconnect fee needs to be charged. Daughter will be at home between 8:00-8:30 a.m.

WORK DONE:

FLUSHED: Yes No

GPM: _____

How Long: _____

Water Loss: _____

WATER LEAK: Yes No

GPM: _____

How Long: _____

Water Loss: _____

PARTS USED TO COMPLETE JOB:

COMMENTS:

Turned meter on. Relite Pilot on for place.

WORK COMPLETED BY: Wes Lo

DATE COMPLETED: 10-17-19

TIME STARTED: _____

TIME FINISHED: _____

DRAKESBORO WORK ORDER

Work Order #: _____

DATE: 10-17-19

Time: _____

Gas

Water

WW Acct #: _____

NAME: Tina Camplin

Meter Number: _____

ADDRESS: 355 Old Ennis Rd

270-820-8016

WORK TO BE DONE:

NEW METER # _____

NEW READING _____

TURN ON & READ 0303

OLD READING _____

READ and LOCK _____

SET METER and LOCK _____

READING ONLY _____

LOCATE LINE _____

(SEE BELOW)

READ and LOCK (NON PAYMENT) _____

GET METER NUMBER _____

CHECK PRESSURE _____

FLUSH LINE _____

CHECK f. LEAK _____

UNLOCK ONLY and READ (DO NOT TURN ON) _____

SPECIAL INSTRUCTIONS:

turn on and read

WORK DONE:

FLUSHED: Yes No

GPM: _____

How Long: _____

Water Loss: _____

WATER LEAK: Yes No

GPM: _____

How Long: _____

Water Loss: _____

PARTS USED TO COMPLETE JOB:

COMMENTS:

Turned on, pilot on fireplace fit.

WORK COMPLETED BY: Dell Lee

DATE COMPLETED: 10-17-19

TIME STARTED: _____

TIME FINISHED: _____

DRAKESBORO WORK ORDER

Work Order #: _____

DATE: 10-18-19

Time: _____

Gas

Water

WW

Acct #: _____

NAME: Joanna McDonald

Meter Number: _____

ADDRESS: 1650 Hazel Creek Rd

270-543-3779

WORK TO BE DONE:

- NEW METER # _____ NEW READING _____
- TURN ON & READ _____ OLD READING _____
- READ and LOCK _____ SET METER and LOCK _____
- READING ONLY _____ LOCATE LINE _____ (SEE BELOW)
- READ and LOCK (NON PAYMENT) _____ GET METER NUMBER _____
- CHECK PRESSURE _____ FLUSH LINE _____ CHECK f. LEAK _____
- UNLOCK ONLY and READ (DO NOT TURN ON) _____

SPECIAL INSTRUCTIONS:

Smell gas inside home.

WORK DONE:

- FLUSHED: Yes No GPM: _____ How Long: _____ Water Loss: _____
- WATER LEAK: Yes No GPM: _____ How Long: _____ Water Loss: _____

PARTS USED TO COMPLETE JOB:

COMMENTS:

Spray test board small leak on a shut off valve behind stove. Tightened shut off valve, Fixed leak.

WORK COMPLETED BY: All Jo

DATE COMPLETED: 10-18-19

TIME STARTED: _____

TIME FINISHED: _____