

PATROLLING OF PIPELINE SYSTEM

FORM 4

COMPANY: DRAKESBORO UTILITIES

Period Covered: Began 1/5/22 Ended 1/5/22

Areas Covered: DITCH LINE NEXT TO W&R HVAC @
4315

Map References: _____

Leakage Indications Discovered (describe locations and indications, such as a condition of vegetation):
NO LEAKS

Describe any unusual conditions at highway and railroad crossings: _____

Other Factors noted which could affect present or future safety or operations of the gas system:
LINE HAS BEEN WAX WRAPPED FOR PROTECTION

Follow-up (repairs, maintenance or test resulting from this inspection): _____

Comments: _____

Number of Persons in Patrol Party: 2

Signature of Person in Charge of Patrol Party: B. Alford

Date: 1/5/22

PATROLLING OF PIPELINE SYSTEM

FORM 4

COMPANY: DRAKESBORO UTILITIES

Period Covered: Began 1/5/22 Ended 1/5/22

Areas Covered: DITCH LINE @ 431 / WESTER ST.

Map References: _____

Leakage Indications Discovered (describe locations and indications, such as a condition of vegetation):

NO LEAKS

Describe any unusual conditions at highway and railroad crossings:

LINE HAS BEEN MILL WRAPPED FOR PROTECTION. HAVE NOT FOUND A WAY TO PROTECT FURTHER

Other Factors noted which could affect present or future safety or operations of the gas system:

Follow-up (repairs, maintenance or test resulting from this inspection):

Comments: _____

Number of Persons in Patrol Party: 2

Signature of Person in Charge of Patrol Party: R. Alled

Date: 1/5/22

PATROLLING OF PIPELINE SYSTEM

FORM 4

COMPANY: DRAKESBORO UTILITIES

Period Covered: Began 1/5/22 Ended 1/5/22

Areas Covered: DITCH LINE @ OLD DOLLAR STORE IN BEECHMONT

Map References: _____

Leakage Indications Discovered (describe locations and indications, such as a condition of vegetation):
NO LEAKS FOUND

Describe any unusual conditions at highway and railroad crossings: _____

Other Factors noted which could affect present or future safety or operations of the gas system:
LINE IS ENCASED IN 4" PVC FOR PROTECTION.
RUFF RAFF AND CONCRETE HAS BEEN PLACED AS A SECOND LAYER OF PROTECTION

Follow-up (repairs, maintenance or test resulting from this inspection): _____

Comments: _____

Number of Persons in Patrol Party: 2

Signature of Person in Charge of Patrol Party: [Signature]

Date: 1/5/22