

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

CITY OF DRAKESBORO D/B/A)
DRAKESBORO NATURAL GAS)
COMPANY)
_____)

ELECTRONIC INVESTIGATION OF ALLEGED)
FAILURE TO COMPLY WITH)
KRS 278.495, 807 KAR 5:027, AND)
49 C.F.R. PART 192)

CASE NO.
2019-00065

AMENDED NOTICE OF GAS LINE PENETRATION

Comes now, the City of Drakesboro (hereafter the "City"), by counsel, and hereby serves notice of penetration or cutting of a line in its system.

The City states that the line cut was at 160 Woodruff Lane, Beech Creek, Kentucky 42321 by the customer, Christopher Steele. The line was cut when the customer dug out an area for the purpose of performing construction work on March 24, 2019.

The meter number for the location is 20744152 and the meter reading was 0066.


The line was a ½ Polly with Tracer Wire.

The line was fixed with 2 x ½ Stab couplings, approximately 12 inches of ½ polly pipe and 16 inches of tracer wire, as well as 2 silicone filled sealed wire nuts and wrapped with black electrical tape.

For further information, the City may be contacted.

Respectfully submitted,


YONTS, SHERMAN & DRISKILL, P.S.C.



Ryan Driskill
P.O. Box 370
Greenville, KY 42345
rdrisk@hotmail.com
Phone: 270.338.0816
Fax: 270.338.0816

CERTIFICATE OF SERVICE

This is to certify that the above notice was filed electronically on this the 9th day of May, 2019 and served upon the Honorable John Parks by electronic mail at John.Park@ky.gov.



Ryan Bennett Driskill