

PIPELINE TEST REPORT

FORM 16

OPERATING COMPANY: Drakeford Gas

Testing Company: Donald Sims/Martin Anderson

This form must be completed for each section of newly installed section of pipe or service line and on each service line that is disconnected from the main for any reason.

Test Data

Type of Pipe: Rally  
Size of Pipe: 2 1/2 inches  
Length of Line: 500 Ft  
Location of Line: City Building

Tested with: Nitrogen ( )  
Air (  )  
Natural Gas ( )  
Water ( )

Other (describe):  
Time Started: 2:15 a.m./p.m. ( p.m. )  
Test Pressure Start: 90 psig  
Test Pressure Stop: 90 psig  
Line Loss: Yes  No   
Amount Loss: \_\_\_\_\_ mcf  
Reason for Line Loss: \_\_\_\_\_

Corrective Measures Taken: \_\_\_\_\_

Remarks: \_\_\_\_\_

Company Representative: Donald Sims  
Signature: [Signature]  
Date: 6-26-19