

CITY OF DRAKESBORO

P.O. Box 129 • Mose Rager Blvd. • Drakesboro, KY 42337
270-476-8986
(888) 662-2406 (Voice/TTY); (866) 557-5762 (Español)



I said may be tomorrow.

Drakesboro Work Order

Work Order #: _____

Date: 6/13/22 Time: _____ Gas Water WW Acct #: 50-80501-02

Name: Steven Smith Mobile Number: 270-225-0844

Address: 175 Corum Landing

Work to be Done:

New Meter# 17242259 New Reading 0* 2777

Turn on & Read _____ Old Reading _____

Read and Lock _____ Set Meter and Lock _____

Reading Only _____ Locate Line (See Below)

Read and Lock (Nonpayment) _____ Get Meter
Number _____

Check Pressure _____ Flush Line _____ Check & Leak _____

Unlock Only and Read (Do Not Turn On) _____

Special Instructions move Gas meter back from House
See if possible - he has to dig at the house where
its located to repair wall. . . . Just see if possible.

Work Done:

Flushed: Yes No GPM: _____ How Long: _____ Water Logs: **COMPLETED**
Water Leak: Yes No GPM: _____ How Long: _____ Water Logs: By: MA Date: 6/13/22

Parts Used to Complete Job: stab fittings

50' foot poly
new riser

Comments: Going to figure bill to move service out
away from house for wall repair to be done

Work Completed By: BA & BJ Date Completed: 6-14-2022

Time Started: _____ Time Ended: _____

Customer signature _____ date _____

Equal Opportunity Employer and Service Provider

The employees of Drakesboro are not trained HVAC personnel. Lighting of pilots are a courtesy and the City can not be held liable.



CITY OF DRAKESBORO

P.O. Box 129 • Mose Rager Blvd. • Drakesboro, KY 42337
270-476-8986
(888) 662-2406 (Voice/TTY); (866) 557-5762 (Español)

Drakesboro Work Order

Work Order #: _____

Date: 6-14-2022 Time: _____ Gas Water WW Acct #: 10-2710-2

Name: Sherry Grubbs Mobile Number: (270)478-8546

Address: 3827 US Highway 431 South

Work to be Done:

New Meter# 485963 New Reading 6943

Turn on & Read _____ Old Reading _____

Read and Lock _____ Set Meter and Lock _____

Reading Only _____ Locate Line (See Below)

Read and Lock (Nonpayment) _____ Get Meter
Number _____

Check Pressure _____ Flush Line _____ Check & Leak _____

Unlock Only and Read (Do Not Turn On) _____

Special Instructions _____

COMPLETED

By: MA Date: 6/14/22

Work Done:

Flushed: Yes No GPM: _____ How Long: _____ Water Logs: _____

Water Leak: Yes No GPM: _____ How Long: _____ Water Logs: _____

Parts Used to Complete Job:

2- insulated spuds & gaskets

1- 1" inch shut off valve

Comments: Found leaks ground shut off valve and insulated spuds replaced all checked for leaks, no leaks found painted meter set

Work Completed By: BA & BJ Date Completed: 6-14-2022

Time Started: _____ Time Ended: _____

Customer signature _____ date _____

Equal Opportunity Employer and Service Provider

The employees of Drakesboro are not trained HVAC personnel. Lighting of pilots are a courtesy and the City can not be held liable.



CITY OF DRAKESBORO

P.O. Box 129 • Mose Rager Blvd. • Drakesboro, KY 42337
270-476-8986
(888) 662-2406 (Voice/TTY); (866) 557-5762 (Español)

Drakesboro Work Order

Work Order #: _____

Date: 6-11-2022 Time: _____

Gas Water WW Acct #: 10-2710-2

Name: Sherry Grubbs

Mobile Number: _____

Address: 3827 US Hwy 431

Work to be Done:

New Meter# 485963 New Reading 6943

Turn on & Read _____ Old Reading _____

Read and Lock _____ Set Meter and Lock _____

Reading Only _____ Locate Line (See Below)

Read and Lock (Nonpayment) _____ Get Meter
Number _____

Check Pressure _____ Flush Line _____ Check & Leak _____

Unlock Only and Read (Do Not Turn On) _____

Special Instructions _____

COMPLETED

By: MA Date: 6/11/22

Work Done:

Flushed: Yes No GPM: _____ How Long: _____ Water Logs: _____

Water Leak: Yes No GPM: _____ How Long: _____ Water Logs: _____

Parts Used to Complete Job:

Comments: Neighbors advised they had smelled gas checked inside house found small leaks at stove and furnace feed line shut gas off at meter until repairs can be made

Work Completed By: B. Jones Date Completed: 6-11-2022

Time Started: _____ Time Ended: _____

Customer signature _____ date _____

The employees of Drakesboro are not trained HVAC personnel. Lighting of pilots are a courtesy and the City can not be held liable.

Incident Number: 22-019743

Incident Type: E911

Incident State: CLOSED

Global Number:

Linked Numbers:

Incident Detail

Received At:	Created At:	Dispatched At:	Created By:
06/11/2022 22:41:08	06/11/2022 22:41:08	06/11/2022 22:41:27	MBURKET

Event Type: GAS LEAK

Incident Case Numbers:

Incident Dispositions: CALL COMPLETED

Disposition Comment:

Caller Location: 3827 U S HIGHWAY 431 S, BEECHMONT [235] (37.166609, -87.033938)

Event Location: 3827 U S HIGHWAY 431 S, BEECHMONT [235] (37.166609, -87.033938)

Location Kind: CIVIC ADDRESS

Caller Name: STA 5 / DBORO GAS

Business Name:

Phone Number:	Service Class:	Cell Sector:	Callback Number:
---------------	----------------	--------------	------------------

Comment:

Event Type Log

Event Type By	Event Type At	Event Type
MBURKET	06/11/2022 22:41:19	GAS LEAK

Location Log

Location By	Location At	Location Kind	Location
MBURKET	06/11/2022 22:41:14	CIVIC ADDRESS	3827 U S HIGHWAY 431 S, BEECHMONT [235] (37.166609, -87.033938)

Disposition Log

Disposition By	Disposition At	Disposition
MBURKET		CALL COMPLETED

Incident State Log

Incident State By	Incident State At	Incident State
MBURKET	06/11/2022 22:41:08	CREATED
MBURKET	06/11/2022 22:41:27	DISPATCHED
MBURKET	06/11/2022 22:55:57	CLOSED

Category Log

Category: EMS

Event Type At: 06/11/2022 22:41:08


Event Type:

Response Area: EMS ESN 235

Final Disposition:

Category Event Type Log

Event Type By	Event Type At	Event Type
---------------	---------------	------------



* 1:00pm
Tomorrow
Call before
hand.

CITY OF DRAKESBORO

P.O. Box 129 • Mose Rager Blvd. • Drakesboro, KY 42337
270-476-8986
(888) 662-2406 (Voice/TTY); (866) 557-5762 (Español)

Drakesboro Work Order

Work Order #: _____

Date: 6/27/22 Time: _____ Gas Water WW Acct #: 20-18320-2
Name: Ladleana Timothy Schmidt Mobile Number: 248-515-2175
Address: 111 Chumley Ln.

Work to be Done:

- New Meter# 486211 New Reading _____
- Turn on & Read 3450 Old Reading 3450 4/1/22
- Read and Lock _____ Set Meter and Lock _____
- Reading Only _____ Locate Line (See Below)
- Read and Lock (Nonpayment) _____ Get Meter _____
- Number _____
- Check Pressure _____ Flush Line _____ Check & Leak _____
- Unlock Only and Read (Do Not Turn On) _____

Special Instructions Customer says gas is still on. Previous customer had left w/no contact. The shut off work order was do for non-payment. is it on?

Work Done:

Flushed: Yes No GPM: _____ How Long: _____ Water Logs: _____
Water Leak: Yes No GPM: _____ How Long: _____ Water Logs: _____

Parts Used to Complete Job:

New customer info?
- Closed out Shelma Chumleys

Comments:

Work Completed By: R. Alford Date Completed: 6/28/22

Time Started: _____ Time Ended: _____

Customer signature _____ date _____

Equal Opportunity Employer and Service Provider

The employees of Drakesboro are not trained HVAC personnel. Lighting of pilots are a courtesy and the City can not be held liable.

COMPLETED
By: MA Date: 6/30/22



CITY OF DRAKESBORO

P.O. Box 129 • Mose Rager Blvd. • Drakesboro, KY 42337
270-476-8986
(888) 662-2406 (Voice/TTY); (866) 557-5762 (Español)

Drakesboro Work Order

Work Order #: _____

Date: 6-11-2022 Time: _____ Gas Water WW Acct #: _____

Name: Vincent Snodgrass Mobile Number: _____

Address: 3795 US Highway 431 South

Work to be Done:

New Meter# 486398 New Reading 1314

Turn on & Read _____ Old Reading _____

Read and Lock _____ Set Meter and Lock _____

Reading Only _____ Locate Line (See Below)

Read and Lock (Nonpayment) _____ Get Meter
Number _____

Check Pressure _____ Flush Line _____ Check & Leak _____

Unlock Only and Read (Do Not Turn On) _____

Special Instructions _____

COMPLETED

By: MA Date: 6/11/22

Work Done:

Flushed: Yes No GPM: _____ How Long: _____ Water Logs: _____

Water Leak: Yes No GPM: _____ How Long: _____ Water Logs: _____

Parts Used to Complete Job: _____

Comments: Gas leaks found in basement at joints in pipe
advised homeowner gas shut off at meter until repairs
could be made

Work Completed By: B. Jones Date Completed: 6-11-2022

Time Started: _____ Time Ended: _____

Customer signature _____ date _____

Equal Opportunity Employer and Service Provider

The employees of Drakesboro are not trained HVAC personnel. Lighting of pilots are a courtesy and the City can not be held liable.

Incident Number: 22-019727

Incident Type: E911

Incident State: CLOSED

Global Number:

Linked Numbers:

Incident Detail

Received At:	Created At:	Dispatched At:	Created By:
06/11/2022 21:57:42	06/11/2022 21:57:42	06/11/2022 21:58:45	MBURKET

Event Type: GAS LEAK

Incident Case Numbers:

Incident Dispositions: CALL COMPLETED

Disposition Comment:

Caller Location: 3795 U S HIGHWAY 431 S, BEECHMONT [235] (37.167087, -87.033979)

Event Location: 3795 U S HIGHWAY 431 S, BEECHMONT [235] (37.167087, -87.033979)

Location Kind: CIVIC ADDRESS

Caller Name: ASHLEY SNODGRASS

Business Name:

Phone Number: (270)-608-1574

Service Class:

Cell Sector:

Callback Number:

Comment: STRONG SMELL OF GAS IN THE HOME

Narrative Log

Narrative By	Narrative At	Category	Is Sensitive	Narrative
MBURKET	06/11/2022 22:06:38		NO	BRIAN JONES W/ DRAKESBORO GAS ENROUTE
BLANDRUM	06/11/2022 22:13:06		NO	BRIAN ON SCENE
JNINIS	06/11/2022 22:37:55		NO	510 ENROUTE TO NEIGHBORS, ADV THEY HAVE GAS LEAK TOO, WILL ADV ADDRESS UPON
JNINIS	06/11/2022 22:38:02		NO	10-97

Event Type Log

Event Type By	Event Type At	Event Type
MBURKET	06/11/2022 21:57:53	GAS LEAK

Location Log

Location By	Location At	Location Kind	Location
MBURKET	06/11/2022 21:57:48	CIVIC ADDRESS	3795 U S HIGHWAY 431 S, BEECHMONT [235] (37.167087, -87.033979)

Disposition Log

Disposition By	Disposition At	Disposition
BLANDRUM	06/11/2022 22:43:38	CALL COMPLETED

Incident State Log

Incident State By	Incident State At	Incident State
MBURKET	06/11/2022 21:57:42	CREATED
JNINIS	06/11/2022 21:58:45	DISPATCHED
MBURKET	06/11/2022 21:58:45	DISPATCHED
BLANDRUM	06/11/2022 22:43:38	CLOSED

ENROUTE	06/11/2022 22:08:40	BLANDRUM	NO
ON SCENE	06/11/2022 22:10:15	BLANDRUM	NO
CLEAR	06/11/2022 22:37:10	JNINIS	NO



CITY OF DRAKESBORO

P.O. Box 129 • Mose Rager Blvd. • Drakesboro, KY 42337
270-476-8986
(888) 662-2406 (Voice/TTY); (866) 557-5762 (Español)

Drakesboro Work Order

Work Order #: _____

Date: 6-14-2022 Time: _____ Gas Water WW Acct #: _____

Name: Vincent Snodgrass Mobile Number: _____

Address: 3795 US Highway 431 South

Work to be Done:

New Meter# 486398 New Reading 1314

Turn on & Read _____ Old Reading _____

Read and Lock _____ Set Meter and Lock _____

Reading Only _____ Locate Line (See Below)

Read and Lock (Nonpayment) _____ Get Meter _____

Check Pressure _____ Flush Line _____ Check & Leak _____

Unlock Only and Read (Do Not Turn On) _____

Special Instructions _____

COMPLETED

By: MA Date: 6/16/22

*Put in final
6/29/22
SNG*

Work Done:

Flushed: Yes No GPM: _____ How Long: _____ Water Logs: _____

Water Leak: Yes No GPM: _____ How Long: _____ Water Logs: _____

Parts Used to Complete Job:

Comments: off for while due to leaks underground

Work Completed By: B. Jones Date Completed: 6-15-2022

Time Started: _____ Time Ended: _____

Customer signature _____ date _____

Equal Opportunity Employer and Service Provider

The employees of Drakesboro are not trained HVAC personnel. Lighting of pilots are a courtesy and the City can not be held liable.



CITY OF DRAKESBORO

P.O. Box 129 • Mose Rager Blvd. • Drakesboro, KY 42337
270-476-8986
(888) 662-2406 (Voice/TTY); (866) 557-5762 (Español)

Drakesboro Work Order

Work Order #: _____

Date: 6/20/22 Time: _____ Gas Water WW Acct #: 10-2700-007

Name: Vincent Snodgrass Mobile Number: (270) 608-1574

Address: 3705 US Hwy 431 S

Work to be Done:

New Meter# 486398 ✓ New Reading 1314 ✓

Turn on & Read _____ Old Reading 1294

Read and Lock _____ Set Meter and Lock

Reading Only _____ Locate Line (See Below)

Read and Lock (Nonpayment) _____ Get Meter
Number _____

Check Pressure _____ Flush Line _____ Check & Leak _____

Unlock Only and Read (Do Not Turn On) _____

Special Instructions LUKE MCKEMIE (270) 584-2925

COMPLETED

By: smg Date: 6/29

Work Done:

Flushed: Yes No GPM: _____ How Long: _____ Water Logs: _____

Water Leak: Yes No GPM: _____ How Long: _____ Water Logs: _____

Parts Used to Complete Job: _____

_____ Inactive

_____ Final Billing

_____ cust. will eventually turn back on.

Comments: Small leak on main shut off valve to be

repaired another shut off valve installed piping

checked / pulled gas meter

Work Completed By: BA4 BJ Date Completed: 6-20-2022

Time Started: _____ Time Ended: _____

Customer signature [Signature] date _____

Equal Opportunity Employer and Service Provider

The employees of Drakesboro are not trained HVAC personnel. Lighting of pilots are a courtesy and the City can not be held liable.



CITY OF DRAKESBORO

P.O. Box 129 • Mose Rager Blvd. • Drakesboro, KY 42337
270-476-8986
(888) 662 - 2406 (Voice/TTY); (866) 557 - 5762 (Español)

Drakesboro Work Order

Work Order #: _____

Date: 6-15-2022 Time: _____ Gas Water WW Acct #: _____

Name: Mary's Mobile Number: _____

Address: 3454 Hwy 431 South

Work to be Done:

New Meter# _____ New Reading _____

Turn on & Read _____ Old Reading _____

Read and Lock _____ Set Meter and Lock _____

Reading Only _____ Locate Line _____ (See Below)

Read and Lock (Nonpayment) _____ Get Meter
Number _____

Check Pressure _____ Flush Line _____ Check & Leak _____

Unlock Only and Read (Do Not Turn On) _____

Special Instructions _____

Work Done:

Flushed: Yes No GPM: _____ How Long: _____ Water Logs: _____

Water Leak: Yes No GPM: _____ How Long: _____ Water Logs: _____

Parts Used to Complete Job:

Comments: Received call of possible gas smell in area only found small leak at 3418 Hwy 431 South took apart meter pipes and repaired

Work Completed By: BA & BJ Date Completed: 6-15-2022

Time Started: _____ Time Ended: _____

Customer signature _____ date _____

Equal Opportunity Employer and Service Provider

The employees of Drakesboro are not trained HVAC personnel. Lighting of pilots are a courtesy and the City can not be held liable.

Incident Number: 22-020234

Incident Type: E911

Incident State: DISPATCHED

Global Number:

Linked Numbers:

Incident Detail

Received At:	Created At:	Dispatched At:	Created By:
06/15/2022 13:34:14	06/15/2022 13:34:14	06/15/2022 13:34:54	JFORD

Event Type: GAS LEAK

Incident Case Numbers:

Incident Dispositions:

Disposition Comment:

Caller Location: 3454 U S HIGHWAY 431 S, BEECHMONT [235] (37.172088, -87.033392)

Event Location: 3454 U S HIGHWAY 431 S, BEECHMONT [235] (37.172088, -87.033392)

Location Kind: CIVIC ADDRESS

Caller Name: MAX FUEL

Business Name:

Phone Number:

Service Class:

Cell Sector:

Callback Number: 2704763998

Comment: GAS SMELL IN THE AREA

Narrative Log

Narrative By	Narrative At	Category	Is Sensitive	Narrative
RAVERY	06/15/2022 13:36:40		NO	D'BORO GAS NOTIFIED - MIKE JONES MESSAGE LEFT
RAVERY	06/15/2022 13:37:18		NO	BRIAN JONES NOTIFIED 10-76
JNINIS	06/15/2022 13:44:17		NO	BRIAN JONES 10-97
RAVERY	06/15/2022 13:46:29		NO	GAS CO 10-97 AUTH E53

Event Type Log

Event Type By	Event Type At	Event Type
JFORD	06/15/2022 13:34:23	GAS LEAK

Location Log

Location By	Location At	Location Kind	Location
JFORD	06/15/2022 13:34:19	CIVIC ADDRESS	3454 U S HIGHWAY 431 S, BEECHMONT [235] (37.172088, -87.033392)

Incident State Log

Incident State By	Incident State At	Incident State
JFORD	06/15/2022 13:34:14	CREATED
JFORD	06/15/2022 13:34:54	DISPATCHED
RAVERY	06/15/2022 13:34:54	DISPATCHED

Category Log

Category: EMS

Event Type At: 06/15/2022 13:34:14

Event Type:

Response Area: EMS ESN 235

Final Disposition:



CITY OF DRAKESBORO

P.O. Box 129 • Mose Rager Blvd. • Drakesboro, KY 42337
270-476-8986
(888) 662-2406 (Voice/TTY); (866) 557-5762 (Español)

Drakesboro Work Order

Work Order #: _____

Date: 6/22/22 Time: 11:45 Gas Water WW Acct #: 50-72700-04
Name: Peter Porter Mobile Number: 820-5906
Address: 710 Hazel Creek Rd

Work to be Done:

New Meter# 216332 New Reading 8435
Turn on & Read _____ Old Reading 8427 (5-27-22)
Read and Lock _____ Set Meter and Lock
Reading Only _____ Locate Line (See Below)
Read and Lock (Nonpayment) _____ Get Meter
Number _____
Check Pressure _____ Flush Line _____ Check & Leak _____
Unlock Only and Read (Do Not Turn On) _____
Special Instructions Check for leaks at meter please

COMPLETED
By: MA Date: 6/22/22

Work Done:

Flushed: Yes No GPM: _____ How Long: _____ Water Logs: _____
Water Leak: Yes No GPM: _____ How Long: _____ Water Logs: _____

Parts Used to Complete Job:

Comments: Checked outside meter connections no bubbles checked inside with cgi on piping and appliances no leaks

Work Completed By: BA & BJ Date Completed: 6-22-2022

Time Started: _____ Time Ended: _____

Customer signature _____ date _____



CITY OF DRAKESBORO

P.O. Box 129 • Mose Rager Blvd. • Drakesboro, KY 42337
270-476-8986
(888) 662-2406 (Voice/TTY); (866) 557-5762 (Español)

Drakesboro Work Order

Work Order #: 62322

Date: 6/23/22 Time: 8:40 Gas Water WW Acct #: 2-9550-01

Name: Dana Robertson Howard Mobile Number: 602-7816

Address: 101 Thom Bresh

Work to be Done:

New Meter# _____ New Reading 1541

Turn on & Read _____ Old Reading _____

Read and Lock _____ Set Meter and Lock _____

Reading Only _____ Locate Line (See Below)

Read and Lock (Nonpayment) _____ Get Meter
Number _____

Check Pressure _____ Flush Line _____ Check & Leak _____

Unlock Only and Read (Do Not Turn On) _____

Special Instructions Her riser was done into a year ago. Lloyd Sorrels came to fix it + put in a welding piece. Over a year ago Brian was going to replace the riser go look + fix it please.

Work Done:

Flushed: Yes No GPM: _____ How Long: _____

Water Leak: Yes No GPM: _____ How Long: _____

Water Logs **COMPLETED**
By: AAA Date: 6/24/22

Parts Used to Complete Job:

Comments: 55 psi at outside faucet going to replace with new line from main and new settler in the next few weeks

Work Completed By: BA + BJ Date Completed: 6-23-2022

Time Started: _____ Time Ended: _____

Customer signature _____ date _____



CITY OF DRAKESBORO

P.O. Box 129 • Mose Rager Blvd. • Drakesboro, KY 42337
270-476-8986
(888) 662 - 2406 (Voice/TTY); (866) 557 - 5762 (Español)

Drakesboro Work Order

Work Order #: _____

Date: 6-23-2022 Time: _____ Gas Water WW Acct #: _____

Name: _____ Mobile Number: _____

Address: Highway 431 before Hwy 70

Work to be Done:

New Meter# _____ New Reading _____

Turn on & Read _____ Old Reading _____

Read and Lock _____ Set Meter and Lock _____

Reading Only _____ Locate Line (See Below) _____

Read and Lock (Nonpayment) _____ Get Meter
Number _____

Check Pressure _____ Flush Line _____ Check & Leak _____

Unlock Only and Read (Do Not Turn On) _____

Special Instructions _____

Work Done:

Flushed: Yes No GPM: _____ How Long: _____ Water Logs: _____

Water Leak: Yes No GPM: _____ How Long: _____ Water Logs: _____

COMPLETED
By: AAA Date: 6/24/22

Parts Used to Complete Job:

Comments: Line markers placed next to 3 abandoned services on this road that have been inactive for a long period or are no longer using natural gas

Work Completed By: BA & BJ Date Completed: 6-23-2022

Time Started: _____

Time Ended: _____

Customer signature _____ date _____

Equal Opportunity Employer and Service Provider

The employees of Drakesboro are not trained HVAC personnel. Lighting of pilots are a courtesy and the City can not be held liable.



CITY OF DRAKESBORO

P.O. Box 129 • Mose Rager Blvd. • Drakesboro, KY 42337
270-476-8986
(888) 662 - 2406 (Voice/TTY); (866) 557 - 5762 (Español)

Drakesboro Work Order

Work Order #: _____

Date: 6-23-2022 Time: _____ Gas Water WW Acct #: _____

Name: _____ Mobile Number: _____

Address: Disney Hill Road

Work to be Done:

New Meter# _____ New Reading _____

Turn on & Read _____ Old Reading _____

Read and Lock _____ Set Meter and Lock _____

Reading Only _____ Locate Line (See Below) _____

Read and Lock (Nonpayment) _____ Get Meter _____
Number _____

Check Pressure _____ Flush Line _____ Check & Leak _____

Unlock Only and Read (Do Not Turn On) _____

Special Instructions _____

Work Done:

Flushed: Yes No GPM: _____ How Long: _____ Water Logs: _____

Water Leak: Yes No GPM: _____ How Long: _____ Water Logs: _____

Parts Used to Complete Job:

Comments: Line markers placed next to meters that are not active or are on abandoned properties

Work Completed By: BA + BJ Date Completed: 6-23-2022

Time Started: _____ Time Ended: _____

Customer signature _____ date _____

Equal Opportunity Employer and Service Provider

The employees of Drakesboro are not trained HVAC personnel. Lighting of pilots are a courtesy and the City can not be held liable.

COMPLETED
By: MA Date: 6/23/22



CITY OF DRAKESBORO

P.O. Box 129 • Mose Rager Blvd. • Drakesboro, KY 42337
270-476-8986
(888) 662-2406 (Voice/TTY); (866) 557-5762 (Español)

Drakesboro Work Order

Work Order #: 61022

Date: 6-10-22 Time: _____ Gas Water WW Acct #: 30-35400-03

Name: Judy Westbrook Mobile Number: 270-543-0707

Address: 389 Merle Travis Hwy Drakesboro Ky 42337

Work to be Done:

New Meter# 6-2002 New Reading _____

Turn on & Read _____ Old Reading 4148 5/27/22

Read and Lock _____ Set Meter and Lock

Reading Only 4150 Locate Line (See Below)

Read and Lock (Nonpayment) _____ Get Meter
Number _____

Check Pressure _____ Flush Line _____ Check & Leak _____

Unlock Only and Read (Do Not Turn On) _____

Special Instructions for a final billing - new owners

COMPLETED

By: MA Date: 6/22/22

Work Done:

Flushed: Yes No GPM: _____ How Long: _____ Water Logs: _____

Water Leak: Yes No GPM: _____ How Long: _____ Water Logs: _____

Parts Used to Complete Job:

Comments: Forwarding Address 11020 State Route 175 S
Greenville Ky 42345

Work Completed By: B. Alled Date Completed: 6/13/22

Time Started: _____ Time Ended: _____

Customer signature _____ date _____

Equal Opportunity Employer and Service Provider

The employees of Drakesboro are not trained HVAC personnel. Lighting of pilots are a courtesy and the City can not be held liable.



CITY OF DRAKESBORO

P.O. Box 129 • Mose Rager Blvd. • Drakesboro, KY 42337
270-476-8986
(888) 662 - 2406 (Voice/TTY); (866) 557 - 5762 (Español)

Drakesboro Work Order

Work Order #: _____

Date: 6/10/22 Time: _____ Gas Water WW Acct #: _____

Name: Bobby Lewis Mobile Number: _____

Address: 389 Merle Travis Hwy Drakesboro

Work to be Done:

New Meter# 6-2002 New Reading _____

Turn on & Read _____ Old Reading _____

Read and Lock _____ Set Meter and Lock _____

Reading Only 4150 Locate Line (See Below)

Read and Lock (Nonpayment) _____ Get Meter
Number _____

Check Pressure _____ Flush Line _____ Check & Leak _____

Unlock Only and Read (Do Not Turn On) _____

Special Instructions New customer - Deposit made -

COMPLETED

By: MA Date: 6/22/22

Work Done:

Flushed: Yes No GPM: _____ How Long: _____ Water Logs: _____

Water Leak: Yes No GPM: _____ How Long: _____ Water Logs: _____

Parts Used to Complete Job:

Comments:

Work Completed By: _____ Date Completed: _____

Time Started: _____ Time Ended: _____

Customer signature _____ date _____

Equal Opportunity Employer and Service Provider

The employees of Drakesboro are not trained HVAC personnel. Lighting of pilots are a courtesy and the City can not be held liable.



CITY OF DRAKESBORO

P.O. Box 129 • Mose Rager Blvd. • Drakesboro, KY 42337
270-476-8986
(888) 662 - 2406 (Voice/TTY); (866) 557 - 5762 (Español)

Drakesboro Work Order

Work Order #: _____

Date: 6/20/22 Time: _____ Gas Water WW Acct #: 30-42250-2

Name: Tara Charbeaune Mobile Number: _____

Address: 307 guitar

Work to be Done:

New Meter# 2012681 New Reading _____

Turn on & Read _____ Old Reading _____

Read and Lock _____ Set Meter and Lock _____

Reading Only 8431 Locate Line (See Below)

Read and Lock (Nonpayment) _____ Get Meter
Number _____

Check Pressure _____ Flush Line _____ Check & Leak _____

Unlock Only and Read (Do Not Turn On) _____

Special Instructions Sold home

COMPLETED

By: MA Date: 6/22/22

Work Done:

Flushed: Yes No GPM: _____ How Long: _____ Water Logs: _____

Water Leak: Yes No GPM: _____ How Long: _____ Water Logs: _____

Parts Used to Complete Job: _____

Comments: _____

Work Completed By: B. Jones Date Completed: 6-20-2022

Time Started: _____ Time Ended: _____

Customer signature _____ date _____

Equal Opportunity Employer and Service Provider

The employees of Drakesboro are not trained HVAC personnel. Lighting of pilots are a courtesy and the City can not be held liable.



CITY OF DRAKESBORO

P.O. Box 129 • Mose Rager Blvd. • Drakesboro, KY 42337
270-476-8986
(888) 662 - 2406 (Voice/TTY); (866) 557 - 5762 (Español)

Drakesboro Work Order

Work Order #: _____

Date: 6/20/22 Time: _____ Gas Water WW Acct #: 30-42250-3

Name: Colton Ashby Mobile Number: (270) 931-0039

Address: 307 Guitar Ave.

Work to be Done:

New Meter# _____ New Reading _____

Turn on & Read _____ Old Reading _____

Read and Lock _____ Set Meter and Lock _____

Reading Only _____ Locate Line (See Below)

Read and Lock (Nonpayment) _____ Get Meter
Number _____

Check Pressure _____ Flush Line _____ Check & Leak _____

Unlock Only and Read (Do Not Turn On) _____

Special Instructions New customer

COMPLETED

By: MA Date: 6/20/22

Work Done:

Flushed: Yes No GPM: _____ How Long: _____ Water Logs: _____

Water Leak: Yes No GPM: _____ How Long: _____ Water Logs: _____

Parts Used to Complete Job:

Comments:

Work Completed By: B. Jones Date Completed: 6-20-2022

Time Started: _____ Time Ended: _____

Customer signature _____ date _____

Equal Opportunity Employer and Service Provider

The employees of Drakesboro are not trained HVAC personnel. Lighting of pilots are a courtesy and the City can not be held liable.



CITY OF DRAKESBORO

P.O. Box 129 • Mose Rager Blvd. • Drakesboro, KY 42337
270-476-8986
(888) 662-2406 (Voice/TTY); (866) 557-5762 (Español)

Drakesboro Work Order

Work Order #: _____

Date: 6-16-2022 Time: _____ Gas Water WW Acct #: _____

Name: Zack Brigance Mobile Number: 270-225-0452

Address: 3418 US Highway 431

Work to be Done:

New Meter# 19M365720 New Reading 1005

Turn on & Read _____ Old Reading _____

Read and Lock _____ Set Meter and Lock _____

Reading Only _____ Locate Line (See Below) _____

Read and Lock (Nonpayment) _____ Get Meter
Number _____

Check Pressure _____ Flush Line _____ Check & Leak _____

Unlock Only and Read (Do Not Turn On) _____

Special Instructions _____

Work Done:

Flushed: Yes No GPM: _____ How Long: _____ Water Logs: _____

Water Leak: Yes No GPM: _____ How Long: _____ Water Logs: _____

Parts Used to Complete Job: _____

Comments: Took meter apart due to finding leaks on shut off valve and reducer, repaired meter and piping checked for leaks, no leaks painted all of meter pipes

Work Completed By: BA & BJ Date Completed: 6-16-2022

Time Started: _____ Time Ended: _____

Customer signature _____ date _____

Equal Opportunity Employer and Service Provider

The employees of Drakesboro are not trained HVAC personnel. Lighting of pilots are a courtesy and the City can not be held liable.



CITY OF DRAKESBORO

P.O. Box 129 • Mose Rager Blvd. • Drakesboro, KY 42337
270-476-8986
(888) 662-2406 (Voice/TTY); (866) 557-5762 (Español)

Mose

Drakesboro Work Order

Work Order #: _____

Date: 6/8/22 Time: 8:27 Gas Water WW Acct #: _____

Name: Porters parking area Mobile Number: _____

Address: _____

Work to be Done:

New Meter# 19M366174 New Reading 5436

Turn on & Read _____ Old Reading _____

Read and Lock _____ Set Meter and Lock _____

Reading Only _____ Locate Line (See Below)

Read and Lock (Nonpayment) _____ Get Meter
Number _____

Check Pressure _____ Flush Line _____ Check & Leak _____

Unlock Only and Read (Do Not Turn On) _____

Special Instructions _____

COMPLETED

By: MA Date: 6/14/22

Work Done:

Flushed: Yes No GPM: _____ How Long: _____ Water Logs: _____

Water Leak: Yes No GPM: _____ How Long: _____ Water Logs: _____

Parts Used to Complete Job: _____

Comments: Replaced 1" nipple and coupling/union on service

Work Completed By: BA + BJ Date Completed: 6-8-2022

Time Started: _____ Time Ended: _____

Customer signature _____ date _____

Equal Opportunity Employer and Service Provider

The employees of Drakesboro are not trained HVAC personnel. Lighting of pilots are a courtesy and the City can not be held liable.



CITY OF DRAKESBORO

P.O. Box 129 • Mose Rager Blvd. • Drakesboro, KY 42337
270-476-8986
(888) 662 - 2406 (Voice/TTY); (866) 557 - 5762 (Español)

Drakesboro Work Order

Work Order #: 61322

Date: 6/13/22 Time: _____ Gas Water WW Acct #: 20-22650-1

Name: Beech Creek Missionary Mobile Number: 270-847-6764

Address: 50 Church Loop Beech Creek

Work to be Done:

New Meter# _____ New Reading _____

Turn on & Read _____ Old Reading _____

Read and Lock 7148 Set Meter and Lock

Reading Only _____ Locate Line (See Below)

Read and Lock (Nonpayment) _____ Get Meter
Number _____

Check Pressure _____ Flush Line _____ Check & Leak _____

Unlock Only and Read (Do Not Turn On) _____

Special Instructions turn off for the summer.

COMPLETED

By: MA Date: 6/13/22

Work Done:

Flushed: Yes No GPM: _____ How Long: _____ Water Logs: _____

Water Leak: Yes No GPM: _____ How Long: _____ Water Logs: _____

Parts Used to Complete Job:

Comments:

Work Completed By: By Alled Date Completed: 6/13/22

Time Started: _____ Time Ended: _____

Customer signature _____ date _____

Equal Opportunity Employer and Service Provider

The employees of Drakesboro are not trained HVAC personnel. Lighting of pilots are a courtesy and the City can not be held liable.



CITY OF DRAKESBORO

P.O. Box 129 • Mose Rager Blvd. • Drakesboro, KY 42337
270-476-8986
(888) 662 - 2406 (Voice/TTY); (866) 557 - 5762 (Español)

Drakesboro Work Order

Work Order #: 01322

Date: 6/13/22 Time: _____ Gas Water WW Acct #: 40-56640-04

Name: Ronnie Brooks Freedom Mobile Number: _____

Address: 100 mine st ministries

Work to be Done:

New Meter# ZOP213487 New Reading 844

Turn on & Read _____ Old Reading _____

Read and Lock _____ Set Meter and Lock _____

Reading Only _____ Locate Line (See Below)

Read and Lock (Nonpayment) _____ Get Meter
Number _____

Check Pressure _____ Flush Line _____ Check & Leak _____

Unlock Only and Read (Do Not Turn On) _____

Special Instructions Turn off for the summer

COMPLETED

By: MA Date: 6/13/22

Work Done:

Flushed: Yes No GPM: _____ How Long: _____ Water Logs: _____

Water Leak: Yes No GPM: _____ How Long: _____ Water Logs: _____

Parts Used to Complete Job:

Comments:

Work Completed By: By Almod Date Completed: 6/13/22

Time Started: _____ Time Ended: _____

Customer signature _____ date _____

Equal Opportunity Employer and Service Provider

The employees of Drakesboro are not trained HVAC personnel. Lighting of pilots are a courtesy and the City can not be held liable.



CITY OF DRAKESBORO

P.O. Box 129 • Mose Rager Blvd. • Drakesboro, KY 42337
270-476-8986
(888) 662-2406 (Voice/TTY); (866) 557-5762 (Español)

Drakesboro Work Order

Work Order #: 61322

Date: 6/13/22 Time: _____ Gas Water WW Acct #: 50-7740-1

Name: Ritchie Penticost Mobile Number: _____

Address: 102 Torie Lane

Work to be Done:

New Meter# 19910751 New Reading 0446

Turn on & Read _____ Old Reading _____

Read and Lock _____ Set Meter and Lock _____

Reading Only _____ Locate Line (See Below)

Read and Lock (Nonpayment) _____ Get Meter
Number _____

Check Pressure _____ Flush Line _____ Check & Leak _____

Unlock Only and Read (Do Not Turn On) _____

Special Instructions Turn off for summer

COMPLETED
By: MA Date: 6/13/22

Work Done:

Flushed: Yes No GPM: _____ How Long: _____ Water Logs: _____

Water Leak: Yes No GPM: _____ How Long: _____ Water Logs: _____

Parts Used to Complete Job: _____

Comments: Meter turned off and locked

Work Completed By: BA & RJ Date Completed: 6-14-2022

Time Started: _____ Time Ended: _____

Customer signature _____ date _____

Equal Opportunity Employer and Service Provider

The employees of Drakesboro are not trained HVAC personnel. Lighting of pilots are a courtesy and the City can not be held liable.



CITY OF DRAKESBORO

P.O. Box 129 • Mose Rager Blvd. • Drakesboro, KY 42337
270-476-8986
(888) 662 - 2406 (Voice/TTY); (866) 557 - 5762 (Español)

Drakesboro Work Order

Work Order #: 6722

Date: 6-7-22 Time: 11:10^{PM} Gas Water WW Acct #: 20-26530-1

Name: Shirley LeGrand Mobile Number: _____

Address: 148 Hazelcreek Rd Beechcreek

Work to be Done:

New Meter# 485927 New Reading 7925

Turn on & Read _____ Old Reading 7925 4-27-22

Read and Lock _____ Set Meter and Lock _____

Reading Only _____ Locate Line (See Below)

Read and Lock (Nonpayment) _____ Get Meter
Number _____

Check Pressure _____ Flush Line _____ Check & Leak _____

Unlock Only and Read (Do Not Turn On) _____

Special Instructions - Turn on so Reattor can spin

- Reconnect fee was paid

COMPLETED

By: MA Date: 6/8/22

Work Done:

Flushed: Yes No GPM: _____ How Long: _____ Water Logs: _____

Water Leak: Yes No GPM: _____ How Long: _____ Water Logs: _____

Parts Used to Complete Job:

Comments: Meter unlocked turned on

Work Completed By: BA + BJ Date Completed: 6-7-2022

Time Started: _____ Time Ended: _____

Customer signature _____ date _____

Equal Opportunity Employer and Service Provider

The employees of Drakesboro are not trained HVAC personnel. Lighting of pilots are a courtesy and the City can not be held liable.



CITY OF DRAKESBORO

P.O. Box 129 • Mose Rager Blvd. • Drakesboro, KY 42337
270-476-8986
(888) 662-2406 (Voice/TTY); (866) 557-5762 (Español)

Drakesboro Work Order

Work Order #: _____

Date: 6/3/22 Time: _____ Gas Water WW Acct #: 20-18750-1

Name: Harold Bratcher Mobile Number: _____

Address: 48 beechcreek Browder rd

Work to be Done:

New Meter# 21976880 New Reading 0994

Turn on & Read _____ Old Reading _____

Read and Lock _____ Set Meter and Lock _____

Reading Only _____ Locate Line (See Below)

Read and Lock (Nonpayment) _____ Get Meter
Number _____

Check Pressure _____ Flush Line _____ Check & Leak _____

Unlock Only and Read (Do Not Turn On) _____

Special Instructions Turn Off for Summer.

Needs to be turned back on before Dec. 3rd.

Work Done:

COMPLETED

Flushed: Yes No GPM: _____ How Long: _____ Water Logs: _____ By: MA Date: 6/3/22

Water Leak: Yes No GPM: _____ How Long: _____ Water Logs: _____

Parts Used to Complete Job:

Comments: Turned off for summer

Work Completed By: B. Jones Date Completed: 6-3-2022

Time Started: _____ Time Ended: _____

Customer signature _____ date _____

Equal Opportunity Employer and Service Provider

The employees of Drakesboro are not trained HVAC personnel. Lighting of pilots are a courtesy and the City can not be held liable.



CITY OF DRAKESBORO

P.O. Box 129 • Mose Rager Blvd. • Drakesboro, KY 42337
270-476-8986
(888) 662-2406 (Voice/TTY); (866) 557-5762 (Español)

Drakesboro Work Order

Work Order #: _____

Date: 4/4/22 Time: _____ Gas Water WW Acct #: 20-30050-2

Name: Whitney Keith Mobile Number: _____

Address: 60 Hillside dr.

Work to be Done:

New Meter# 486162 New Reading 8039

Turn on & Read _____ Old Reading _____

Read and Lock _____ Set Meter and Lock _____

Reading Only _____ Locate Line (See Below)

Read and Lock (Nonpayment) _____ Get Meter
Number _____

Check Pressure _____ Flush Line _____ Check & Leak _____

Unlock Only and Read (Do Not Turn On) _____

Special Instructions Bought home. New customer

Work Done:

Flushed: Yes No GPM: _____ How Long: _____

COMPLETED
Water Logs: _____
By: MA Date: 6/8/22

Water Leak: Yes No GPM: _____ How Long: _____

Parts Used to Complete Job:

Comments:

Work Completed By: B. Jones Date Completed: 6-6-2022

Time Started: _____ Time Ended: _____

Customer signature _____ date _____

Equal Opportunity Employer and Service Provider

The employees of Drakesboro are not trained HVAC personnel. Lighting of pilots are a courtesy and the City can not be held liable.



CITY OF DRAKESBORO

P.O. Box 129 • Mose Rager Blvd. • Drakesboro, KY 42337
270-476-8986
(888) 662 - 2406 (Voice/TTY); (866) 557 - 5762 (Español)

Drakesboro Work Order

Work Order #: _____

Date: 6/6/22 Time: _____ Gas Water WW Acct #: 20-30050-1

Name: William Price Mobile Number: _____

Address: 60 Hillside dr.

Work to be Done:

New Meter# 486162 New Reading 8039

Turn on & Read _____ Old Reading _____

Read and Lock _____ Set Meter and Lock _____

Reading Only _____ Locate Line (See Below)

Read and Lock (Nonpayment) _____ Get Meter _____
Number _____

Check Pressure _____ Flush Line _____ Check & Leak _____

Unlock Only and Read (Do Not Turn On) _____

Special Instructions Final billing, sold home.

Work Done:

Flushed: Yes No GPM: _____ How Long: _____ Water Logs: _____

Water Leak: Yes No GPM: _____ How Long: _____ Water Logs: _____

COMPLETED

By: MA Date: 6/8/22

Parts Used to Complete Job:

Comments:

Work Completed By: B. Jones Date Completed: 6-6-2022

Time Started: _____ Time Ended: _____

Customer signature _____ date _____

Equal Opportunity Employer and Service Provider

The employees of Drakesboro are not trained HVAC personnel. Lighting of pilots are a courtesy and the City can not be held liable.



CITY OF DRAKESBORO

P.O. Box 129 • Mose Rager Blvd. • Drakesboro, KY 42337
270-476-8986
(888) 662-2406 (Voice/TTY); (866) 557-5762 (Español)

Drakesboro Work Order

Work Order #: _____

Date: 6/6/22 Time: _____ Gas Water WW Acct #: 40-60750-1

Name: Eddie L. Brake Mobile Number: _____

Address: 201 Christian St

Work to be Done:

New Meter# 170102 New Reading 4489

Turn on & Read _____ Old Reading _____

Read and Lock _____ Set Meter and Lock _____

Reading Only _____ Locate Line (See Below)

Read and Lock (Nonpayment) _____ Get Meter
Number _____

Check Pressure _____ Flush Line _____ Check & Leak _____

Unlock Only and Read (Do Not Turn On) _____

Special Instructions Moving.

COMPLETED
By: MA Date: 6/8/22

Work Done:

Flushed: Yes No GPM: _____ How Long: _____ Water Logs: _____

Water Leak: Yes No GPM: _____ How Long: _____ Water Logs: _____

Parts Used to Complete Job:

Comments:

Work Completed By: BA + BS Date Completed: 6-7-2022

Time Started: _____ Time Ended: _____

Customer signature _____ date _____

Equal Opportunity Employer and Service Provider

The employees of Drakesboro are not trained HVAC personnel. Lighting of pilots are a courtesy and the City can not be held liable.



CITY OF DRAKESBORO

P.O. Box 129 • Mose Rager Blvd. • Drakesboro, KY 42337
270-476-8986
(888) 662-2406 (Voice/TTY); (866) 557-5762 (Español)

6/2/22 Drakesboro Work Order Work Order #: 53122
Date: 5/31/22 Time: 12:30 Gas Water WW Acct #: 10-01270-02
Name: Cyndrea Robertson Mobile Number: 873-9934
Address: 4847 US Hwy 431 S. 293-7097 or

Work to be Done:

New Meter# 20P273488 New Reading 291
Turn on & Read Old Reading _____
Read and Lock _____ Set Meter and Lock _____
Reading Only _____ Locate Line (See Below) _____
Read and Lock (Nonpayment) _____ Get Meter _____
Number _____
Check Pressure _____ Flush Line _____ Check & Leak _____
Unlock Only and Read (Do Not Turn On) _____
Special Instructions _____

COMPLETED
By: MA Date: 6/3/22

Work Done:

Flushed: Yes No GPM: _____ How Long: _____ Water Logs: _____
Water Leak: Yes No GPM: _____ How Long: _____ Water Logs: _____

Parts Used to Complete Job:

Comments: Gas unlocked turned back on

Work Completed By: BA & BJ Date Completed: 6-2-2022

Time Started: _____ Time Ended: _____

Customer signature _____ date _____

Equal Opportunity Employer and Service Provider

The employees of Drakesboro are not trained HVAC personnel. Lighting of pilots are a courtesy and the City can not be held liable.

Category Event Type Log

Event Type By Event Type At Event Type

Category: FIRE

Event Type At: 06/15/2022 13:34:14

Event Type:

Response Area: FIRE ESN 235

Final Disposition:

Category Event Type Log

Event Type By Event Type At Event Type

Category: LAW

Event Type At: 06/15/2022 13:34:14

Event Type:

Response Area: LAW ESN 235

Final Disposition:

Category Event Type Log

Event Type By Event Type At Event Type

Resource Dispatch Log

Agency Category Agency Run Numbers:

BEECHMONT FIRE DEPARTMENT

FIRE

Dispositions:

Resource Assigned Station: Resource Run Numbers:

BEECHMONT FD

Case Numbers:

Personnel:

Dispositions:

Comment:

Dispatch State	Dispatch State At	Dispatch State By	Odometer	Was Voided
DISPATCHED	06/15/2022 13:34:54	JFORD		NO

E53

Case Numbers:

Personnel:

Dispositions:

Comment:

Dispatch State	Dispatch State At	Dispatch State By	Odometer	Was Voided
DISPATCHED	06/15/2022 13:46:09	RAVERY		NO
ON SCENE	06/15/2022 13:46:09	RAVERY		NO
CLEAR	06/15/2022 13:50:21	RAVERY		NO



CITY OF DRAKESBORO

P.O. Box 129 • Mose Rager Blvd. • Drakesboro, KY 42337
270-476-8986
(888) 662 - 2406 (Voice/TTY); (866) 557 - 5762 (Español)

Drakesboro Work Order

Work Order #: _____

Date: 6/6/22 Time: _____ Gas Water WW Acct #: 40-60750-2

Name: Oscar Allen III Mobile Number: _____

Address: 201 Christian St

Work to be Done:

New Meter# 170102 New Reading 4489

Turn on & Read _____ Old Reading _____

Read and Lock _____ Set Meter and Lock _____

Reading Only _____ Locate Line (See Below)

Read and Lock (Nonpayment) _____ Get Meter
Number _____

Check Pressure _____ Flush Line _____ Check & Leak _____

Unlock Only and Read (Do Not Turn On) _____

Special Instructions _____

COMPLETED
By: MA Date: 6/8/22

Work Done:

Flushed: Yes No GPM: _____ How Long: _____ Water Logs: _____

Water Leak: Yes No GPM: _____ How Long: _____ Water Logs: _____

Parts Used to Complete Job: _____

Comments: _____

Work Completed By: BA + BJ Date Completed: 6-7-2022

Time Started: _____ Time Ended: _____

Customer signature _____ date _____

Equal Opportunity Employer and Service Provider

The employees of Drakesboro are not trained HVAC personnel. Lighting of pilots are a courtesy and the City can not be held liable.