

CASE NO. 2020-00040
TURKEY CREEK SOLAR, LLC
CORRECTED RESPONSES TO SITING BOARD'S SUPPLEMENTAL REQUEST FOR INFORMATION
(CHANGES FROM ORIGINAL ARE HIGHLIGHTED IN ITALICS)

1. The property for the proposed solar project is served by two electric distribution utilities: Kentucky Utilities Company (KU) in the northern end of the site and Inter-County Energy Cooperative (Inter-County) for the majority of the acreage. See the boundary on the web by following these instructions:

- Go to: <https://kygeonet.ky.gov/govmaps/>
- Scroll down to “Featured Web Maps and click on “Electric Service Areas”
- Fill in the address “1928 Crab Orchard Rd, Lancaster, KY, 40444” in the space labeled “Find address or place” and click on the search button. Use the – button to zoom out to cover most of the project site.
- Some suggestions: Change the Basemap to “Imagery Hybrid”. Under “Contents” the layers can be clicked on and off.

a. State whether Turkey Creek has been approached by any of these electric distribution utilities about supplying electric power to the site during the construction or operation phase. If so, please describe the interaction.

b. State whether the proposed solar facility will need to have electricity supplied to both electric territories during the construction or operation phase. State whether the electricity will be provided by both KU and Inter-County to serve the proposed solar facility that is located in their respective service territory.

c. State whether Turkey Creek intends to use one electric supplier and have the chosen utility file an electric territory boundary change with the Public Service Commission.

RESPONSE: 1a. No. Neither Turkey Creek nor its past or present representatives have

CASE NO. 2020-00040
TURKEY CREEK SOLAR, LLC
CORRECTED RESPONSES TO SITING BOARD'S SUPPLEMENTAL REQUEST FOR INFORMATION
(CHANGES FROM ORIGINAL ARE HIGHLIGHTED IN ITALICS)

been approached by an electric distribution utility.

1b. *During the operational phase a small amount of power will also be needed from the local retail supplier for the substation. The "station service" power needed on-site during operation will likely to be provided by Inter-County Energy Cooperative. The retail provider used to deliver power to the office trailer during construction will be dependent upon the trailers' placement within the project area. This location will not be determined until the project is closer to the construction phase.*

1c. *One electric supplier may be used during each phase (construction and operational), as discussed in response to Item 1b above.* The supplier used will be based on the territory boundary where the laydown yard will be located. Turkey Creek does not anticipate asking the chosen utility to file an electric territory boundary change with the PSC.

Witness: 1a. Carson Harkrader
 1b. Hugh Tillett
 1c. Hugh Tillett