

**COMMONWEALTH OF KENTUCKY**  
**BEFORE THE PUBLIC SERVICE COMMISSION**

In the Matter of:

**ELECTRONIC APPLICATION OF WESTERN )  
PULASKI COUNTY WATER DISTRICT FOR THE )  
ISSUANCE OF A CERTIFICATE OF PUBLIC )  
CONVENIENCE AND NECESSITY TO )  
CONSTRUCT A WATER IMPROVEMENTS ) Case No. 2020 - 00119  
PROJECT PURSUANT TO THE PROVISIONS )  
OF KRS 278.020 AND 807 KAR 5:001 )**

**Response to Commission Staff's Initial Request for Information**

Western Pulaski County Water District ("Western Pulaski District"), by Counsel, hereby files its Response to the Commission Staff's Initial Request for Information, dated April 21, 2020, as follows:

**REQUEST 1:** Provide Western Pulaski District's quarterly meter testing results for calendar years 2018, 2019 and for the first quarter of 2020.

**WITNESS:** Don Calder, Chairman, Western Pulaski County Water District.

**RESPONSE 1:** The requested meter results are attached hereto as **Exhibit "A"**.

**REQUEST 2.** Provide Western Pulaski District's results of its three most recent master meter testings.

**WITNESS:** Don Calder, Chairman, Western Pulaski County Water District.

**RESPONSE 2:** Attached hereto as **Exhibit "B"** are the records Western Pulaski District has regarding the testing of the master meters where Western Pulaski District purchased water from the City of Somerset. There are four (4) master meters and Western Pulaski District has test results dated for; July, 2016 for the master meters identified as North Section and Oak Hill; August, 2016 for the Highway 80 and Bourbon master meters; and November 7, 2018 for the Highway 80 master meter.

**REQUEST 3:** Explain how Western Pulaski District coordinates with the City of Somerset to ensure master meters are tested according to 807 KAR 5:066, Section 16(1).

**WITNESS:** Don Calder, Chairman, Western Pulaski County Water District.

**RESPONSE 3:** The master meters are owned by the City of Somerset and Western Pulaski District has no control over when and how they test their meters.

**REQUEST 4.** Since Case No. 2017-00063, Western Pulaski District's water loss has increased from 21.67 percent to 29.99 percent as reported in its 2018 Annual Report.

**(a).** Provide Western Pulaski District's plan for addressing its excessive water loss.

**WITNESS:** Don Calder, Chairman, Western Pulaski County Water District.

**RESPONSE 4(a):** Western Pulaski District is of the opinion that its water loss is due to leaks in system and customer meters that do not register properly. Western Pulaski District has been aggressively repairing leaks as they occur as indicated on the attached list of repairs for the year 2019 (see Exhibit "C"- Western Pulaski District's manager's hand written log attached hereto). During 2019, Western Pulaski District repaired 252 leaks with most of the number of leaks on customer service lines and the larger leaks on main line breaks. In regard to meter replacement, since January 1, 2020, Western Pulaski District has replaced 600 meters that were over 10 years old with new radio read meters. Of these, 368 have been tested and our goal is to replace approximately 1,100 this year. Due to the impact of the coronavirus, we have put our meter replacement program on hold and plan to resume as soon as possible. In addition, we are working with our engineers in prioritizing areas for water line replacement.

**(b).** If Western Pulaski District has not adopted a plan to address water loss, explain why a plan has not been adopted.

**WITNESS:** Don Calder, Chairman, Western Pulaski County Water District.

**RESPONSE 4(b):** Western Pulaski District has not adopted a written plan to address water loss, however, we spend the majority of our time fixing leaks, replacing meters and identifying areas for line replacement. We see the need to have a written plan in place so we are in the process of formulating a Water Loss Prevention and Leak Detection Program, and we plan on adopting it as soon as our Board approves it. The written plan will be an extension of the efforts that we have undertaken over the past years, that being leak repair, meter replacement and prioritizing areas of the water system that need to be upgraded.

**(c).** Given the increase in Western Pulaski District's water loss, explain why Western Pulaski District eliminated the following items from its originally proposed Phase II project: replacement of dilapidated and undersized water lines; installation of 100 radio read meters; and replacement of service lines.

**WITNESS:** Don Calder, Chairman, Western Pulaski County Water District.

**RESPONSE 4(c):** Western Pulaski District has not eliminated the replacement of the listed dilapidated and undersized water lines, the installation of 100 radio read meters and the replacement of service lines. In regards to the replacement of dilapidated and undersized water lines, the Slate Branch Road/Oak Hill Road area is currently being constructed and is planned to be completed as soon as weather permits. The Kentucky 80 section which lies in close proximity to the Fishing Creek Bridge, is included with the replacement of the water line that lies on the Bridge. That work is planned to take place in the fall season of this year. The WTLO Road is planned to be done once this current project is completed using contingency funds as shown on the Final Budget. The replacement of 100 radio read meters has been completed in house. The Clifty Road service line replacements are planned to be done along with the WTLO Road replacement and if sufficient project funds are not available, the work will be done in house or with outside contracting.

**REQUEST 5.** Provide copies of the minutes of the Western Pulaski District's Board of Commissioners meetings at which the proposed Phase II project was discussed.

**WITNESS:** Don Calder, Chairman, Western Pulaski County Water District.

**RESPONSE 5:** With the exception of the June 18, 2019 Board of Commissioners meeting, there are no Board of Commissioners minutes relating to the Phase II project because the scope of the project has not changed. Please see the June 18, 2019 minutes attached hereto as **Exhibit "D"** in which the Board of Commissioners instructed its engineer to proceed with the development of the Slate Branch Road/Oak Hill Road water line replacement. This work was necessitated by a major leak that occurred in the area and we were concerned that the potential for subsequent disruptions in service could occur unless the dilapidated water line was replaced.

**REQUEST 6.** Explain whether Western Pulaski District requested and received bids for its Phase II project as originally proposed in Case No. 2017-00063.

**(a)** If Western Pulaski District received bids for the originally proposed project, provide copies of the bids it received.

**WITNESS:** Don Calder, Chairman, Western Pulaski County Water District.

**RESPONSE 6(a):** For the Phase II project, Western Pulaski District received bids for the Slate Branch Road/Oak Hill Road section, as described in Response 5, and a copy of the bid results is attached hereto as **Exhibit "E"**.

**(b)** If Western Pulaski District did not request bids, provide a detailed explanation as to why bids were not requested.

**RESPONSE 6(b):** The remainder of the work as described in Phase II is still planned to take place either as a part of another project or once the current project is completed using contingency funds or in house efforts.

**REQUEST 7.** For each item listed below that was eliminated for Western Pulaski District's originally proposed Phase II project, provide the estimated construction cost, the estimated impact on water loss, and the future construction plans;

- (a) Replacement of dilapidated and undersized water lines;
- (b) Installation of 100 radio read meters; and
- (c) Replacement of service lines.

**WITNESS:** Don Calder, Chairman, Western Pulaski County Water District.

**RESPONSE 7(a)(b) and (c):** Please see my Response for Request 6(b) above.

**REQUEST 8.** Provide the number of meters Western Pulaski District has in service that are over ten years old and have not been tested as required by 807 KAR 5:066, Section 16(1).

**WITNESS:** Don Calder, Chairman, Western Pulaski County Water District.

**RESPONSE 8:** There are approximately 4,629 meters that are over ten years old and have not been tested. We are in the process of changing all of our meters to a radio read telemetry type system and plan to have that completed in five years. The initial meter replacement will be focused on the meters that are over ten years old and as of this date, we have converted approximately 1,375 meters to the new style of which 600 have been changed since January 1, 2020.


**REQUEST 9.** If Western Pulaski District has adopted a meter replacement program, provide a copy of the program and the records of meter replacement. If a program has not been adopted, explain why.

**WITNESS:** Don Calder, Chairman, Western Pulaski County Water District.

**RESPONSE 9:** The meter replacement program will be a part of the Water Loss Prevention and Leak Detection Program as described in Response 4(b).

#### **Certification of Responses to Commission Staff's Initial Request for Information**


I hereby certify that I have provided the responses to the Commission Staff's Initial Request for Information. This information provided is the Responses is true and accurate to the best of my knowledge, information, and belief formed after a reasonable inquiry.

  
Don Calder, Chairman  
Western Pulaski County Water District

The undersigned has prepared this Response as Counsel to and on behalf of the Western Pulaski County Water District, a governmental agency, and hereby certifies that this Response is true and accurate to the best of the undersign's knowledge, information and belief formed after a reasonable inquiry.


Respectfully Submitted:

Rubin & Hays

By   
W. Randall Jones, Esq., Counsel for Western  
Pulaski County Water District  
450 South Third Street  
Louisville, Kentucky 40202  
Telephone: (502) 569-7525  
Fax: (502) 569-7555  
Email: [wrjones@rubinhays.com](mailto:wrjones@rubinhays.com)

#### **CERTIFICATE OF SERVICE**

The undersigned, in accordance with 807 KAR 5:001, Section 8, hereby certifies that Western Pulaski County Water District's electronic filing of the foregoing Response is a true and accurate copy of the same document being filed in paper medium; that the electronic filing was transmitted to the Kentucky Public Service Commission on May 7, 2020; that there are currently no parties that the Kentucky Public Service Commission has excused from participation by electronic means in this proceeding; and that this Response in paper medium will be delivered to the offices of the Kentucky Public Service Commission in Frankfort, Kentucky in accordance with the mandates set forth in the Commission's March 16, 2020 and March 24, 2020 Orders in Case No. 2020-00085 within 30 days of the lifting of the current state of emergency.

  
W. Randall Jones, Esq.  
Rubin & Hays  
450 South Third Street  
Louisville, Kentucky 40202  
Phone: (502) 569-7525  
Fax: (502) 569-7555  
Counsel for Western Pulaski County Water  
District

## EXHIBIT A

**QUARTERLY METER REPORT  
TO THE KENTUCKY PUBLIC SERVICE COMMISSION**

GENERAL INFORMATION

NAME OF UTILITY	<u>Western Pulaski Water District</u>	QUARTER	<u>1st quarter 2018</u>
ADDRESS	<u>2128 west hwy 80</u>	TEST YEAR	<u>2017</u>
CITY, STATE, ZIP	<u>Somerset, KY 42503</u>	DATE SUBMITTED	<u>April 4, 2018</u>

METER TYPE RESULTS

CUSTOMER TYPE	METERED	NON-METERED	TOTAL
RESIDENTIAL	8458	0	8458
COMMERCIAL	67	0	67
INDUSTRIAL	0	0	0
OTHER	0	0	0
<b>TOTALS</b>	<b>8525</b>	<b>0</b>	<b>8525</b>

STATUS OF METER TEST PROGRAM	QUANTITY
METERS TO BE TESTED THIS YEAR	1000
METERS TESTED THIS YEAR (TO DATE)	180
METERS STILL TO TEST THIS YEAR	820

METER TESTING RESULTS

YEARS SINCE METER WAS LAST TESTED	METER TEST RESULTS				METERS TESTED	METERS NOT TESTED
	WITHIN ±2%	> 2% FAST	> 2% SLOW	NR*		
NEW - 5 YEARS	0	0	0	0	0	0
5 - 8 YEARS	0	0	0	0	0	0
9 YEARS	0	0	0	0	0	0
10 YEARS	0	0	0	0	0	0
10+ YEARS	94	1	44	41	180	0
UNKNOWN		0	0	0	0	0
<b>TOTALS</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>180</b>	<b>0</b>
<b>PERCENT</b>	<b>0.00%</b>	<b>0.00%</b>	<b>0.00%</b>	<b>0.00%</b>	<b>100.00%</b>	<b>0.00%</b>

\* Non-Registering

PERIODIC METER TEST PROGRAM	yes
CASE NUMBER and/or SAMPLE METHOD PLAN	
METERS REMOVED FROM SERVICE AND TESTED THIS QUARTER	0
NEW SERVICE CONNECTIONS (METERS) INSTALLED THIS QUARTER	25
TOTAL METERS TESTED THIS QUARTER	180
UTILITY OR APPROVED AGENCY DOING METER TESTING	Western pulaski water
METERS THAT TEST MORE THAN 2% FAST OR 2% SLOW	Discard&Replace

CUSTOMER AND REFUND INFORMATION

NUMBER OF TESTS MADE AT CUSTOMER'S REQUEST	0
NUMBER OF TESTS MADE AT COMMISSION'S REQUEST	0
NUMBER OF METERS ON WHICH REFUNDS WERE MADE	0
TOTAL AMOUNT OF REFUNDS MADE DURING THIS QUARTER	\$0.00
NUMBER OF CUSTOMERS BILLED FOR SLOW METERS	0
TOTAL AMOUNT BILLED ON SLOW METERS	\$0.00
NUMBER OF CUSTOMERS BILLED FOR NON-REGISTERING METERS	0
TOTAL AMOUNT BILLED ON NON-REGISTERING METERS	\$0.00

METER TESTING INFORMATION APPROVED BY:

CUSTOMER & REFUND INFORMATION APPROVED BY:

SIGNED Joe McClendon  
TITLE Field Manager

SIGNED Tammy Vaught  
TITLE Office Manager

**QUARTERLY METER REPORT  
TO THE KENTUCKY PUBLIC SERVICE COMMISSION**

**GENERAL INFORMATION**

NAME OF UTILITY	<u>Western Pulaski Water District</u>	QUARTER	<u>2nd quarter 2018</u>
ADDRESS	<u>2128 west hwy 80</u>	TEST YEAR	<u>2018</u>
CITY, STATE, ZIP	<u>Somerset, KY 42503</u>	DATE SUBMITTED	<u>December 26 2018</u>

CUSTOMER TYPE	METERED	NON-METERED	TOTAL
RESIDENTIAL	8479	0	8627
COMMERCIAL	67	0	67
INDUSTRIAL	0	0	0
OTHER	0	0	0
<b>TOTALS</b>	<b>8546</b>	<b>0</b>	<b>8694</b>

STATUS OF METER TEST PROGRAM	QUANTITY
METERS TO BE TESTED THIS YEAR	1000
METERS TESTED THIS YEAR (TO DATE)	220
METERS STILL TO TEST THIS YEAR	780

**METERS TESTING**

YEARS SINCE METER WAS LAST TESTED	METER TEST RESULTS				METERS TESTED	METERS NOT TESTED
	WITHIN ±2%	> 2% FAST	> 2% SLOW	NR*		
NEW - 5 YEARS	0	0	0	0	0	0
5 - 8 YEARS	0	0	0	0	0	0
9 YEARS	0	0	0	0	0	0
10 YEARS	0	0	0	0	0	0
10+ YEARS	15	0	5	20	40	0
UNKNOWN		0	0	0	0	0
<b>TOTALS</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>40</b>	<b>0</b>
<b>PERCENT</b>	<b>0.00%</b>	<b>0.00%</b>	<b>0.00%</b>	<b>0.00%</b>	<b>100.00%</b>	<b>0.00%</b>

\* Non-Registering

PERIODIC METER TEST PROGRAM	yes
CASE NUMBER and/or SAMPLE METHOD PLAN	
METERS REMOVED FROM SERVICE AND TESTED THIS QUARTER	0
NEW SERVICE CONNECTIONS (METERS) INSTALLED THIS QUARTER	21
TOTAL METERS TESTED THIS QUARTER	40
UTILITY OR APPROVED AGENCY DOING METER TESTING	Western pulaski water
METERS THAT TEST MORE THAN 2% FAST OR 2% SLOW	Discard&Replace

**CUSTOMER AND REFUND INFORMATION**

NUMBER OF TESTS MADE AT CUSTOMER'S REQUEST	0
NUMBER OF TESTS MADE AT COMMISSION'S REQUEST	0
NUMBER OF METERS ON WHICH REFUNDS WERE MADE	0
TOTAL AMOUNT OF REFUNDS MADE DURING THIS QUARTER	\$0.00
NUMBER OF CUSTOMERS BILLED FOR SLOW METERS	0
TOTAL AMOUNT BILLED ON SLOW METERS	\$0.00
NUMBER OF CUSTOMERS BILLED FOR NON-REGISTERING METERS	0
TOTAL AMOUNT BILLED ON NON-REGISTERING METERS	\$0.00

METER TESTING INFORMATION APPROVED BY:

CUSTOMER & REFUND INFORMATION APPROVED BY:

SIGNED Joe McClendon  
TITLE Field Manager

SIGNED Tammy Vaught  
TITLE Office Manager



**QUARTERLY METER REPORT  
TO THE KENTUCKY PUBLIC SERVICE COMMISSION**

**GENERAL INFORMATION**

NAME OF UTILITY	<u>Western Pulaski Water District</u>	QUARTER	<u>3rd quarter 2018</u>
ADDRESS	<u>2128 west hwy 80</u>	TEST YEAR	<u>2018</u>
CITY, STATE, ZIP	<u>Somerset, KY 42503</u>	DATE SUBMITTED	<u>December 26 2018</u>

**METER SUMMARY**

CUSTOMER TYPE	METERED	NON-METERED	TOTAL
RESIDENTIAL	8665	0	8665
COMMERCIAL	67	0	67
INDUSTRIAL	0	0	0
OTHER	0	0	0
<b>TOTALS</b>	<b>8732</b>	<b>0</b>	<b>8694</b>

STATUS OF METER TEST PROGRAM	QUANTITY
METERS TO BE TESTED THIS YEAR	1000
METERS TESTED THIS YEAR (TO DATE)	713
METERS STILL TO TEST THIS YEAR	287

**METERS TESTING**

YEARS SINCE METER WAS LAST TESTED	METER TEST RESULTS				METERS TESTED	METERS NOT TESTED
	WITHIN ±2%	> 2% FAST	> 2% SLOW	NR*		
NEW - 5 YEARS	0	0	0	0	0	0
5 - 8 YEARS	0	0	0	0	0	0
9 YEARS	0	0	0	0	0	0
10 YEARS	0	0	0	0	0	0
10+ YEARS	209	0	166	118	493	0
UNKNOWN		0	0	0	0	0
<b>TOTALS</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>493</b>	<b>0</b>
<b>PERCENT</b>	<b>0.00%</b>	<b>0.00%</b>	<b>0.00%</b>	<b>0.00%</b>	<b>100.00%</b>	<b>0.00%</b>

\* Non-Registering

PERIODIC METER TEST PROGRAM	yes
CASE NUMBER and/or SAMPLE METHOD PLAN	
METERS REMOVED FROM SERVICE AND TESTED THIS QUARTER	0
NEW SERVICE CONNECTIONS (METERS) INSTALLED THIS QUARTER	38
TOTAL METERS TESTED THIS QUARTER	493
UTILITY OR APPROVED AGENCY DOING METER TESTING	Western pulaski water
METERS THAT TEST MORE THAN 2% FAST OR 2% SLOW	Discard&Replace

**CUSTOMER AND REFUND INFORMATION**

NUMBER OF TESTS MADE AT CUSTOMER'S REQUEST	0
NUMBER OF TESTS MADE AT COMMISSION'S REQUEST	0
NUMBER OF METERS ON WHICH REFUNDS WERE MADE	0
TOTAL AMOUNT OF REFUNDS MADE DURING THIS QUARTER	\$0.00
NUMBER OF CUSTOMERS BILLED FOR SLOW METERS	0
TOTAL AMOUNT BILLED ON SLOW METERS	\$0.00
NUMBER OF CUSTOMERS BILLED FOR NON-REGISTERING METERS	0
TOTAL AMOUNT BILLED ON NON-REGISTERING METERS	\$0.00

METER TESTING INFORMATION APPROVED BY:

CUSTOMER & REFUND INFORMATION APPROVED BY:

SIGNED Joe McClendon  
TITLE Field Manager

SIGNED Tammy Vaught  
TITLE Office Manager

**QUARTERLY METER REPORT  
TO THE KENTUCKY PUBLIC SERVICE COMMISSION**

**GENERAL INFORMATION**

NAME OF UTILITY	<u>Western Pulaski Water District</u>	QUARTER	<u>4th quarter 2018</u>
ADDRESS	<u>2128 west hwy 80</u>	TEST YEAR	<u>2018</u>
CITY, STATE, ZIP	<u>Somerset, KY 42503</u>	DATE SUBMITTED	<u>December 26 2018</u>

**METER SUMMARY**

CUSTOMER TYPE	METERED	NON-METERED	TOTAL
RESIDENTIAL	8691	0	8691
COMMERCIAL	67	0	67
INDUSTRIAL	0	0	0
OTHER	0	0	0
<b>TOTALS</b>	<b>8758</b>	<b>0</b>	<b>8694</b>

STATUS OF METER TEST PROGRAM	QUANTITY
METERS TO BE TESTED THIS YEAR	1000
METERS TESTED THIS YEAR (TO DATE)	781
METERS STILL TO TEST THIS YEAR	219

**METER TESTING**

YEARS SINCE METER WAS LAST TESTED	METER TEST RESULTS				METERS TESTED	METERS NOT TESTED
	WITHIN ±2%	> 2% FAST	> 2% SLOW	NR*		
NEW - 5 YEARS	0	0	0	0	0	0
5 - 8 YEARS	0	0	0	0	0	0
9 YEARS	0	0	0	0	0	0
10 YEARS	0	0	0	0	0	0
10+ YEARS	34	0	14	20	68	0
UNKNOWN		0	0	0	0	0
<b>TOTALS</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>68</b>	<b>0</b>
<b>PERCENT</b>	<b>0.00%</b>	<b>0.00%</b>	<b>0.00%</b>	<b>0.00%</b>	<b>100.00%</b>	<b>0.00%</b>

\* Non-Registering

PERIODIC METER TEST PROGRAM	yes
CASE NUMBER and/or SAMPLE METHOD PLAN	
METERS REMOVED FROM SERVICE AND TESTED THIS QUARTER	0
NEW SERVICE CONNECTIONS (METERS) INSTALLED THIS QUARTER	26
TOTAL METERS TESTED THIS QUARTER	68
UTILITY OR APPROVED AGENCY DOING METER TESTING	Western pulaski water
METERS THAT TEST MORE THAN 2% FAST OR 2% SLOW	Discard&Replace

**CUSTOMER AND REFUND INFORMATION**

NUMBER OF TESTS MADE AT CUSTOMER'S REQUEST	0
NUMBER OF TESTS MADE AT COMMISSION'S REQUEST	0
NUMBER OF METERS ON WHICH REFUNDS WERE MADE	0
TOTAL AMOUNT OF REFUNDS MADE DURING THIS QUARTER	\$0.00
NUMBER OF CUSTOMERS BILLED FOR SLOW METERS	0
TOTAL AMOUNT BILLED ON SLOW METERS	\$0.00
NUMBER OF CUSTOMERS BILLED FOR NON-REGISTERING METERS	0
TOTAL AMOUNT BILLED ON NON-REGISTERING METERS	\$0.00

METER TESTING INFORMATION APPROVED BY:

CUSTOMER & REFUND INFORMATION APPROVED BY:

SIGNED Joe McClendon  
TITLE Field Manager

SIGNED Tammy Vaught  
TITLE Office Manager

Sent 6-28-19

**QUARTERLY METER REPORT  
TO THE KENTUCKY PUBLIC SERVICE COMMISSION**

GENERAL INFORMATION

NAME OF UTILITY	<u>Western Pulaski Water District</u>	QUARTER	<u>1st quarter</u>
ADDRESS	<u>2128 west hwy 80</u>	TEST YEAR	<u>2019</u>
CITY, STATE, ZIP	<u>Somerset, KY 42503</u>	DATE SUBMITTED	<u>June 28, 2019</u>

METER STATISTICS

CUSTOMER TYPE	METERED	NON-METERED	TOTAL
RESIDENTIAL	8717	0	8717
COMMERCIAL	67	0	67
INDUSTRIAL	0	0	0
OTHER	0	0	0
<b>TOTALS</b>	<b>8784</b>	<b>0</b>	<b>8784</b>

STATUS OF METER TEST PROGRAM	QUANTITY
METERS TO BE TESTED THIS YEAR	1000
METERS TESTED THIS YEAR (TO DATE)	123

METER TESTING

YEARS SINCE METER WAS LAST TESTED	METER TEST RESULTS				METERS TESTED	METERS NOT TESTED
	WITHIN ±2%	> 2% FAST	> 2% SLOW	NR*		
NEW - 5 YEARS	0	0	0	0	0	0
5 - 8 YEARS	0	0	0	0	0	0
9 YEARS	0	0	0	0	0	0
10 YEARS	0	0	0	0	0	0
10+ YEARS	34	0	14	20	68	0
UNKNOWN	0	0	0	0	0	0
<b>TOTALS</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>68</b>	<b>0</b>
PERCENT	0.00%	0.00%	0.00%	0.00%	100.00%	0.00%

\* Non-Registering

PERIODIC METER TEST PROGRAM	yes
CASE NUMBER and/or SAMPLE METHOD PLAN	
METERS REMOVED FROM SERVICE AND TESTED THIS QUARTER	0
NEW SERVICE CONNECTIONS (METERS) INSTALLED THIS QUARTER	26
TOTAL METERS TESTED THIS QUARTER	123
UTILITY OR APPROVED AGENCY DOING METER TESTING	Western pulaski water
METERS THAT TEST MORE THAN 2% FAST OR 2% SLOW	Discard&Replace

CUSTOMER AND REFUND INFORMATION

NUMBER OF TESTS MADE AT CUSTOMER'S REQUEST	0
NUMBER OF TESTS MADE AT COMMISSION'S REQUEST	0
NUMBER OF METERS ON WHICH REFUNDS WERE MADE	0
TOTAL AMOUNT OF REFUNDS MADE DURING THIS QUARTER	\$0.00
NUMBER OF CUSTOMERS BILLED FOR SLOW METERS	0
TOTAL AMOUNT BILLED ON SLOW METERS	\$0.00
NUMBER OF CUSTOMERS BILLED FOR NON-REGISTERING METERS	0
TOTAL AMOUNT BILLED ON NON-REGISTERING METERS	\$0.00

METER TESTING INFORMATION APPROVED BY:

CUSTOMER & REFUND INFORMATION APPROVED BY:

SIGNED Joe McClendon  
TITLE Field Manager

SIGNED Tammy Vaught  
TITLE Office Manager

**QUARTERLY METER REPORT**  
**TO THE KENTUCKY PUBLIC SERVICE COMMISSION**

*Sent 6-28-19*

GENERAL INFORMATION

NAME OF UTILITY	<u>Western Pulaski Water District</u>	QUARTER	<u>2nd quarter</u>
ADDRESS	<u>2128 west hwy 80</u>	TEST YEAR	<u>2019</u>
CITY, STATE, ZIP	<u>Somerset, KY 42503</u>	DATE SUBMITTED	<u>June 28, 2019</u>

METER STATISTICS

CUSTOMER TYPE	METERED	NON-METERED	TOTAL
RESIDENTIAL	8758	0	8758
COMMERCIAL	68	0	68
INDUSTRIAL	0	0	0
OTHER	0	0	0
<b>TOTALS</b>	<b>8826</b>	<b>0</b>	<b>8826</b>

STATUS OF METER TEST PROGRAM	QUANTITY
METERS TO BE TESTED THIS YEAR	1000
METERS TESTED THIS YEAR (TO DATE)	216

METER TESTING

YEARS SINCE METER WAS LAST TESTED	METER TEST RESULTS				METERS TESTED	METERS NOT TESTED
	WITHIN ±2%	> 2% FAST	> 2% SLOW	NR*		
NEW - 5 YEARS	0	0	0	0	0	0
5 - 8 YEARS	0	0	0	0	0	0
9 YEARS	0	0	0	0	0	0
10 YEARS	0	0	0	0	0	0
10+ YEARS	46	0	29	18	93	0
UNKNOWN		0	0	0	0	0
<b>TOTALS</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>93</b>	<b>0</b>
<b>PERCENT</b>	<b>0.00%</b>	<b>0.00%</b>	<b>0.00%</b>	<b>0.00%</b>	<b>100.00%</b>	<b>0.00%</b>

\* Non-Registering

PERIODIC METER TEST PROGRAM	yes
CASE NUMBER and/or SAMPLE METHOD PLAN	
METERS REMOVED FROM SERVICE AND TESTED THIS QUARTER	0
NEW SERVICE CONNECTIONS (METERS) INSTALLED THIS QUARTER	41
TOTAL METERS TESTED THIS QUARTER	216
UTILITY OR APPROVED AGENCY DOING METER TESTING	Western pulaski water
METERS THAT TEST MORE THAN 2% FAST OR 2% SLOW	Discard&Replace

CUSTOMER AND REFUND INFORMATION

NUMBER OF TESTS MADE AT CUSTOMER'S REQUEST	0
NUMBER OF TESTS MADE AT COMMISSION'S REQUEST	0
NUMBER OF METERS ON WHICH REFUNDS WERE MADE	0
TOTAL AMOUNT OF REFUNDS MADE DURING THIS QUARTER	\$0.00
NUMBER OF CUSTOMERS BILLED FOR SLOW METERS	0
TOTAL AMOUNT BILLED ON SLOW METERS	\$0.00
NUMBER OF CUSTOMERS BILLED FOR NON-REGISTERING METERS	0
TOTAL AMOUNT BILLED ON NON-REGISTERING METERS	\$0.00

METER TESTING INFORMATION APPROVED BY:

CUSTOMER & REFUND INFORMATION APPROVED BY:

SIGNED Joe McClendon  
 TITLE Field Manager

SIGNED Tammy Vaught  
 TITLE Office Manager

**QUARTERLY METER REPORT  
TO THE KENTUCKY PUBLIC SERVICE COMMISSION**

**Sent 12-9-19**

**GENERAL INFORMATION**

NAME OF UTILITY	<u>Western Pulaski Water District</u>	QUARTER	<u>3rd July-September</u>
ADDRESS	<u>2128 west Hwy 80</u>	TEST YEAR	<u>2019</u>
CITY, STATE, ZIP	<u>Somerset, KY 42503</u>	DATE SUBMITTED	<u>October 15, 2019</u>

**METER STATISTICS**

CUSTOMER TYPE	METERED	NON-METERED	TOTAL
RESIDENTIAL	8812	0	8812
COMMERCIAL	68	0	68
INDUSTRIAL	0	0	0
OTHER	0	0	0
<b>TOTALS</b>	<b>8880</b>	<b>0</b>	<b>8880</b>

STATUS OF METER TEST PROGRAM	QUANTITY
METERS TO BE TESTED THIS YEAR	1000
METERS TESTED THIS YEAR (TO DATE)	230

**METER TESTING**

YEARS SINCE METER WAS LAST TESTED	METER TEST RESULTS				METERS TESTED	METERS NOT TESTED
	WITHIN ±2%	> 2% FAST	> 2% SLOW	NR*		
NEW - 5 YEARS	0	0	0	0	0	0
5 - 8 YEARS	0	0	0	0	0	0
9 YEARS	0	0	0	0	0	0
10 YEARS	0	0	0	0	0	0
10+ YEARS	0	0	0	0	0	0
UNKNOWN	8	0	6	0	14	0
<b>TOTALS</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>14</b>	<b>0</b>
PERCENT	0.00%	0.00%	0.00%	0.00%	100.00%	0.00%

\* Non-Registering

PERIODIC METER TEST PROGRAM	yes
CASE NUMBER and/or SAMPLE METHOD PLAN	
METERS REMOVED FROM SERVICE AND TESTED THIS QUARTER	14
NEW SERVICE CONNECTIONS (METERS) INSTALLED THIS QUARTER	54
TOTAL METERS TESTED THIS QUARTER	14
UTILITY OR APPROVED AGENCY DOING METER TESTING	Western pulaski water
METERS THAT TEST MORE THAN 2% FAST OR 2% SLOW	Discard&Replace

**CUSTOMER AND REFUND INFORMATION**

NUMBER OF TESTS MADE AT CUSTOMER'S REQUEST	2
NUMBER OF TESTS MADE AT COMMISSION'S REQUEST	0
NUMBER OF METERS ON WHICH REFUNDS WERE MADE	0
TOTAL AMOUNT OF REFUNDS MADE DURING THIS QUARTER	\$0.00
NUMBER OF CUSTOMERS BILLED FOR SLOW METERS	0
TOTAL AMOUNT BILLED ON SLOW METERS	\$0.00
NUMBER OF CUSTOMERS BILLED FOR NON-REGISTERING METERS	0
TOTAL AMOUNT BILLED ON NON-REGISTERING METERS	\$0.00

METER TESTING INFORMATION APPROVED BY:

CUSTOMER & REFUND INFORMATION APPROVED BY:

SIGNED Joe McClendon  
TITLE Field Manager

SIGNED Tammy Vaught  
TITLE Office Manager

**QUARTERLY METER REPORT**  
**TO THE KENTUCKY PUBLIC SERVICE COMMISSION**

Sent 1-6-2020 @ 9:57

GENERAL INFORMATION

NAME OF UTILITY Western Pulaski Water District QUARTER 4th Quarter  
 ADDRESS 2128 west Hwy 80 TEST YEAR 2019  
 CITY, STATE, ZIP Somerset, KY 42503 DATE SUBMITTED January 6, 2020

METER STATISTICS

CUSTOMER TYPE	METERED	NON-METERED	TOTAL
RESIDENTIAL	8850	0	8850
COMMERCIAL	68	0	68
INDUSTRIAL	0	0	0
OTHER	0	0	0
TOTALS	8918	0	8918

STATUS OF METER TEST PROGRAM	QUANTITY
METERS TO BE TESTED THIS YEAR	1000
METERS TESTED THIS YEAR (TO DATE)	1000
METERS STILL TO TEST THIS YEAR	0

METER TESTING

YEARS SINCE METER WAS LAST TESTED	METER TEST RESULTS				METERS TESTED	METERS NOT TESTED
	WITHIN ±2%	> 2% FAST	> 2% SLOW	NR*		
NEW - 5 YEARS	0	0	0	0	0	0
5 - 8 YEARS	0	0	0	0	0	0
9 YEARS	0	0	0	0	0	0
10 YEARS	0	0	0	0	0	0
10+ YEARS	0	0	0	0	0	0
UNKNOWN	390	0	246	134	770	0
TOTALS	0	0	0	0	770	0
PERCENT	0.00%	0.00%	0.00%	0.00%	100.00%	0.00%

\* Non-Registering

PERIODIC METER TEST PROGRAM	yes
CASE NUMBER and/or SAMPLE METHOD PLAN	
METERS REMOVED FROM SERVICE AND TESTED THIS QUARTER	770
NEW SERVICE CONNECTIONS (METERS) INSTALLED THIS QUARTER	38
TOTAL METERS TESTED THIS QUARTER	770
UTILITY OR APPROVED AGENCY DOING METER TESTING	Western pulaski water
METERS THAT TEST MORE THAN 2% FAST OR 2% SLOW	Discard&Replace

CUSTOMER AND REFUND INFORMATION

NUMBER OF TESTS MADE AT CUSTOMER'S REQUEST	0
NUMBER OF TESTS MADE AT COMMISSION'S REQUEST	0
NUMBER OF METERS ON WHICH REFUNDS WERE MADE	0
TOTAL AMOUNT OF REFUNDS MADE DURING THIS QUARTER	\$0.00
NUMBER OF CUSTOMERS BILLED FOR SLOW METERS	0
TOTAL AMOUNT BILLED ON SLOW METERS	\$0.00
NUMBER OF CUSTOMERS BILLED FOR NON-REGISTERING METERS	0
TOTAL AMOUNT BILLED ON NON-REGISTERING METERS	\$0.00

METER TESTING INFORMATION APPROVED BY:

CUSTOMER & REFUND INFORMATION APPROVED BY:

SIGNED Joe McClendon  
 TITLE Field Manager

SIGNED Tammy Vaught  
 TITLE Office Manager

**QUARTERLY METER REPORT**  
**TO THE KENTUCKY PUBLIC SERVICE COMMISSION**

**GENERAL INFORMATION**

NAME OF UTILITY	Western Pulaski Water District	QUARTER	1st
ADDRESS	2128 west Hwy 80	TEST YEAR	2020
CITY, STATE, ZIP	Somerset, KY 42503	DATE SUBMITTED	April 23, 2020

**METER STATISTICS**

CUSTOMER TYPE	METERED	NON-METERED	TOTAL
RESIDENTIAL	8864	0	8864
COMMERCIAL	68	0	68
INDUSTRIAL	0	0	0
OTHER	0	0	0
<b>TOTALS</b>	<b>8932</b>	<b>0</b>	<b>8932</b>

STATUS OF METER TEST PROGRAM	QUANTITY
METERS TO BE TESTED THIS YEAR	1000
METERS TESTED THIS YEAR (TO DATE)	368
METERS STILL TO TEST THIS YEAR	632

**METER TESTING**

YEARS SINCE METER WAS LAST TESTED	METER TEST RESULTS				METERS TESTED	METERS NOT TESTED
	WITHIN ±2%	> 2% FAST	> 2% SLOW	NR*		
NEW - 5 YEARS	0	0	0	0	0	0
5 - 8 YEARS	0	0	0	0	0	0
9 YEARS	0	0	0	0	0	0
10 YEARS	0	0	0	0	0	0
10+ YEARS	235	0	87	46	368	Error
UNKNOWN		0				0
<b>TOTALS</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>368</b>	<b>0</b>
<b>PERCENT</b>	<b>0.00%</b>	<b>0.00%</b>	<b>0.00%</b>	<b>0.00%</b>	<b>100.00%</b>	<b>0.00%</b>

\* Non-Registering

PERIODIC METER TEST PROGRAM	yes
CASE NUMBER and/or SAMPLE METHOD PLAN	
METERS REMOVED FROM SERVICE AND TESTED THIS QUARTER	368
NEW SERVICE CONNECTIONS (METERS) INSTALLED THIS QUARTER	14
TOTAL METERS TESTED THIS QUARTER	368
UTILITY OR APPROVED AGENCY DOING METER TESTING	Western pulaski water
METERS THAT TEST MORE THAN 2% FAST OR 2% SLOW	Discard&Replace

**CUSTOMER AND REFUND INFORMATION**

NUMBER OF TESTS MADE AT CUSTOMER'S REQUEST	0
NUMBER OF TESTS MADE AT COMMISSION'S REQUEST	0
NUMBER OF METERS ON WHICH REFUNDS WERE MADE	0
TOTAL AMOUNT OF REFUNDS MADE DURING THIS QUARTER	\$0.00
NUMBER OF CUSTOMERS BILLED FOR SLOW METERS	0
TOTAL AMOUNT BILLED ON SLOW METERS	\$0.00
NUMBER OF CUSTOMERS BILLED FOR NON-REGISTERING METERS	0
TOTAL AMOUNT BILLED ON NON-REGISTERING METERS	\$0.00

METER TESTING INFORMATION APPROVED BY:

CUSTOMER & REFUND INFORMATION APPROVED BY:

SIGNED Joe McClendon  
 TITLE Field Manager

SIGNED Tammy Vaught  
 TITLE Office Manager

**EXHIBIT B**



North Master Meter

# City of Somerset

## WATER/WASTEWATER DEPARTMENT

105 College Street  
PO Box 989

SOMERSET, KENTUCKY 42502-0989  
(606) 678-6646 • fax (606) 679-6227  
E-mail: cdick@cityofsomerset.com



**EDDIE R. GIRDLER**  
Mayor

**CHARLES R. DICK**  
Manager

Service Location: Orkhill Beginning Read: High: 40096100 Low: 4164320.0  
Date: 7/13/16 Final Read: High: 40099869 Low: 4164575.7

10 Gallons @ 2.0 gallons per minute. 25% flow. Ran 10.0 gallons total.

	High Side Reading	Low Side Reading
Finish:	<u>40096100</u>	<u>4164330.1</u>
Start:	<u>40096100</u>	<u>4164320.0</u>
Total	<u>0</u>	<u>10.1</u>

Correct Percentage: 100 %

2.  
10 Gallons @ 5.0 gallons per minute. 50% flow. Ran 10.0 gallons total.

	High Side Reading	Low Side Reading
Finish:	<u>40096100</u>	<u>4164339.9</u>
Start:	<u>40096100</u>	<u>4164320.1</u>
Total	<u>0</u>	<u>9.8</u>

Correct Percentage: 98 %

3.  
10 Gallons @ 8.0 gallons per minute. 75% flow. Ran 10.0 gallons total.

	High Side Reading	Low Side Reading
Finish:	<u>40096100</u>	<u>4164349.5</u>
Start:	<u>40096100</u>	<u>4164339.9</u>
Total	<u>0</u>	<u>9.6</u>

Correct Percentage: 96 %

4.  
10 Gallons @ 14.0 gallons per minute. 100% flow. Ran 10.0 gallons total.

	High Side Reading	Low Side Reading
Finish:	<u>40096100</u>	<u>4164359.2</u>
Start:	<u>40096100</u>	<u>4164349.5</u>
Total	<u>0</u>	<u>9.7</u>

Correct Percentage: 97 %

Total Percentage for Low Side Test: 98 % Total Correct Percentage: 98.8187 %

Tester: Adm Crow Remarks: Good Test

No Adjustment

# City of Somerset

## WATER/WASTEWATER DEPARTMENT

105 College Street  
PO Box 989

SOMERSET, KENTUCKY 42502-0989  
(606) 678-6646 • fax (606) 679-6227  
E-mail: cdick@cityofsomerset.com



EDDIE R. GIRDLER  
Mayor

CHARLES R. DICK  
Manager

1.

Gallons @ 450 gallons per minute. 100% flow. Ran 1000 gallons total.

	High Side Reading	Low Side Reading	
Finish:	<u>40097082</u>	<u>4164386.7</u>	
Start:	<u>40096100</u>	<u>4164359.2</u>	
Total	<u>982</u>	<u>27.5</u>	1009.5

Correct Percentage: 100.95%

2.

Gallons @ 325 gallons per minute. 75% flow. Ran 1000 gallons total.

	High Side Reading	Low Side Reading	
Finish:	<u>40098048</u>	<u>4164406.3</u>	
Start:	<u>40097082</u>	<u>4164386.7</u>	
Total	<u>966</u>	<u>19.6</u>	985.6

Correct Percentage: 99.56%

3.

Gallons @ 225 gallons per minute. 50% flow. Ran 1000 gallons total.

	High Side Reading	Low Side Reading	
Finish:	<u>40098995</u>	<u>4164456.6</u>	
Start:	<u>40098048</u>	<u>4164406.3</u>	
Total	<u>947</u>	<u>50.3</u>	997.3

Correct Percentage: 99.73%

4.

Gallons @ 110 gallons per minute. 25% flow. Ran 1000 gallons total.

	High Side Reading	Low Side Reading	
Finish:	<u>40099869</u>	<u>4164575.7</u>	
Start:	<u>40098995</u>	<u>4164456.6</u>	
Total	<u>874</u>	<u>119.1</u>	993.1

Correct Percentage: 99.31%

Total Percentage for High Side test: 99.6375%

Tester: Alan Gini

DAK HILL MASTER METER

# City of Somerset

## WATER/WASTEWATER DEPARTMENT

105 College Street  
PO Box 989

SOMERSET, KENTUCKY 42502-0989  
(806) 678-8846 • fax (806) 679-6227  
E-mail: cdick@cityofsomerset.com

EDDIE R. GIRDLER  
Mayor

CHARLES R. DICK  
Manager



Service Location: Pleasant Hill Beginning Read: High: 74635300 Low: 2518940.0  
Date: 7/20/16 Final Read: High: 74643754 Low: 2518955.7

10 Gallons @ 2.0 gallons per minute. 25% flow. Ran 10.0 gallons total.  
High Side Reading Low Side Reading

Finish:	74635300	2518950.0	
Start:	74635300	2518940.0	
Total	0	10.0	100%

Correct Percentage: 100%

2.  
10 Gallons @ 5.0 gallons per minute. 50% flow. Ran 10.0 gallons total.  
High Side Reading Low Side Reading

Finish:	74635300	2518960.0
Start:	74635300	2518950.0
Total	0	10.0

Correct Percentage: 100%

3.  
10 Gallons @ 8.0 gallons per minute. 75% flow. Ran 10.0 gallons total.  
High Side Reading Low Side Reading

Finish:	74635300	2518968.9
Start:	74635300	2518960.0
Total	0	8.9

Correct Percentage: 99%

4.  
10 Gallons @ 10.0 gallons per minute. 100% flow. Ran 10.0 gallons total.  
High Side Reading Low Side Reading

Finish:	74635300	2518978.9
Start:	74635300	2518968.9
Total	0	10.0

Correct Percentage: 100%

Total Percentage for Low Side Test: 99.75 Total Correct Percentage: 100.053%

Tester: Alan Green Remarks: Small adjustment on High Side  
- Very good test

# City of Somerset

## WATER/WASTEWATER DEPARTMENT

105 College Street  
PO Box 989

SOMERSET, KENTUCKY 42502-0989  
(606) 678-6646 • fax (606) 679-6227  
E-mail: cdick@cityofsomerset.com



EDDIE R. GIRDLER  
Mayor

CHARLES R. DICK  
Manager

1.  
Gallons @ 430 gallons per minute. 100% flow. Ran 1004 gallons total.  
High Side Reading                      Low Side Reading  
Finish:                      74636299                      2519018.8  
Start:                      74635300                      2518979.9  
Total                      999                      38.9                      1037.9

Correct Percentage: 103.37%

2.  
Gallons @ 325 gallons per minute. 75% flow. Ran 1000 gallons total.  
High Side Reading                      Low Side Reading  
Finish:                      74637279                      2519046.8  
Start:                      74636299                      2519018.8  
Total                      980                      28.0                      1008

Correct Percentage: 100.8%

3.  
Gallons @ 215 gallons per minute. 50% flow. Ran 1000 gallons total.  
High Side Reading                      Low Side Reading  
Finish:                      74638234                      2519115.6  
Start:                      74637279                      2519046.8  
Total                      955                      68.8                      1023.8

Correct Percentage: 102.38%

4.  
Gallons @ 110 gallons per minute. 25% flow. Ran 1000 gallons total.  
High Side Reading                      Low Side Reading  
Finish:                      74639098                      2519268.1  
Start:                      74638234                      2519115.6  
Total                      864                      152.5                      1016.5

Correct Percentage: 101.65%

Total Percentage for High Side test: 102.05% - out of state Regs by

Tester: Alvin Crum                      • 55%

# City of Somerset

## WATER/WASTEWATER DEPARTMENT

105 College Street

PO Box 989

SOMERSET, KENTUCKY 42502-0989

(606) 678-6646 • fax (606) 679-6227

E-mail: cdick@cityofsomerset.com



EDDIE R. GIRDLER  
Mayor

CHARLES R. DICK  
Manager

1. *High side test after adjustment*  
Gallons @ 425 gallons per minute. 100% flow. Ran 1000 gallons total.  
High Side Reading Low Side Reading  
Finish: 746 41003 251 93 27.8  
Start: 746 40027 251 92 78.4 1005.4  
Total 976 29.4  
Correct Percentage: 100.54%

2.  
Gallons @ 325 gallons per minute. 75% flow. Ran 1000 gallons total.  
High Side Reading Low Side Reading  
Finish: 746 41968 251 9367.7  
Start: 746 41003 251 9327.8 1004.9  
Total 965 39.9  
Correct Percentage: 100.49%

3.  
Gallons @ 215 gallons per minute. 50% flow. Ran 1000 gallons total.  
High Side Reading Low Side Reading  
Finish: 746 42904 251 9435.0  
Start: 746 41968 251 9367.7 1003.3  
Total 936 67.3  
Correct Percentage: 100.33%

4.  
Gallons @ 110 gallons per minute. 25% flow. Ran 1000 gallons total.  
High Side Reading Low Side Reading  
Finish: 746 43754 251 9585.7  
Start: 746 42904 251 9435.0 1000.7  
Total 850 150.7  
Correct Percentage: 100.07%

Total Percentage for High Side test: 100.3575%

Tester: Al Green

NIGHTLY SO MASTER METER

# City of Somerset

## WATER/WASTEWATER DEPARTMENT

EDDIE R. GIRDLER  
Mayor

CHARLES R. DICK  
Manager

105 College Street  
PO Box 989

SOMERSET, KENTUCKY 42502-0989  
(806) 878-6646 • fax (806) 679-8227

Western Water email: cdick@cityofsomerset.com



Service Location: Nancy Pit Beginning Read: High: 815094400 Low: 1491374.0  
Date: 8/16/16 Final Read: High: 815109590 Low: 1492358.5

10 Gallons @ 2.0 gallons per minute. 25% flow. Ran 10.0 gallons total.  
High Side Reading Low Side Reading

Finish: 815094400 1491383.9  
Start: 815094400 1491374.0  
Total 9.9

Correct Percentage: 99%

2.  
10 Gallons @ 5.0 gallons per minute. 50% flow. Ran 10.0 gallons total.  
High Side Reading Low Side Reading

Finish: 815094400 1491383.7  
Start: 815094400 1491383.8  
Total 9.9

Correct Percentage: 99%

3.  
10 Gallons @ 9.0 gallons per minute. 75% flow. Ran 10.0 gallons total.  
High Side Reading Low Side Reading

Finish: 815094400 1491403.5  
Start: 815094400 1491383.7  
Total 9.8

Correct Percentage: 98%

4.  
10 Gallons @ 12.0 gallons per minute. 100% flow. Ran 10.0 gallons total.  
High Side Reading Low Side Reading

Finish: 815094400 1491413.1  
Start: 815094400 1491403.5  
Total 9.6

Correct Percentage: 96%

Total Percentage for Low Side Test: 97.75% Total Correct Percentage: 99.26%

Tester: Ash Con Remarks: Low side out of ALUMIN standards  
will require meter change

# City of Somerset

## WATER/WASTEWATER DEPARTMENT

105 College Street  
PO Box 989

SOMERSET, KENTUCKY 42502-0989  
(808) 678-6646 • fax (808) 678-6227  
E-mail: cdick@cityofsomerset.com



EDDIE R. GIRDLER  
Mayor

CHARLES R. DICK  
Manager

1.

Gallons @ 350 gallons per minute. 100% flow. Ran 1000 gallons total.

	High Side Reading	Low Side Reading	
Finish:	<u>815107240</u>	<u>1491734.1</u>	
Start:	<u>815106310</u>	<u>1491648.7</u>	
Total	<u>930</u>	<u>85.4</u>	1015.4

Correct Percentage: 101.54%

2.

Gallons @ 260 gallons per minute. 75% flow. Ran 1000 gallons total.

	High Side Reading	Low Side Reading	
Finish:	<u>815108140</u>	<u>1491855.5</u>	
Start:	<u>815107240</u>	<u>1491734.1</u>	
Total	<u>900</u>	<u>121.4</u>	1021.4

Correct Percentage: 102.14%

3.

Gallons @ 175 gallons per minute. 50% flow. Ran 1000 gallons total.

	High Side Reading	Low Side Reading	
Finish:	<u>815108950</u>	<u>1492036.2</u>	
Start:	<u>815108140</u>	<u>1491855.5</u>	
Total	<u>810</u>	<u>180.7</u>	990.7

Correct Percentage: 99.07%

4.

Gallons @ 90 gallons per minute. 25% flow. Ran 1000 gallons total.

	High Side Reading	Low Side Reading	
Finish:	<u>815109570</u>	<u>1492392.5</u>	
Start:	<u>815108950</u>	<u>1492036.2</u>	
Total	<u>640</u>	<u>363.3</u>	1003.3

Correct Percentage: 100.33

Total Percentage for High Side test: ~~100.33%~~ 100.77%

Tester: Al Coni

Bourbon Master Meter

# City of Somerset

## WATER/WASTEWATER DEPARTMENT

105 College Street  
PO Box 989

SOMERSET, KENTUCKY 42502-0989  
(606) 678-6646 • fax (606) 679-6227  
E-mail: cdick@cityofsomerset.com



EDDIE R. GIRDLER  
Mayor

CHARLES R. DICK  
Manager

*Weston Drive*

Service Location: Weston  
Date: 8/18/16

Beginning Read: High: 280355920 Low: 8564038.5  
Final Read: High: \_\_\_\_\_ Low: \_\_\_\_\_

10 Gallons @ 2.0 gallons per minute. 25% flow. Ran 10.0 gallons total.  
High Side Reading Low Side Reading

Finish: \_\_\_\_\_  
Start: 280355920 8564048.5  
Total: \_\_\_\_\_ 8564038.5  
10.0

Correct Percentage: 100%

2.  
10 Gallons @ 5.0 gallons per minute. 50% flow. Ran 10.0 gallons total.  
High Side Reading Low Side Reading

Finish: \_\_\_\_\_  
Start: \_\_\_\_\_ 8564058.7  
Total: \_\_\_\_\_ 8564048.5  
10.2

Correct Percentage: 102%

3.  
10 Gallons @ 9.0 gallons per minute. 75% flow. Ran 10.0 gallons total.  
High Side Reading Low Side Reading

Finish: \_\_\_\_\_  
Start: \_\_\_\_\_ 8564068.0  
Total: \_\_\_\_\_ 8564058.7  
10.3

Correct Percentage: 103%

4.  
10 Gallons @ 12.0 gallons per minute. 100% flow. Ran 10.0 gallons total.  
High Side Reading Low Side Reading

Finish: \_\_\_\_\_  
Start: \_\_\_\_\_ 8564078.2  
Total: \_\_\_\_\_ 8564068.0  
10.2

Correct Percentage: 102%

Total Percentage for Low Side Test: 101.75% Total Correct Percentage: 102.323

Tester: Allen Brown Remarks: Runs fast 823%



# City of Somerset

## WATER/WASTEWATER DEPARTMENT

105 College Street

PO Box 889

SOMERSET, KENTUCKY 42502-0889

(806) 678-6646 • fax (806) 679-8227

E-mail: [cdick@cityofsomerset.com](mailto:cdick@cityofsomerset.com)



EDDIE R. GIRDLER  
Mayor

CHARLES R. DICK  
Manager

1.

Gallons @ 400 gallons per minute. 100% flow. Ran 1000 gallons total.

	High Side Reading	Low Side Reading	
Finish:	280356840	8564148.6	
Start:	280355920	8564079.2	
Total	920	69.4	989.4

Correct Percentage: 98.94%

2.

Gallons @ 300 gallons per minute. 75% flow. Ran 1000 gallons total.

	High Side Reading	Low Side Reading	
Finish:	280357750	8564243.0	
Start:	280356840	8564148.6	
Total	910	94.4	1004.4

Correct Percentage: 100.44%

3.

Gallons @ 200 gallons per minute. 50% flow. Ran 1000 gallons total.

	High Side Reading	Low Side Reading	
Finish:	280359400	8564699.2	
Start:	280358480	8564545.8	
Total	920	153.4	1073.4

Correct Percentage: 107.34%

4.

Gallons @ 100 gallons per minute. 25% flow. Ran 1000 gallons total.

	High Side Reading	Low Side Reading	
Finish:	280361100	8565405.2	
Start:	280360180	8565106.5	
Total	720	298.7	1048.7

Correct Percentage: 104.87%

Total Percentage for High Side test: 102.8975%

Tester: APL Am

# WIGWAG 30 MASTER METER

Service Location: Nancy Beginning Read: High: 198757300 Low: 7628028.53  
 Date: 11/7/18 Final Read: High: \_\_\_\_\_ Low: \_\_\_\_\_

1)  
 Gallons @ 2.0 gallons per minute. LOW flow. Ran 10.0 gallons total.  

	High Side Reading		Low Side Reading
Finish:			<u>7628038.45</u>
Start:	<u>198757300</u>		<u>7628028.53</u>
Total			<u>9.92</u>

$$\frac{9.92}{10} \times 101.2$$

Corrected Percentage: 100.3904%

2)  
 Gallons @ 8.0 gallons per minute. MEDIUM flow. Ran 10.0 gallons total.  

	High Side Reading		Low Side Reading
Finish:			<u>7628048.14</u>
Start:	<u>198757300</u>		<u>7628038.45</u>
Total			<u>9.69</u>

$$\frac{9.69}{10} \times 100.6$$

Corrected Percentage: 99.4814

3)  
 Gallons @ 15.0 gallons per minute. HIGH flow. Ran 10.0 gallons total.  

	High Side Reading		Low Side Reading
Finish:			<u>7629052.97</u>
Start:	<u>198757300</u>		<u>7628048.14</u>
Total			<u>9.83</u>

$$\frac{9.83}{10} \times 100.6$$

Corrected Percentage: 98.8878

Total Percentage for Low Side Test: 98.92 Total Correct Percentage: 100.011%

Tester: Adm Remarks: Good Test

1)  
 Gallons @ 400 gallons per minute. HIGH flow. Ran 1000 gallons total.  

	High Side Reading	Low Side Reading
Finish:	<u>198,761,952</u>	<u>7268312.85</u>
Start:	<u>198,761,074</u>	<u>7268223.72</u>
Total	879	89.13

Corrected Percentage: 95.359%       $\frac{87.13}{1000} \times 98.6$

2)  
 Gallons @ 200 gallons per minute. MEDIUM flow. Ran 1000 gallons total.  

	High Side Reading	Low Side Reading
Finish:	<u>198,762,744</u>	<u>7268480.43</u>
Start:	<u>198,761,952</u>	<u>7268312.85</u>
Total	792	176.58

Corrected Percentage: 96.276%       $\frac{176.58}{1000} \times 99.4$

3)  
 Gallons @ \_\_\_\_\_ gallons per minute. LOW flow. Ran \_\_\_\_\_ gallons total.  

	High Side Reading	Low Side Reading
Finish:	_____	_____
Start:	_____	_____
Total	_____	_____

Corrected Percentage: \_\_\_\_\_

*Flow meter to be turned down  
 as low as possible.*

Total Percentage for High Side test: \_\_\_\_\_

Tester: \_\_\_\_\_

*KG*

1) Gallons @ 400 gallons per minute. HIGH flow. Ran 1000.1 gallons total.

	High Side Reading	Low Side Reading
Finish:	198,764,642	7628657.57
Start:	198,763,720	7628572.92
Total	<u>922</u>	<u>84.59</u>

Corrected Percentage: 99.249%  $\frac{1006.59}{1000} \times 98.6$

2) Gallons @ 200 gallons per minute. MEDIUM flow. Ran 1000 gallons total.

	High Side Reading	Low Side Reading
Finish:	198,765,499	7628826.82
Start:	198,764,642	7628657.51
Total	<u>857</u>	<u>169.31</u>

Corrected Percentage: 102.015%  $\frac{1026.31}{1000} \times 99.4$

3) Gallons @ 75 gallons per minute. LOW flow. Ran 1000.1 gallons total.

	High Side Reading	Low Side Reading
Finish:	198,766,063	7629270.26
Start:	198,765,499	7628826.82
Total	<u>564</u>	<u>443.44</u>

Corrected Percentage: 102.043%  $\frac{1007.44}{1000.1} \times 101.3$

Total Percentage for High Side test: 101.102%

Tester: \_\_\_\_\_

**EXHIBIT C**

Date

Jan 2019 Water Leaks

- 1-9-19 1. 6" main line leak at sleepy hollow
- 1-8-19 2. Roger owens 3/4 service line leak
- 1-18-19 3. 218 Normandy Ct service line leak
- 1-21-19 4. Tim Tarter meter 761 Busted (3510)
- 1-21-19 5. Wolf Creek Marina 3" Main
- 1-22-19 6. 1" Service @ Shepola Rd.
- 1-28-19 7. 119 observation pt 1" service line leak
- 1-28-19 8. 676 highway dr busted bottom
- 1-31-19 9. Daws Ridge Busted Bottom
- 10.

(~~8~~/44) STOPPED METERS January

Date

Feb 2019 Leaks

- 2-1-19 1 Daws Ridge Rd. busted meter bottom
- 2-4-19 2 102 Karaha Ln. 3/4" service
- 2-4-19 3 5893 W. Hwy 80. 3/4" service
- 2-4-19 4 305 patterson branch 3/4" service
- 2-8-19 5 Bottom of Clifty hill Rd. 1" service
- 2-9-19 6 6" main @ Campbell Rd.
- 2-10-19 7 6" main @ slate branch Rd.
- 2-11-19 8 1" service leak over hill Clifty Rd.
- 2-14-19 9 305 patterson br 3/4" service line leak
- 2-14-19 10 Wilson + Roy Shop 3/4" service line leak
- 2-14-19 11 bridle brook 3" main line leak
- 2-14-19 12 bridle brook 3" main line leaking at 22 + slip coulin
- 2-19-19 13 Hickory Hill 3/4" service line leak
- 2-21-19 14 6" main leak W. 80 @ Sleepy hollow
- 2-25-19 15 1600 WTLA rd 3/4" service line leak
- 2-25-19 16 1166 oak hill Rd. Busted Bottom
- 2-25-19 17 47 Hughes Ct. Busted Bottom

18

19

20

Mar 2019 Water Leaks

- |                        |    |  |
|------------------------|----|--|
| 3-7-19                 | 1  | 8" Main Leak (Bad)                                     |
| -11-19                 | 2  | 56 Sumner Wind $\frac{3}{4}$ " Service line            |
| -11-19                 | 3  | Todd rd 3" main line                                   |
| -19-19                 | 4  | 200 Mooreland Pt Service line leak                     |
| -20-19                 | 5  | 3009 Simpson dr $\frac{3}{4}$ service line leak        |
| 20-19                  | 6  | 3011 Simpson dr 1" service line leak                   |
| 20-19                  | 7  | 1901 Tigers Way $\frac{3}{4}$ service line leak        |
| 21-19                  | 8  | 1825 Wolf creek rd 1" service line leak                |
| 22-19                  | 9  | 2329 Ringgold rd 4" main line leak                     |
| <del>23</del><br>24-19 | 10 | Cedar crest regulator pit 2" main                      |
| <del>24</del><br>24-19 |    | 81 Todd blvd $\frac{3}{4}$ service line leak           |
| 24-19                  |    | 168 Lakebreeze busted meter bottom                     |
| 29-19                  |    | Calvary baptist church $\frac{3}{4}$ service line leak |



## April 2019 LEAKS

1-1-19	1)	684 Tapping Slope leaking Hwy 1248	4-24-19	28)	496 Ferry Rd. Busted
1-2-19	2)	Royce shop 3/4" service leak	4-25-19	29)	171 Arlen dr 3/4 service line
1-2-19	3)	W. 80 Dance hall 1" service leak	4-25-19	30)	Circle pt Busted Bottom
1-3-19	4)	828 Hwy 235 3/4 service line leak	4-26-19	31)	8" Ringsold Rd (new line)
4-19	5)	Enchanted dr 1" service line leak		32)	
1-4-19	6)	Shady grove rd 3" main line leak		33)	
-8-19	7)	Danielle Ln. 1" service line leak			
-10-19	8)	2042 Recreay Rd <del>leak</del> service line leak			
-10-19	9)	291 Wilson Rd service line leak			
-11-19	10)	valley rd 3" main line leak			
-12-19	11)	155 Danielle Ln. 1" service leak			
-15-19	12)	1" service line in (3 places) Lee's ford			
1-16-19	13)	Boat Place on 80 Access from 3345 3/4 service line leak			
1-16-19	14)	171 Enchanted dr 3/4 service line leak			
-16-19	15)	Slo Oakland dr 3" main line leak			
1-16-19	16)	1441 Hwy 1674 3/4 service line leak			
-17-19	17)	3905 Hickory hill dr 3/4 service line leak			
-17-19	18)	Slate branch spar @ END 3" Main			
-17-19	19)	Busted Bottom Gover Ln.			
-18-19	20)	3714 Hickory Hill Busted Bottom			
-18-19	21)	<del>3714</del> Oakwood @ Busted Bottom			
-22-19	22)	150 Crooked 3/4" service			
-22-19	23)	Country pt. Ln. 3/4" service			
-22-19	24)	980 Slate branch Busted meter Bottom			
-23-19	25)	Robin Dr. 3" main			
24-19	26)	Fish -N- Stk. Busted Bottom			
-24-19	27)	115 Alder Ct. Busted Bottom			

May 2019 Water Leaks

5-1-19	1.	12 Deck Dr. Busted Bottom	29-771 Enchanted dr 3/4 service line leak
5-1-19	2.	93 Kelsons ct 3/4 service line leak	
5-1-19	3.	6141 W hwy 80 3/4 service line leak	
5-1-19	4.	3160 hwy 2993 busted meter bottom	
5-2-19	5.	505 Nature's Point 3/4 service line leak	
5-2-19	6.	1039 Hwy 3091 3/4 service line leak	
5-7-19	7.	Charlie beasley loop 3/4 service line leak	
5-10-19	8.	Buck Trail 3" main line leak	
5-11-19	9.	260 Circle Pt. Busted Bottom	
5-14-19	10.	J-oaks rd 3/4 service line leak	
5-16-19	11.	2041 Lyth wood Dr Busted meter	
5-16-19	12.	Lockout circle 3/4 service line leak	
5-16-19	13.	1014 South Fork dr 3/4 service line leak	
5-16-19	14.	621 Prother dr 3/4 service line leak	
5-17-19	15.	5993 W. 80 3/4 service line leak	
5-17-19	16.	102 Snetta Ave 3/4 service line leak	
5-20-19	17.	1905 Rollin dr 3/4 service line leak	
5-20-19	18.	1908 Rollin dr 3/4 service line leak	
5-21-19	19.	66 Isie St Busted Bottom	
5-22-19	20.	Chapman Dairy 6" main line	
5-23-19	21.	1903 Tigers way 3/4" service	
5-24-19	22.	223 Lenetaw rd 1" service line leak	
5-28-19	23.	85 hwy 235 3/4 service line leak	
5-28-19	24.	Kates rd 3/4 service line leak	
5-28-19	25.	Robin dr 3" main line leak	
5-31-19	26.	6484 ZU 80 Busted meter.	
5-31-19	27.	175 Muse Ln 1" Service line leak	
5-31-19	28.	860 old Columbia rd 3/4 service line leak	

## June 2019 Water Leaks

- |         |     |   |
|---------|-----|---|
| 6-3-19  | 1-  | 277 bates rd $\frac{3}{4}$ service line leak              |
| 6-3-19  | 2-  | 219 oakview dr $\frac{3}{4}$ service line leak            |
| 6-3-19  | 3-  | 205 Richwood dr $\frac{3}{4}$ service line Leak           |
| 6-4-19  | 4-  | Fish N Ski $\frac{3}{4}$ service line leak                |
| 6-6-19  | 5-  | 1447 oakhill rd. Service leak                             |
| 6-8-19  | 6-  | 6" Main Leak old millspring (Larry sheppards farm)        |
| 6-11-19 | 7-  | 8" main Leak Hickory Nut Rd. Bottom of Hill (Contractors) |
| 6-12-19 | 8-  | Woodland dr $\frac{3}{4}$ service line leak               |
| 6-14-19 | 9-  | 3230 Ard Pidge Rd. busted MT Bottom                       |
| 6-14-19 | 10- | Rudley Hill Busted meter Bottom                           |
| 6-17-19 | 11- | Busted meter bottom Gouy Ln.                              |
| 6-18-19 | 12- | 6" Main Sate branch @ oakhill                             |
| 6-19-19 | 13- | 88 Jody way $\frac{3}{4}$ Service line leak               |
| 6-19-19 | 14- | 6450 Hwy 761 $\frac{3}{4}$ service line leak              |
| 6-21-19 | 15- | 914 Bypass 6" main  |
| 6-21-19 | 16- | 48 gouy LN Busted bottom                                  |
| 6-21-19 | 17- | wild wood DR.   |
| 6-22-19 | 18- | 512 water cliff DR. Busted bottom                         |
| 6-25-19 | 19- | 512 Clifty rd. $\frac{3}{4}$ " service leak               |
| 6-26-19 | 20- | 810 Coffey Rd $\frac{3}{4}$ " Service leak                |

21.

22.

23.

24.

25.

July 2019 Water Leaks

7-1-19	1.	Luke stevegon Its	3/4" service line	
7-1-19	2.	1775 patterson branch	3/4" service line	
7-1-19	3.	200 moreland DR.	3/4" service line	
2-19	4.	Todd rd	3" main line leak	
2-19	5.	87 Summer wind dr	busted meter bottom	
7-3-19	6.	Sleepy Hollow	3/4" service line	
-6-19	7.	W.hwy 80 at H.E. blonds storage buildings	busted meter bottom	
8-19	8.	2904 Richardson rd	3/4 service line leak	
7-9-19	9.	109 Evert Ln.	Busted Bottom	29-517 natures point 3/4 service line leak
-9-19	10.	220 Redmond Rd.	Busted Bottom	30-190 Aldons Way 3/4 service line leak
-9-19	11.	Lake field DR.	1" service leak	31. 107 Deck DR. Apt A Sewer
9-19	12.	Branchwood DR.	3/4" service leak	32. Brian's DR <sup>7-29-19</sup> service leak
-9-19	13.	8882 Hwy 761	3/4" service leak	33. McKee Rd <sup>7-31-19</sup> Service Leak
-9-19	14.	chickasaw rd	3" main line leak	34. Blassinger circle 3/4 service leak
12-19	15.	15919 W hwy 80	6" main line leak	35. Hobb box 1145 3/4 service leak
2-19	16.	307 buckeye dr	3/4 service line leak	36. Bates rd 3/4 service line leaked
7-13-19	17.	49 Edge water pt	3/4 service leak	
7-14-19	18.	314 Hwy 235	Busted Bottom	
15-19	19.	3904 Rollin dr	3/4 service line leak	
5-19	20.	3830 Hickory Hill	3/4 service line leak	
-15-19	21.	505 branchwood dr	3/4 service line leak	
15-19	22.	White oak dr	3/4 service line leak	
7-16-19	23.	Hwy 761	4" Main. state hit line	
7-17-19	24.	Patterson branch	leak 4" main	
7-18-19	25.	Hwy 761	Leak 3" main	
7-19-19	26.	1550 Bridge Hollow Rd	busted MT bottom	
24-19	27.	960 New hope rd	3/4 service line leak	
24-19	28.	212 Woodline dr	3/4 service line leak	



# September 2019

1. Busted Bottom Valley View Dr. Vandy
2. Busted Bottom 80 Blue Heron Dr.
- 9-9-19 3. End of Suits us Dr. 3" main line leak
- 9-19 4. Lakepoint dr. 2" main line leak
- 11-19 5. 127 Tanahawk Dr. 3/4" Service Leak
- 1-10-19 6. 3009 Simpson ct. 3/4" Service Leak
- 1-13-19 7. 3206 Shwy 837 busted bottom
- 2-17-19 8. 2446 richardson Rd. busted bottom
- 3-18-19 9. 1215 Shafter shapala 3/4" service
- 1-19-19 10. 469 ferry Rd. 3/4" service
- 2-17-19 11. Ard ridge busted bottom
- 1-20-19 12. 102 Suetta Dr. Service line 3/4 banded
- 2-3-19 13. 112 Mallard circle 3/4 service line leak
- 23-19 14. 1756 slate br spur 3/4 service line leak
- 24-19 15. 331 breezy hills 3/4 service line leak
- 7-24-19 16. 1003 Winding Ridge Dr 3/4 service line leak
- 1-24-19 17. 166 Enchanted Dr. 3/4 service line leak
- 1-25-19 18. 234 George st. Busted Meter Bottom
- 2-25-19 19. 1362 Thurman Rd. 3/4 Service Leak
- 7-26-19 20. 306 Gaynelle Ct. 3/4 Service Leak
- 7-28-19 21. 6" 914 By-Pass (BAD)
- 1-27-19 22. N. 837 6" (Bad)
- 1-27-19 23. Rock lick 3" Main
- 30-19 24. 7555 Hwy 761 1" service Leak
- 1-30-19 25. 17 Arlan Dr. 2/4" service Leak
- 28-19 26. W. 80 Busted Bottom @ sardis
- 28-19 27. 6" main on 914 lost 220 thousand gallons



# October 2019 LEAKS

- 10-1-19 1. TANK over flow
- 10-1-19 2. 84 Buddy Carter
- 0-1-19 3. 1151 Shafter Shepola rd
- 0-8-19 4. Tiger Way behind UPS  $\frac{3}{4}$ " service
- 1-11-19 5. 1010 South Park  $\frac{3}{4}$  service line leak
- 2-15-19 6. 1412 W Hwy 914 Busted meter
- 3-16-19 7. 210 Enchanted dr  $\frac{3}{4}$  service line leak
- 3-18-19 8. 203 Knob hill rd 3" main line leak
- 3-22-19 9. breezy hills  $\frac{3}{4}$  service line leak
- 3-22-19 10. Castlewood  $\frac{3}{4}$  service line leak
- 3-25-19 11. 780 Joe Lewis rd 1" service line leak
- 3-25-19 12. 95 Denham rd 2" main line leak

NOV 2019 Water leaks

- |         |     |                  |                       |
|---------|-----|------------------|-----------------------|
| 1-6-19  | 1.  | 1452 Thurman rd  | 3/4 service line leak |
| -6-19   | 2.  | 1432 Thurman rd  | 3/4 service line leak |
| -8-19   | 3.  | 2993 + Dixon rd  | 6" main line leak     |
| -9-19   | 4.  | 212 Austin rd    | regulator leaking     |
| -11-19  | 5.  | 39 Day meadow    | 3/4 service line leak |
| -14-19  | 6.  | 4174 Oakhill rd  | 6" main line leak     |
| 1-21-19 | 7.  | 111 Service line | Ramp rd               |
| 2-8-19  | 8.  | 836 Hwy 1674     | 3/4 service line leak |
| 2-7-19  | 9.  | 1723 Clifflly rd | busted bottom         |
| 1-29-17 | 10. | 195 Ford Hwy     | Rd.                   |



Date Dec. 2019 Water leaks

- 1-2-19 1 Goldenburg Ln 3" main line leak
- 1-4-19 2 Calvary Church 3/4" service line leak
- 2-5-19 3 1621 Patterson branch 3/4" service Leak
- 2-11-19 4 1412 Wtlo 3" main line leak
- 2-18-19 5 1705 Sherri Dr. 3/4" service
- 2-18-19 6 Min spring setter Leak
- 2-20-19 7 189 Jody dr 3/4 service line leak
- 2-21-19 8 Oakhill Rd across from Church 6" main
- 9.
- 10.

**EXHIBIT D**

**Western Pulaski County Water District  
Board Meeting Minutes  
June 18, 2019**

**Don Calder-Chairman  
Jimmy Dalton-Co-Chairman/Asst. Treasurer  
Randall Wilson-Treasurer  
Joel Wilson-Secretary  
Steve Davis-Commissioner  
Joe McClendon-General Manager  
Tammy Vaught-Office Manager**

Don Calder called the meeting to order and opened with prayer.

Randall Wilson moved a motion to accept the May minutes. Steve Davis seconded the motion. All board members in favor, motion passed.

Joel Wilson moved a motion to accept the treasurer report. Steve Davis seconded the motion. All board members in favor, motion passed.

Randall Wilson moved a motion to pay the monthly and yearly bills. Joel Wilson seconded the motion. All board members in favor, motion passed.

David Bowles/Monarch Engineering report, the pump station at the office will be put into operation on Tuesday, June 25<sup>th</sup>. The pump station will fill the Denham Knob Water Tank.

Joel Wilson moved a motion to give David Bowles the authority to work on plans for the Oak Hill/Slate Branch water line. Randall Wilson seconded the motion. All board members in favor, motion passed.

Joe McClendon report – the City of Somerset is having the survey done at this time for water line placement for the tie in involving WPCWD and the City of Somerset.


Joe has spoken to H.C. Sumpter concerning the purchase of a 2018 4WD Chevrolet Siverado for \$15,000.00 and a 2013 Ford Explorer for \$2,800.00.

Randall Wilson moved a motion for the Water District to purchase both vehicles. Steve Davis seconded the motion. All board members in favor, motion passed.

Joel Wilson moved a motion for the Water District to purchase a \$50.00 gift card from Texas Roadhouse for each employee for job performance/incentive. Randall Wilson seconded the motion. All board members in favor, motion passed.

Joel Wilson moved a motion to adjourn. Randall Wilson seconded the motion. All board members in favor, motion passed.

  
\_\_\_\_\_  
Joel Wilson, Secretary  
WPCWD Board of Commissioners

  
\_\_\_\_\_  
Date

**EXHIBIT E**


MONARCH ENGINEERING, INC.  
 556 Carlton Drive  
 Lawrenceburg, KY 40342  
 Phone (502) 839-1310  
 Fax (502) 839-1373

**BID TABULATIONS**  
**WESTERN PULASKI COUNT WATER DISTRICT**  
**WATER SYSTEM IMPROVEMENTS & REPLACEMENTS:**  
**CONTRACT NO. 2A**  
**HEARTLAND DRIVE/SLATE BRANCH ROAD/OAK HILL ROAD**  
**PULASKI COUNTY, KENTUCKY**  
**BID DATE: OCTOBER 10, 2019 @ 11:00 A.M. LOCAL TIME**

		Stotts Construction Co., Inc. P.O. Box 1689 Columbia, KY 42728		Cumberland Pipeline, LLC 2909 Cane Valley Mill Road Columbia, KY 42728	
ITEM NO.	DESCRIPTION	QUANTITY	UNIT PRICE	TOTAL COST	TOTAL COST
	<b>BASE BID CONTRACT</b>				
1	6-Inch PVC SDR 21 Water Line	2,130 LF	\$13.00	\$27,690.00	\$19.00
2	Bore & Case for 6-Inch Water Line	40 LF	100.00	4,000.00	125.00
3	6-Inch Gate Valve	4 EA	1,700.00	6,800.00	1,291.00
4	Type I Connection	1 EA	2,500.00	2,500.00	1,582.00
5	Type II Connection	3 EA	2,000.00	6,000.00	1,000.00
6	3-Way Flush Hydrant	3 EA	4,500.00	13,500.00	4,300.00
7	Meter Reconnection	4 EA	350.00	1,400.00	625.00
8	New Meter Setting	3 EA	1,100.00	3,300.00	1,250.00
9	3/4-Inch Service Line Tubing	350 LF	10.00	3,500.00	10.00
10	Ex. Meter Removal/Corp Stop Shut-Off	2 EA	100.00	200.00	500.00
11	Exploration	10 HR	100.00	1,000.00	250.00
	<b>TOTAL BASE BID</b>			<b>\$69,890.00</b>	<b>\$81,366.00</b>

THE ABOVE IS A TRUE AND COMPLETE TABULATION OF BIDS RECEIVED AT 11:00 A.M. LOCAL TIME, THURSDAY, OCTOBER 10, 2019 AT THE WESTERN PULASKI COUNTY WATER DISTRICT.

BY:

  
 Deron S. Byrne

10/11/2020  
 Date

MONARCH ENGINEERING, INC.  
 556 Carlton Drive  
 Lawrenceburg, KY 40342  
 Phone (502) 839-1310  
 Fax (502) 839-1373

**BID TABULATIONS**  
**WESTERN PULASKI COUNT WATER DISTRICT**  
**WATER SYSTEM IMPROVEMENTS & REPLACEMENTS:**  
**CONTRACT NO. 2A**  
**HEARTLAND DRIVE/SLATE BRANCH ROAD/OAK HILL ROAD**  
**PULASKI COUNTY, KENTUCKY**  
**BID DATE: OCTOBER 10, 2019 @ 11:00 A.M. LOCAL TIME**

ITEM NO.	DESCRIPTION	QUANTITY	Weddle Enterprises, Inc.		United Pipeline, Inc.		TOTAL COST
			UNIT PRICE	TOTAL COST	UNIT PRICE	TOTAL COST	
	<b>BASE BID CONTRACT</b>						
1	6-Inch PVC SDR 21 Water Line	2,130 LF	\$17.80	\$37,914.00	\$19.00	\$40,470.00	
2	Bore & Case for 6-Inch Water Line	40 LF	242.50	9,700.00	170.00	6,800.00	
3	6-Inch Gate Valve	4 EA	1,550.00	6,200.00	1,900.00	7,600.00	
4	Type I Connection	1 EA	4,600.00	4,600.00	3,000.00	3,000.00	
5	Type II Connection	3 EA	1,825.00	5,475.00	2,900.00	8,700.00	
6	3-Way Flush Hydrant	3 EA	4,550.00	13,650.00	5,400.00	16,200.00	
7	Meter Reconnection	4 EA	25.00	100.00	1,500.00	6,000.00	
8	New Meter Setting	3 EA	1,000.00	3,000.00	1,800.00	5,400.00	
9	3/4-Inch Service Line Tubing	350 LF	2.00	700.00	10.00	3,500.00	
10	Ex. Meter Removal/Corp Stop Shut-Off	2 EA	415.00	830.00	500.00	1,000.00	
11	Exploration	10 HR	10.00	100.00	100.00	1,000.00	
	<b>TOTAL BASE BID</b>			<b>\$82,269.00</b>		<b>\$99,670.00</b>	