



American Electric Power
1 Riverside Plaza
Columbus, OH 43215
AEP.com

June 22nd, 2020

Christon Enterprises Inc
29 Isom Drive
Isom, KY 41824

Dear Christon Enterprises Inc,

The Interconnection Application (**APKY-20011**) to grid connect a 45.0 kW (AC) solar photovoltaic generator (account # 030-290-095-4) has been approved subject to the following conditions:

- Completion of Small Generator Facility Certificate of Completion
- Verification of an alternating current (AC) generator disconnect switch installed next to the Appalachian Power (AP) meter as indicated on the Interconnection Application site diagram.
- Execution of an Interconnection Agreement (provided by AP).

Please do not permit the operation of the proposed solar generator until AP has inspected the site.

Please feel free to contact me should you have any questions/concerns.

Sincerely,

Jacob H. Crocker
Customer Programs Service Analyst
P: 614-716-2080 | E: dgcoordinator@aep.com