



**Sturgill, Turner, Barker & Moloney, PLLC**  
333 West Vine Street, Suite 1500  
Lexington, KY 40507  
p: 859.255.8581 f: 859.231.0851  
www.sturgillturner.com

**James W. Gardner**  
Of Counsel  
jgardner@sturgillturner.com

July 7, 2020

Kentucky State Board on Electric Generation and Transmission Siting  
Kentucky Public Service Commission  
211 Sower Boulevard  
P. O. Box 615  
Frankfort, KY 40602

Re: Notice of Intent to File Application of AEUG Madison Solar, LLC for Certificate of Construction for: an approximately 100 Megawatt Merchant Electric Solar Generating Facility in Madison County, Kentucky pursuant to KRS 278.700, *et seq.*, and 807 KAR 5:110

To Whom It May Concern:

AEUG Madison Solar, LLC hereby submits for filing this Notice of Intent to file an application for a Certificate of Construction for an approximately 100 MW solar facility (“Madison Solar Project”).

- a. The name, address and telephone number of the person who intends to file the application is:

AEUG Madison Solar, LLC  
55 E. Monroe St., Suite 1925  
Chicago, Il. 60603  
Phone: (312) 870-1480  
Attention: Adam W. Stratton, Director, Solar Business Development  
Email: [astratton@acciona.com](mailto:astratton@acciona.com)


- b. The proposed construction is briefly described as follows:

The Madison Solar Project will consist of approximately 1100 acres of solar photovoltaic panels and associated racking (approximately 100MW), 35 inverters, and a project substation transformer which will connect to East Kentucky Power Cooperatives Three Forks-Dale 138kv transmission line near the City of Richmond in Madison County, Kentucky.

- c. The street address of the proposed Madison Solar Project is 2146 Red House Road Richmond, KY 40475 and the latitude and longitude are: 37.48'46.75" N and 84.16'38.33" W. The Madison Solar Project is not located within the limits of any city.
- d. The Madison County Planning and Zoning Commission with an address of 135 W. Irvine St, 3<sup>rd</sup> Floor, Richmond Kentucky 40475 has jurisdiction over the site.
- e. The local setback requirements applicable to this site are:  
  
50 feet from the Center of the Road on a County Road or 125 feet from the Centerline of a State Highway, and  
  
Side and Rear Setbacks for an Accessory Structure are 10 feet from the Property line.
- f. Pursuant to KRS 278.704(4), the applicant will not request a deviation from the setback requirements found in KRS 278.704(2) because the local planning and zoning requirements have primacy.

Thank you for accepting this Notice of Intent to File Application. Please feel free to contact me if you have any questions or need further information.

Very truly yours,



James W. Gardner  
M. Todd Osterloh  
Sturgill, Turner, Barker & Moloney, PLLC  
333 West Vine Street, Suite 1500  
Lexington, KY 40507  
Telephone: (859) 255-8581  
Email: [jgardner@sturgillturner.com](mailto:jgardner@sturgillturner.com)  
[tosterloh@sturgillturner.com](mailto:tosterloh@sturgillturner.com)